

October 13, 1995

Duke Power Company  
ATTN: Mr. T. C. McMeekin  
Vice President  
McGuire Site  
12700 Hagers Ferry Road  
Huntersville, NC 28078-8985

SUBJECT: PLANT PERFORMANCE REVIEW (PPR) - MCGUIRE

Dear Mr. McMeekin:

On September 21, 1995, the NRC staff completed the semiannual Plant Performance Review (PPR) of the McGuire Nuclear Station. The staff conducts these reviews for all operating nuclear power plants to develop an integrated understanding of safety performance. The results are used by regional management to facilitate planning and allocation of inspection resources. The PPR for McGuire involved the participation of all regional technical divisions and NRR in evaluating inspection results and safety performance information for the period from March 1995 to September 1995. PPRs provide regional management with a current summary of licensee performance and serve as inputs to the NRC Systematic Assessment of Licensee Performance (SALP) and senior management meeting (SMM) reviews.

This letter advises you of our planned inspection effort resulting from the McGuire PPR review. It is provided to minimize the resource impact on your staff and to allow for scheduling conflicts and personnel availability issues to be resolved in advance of inspector arrival onsite. The enclosure details our inspection plan for the next six months. The basis for each inspection outside the core inspection program is provided so that you are aware of the reason for emphasis in these program areas. Resident inspections are not listed due to their ongoing and continuous nature.

We will inform you of any changes to the inspection plan. If you have any questions, please contact R. Crlenjak at (404) 331-5506.

Sincerely,

(S)  
Ellis W. Merschoff, Director  
Division of Reactor Projects

Docket Nos.: 50-369, 50-370  
License Nos.: NPF-9, NPF-17

Enclosure: Inspection Plan

cc w/encl: (See page 2)

9510240136 951013  
PDR ADOCK 05000369  
G PDR

IEO1

cc w/encl:  
James Snyder  
Regulatory Compliance  
Duke Power Company  
12700 Hagers Ferry Road  
Huntersville, NC 28078-8985

G. A. Copp  
Licensing - EC050  
Duke Power Company  
P. O. Box 1006  
Charlotte, NC 28201-1006

A. V. Carr, Esq.  
Duke Power Company  
422 South Church Street  
Charlotte, NC 28242-0001

Mr. Robert P. Gruber  
Executive Director  
Public Staff - NCUC  
P. O. Box 29520  
Raleigh, NC 27626-0520

J. Michael McGarry, III, Esq.  
Winston and Strawn  
1400 L Street, NW  
Washington, D. C. 20005

Dayne H. Brown, Director  
Division of Radiation Protection  
N. C. Department of Environment,  
Health & Natural Resources  
P. O. Box 27687  
Raleigh, NC 27611-7687

County Manager of Mecklenburg County  
720 East Fourth Street  
Charlotte, NC 28202

(cc w/encl cont'd - See page 3)

(cc w/encl cont'd)  
 Peter R. Harden IV  
 Account Sales Manager  
 Power Systems Field Sales  
 Westinghouse Electric Corporation  
 P. O. Box 7288  
 Charlotte, NC 28241





Dr. John M. Barry, Director  
 Mecklenburg County Department  
 of Environmental Protection  
 700 North Tryon Street  
 Charlotte, NC 28203

Karen E. Long  
 Assistant Attorney General  
 N. C. Department of Justice  
 P. O. Box 629  
 Raleigh, NC 27602

Distribution w/encl:

V. Nerses, NRR  
 R. Watkins, RII  
 R. V. Crlenjak, RII  
 G. A. Hallstrom, RII  
 PUBLIC

NRC Resident Inspector  
 U.S. Nuclear Regulatory Commission  
 12700 Hagers Ferry Road  
 Huntersville, NC 28078-8985

SEND TO PUBLIC DOCUMENT ROOM?		YES		NO					
OFFICE	RII:DRP	RII:DRP	RII:DRSS	RII:DRS					
SIGNATURE									
NAME	S. Radtall	R. Crlenjak	K. Barr	C. Casto					
DATE	10/11/95	10/11/95	10/12/95	10/12/95	10/ / 95	10/ / 95			
COPY?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO

MCGUIRE INSPECTION PLAN		
Inspection Title	Dates	# Insp
Resident Inspector - core program to focus on component mispositionings and reactivity management Module 71707	ongoing	1
DRS - outage work review: S/G tube plugging; KC piping cracking issues; PORV work; power range testing (regional initiative) Module 73753, 72700 (3 weeks)	TBD* (U1 & U2 RFO)	
DRS - assist RI in maintenance core program Modules 62703 and 61726	bi-monthly	1
DRS - assist RI in design review (core program) Module 37551 (3 weeks)	TBD*	
DRS - MOV (GL 89-10) closeout Module TI 2515/109 (2 weeks)	TBD*	
DRS - Access Authorization Module TI 2515/127	11/13-17/95	1
DRS - FRP core program Module 83750	12/18-22/95	1
DRS - REC core program Module 84750 and 86750	12/18-22/95	1
DRS - Initial Exams Module 71001	(preps) 1/8-12/96	3
	(exam) 1/22-26/96	3

\* Inspection dates and inspectors to be determined. Inspections will be completed during the next six months.