

Pilgrim Nuclear Power Station Rocky Hill Road Plymouth, Massachusetts 02360

E. T. Boulette, PhD Senior Vice President — Nuclear

> October 16, 1995 BECo Ltr. #95- 108

U.S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, DC 20555

> Docket No. 50-293 License No. DPR-35

Generic Letter 95-07: Pressure Locking and Thermal Binding of Safety-Related Power Operated Valves

Boston Edison intends to implement the actions addressed in this Generic Letter by February 23, 1996 as requested. As part of our Generic Letter 89-10 MOV Program, we have addressed the pressure locking and thermal binding issue and taken action in accordance with GL89-10 per our Long Term Plan Schedule commitments. We are in the process of reviewing other safety related, power operated gate valves to determine susceptibility. Based on our review to date, we do not expect to need additional valve modifications.

Should you have any questions regarding this subject, please call Marie Lenhart at 508-830-7937.

ET Boulette, PhD

Commonwealth of Massachusetts)
County of Plymouth

Then personally appeared before me, E. T. Boulette, who being duly sworn, did state that he is Senior Vice President - Nuclear of Boston Edison Company and that he is duly authorized to execute and file the submittal contained herein in the name and on behalf of Boston Edison Company and that the statements in said submittal are true to the best of his knowledge and belief.

My commission expires:

MAR 4 - 1999

NOTARY PUBLIC

GERALD G. WHITNEY, Notary Public

My Commission Expires March 4, 1999

ETB/MTL/nas/Rap95/Preslock

cc: See next page

9510240190 951016 PDR ADOCK 05000293 cc: Mr. R. Eaton, Project Manager
Division of Reactor Projects - I/II
Mail Stop: 14D1
U. S. Nuclear Regulatory Commission
1 White Flint North
11555 Rockville Pike
Rockville, MD 20852

U.S. Nuclear Regulatory Commission Region I 475 Allendale Road King of Prussia, PA 19406

Senior Resident Inspector Pilgrim Nuclear Power Station