



# Duquesne Light

Nuclear Construction Division  
Robinson Plaza, Building 2, Suite 210  
Pittsburgh, PA 15205

2NRC-4-105

(412) 787-5141

(412) 923-1900

Telecopy (412) 787-2829

July 13, 1984

United States Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, PA 19406

ATTENTION: Dr. Thomas E. Murley  
Administrator

SUBJECT: Beaver Valley Power Station - Unit No. 2  
Docket No. 50-412  
IE Bulletin 84-02

Gentlemen:

Beaver Valley Power Station Unit No. 2 (BVPS-2) has reviewed IE Bulletin 84-02, "Failures of General Electric Type HFA Relays in Use in Class 1E Safety Systems," for applicability to BVPS-2.

As a result of BVPS-2's review, no HFA relays were identified as being installed or planned for installation in safety-related systems at BVPS-2. Item 3 of the bulletin states: "... if your plant does not use or plan to use the nylon or Lexan-type GE HFA relays in the safety-related systems discussed above, a negative response is requested within 120 days of receipt of this bulletin, and no further action is required." Accordingly, BVPS-2 actions with respect to the bulletin are complete.

However, in order to adequately address the generic concerns, as recommended on page 5 of the bulletin and in IE Information Notice 84-20, additional reviews are being performed in order to identify any related potential problems for relays used in Class 1E safety-related circuits. Thus far, the review has not found any failures similar to those experienced with the GE HFA relays as identified in the bulletin for the types of relays used at BVPS-2 for Class 1E safety-related circuits. Nor have any reports of similar failures been identified for the types of relays used at BVPS-2 in Class 1E safety-related circuits to date. If similar failures should occur with other types of relays, these failures will be handled by the problem report system and corrective action, if required, will be initiated.

8407310115 840713  
PDR ADOCK 05000412  
Q PDR

DUQUESNE LIGHT COMPANY

SUBSCRIBED AND SWORN TO BEFORE ME THIS  
13th DAY OF July, 1984.

Anita Elaine Reiter  
Notary Public

By E. J. Woolever  
E. J. Woolever  
Vice President

ANITA ELAINE REITER, NOTARY PUBLIC  
ROBINSON TOWNSHIP, ALLEGHENY COUNTY  
MY COMMISSION EXPIRES OCTOBER 20, 1986

1/0

United States Nuclear Regulatory Commission  
Mr. George W. Knighton, Chief  
Page 2

SDH/wjs

REFERENCES: (a) IE Bulletin 84-02  
(b) IE Information Notice 84-20

cc: Mr. R. DeYoung, Director (3)  
Mr. E. A. Licitra, Project Manager  
Mr. G. Walton, NRC Resident Inspector  
INPO Records Center  
NRC Document Control Desk

