

NUREG-0020
Vol. 8, No. 8
August 1984

LICENSED OPERATING REACTORS

STATUS SUMMARY REPORT
DATA AS OF 07-31-84

UNITED STATES NUCLEAR REGULATORY COMMISSION



B410180141 840930
PDR NUREG
0020 R PDR

Available from

NRC/GPO Sales Program

Superintendent of Documents
Government Printing Office
Washington, D. C. 20402

A year's subscription consists of 12 issues for
this publication.

Single copies of this publication
are available from National Technical
Information Service, Springfield, VA 22161

Microfiche of single copies are
available from NRC/GPO Sales Program
Washington, D. C. 20555

NJREG-0020
Vol. 8, No. 8
August 1984

LICENSED OPERATING REACTORS

STATUS SUMMARY REPORT

DATA AS OF 07-31-84

Manuscript Completed: September 1984
Date Published: September 1984

OFFICE OF RESOURCE MANAGEMENT
U.S. NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555



AUTHORIZATION AND CLEARANCE

The U.S. Nuclear Regulatory Commission's Office of Resource Management publishes this month status report "as part of the reporting requirements in Section 50.36 of 10 CFR Part 50 under GAO Clearance Number B-180225, with an expiration date of September 30, 1981," as stated in the October 3, 1978 letter from John M. Lovelady, Assistant Director, General Government Division, U.S. General Accounting Office, to J.M. Felton, Director, Division of Rules and Records, U.S. Nuclear Regulatory Commission

*Extended to April 30, 1985 by OMB Directive 3150-0011.

STATEMENT OF PURPOSE

The U.S. Nuclear Regulatory Commission's monthly LICENSED OPERATING REACTORS Status Summary Report provides data on the operation of nuclear units as timely and accurately as possible. This information is collected by the Office of Resource Management, from the Headquarters Staff of NRC's Office of Inspection and Enforcement, from NRC's Regional Offices, and from utilities. Since all of the data concerning operation of the units is provided by the utility operators less than two weeks after the end of the month, necessary corrections to published information are shown on the ERRATA page.

This report is divided into three sections: the first contains monthly highlights and statistics for commercial operating units, and errata from previously reported data; the second is a compilation of detailed information on each unit, provided by NRC Regional Offices, IE Headquarters and the Utilities; and the third section is an appendix for miscellaneous information such as spent fuel storage capability, reactor years of experience and non-power reactors in the United States.

The percentage computations, Items 20 through 24 in Section 2, the vendor capacity factors on page 1-7, and actual vs. potential energy production on Page 1-2 are computed using actual data for the period of consideration. The percentages listed in power generation on Page 1-2 are computed as an arithmetic average. The factors for the life-span of each unit (the "Cumulative" column) are reported by the utility and are not entirely re-computed by NRC. Utility power production data is checked for consistency with previously submitted statistics.

It is hoped this status report proves informative and helpful to all agencies and individuals interested in analyzing trends in the nuclear industry which might have safety implications, or in maintaining an awareness of the U.S. energy situation as a whole.

T A B L E O F C O N T E N T S

	PAGE
GLOSSARY	ii
INDEX TO LICENSED UNITS	vii
<u>SECTION 1 - CURRENT DATA SUMMARIES</u>	
MONTHLY HIGHLIGHTS OF COMMERCIAL NUCLEAR POWER UNITS	1-2
Licensed Power Reactors	1-2
Power Generation	1-2
Actual vs. Potential Energy Production	1-2
Outage Data	1-2
Reasons for Shutdown	1-3
Derated Units	1-3
Shutdowns Greater Than 72 Hours Each	1-3
UNIT AVAILABILITY, CAPACITY, AND FORCED OUTAGE RATE PLOT	1-4
AVERAGE DAILY POWER LEVEL FOR ALL COMMERCIAL OPERATING UNITS	1-5
AVERAGE CAPACITY FACTORS BY VENDOR	
Vendor Plot	1-6
Statistics	1-7
MEMORANDA - SPECIAL INFORMATION	1-8
ERRATA - CORRECTIONS TO PREVIOUSLY REPORTED DATA	1-9
<u>SECTION 2 - OPERATING POWER REACTORS</u>	
ARKANSAS 1 THROUGH ZION 2	2-002 through 2-370
For each reactor:	
Operating Status	
Average Daily Power Level (MWe) Plot	
Unit Shutdowns/Reductions Summary	
Facility Data	
Inspection Status	
Licensee Reports	
<u>SECTION 3 - APPENDIX</u>	
STATUS OF SPENT FUEL STORAGE CAPABILITY	3-2
REACTOR-YEARS OF OPERATION	3-4
NON-POWER REACTORS IN THE U.S.	3-5

G L O S S A R Y

AVERAGE DAILY POWER LEVEL (MWe)	The net electrical energy generated during the day (measured from 0001 to 2400 hours inclusive) in megawatts hours, divided by 24 hours.
LICENSED THERMAL POWER (MWt)	The maximum thermal power of the reactor authorized by the NRC, expressed in megawatts.
DATE OF COMMERCIAL OPERATION	Date unit was declared by utility owner to be available for the regular production of electricity; usually related to satisfactory completion of qualification tests as specified in the purchase contract and to accounting policies and practices of utility.
DESIGN ELECTRICAL RATING (DER) (NET MWe)	The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design.
FORCED OUTAGE	An outage required to be initiated no later than the weekend following discovery of an offnormal condition.
FORCED OUTAGE HOURS	The clock hours during the report period that a unit is unavailable due to forced outages.
GROSS ELECTRICAL ENERGY GENERATED (MWH)	Electrical output of the unit during the report period as measured at the output terminals of the turbine generator, in megawatts hours.
GROSS HOURS	The clock hours from the beginning of a specified situation until its end. For outage durations, the clock hours during which the unit is not in power production.
GROSS THERMAL ENERGY GENERATED (MWH)	The thermal energy produced by the unit during the report period as measured or computed by the licensee in megawatt hours.
HOURS GENERATOR ON-LINE	Also, "Unit Service Hours." The total clock hours in the report period during which the unit operated with breakers closed to the station bus. These hours added to the total outage hours experienced by the unit during the report period, shall equal the hours in the report period.
HOURS IN REPORTING PERIOD	<p>For units in power ascension at the end of the period, the gross hours from the beginning of the period or the first electrical production, whichever comes last, to the end of the period.</p> <p>For units in commercial operation at the end of the period, the gross hours from the beginning of the period or of commercial operation, whichever comes last, to the end of the period or decommissioning, whichever comes first.</p>

G L O S S A R Y (continued)

HOURS REACTOR CRITICAL	The total clock hours in the report period during which the reactor sustained a controlled chain reaction.
MAXIMUM DEPENDABLE CAPACITY (GROSS) (MDC Gross) (Gross MWe)	Dependable main-unit gross capacity, winter or summer, whichever is smaller. The dependable capacity varies because the unit efficiency varies during the year due to cooling water temperature variations. It is the gross electrical output as measured at the output terminals of the turbine generator during the most restrictive seasonal conditions (usually summer).
MAXIMUM DEPENDABLE CAPACITY (NET) (MDC Net) (Net MWe)	Maximum Dependable Capacity (Gross) less the normal station service loads.
NAMEPLATE RATING (Gross MWe)	The nameplate power designation of the generator in megavolt amperes (MVA) times the nameplate power factor of the generator. NOTE: The nameplate rating of the generator may not be indicative of the maximum or dependable capacity, since some other item of equipment of a lesser rating (e.g., turbine) may limit unit output.
NET ELECTRICAL ENERGY GENERATED	Gross electrical output of the unit measured at the output terminals of the turbine generator during the reporting period, minus the normal station service electrical energy utilization. If this quantity is less than zero, a negative number should be recorded.
OUTAGE	A situation in which no electrical production takes place.
OUTAGE DATE	As reported on Appendix D of Reg. Guide 1.16, the date of the start of the outage. If continued from a previous month, report the same outage date but change "Method of Shutting Down Reactor" to "4 (continuations)" and add a note: "Continued from previous month."
OUTAGE DURATION	The Total clock hours of the outage measured from the beginning of the report period or the outage, whichever comes last, to the end of the report period or the outage, whichever comes first.
OUTAGE NUMBER	A number unique to the outage assigned by the licensee. The same number is reported each month in which the outage is in progress. One format is "76-05" for the fifth outage to occur in 1976.
PERIOD HOURS	See "Hours in Reporting Period."
POWER REDUCTION	A reduction in the Average Daily Power Level of more than 20% from the previous day. All power reductions are defined as outage of zero hours durations for the purpose of computing unit service and availability factors, and forced outage rate.

G L O S S A R Y (continued)

REACTOR AVAILABLE HOURS	The Total clock hours in the report period during which the reactor was critical or was capable of being made critical. (Reactor Reserve Shutdown Hours + Hours Reactor Critical.)
REACTOR AVAILABILITY FACTOR	$\frac{\text{Reactor Available Hours} \times 100}{\text{Period Hours}}$
REACTOR RESERVE SHUTDOWN	The cessation of criticality in the reactor for administrative or other similar reasons when operation could have been continued.
REACTOR RESERVE SHUTDOWN HOURS	The total clock hours in the report period that the reactor is in reserve shutdown mode. NOTE: No credit is given for NRC imposed shutdowns.
REACTOR SERVICE FACTOR	$\frac{\text{Hours Reactor Critical} \times 100}{\text{Period Hours}}$
REPORT PERIOD	Usually, the preceding calendar month. Can also be the preceding calendar year, (Year-to-Date), or the life-span of a unit (cumulative).
RESTRICTED POWER LEVEL	Maximum net electrical generation to which the unit is restricted during the report period due to the state of equipment, external conditions, administrative reasons, or a direction by NRC.
SCHEDULED OUTAGE	Planned removal of a unit from service for refueling, inspection, training, or maintenance. Those outages which do not fit the definition of "Forced Outage" perforce are "Scheduled Outages."
STARTUP AND POWER ASCENSION TEST PHASE	Period following initial criticality during which the unit is tested at successively higher levels, culminating with operation at full power for a sustained period and completion of warranty runs. Following this phase, the utility generally considers the unit to be available for commercial operation.
UNIT	The set of equipment uniquely associated with the reactor, including turbine generators, and ancillary equipment, considered as a single electrical energy production facility.
UNIT AVAILABLE HOURS	The total clock hours in the report period during which the unit operated on-line or was capable of such operation. (Unit Reserve Shutdown Hours + Hours Generator On-Line.)

G L O S S A R Y (continued)

UNIT AVAILABILITY FACTOR	$\frac{\text{Unit Available Hours} \times 100}{\text{Period Hours}}$
UNIT CAPACITY FACTORS	
- Using Licensed Thermal Power	$\frac{\text{Gross Thermal Energy Generated} \times 100}{\text{Period Hours} \times \text{Lic. Thermal Power}}$
- Using Nameplate Rating	$\frac{\text{Gross Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{Nameplate Rating}}$
- Using DER	$\frac{\text{Net Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{DER}}$
- Using MDC Gross	$\frac{\text{Gross Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{MDC Gross}}$
- Using MDC Net	$\frac{\text{Net Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{MDC Net}}$
NOTE: if MDC GROSS and/or MDC NET have not been determined, the DER is substituted for this quantity for Unit Capacity Factor calculations.	
UNIT FORCED OUTAGE RATE	$\frac{\text{Forced Outage Hours}}{\text{Unit Service Hours} + \text{Forced Outage Hours}}$
UNIT RESERVE SHUTDOWN	The removal of the unit from on-line operation for economic or other similar reasons when operation could have been continued.
UNIT RESERVE SHUTDOWN HOURS	The total clock hours in the report period during which the unit was in reserve shutdown mode.
UNIT SERVICE FACTOR	$\frac{\text{Unit Service Hours} \times 100}{\text{Period Hours}}$
UNIT SERVICE HOURS	See "Hours Generator On-Line."

NOTE:

At the end of each statement in the Enforcement Summary for any given facility may be found numbers in parentheses. These numbers are related to the inspection, e.g., 8111 (the 11th inspection of the plant in 1981); and the severity level, e.g., 4 (severity level IV). Violations are ranked by severity levels from I through V with level I being the most serious. The severity level is used in the determination of any resulting enforcement action. Gray Book lists severity level by Arabic numbers corresponding to the Roman numerals. Details on the various severity levels and enforcement actions can be found in Appendix C to 10 CFR Part 2 published in the Federal Register of March 9, 1982 pages 9987 through 9995, and as corrected April 14, 1982.

INDEX TO OPERATING POWER REACTORS

	PAGE		PAGE
ARKANSAS 1	2-002	NORTH ANNA 1	2-186
ARKANSAS 2	2-006	NORTH ANNA 2	2-190
BEAVER VALLEY 1	2-010	OCONEE 1	2-194
BIG ROCK POINT 1	2-014	OCONEE 2	2-198
BROWNS FERRY 1	2-020	OCONEE 3	2-202
BROWNS FERRY 2	2-026	OYSTER CREEK 1	2-206
BROWNS FERRY 3	2-032	PALISADES	2-212
BRUNSWICK 1	2-038	PEACH BOTTOM 2	2-218
BRUNSWICK 2	2-042	PEACH BOTTOM 3	2-222
CALVERT CLIFFS 1	2-046	PILGRIM 1	2-226
CALVERT CLIFFS 2	2-050	POINT BEACH 1	2-230
COOK 1	2-054	POINT BEACH 2	2-236
COOK 2	2-058	PRAIRIE ISLAND 1	2-240
COOPER STATION	2-062	PRAIRIE ISLAND 2	2-246
CRYSTAL RIVER 3	2-066	QUAD CITIES 1	2-250
DAVIS-BESSE 1	2-070	QUAD CITIES 2	2-254
DRESDEN 2	2-076	RANCHO SECO 1	2-258
DRESDEN 3	2-080	ROBINSON 2	2-264
DUANE AKNOLD	2-084	SALEM 1	2-268
FARLEY 1	2-088	SALEM 2	2-272
FARLEY 2	2-092	SAN ONOFRE 1	2-276
FITZPATRICK	2-096	SAN ONOFRE 2	2-280
FORT CALHOUN 1	2-100	SAN ONOFRE 3	2-286
FORT ST VRAIN	2-104	SEQUOYAH 1	2-292
GINNA	2-110	SEQUOYAH 2	2-296
HADDAM NECK	2-114	ST LUCIE 1	2-300
HATCH 1	2-118	ST LUCIE 2	2-304
HATCH 2	2-122	SUMMER 1	2-308
INDIAN POINT 2	2-126	SURRY 1	2-312
INDIAN POINT 3	2-130	SURRY 2	2-316
KEWAUNEE	2-134	SUSQUEHANNA 1	2-320
LA CROSSE	2-138	SUSQUEHANNA 2	2-324
LASALLE 1	2-144	THREE MILE ISLAND 1	2-328
LASALLE 2	2-150	TROJAN	2-332
MAINE YANKEE	2-156	TURKEY POINT 3	2-338
MCGUIRE 1	2-160	TURKEY POINT 4	2-344
MCGUIRE 2	2-166	VERMONT YANKEE 1	2-350
MILLSTONE 1	2-170	WASHINGTON NUCLEAR 2	2-354
MILLSTONE 2	2-174	YANKEE-ROWE 1	2-358
MONTICELLO	2-178	ZION 1	2-362
NINE MILE POINT 1	2-182	ZION 2	2-366

SECTION 1

**CURRENT
DATA
SUMMARIES**

MONTHLY HIGHLIGHTS

***** 79 IN COMMERCIAL OPERATION 62,118 CAPACITY MWe (Net) --Based upon maximum dependable
 * LICENSED * (a) 3 IN POWER ASCENSION. 3,201 capacity; design elec. rating
 * POWER * --- used if MDC not determined
 * REACTORS * (b) 82 LICENSED TO OPERATE 65,319 TOTAL
 ***** (c) 3 LICENSED FOR FUEL LOADING
 AND LOW POWER TESTING

MDC NET		DER		DATE	DER
(a) LASALLE 2 1036	(b) Excludes these plants	1. DRESDEN 1 200	(c) GRAND GULF 1 06/16/82 1250	
WASH. NUC. 2 1100	licensed for operation	2. HUMBOLDT BAY 65	DIABLO CANYON 1 04/19/84 1084	
SUSQUEHANNA 2 1065	which are shut down	3. TMI 2 906	CALLAWAY 1 06/11/84 1188	
	indefinitely				

	REPORT MONTH	PREVIOUS MONTH	YEAR-TO-DATE
***** 1. GROSS ELECTRICAL (MWHE)	28,811,822	26,298,261	194,129,816
* POWER * 2. NET ELECTRICAL (MWHE)	27,430,862	25,004,342	184,518,586
* GENERATION * 3. AVG. UNIT SERVICE FACTOR (%)	64.2	59.5	62.6
***** 4. AVG. UNIT AVAILABILITY FACTOR (%)	64.2	59.5	62.6
5. AVG. UNIT CAPACITY FACTOR (MDC) (%)	58.8	54.7	58.2
6. AVG. UNIT CAPACITY FACTOR (DER) (%)	57.4	53.5	56.8
7. FORCED OUTAGE RATE (%)	13.1	8.9	9.7

		% OF POTENTIAL PRODUCTION
***** 1. ENERGY ACTUALLY PRODUCED DURING THIS REPORT PERIOD.	27,430,862 NET	59.4
* ACTUAL VS. * 2. ENERGY NOT PRODUCED DUE TO SCHEDULED OUTAGES (NET).	10,906,070 MWHe	23.6
* POTENTIAL * 3. ENERGY NOT PRODUCED DUE TO FORCED OUTAGES (NET)	5,174,022 MWHe	11.2
* ENERGY * 4. ENERGY NOT PRODUCED FOR OTHER REASONS (NET)	2,704,838 MWHe	5.9
* PRODUCTION * *****		
POTENTIAL ENERGY PRODUCTION IN THIS PERIOD BY UNITS IN COMMERCIAL OPERATION	46,215,792 MWHe	100.0% TOTAL
(Using Maximum Dependable Capacity Net)		
5. ENERGY NOT PRODUCED DUE TO NRC-REQUIRED OUTAGES	582,688 MWHe	
6. ENERGY NOT PRODUCED DUE TO NRC RESTRICTED POWER LEVELS. MWHe	0 UNIT(S) WITH NRC RESTRICTION

	NUMBER	HOURS	PERCENT OF CLOCK TIME	MWHE LOST PRODUCTION
***** 1. FORCED OUTAGES DURING REPORT PERIOD	48	7,163.1	12.2	5,174,022
* OUTAGE * 2. SCHEDULED OUTAGES DURING REPORT PERIOD.	28	13,864.6	23.6	10,906,070
* DATA * *****				
TOTAL	76	21,027.7	35.8	16,080,092

MWHE LOST PRODUCTION = Down time X maximum dependable capacity net

MONTHLY HIGHLIGHTS


		NUMBER	HOURS LOST
*****	A - Equipment Failure	32	5,252.2
* REASONS *	B - Maintenance or Test	8	2,028.0
* FOR *	C - Refueling	18	10,921.9
* SHUTDOWNS *	D - Regulatory Restriction.	2	827.5
*****	E - Operator Training & License Examination	0	0.0
	F - Administrative.	0	0.0
	G - Operational Error	6	146.4
	H - Other	9	1,534.9
	TOTAL	75	20,710.9

		MDC (MWe Net)	POWER LIMIT (MWe Net)	TYPE
* DERATED *	BROWNS FERRY 2	*65	640	Self-imposed
* UNITS *	FORT ST VRAIN	330	280	Self-imposed

	UNIT	REASON	UNIT	REASON	UNIT	REASON	UNIT	REASON
* SHUTDOWNS *	ARKANSAS 2	H	BEAVER VALLEY 1	A	BIG ROCK POINT 1	C,D	BROWNS FERRY 3	C
* GREATER *	BRUNSWICK 2	C	CALVERT CLIFFS 2	A	COOK 1	B	COOK 2	C
* THAN 72 HRS *	DRESDEN 3	A	FORT CALHOUN 1	C	FORT ST VRAIN	A	HATCH 2	H
* EACH *	INDIAN POINT 2	C	LA CROSSE	A	MCGUIRE 2	A	MONTICELLO	C
*****	NORTH ANNA 1	C	OYSTER CREEK 1	C	PALISADES	C	PEACH BOTTOM 2	C
	PEACH BOTTOM 3	H	PILGRIM 1	C	QUAD CITIES 1	C	RANCHO SECO 1	A
	ROBINSON 2	C	SALEM 1	A,C	SALEM 2	A,A	SAN ONOFRE 1	B
	SAN ONOFRE 2	B	SAN ONOFRE 3	A,B	ST LUCIE 1	A	SUMMER 1	A
	SURRY 1	B	SUSQUEHANNA 1	H	THREE MILE ISLAND 1	D	TROJAN	C
	TURKEY POINT 3	A	TURKEY POINT 4	A	VERMONT YANKEE 1	C	YANKEE-ROWE 1	H
	ZION 1		ZION 2	H				

Unit Availability, Capacity, Forced Outage

Avg. Unit Percentage as of 07-31-84




AVERAGE DAILY POWER LEVEL FOR ALL COMMERCIALY OPERATING UNITS

This chart depicts the average daily power level for the units in commercial operation during the month.

The straight line on the graph labelled "SUM OF MDC" is plotted at the value shown by summing the separate maximum dependable capacities of the commercially operating units (in Net MWe). The plot shown below the line is calculated by summing the separate average daily power levels of the same units for each day of the month.

The scale on the left vertical axis runs in 1,000 MWe increments from 0 to 55,000 MWe (Net). The right vertical axis shows the percentage in 10% increments, up to 100% of the "SUM OF MDC".


It should be recognized that the 100% line would be obtainable only if all of the commercially operating units operated at 100% capacity, 24 hours per day, for the entire month. In other words, since any power generator must occasionally shut down to refuel and/or perform needed maintenance, and also since 100% capacity production is not always required by power demands, the 100% line is a theoretical goal and not a practical one.



JULY 1984

Vendor Average Capacity Factors

As Of 07-31-84



NOTE: This display of average capacity factors provides a general performance comparison of plants supplied by the four nuclear steam supply system vendors. One must be careful when drawing conclusions regarding the reasons for the performance levels indicated, since plant performance may be affected by unspecified factors such as: (1) various plant designs and models are included for each vendor; (2) turbine/generators and (3) different architect/engineers are also involved.

AVERAGE CAPACITY FACTORS BY VENDORS

***** CFMDC	CFMDC	CFMDC	CFMDC
* GENERAL * 94.5 BROWNS FERRY 1	56.5 BROWNS FERRY 2	0.0 BROWNS FERRY 3	96.4 BRUNSWICK 1
* ELECTRIC * 0.0 BRUNSWICK 2	87.4 COOPER STATION	75.2 DRESDEN 2	11.2 DRESDEN 3
***** 83.4 DUANE ARNOLD	90.7 FITZPATRICK	92.0 HATCH 1	0.0 HATCH 2
90.5 LASALLE 1	96.0 MILLSTONE 1	0.0 MONTICELLO	97.4 NINE MILE POINT 1
0.0 OYSTER CREEK 1	0.0 PEACH BOTTOM 2	87.1 PEACH BOTTOM 3	0.0 PILGRIM 1
0.0 QUAD CITIES 1	96.9 QUAD CITIES 2	60.1 SUSQUEHANNA 1	0.0 VERMONT YANKEE 1

***** CFMDC	CFMDC	CFMDC	CFMDC
* BABCOCK & * 87.2 ARKANSAS 1	95.4 CRYSTAL RIVER 3	90.2 DAVIS-BESSE 1	99.1 OCONEE 1
* WILCOX * 97.3 OCONEE 2	98.8 OCONEE 3	5.7 RANCHO SECO 1	0.0 THREE MILE ISLAND 1

***** CFMDC	CFMDC	CFMDC	CFMDC
* COMBUSTION * 67.6 ARKANSAS 2	102.9 CALVERT CLIFFS 1	57.9 CALVERT CLIFFS 2	36.8 FORT CALHOUN 1
* ENGINEERING * 98.4 MAINE YANKEE	91.0 MILLSTONE 2	0.3 PALISADES	12.9 SAN ONOFRE 2
***** 30.2 SAN ONOFRE 3	89.5 ST LUCIE 1	102.5 ST LUCIE 2	

***** CFMDC	CFMDC	CFMDC	CFMDC
* WESTINGHOUSE* 84.6 BEAVER VALLEY 1	85.8 COOK 1	54.6 COOK 2	102.2 FARLEY 1
***** 98.9 FARLEY 2	101.0 GINNA	74.9 HADDAM NECK	0.0 INDIAN POINT 2
93.8 INDIAN POINT 3	101.4 KEWAUNEE	87.9 MCGUIRE 1	59.0 MCGUIRE 2
0.0 NORTH ANNA 1	84.0 NORTH ANNA 2	96.3 POINT BEACH 1	100.9 POINT BEACH 2
99.5 PRAIRIE ISLAND 1	101.6 PRAIRIE ISLAND 2	0.0 ROBINSON 2	0.0 SALEM 1
14.6 SALEM 2	0.0 SAN ONOFRE 1	94.0 SEQUOYAH 1	78.9 SEQUOYAH 2
37.6 SUMMER 1	52.1 SURRY 1	90.2 SURRY 2	0.0 TROJAN
84.5 TURKEY POINT 3	61.9 TURKEY POINT 4	73.5 YANKEE-ROWE 1	55.2 ZION 1
51.8 ZION 2			

***** Units excluded are:
 * OTHER INFO * BIG ROCK POINT
 ***** DRESDEN 1
 FORT ST VRAIN
 HUMBOLDT BAY
 LACROSSE
 THREE MILE ISLAND 2

Capacity factor in this page, denoted as CFMDC, is a function of the net maximum dependable capacity. See the corresponding definition in the glossary. The vendor averages are computed by the formula:

$$\frac{\text{Net Electrical Energy Produced by Vendor}}{\text{Potential Electrical Production by Vendor in this Month}} \times 100\%$$

	GE BWRs	West PWRs	Comb PWRs	B&W PWRs	ALL PWRs
NET ELECTRICAL PRODUCTION.....	7,437,092	12,123,429	4,218,106	3,638,042	19,979,577
MDC NET.....	19,226	26,641	9,049	6,760	42,450
CFMDC.....	52.0	61.2	62.7	72.3	63.3

M E M O R A N D A

THE FOLLOWING UNITS USE WEIGHTED AVERAGES TO CALCULATE CAPACITY FACTORS:

ITEM 22

BIG ROCK POINT 1
CALVERT CLIFFS 1 & 2
FARLEY 1
FITZPATRICK
FORT CALHOUN 1
INDIAN POINT 2*
KEWAUNEE
OYSTER CREEK 1
POINT BEACH 1 & 2
THREE MILE ISLAND 1
TURKEY POINT 3 & 4

ITEM 22 & 23

GINNA
HADDAM NECK (CONNECTICUT YANKEE)
MAINE YANKEE
MILLSTONE 2
OCONEE 1, 2, & 3
YANKEE-ROWE 1

*COMPUTED SINCE 7/1/74, THE DATE OF COMPLETION OF A 100 DAY - 100% POWER OPERATION TEST.

THE FOLLOWING UNITS USE THE DATE OF FIRST ELECTRICAL GENERATION INSTEAD OF COMMERCIAL OPERATION,
FOR THEIR CUMULATIVE DATA:

ITEMS 20 THROUGH 24

COOK 1 & 2
BEAVER VALLEY 1
SAN ONOFRE 1

ITEM 24 ONLY

BIG ROCK POINT 1

E R R A T A
CORRECTIONS TO PREVIOUSLY REPORTED DATA

NOTE: THESE CHANGES ARE REFLECTED IN THE DATA CONTAINED IN THE CURRENT REPORT

REVISED MONTHLY HIGHLIGHTS

NONE

SECTION 2

**OPERATING
POWER
REACTORS**

1. Docket: 50-313 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: K. L. MORTON (501) 964-3155

4. Licensed Thermal Power (MWt): 2568

5. Nameplate Rating (Gross MWe): 1003 X 0.9 = 903

6. Design Electrical Rating (Net MWe): 850

7. Maximum Dependable Capacity (Gross MWe): 883

8. Maximum Dependable Capacity (Net MWe): 836

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>84,306.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,480.4</u>	<u>56,915.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>5,044.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,462.6</u>	<u>55,712.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>817.5</u>
17. Gross Therm Ener (MWH)	<u>1,711,985</u>	<u>10,728,142</u>	<u>132,648,439</u>
18. Gross Elec Ener (MWH)	<u>569,565</u>	<u>3,596,565</u>	<u>43,734,930</u>
19. Net Elec Ener (MWH)	<u>542,437</u>	<u>3,438,354</u>	<u>41,696,741</u>
20. Unit Service Factor	<u>100.0</u>	<u>87.3</u>	<u>66.1</u>
21. Unit Avail Factor	<u>100.0</u>	<u>87.3</u>	<u>67.1</u>
22. Unit Cap Factor (MDC Net)	<u>87.2</u>	<u>80.5</u>	<u>59.2</u>
23. Unit Cap Factor (DER Net)	<u>85.8</u>	<u>79.1</u>	<u>58.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.3</u>	<u>15.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>14.8</u>	<u>10,192.9</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
REFUELING & MAINTENANCE: 10/16/84 THROUGH 01/01/85

27. If Currently Shutdown Estimated Startup Date: N/A

* ARKANSAS 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ARKANSAS 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* ARKANSAS 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

* SUMMARY *

ARKANSAS 1 OPERATED WITH NO OUTAGES OR REDUCTIONS DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

 * ARKANSAS 1 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
 STATE.....ARKANSAS
 COUNTY.....POPE
 DIST AND DIRECTION FROM
 NEAREST POPULATION CTR...6 MI WNW OF
 RUSSELLVILLE, AR
 TYPE OF REACTOR.....PWR
 DATE INITIAL CRITICALITY...AUGUST 6, 1974
 DATE ELEC ENER 1ST GENER...AUGUST 17, 1974
 DATE COMMERCIAL OPERATE...DECEMBER 19, 1974
 CONDENSER COOLING METHOD...ONCE THRU
 CONDENSER COOLING WATER...DARDANELLE RESERVOIR
 ELECTRIC RELIABILITY
 COUNCIL.....SOUTHWEST POWER POOL

UTILITY
 LICENSEE.....ARKANSAS POWER & LIGHT
 CORPORATE ADDRESS.....NINTH & LOUISIANA STREETS
 LITTLE ROCK, ARKANSAS 72203
 CONTRACTOR
 ARCHITECT/ENGINEER.....BECHTEL
 NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
 CONSTRUCTOR.....BECHTEL
 TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
 IE RESIDENT INSPECTOR.....B. JOHNSON
 LICENSING PROJ MANAGER.....G. VISSING
 DOCKET NUMBER.....50-313
 LICENSE & DATE ISSUANCE...DPR-51, MAY 21, 1974
 PUBLIC DOCUMENT ROOM.....ARKANSAS TECH UNIVERSITY
 RUSSELLVILLE, ARKANSAS 72801

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED JUNE 1-30, 1984 (84-18) ROUTINE, ANNOUNCED INSPECTION OF MAINTENANCE, SURVEILLANCE, OPERATIONAL SAFETY VERIFICATION, AND FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS, IE BULLETINS, AND GENERIC LETTER 83-28.
 WITHIN THE AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:
 POWER LIMITED TO ABOUT 90% DUE TO ELEVATED 'A' STEAM GENERATOR WATER LEVEL.
 FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

 * ARKANSAS 1 *

OTHER ITEMS

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

POWER OPERATION

LAST IE SITE INSPECTION DATE: JUNE 1-30, 1984

INSPECTION REPORT NO: 50-313/84-18

R E P O R T S F R O M L I C E N S E E

```

=====
NUMBER   DATE OF    DATE OF    SUBJECT
        EVENT    REPORT
-----
84-001   3-21-84   4-20-84   SAFETY RELATED SHOCK SUPPRESSOR (SIXUBBER) FAILURE RX TRIP ON ANTICIPATED LOSS OF BOTH MFW PUMPS
84-002   3-16-84   4-13-84   RCS PRESSURE TRANSMITTERS OUT OF TOLERANCE RX TRIP DUE TO TROUBLESHOOTING ACTIVITIES WITH THRUST
84-003   3-28-84   4-20-84   BEARING
84-004   4-21-84   5-17-84
=====
    
```

1. Docket: 50-368 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: LINDY BRAMLETT (501) 964-3145

4. Licensed Thermal Power (MWt): 2815

5. Nameplate Rating (Gross MWe): 943

6. Design Electrical Rating (Net MWe): 912

7. Maximum Dependable Capacity (Gross MWe): 897

8. Maximum Dependable Capacity (Net MWe): 858

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>38,135.0</u>
13. Hours Reactor Critical	<u>550.8</u>	<u>4,220.0</u>	<u>25,892.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,430.1</u>
15. Hrs Generator On-Line	<u>548.3</u>	<u>4,058.6</u>	<u>25,008.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>75.0</u>
17. Gross Therm Ener (MWH)	<u>1,372,786</u>	<u>10,320,125</u>	<u>62,869,665</u>
18. Gross Elec Ener (MWH)	<u>453,432</u>	<u>3,435,752</u>	<u>20,452,703</u>
19. Net Elec Ener (MWH)	<u>431,843</u>	<u>3,276,171</u>	<u>19,482,511</u>
20. Unit Service Factor	<u>73.7</u>	<u>79.4</u>	<u>65.6</u>
21. Unit Avail Factor	<u>73.7</u>	<u>79.4</u>	<u>65.8</u>
22. Unit Cap Factor (MDC Net)	<u>67.6</u>	<u>74.7</u>	<u>59.5</u>
23. Unit Cap Factor (DER Net)	<u>63.6</u>	<u>70.3</u>	<u>56.0</u>
24. Unit Forced Outage Rate	<u>26.3</u>	<u>6.9</u>	<u>18.5</u>
25. Forced Outage Hours	<u>195.7</u>	<u>301.2</u>	<u>5,679.7</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* ARKANSAS 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
ARKANSAS 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* ARKANSAS 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-07	07/20/84	F	195.7	H	2	84-19-00	ZZ	ZZZZZ	THE UNIT WAS MANUALLY TRIPPED DUE TO INDICATIONS RECEIVED WHEN AN INVERTER WAS INADVERTENTLY TRANSFERRED. THE UNIT REMAINED SHUTDOWN FOR EQUIPMENT MAINTENANCE (EXCORE DETECTORS, RCS TEMPERATURE ELEMENTS, AND RCP SEALS).

***** ARKANSAS 2 OPERATED WITH 1 OUTAGE DURING JULY.
* SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* ARKANSAS 2 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ARKANSAS
COUNTY.....POPE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...6 MI WNW OF
RUSSELLVILLE, AR
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 5, 1978
DATE ELEC ENER 1ST GENER...DECEMBER 26, 1978
DATE COMMERCIAL OPERATE...MARCH 26, 1980
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...DARDANELLE RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ARKANSAS POWER & LIGHT
CORPORATE ADDRESS.....NINTH & LOUISIANA STREETS
LITTLE ROCK, ARKANSAS 72203
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....W. JOHNSON
LICENSING PROJ MANAGER.....R. LEE
DOCKET NUMBER.....50-368
LICENSE & DATE ISSUANCE...NPF-6, SEPTEMBER 1, 1978
PUBLIC DOCUMENT ROOM.....ARKANSAS TECH UNIVERSITY
RUSSELLVILLE, ARKANSAS 72801

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED ON JUNE 1-30, 1984 (84-18) ROUTINE, ANNOUNCED INSPECTION OF OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE, AND FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS, IE BULLETINS, AND GENERIC LETTER 83-28.
WITHIN AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* ARKANSAS 2 *

OTHER ITEMS

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

POWER OPERATION

LAST IE SITE INSPECTION DATE: JUNE 1-30, 1984

INSPECTION REPORT NO: 50-368/84-18

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-011/00	5-7-84	6-7-84	REACTOR ON HIGH STEAM GENERATOR LEVEL.
84-012/00	5-7-84	6-18-84	PRIMARY PROTECTION DEVICE.

1. Docket: 50-334 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. L. HOLTZ (412) 643-1369

4. Licensed Thermal Power (MWt): 2660

5. Nameplate Rating (Gross MWe): 1026 X 0.9 = 923

6. Design Electrical Rating (Net MWe): 835

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 810

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>72,335.0</u>
13. Hours Reactor Critical	<u>71.6</u>	<u>4,757.3</u>	<u>35,640.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>4,482.7</u>
15. Hrs Generator On-Line	<u>667.8</u>	<u>4,585.1</u>	<u>34,364.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,737,076</u>	<u>11,525,795</u>	<u>79,115,327</u>
18. Gross Elec Ener (MWH)	<u>545,000</u>	<u>3,719,500</u>	<u>25,148,440</u>
19. Net Elec Ener (MWH)	<u>510,080</u>	<u>3,499,545</u>	<u>23,388,343</u>
20. Unit Service Factor	<u>89.8</u>	<u>89.7</u>	<u>49.8</u>
21. Unit Avail Factor	<u>89.8</u>	<u>89.7</u>	<u>49.8</u>
22. Unit Cap Factor (MDC Net)	<u>84.6</u>	<u>84.5</u>	<u>43.5</u>
23. Unit Cap Factor (DER Net)	<u>82.1</u>	<u>82.0</u>	<u>42.2</u>
24. Unit Forced Outage Rate	<u>10.2</u>	<u>4.1</u>	<u>28.1</u>
25. Forced Outage Hours	<u>76.2</u>	<u>195.0</u>	<u>17,872.1</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
SCHEDULED SHUTDOWN IN OCTOBER FOR 4TH REFUELING.

27. If Currently Shutdown Estimated Startup Date: N/A

* BEAVER VALLEY 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
BEAVER VALLEY 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * BEAVER VALLEY 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
9	07/05/84	F	76.2	A	1		AA	VALVOP	AT 2130 HOURS ON THE 5TH, VALVE TV-CC-110D, CONTAINMENT RECIRC. COOLING COILS OUTLET CONTAINMENT ISOLATION VALVE, FAILED SHUT DUE TO A TORN DIAPHRAGM IN THE VALVE OPERATOR. THE PLANT WAS BROUGHT DOWN INTO COLD SHUTDOWN WHILE REPAIRS WERE MADE. THE VALVE WAS DECLARED OPERABLE AT 2052 HOURS ON THE 6TH AND STATION HEATUP WAS BEGUN SOON AFTERWARD.

 * SUMMARY *

 BEAVER VALLEY 1 OPERATED WITH 1 OUTAGE FOR EQUIPMENT FAILURE IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BEAVER VALLEY 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA

COUNTY.....BEAVER

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI E OF
E. LIVERPOOL, OH

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...MAY 10, 1976
DATE ELEC ENER 1ST GENER...JUNE 14, 1976
DATE COMMERCIAL OPERATE....OCTOBER 1, 1976
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...OHIO RIVER

ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUQUESNE LIGHT

CORPORATE ADDRESS.....ONE OXFORD CENTRE, 301 GRANT STREET
PITTSBURGH, PENNSYLVANIA 15279

CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....W. TROSKOSKI
LICENSING PROJ MANAGER.....P. TAM
DOCKET NUMBER.....50-334
LICENSE & DATE ISSUANCE...DPR-66, JULY 2, 1976
PUBLIC DOCUMENT ROOM.....B.F. JONES MEMORIAL LIBRARY
633 FRANKLIN AVENUE
ALIQIPPA, PA 15001

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* BEAVER VALLEY 1 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

1. Docket: 50-155 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: LINDA BALCH (616) 547-6537

4. Licensed Thermal Power (Mwt): 240

5. Nameplate Rating (Gross MWe): 70.6 X 0.85 = 60

6. Design Electrical Rating (Net MWe): 72

7. Maximum Dependable Capacity (Gross MWe): 69

8. Maximum Dependable Capacity (Net MWe): 64

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>187,098.0</u>
13. Hours Reactor Critical	<u>124.3</u>	<u>3,395.1</u>	<u>131,105.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>107.1</u>	<u>3,336.6</u>	<u>128,629.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>7,460</u>	<u>620,698</u>	<u>24,106,589</u>
18. Gross Elec Ener (MWH)	<u>2,210</u>	<u>201,578</u>	<u>7,617,187</u>
19. Net Elec Ener (MWH)	<u>1,948</u>	<u>190,039</u>	<u>7,202,251</u>
20. Unit Service Factor	<u>14.4</u>	<u>65.3</u>	<u>68.7</u>
21. Unit Avail Factor	<u>14.4</u>	<u>65.3</u>	<u>68.7</u>
22. Unit Cap Factor (MDC Net)	<u>4.1</u>	<u>58.1</u>	<u>57.4*</u>
23. Unit Cap Factor (DER Net)	<u>3.6</u>	<u>51.6</u>	<u>53.5</u>
24. Unit Forced Outage Rate	<u>85.6</u>	<u>24.0</u>	<u>16.8</u>
25. Forced Outage Hours	<u>636.9</u>	<u>1,054.4</u>	<u>10,954.7</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>NONE</u>			

27. If Currently Shutdown Estimated Startup Date: N/A

* BIG ROCK POINT 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BIG ROCK POINT 1



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * BIG ROCK POINT 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-03	05/30/84	F	533.2	C	4	84-003	WF	PIPEXX	SUSPECTED PIPE BREAK IN A SIX-INCH PIPE FROM THE CONDENSATE STORAGE TANK CAUSED THE PLANT TO SHUT DOWN. DECIDED TO COMMENCE 19TH REFUELING DUE TO INCREASED OFF GAS (REF: LER 84-002) ACTIVITY. LEAK ISOLATED AND TEMPORARY MAKEUP LINE INSTALLED.
84-04	07/23/84	F	83.5	D	9				10 CFR 50 APPENDIX "R" EXEMPTION REQUEST NOT APPROVED AT END OF 19TH REFUELING OUTAGE.
84-05	07/26/84	F	20.2	A	3		HE	VALVEX	DURING TURBINE OVERSPEED TRIP TEST, TURBINE BYPASS VALVE CLOSED CAUSING REACTOR TRIP ON HIGH PRESSURE.

 * SUMMARY *

 BIG ROCK POINT 1 RETURNED ONLINE FROM REFUELING AND MAINTENANCE ON JULY 26TH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

 * BIG ROCK POINT 1 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
 STATE.....MICHIGAN

 COUNTY.....CHARLEVOIX

 DIST AND DIRECTION FROM
 NEAREST POPULATION CTR...4 MI NE OF
 CHARLEVOIX, MICH

 TYPE OF REACTOR.....BWR

 DATE INITIAL CRITICALITY...SEPTEMBER 27, 1962

 DATE ELEC ENER 1ST GENER...DECEMBER 8, 1962

 DATE COMMERCIAL OPERATE...MARCH 29, 1963

 CONDENSER COOLING METHOD...ONCE THRU

 CONDENSER COOLING WATER...LAKE MICHIGAN

 ELECTRIC RELIABILITY
 COUNCIL.....EAST CENTRAL AREA
 RELIABILITY COORDINATION
 AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
 LICENSEE.....CONSUMERS POWER

 CORPORATE ADDRESS.....212 WEST MICHIGAN AVENUE
 JACKSON, MICHIGAN 49201

 CONTRACTOR
 ARCHITECT/ENGINEER.....BECHTEL

 NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

 CONSTRUCTOR.....BECHTEL

 TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

 IE RESIDENT INSPECTOR.....S. GUTHRIE

 LICENSING PROJ MANAGER....R. EMCH
 DOCKET NUMBER.....50-155

 LICENSE & DATE ISSUANCE...DPR-6, AUGUST 30, 1962

 PUBLIC DOCUMENT ROOM.....NORTH CENTRAL MICHIGAN COLLEGE
 1515 HOWARD STREET
 PETOSKEY, MICHIGAN 49770

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MAY 21-23, (84-03): ROUTINE, ANNOUNCED INSPECTION OF THE FOLLOWING AREAS: BIG ROCK POINT NUCLEAR PLANT EMERGENCY PREPAREDNESS EXERCISE INVOLVING OBSERVATIONS OF KEY FUNCTIONS AND LOCATIONS DURING THE EXERCISE BY EIGHT NRC REPRESENTATIVES; LICENSEE ACTIONS ON PREVIOUSLY IDENTIFIED EMERGENCY PREPAREDNESS ITEMS; AND LICENSEE ACTIONS ON PREVIOUS EXERCISE WEAKNESSES. THE INSPECTION INVOLVED 155 INSPECTOR HOURS ONSITE BY FOUR NRC INSPECTORS AND FOUR CONSULTANTS. ONE APPARENT ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN ONE AREA (FAILURE TO DEMONSTRATE CAPABILITY TO NOTIFY OFFSITE AGENCIES WITH 15 MINUTES AFTER DECLARATION OF AN EMERGENCY.

INSPECTION FROM APRIL 21 - JUNE 15. (84-05): ROUTINE, UNANNOUNCED INSPECTION BY ACTING RESIDENT INSPECTORS OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS, OPERATIONAL SAFETY AND SURVEILLANCE. THE INSPECTION INVOLVED 81 INSPECTOR HRS ONSITE BY THREE NRC INSPECTORS. NO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED.

INSPECTION ON JUNE 4-7 AND 11, (84-06): ROUTINE, ANNOUNCED INSPECTION OF (1) THE IMPLEMENTATION OF THE RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM, (2) THE CONFIRMATORY MEASUREMENTS PROGRAM INCLUDING QUALITY CONTROL OF ANALYTICAL MEASUREMENTS AND THE LICENSEE AND ANALYZED USING THE RIII MOBILE LABORATORY AND (3) FOLLOWUP OF THE LICENSEE'S RESAMPLING PROGRAM RELATED TO THE LEAK OF CONTAMINATED WATER INTO THE RADWASTE BUILDING. THE INSPECTION INVOLVED 56.5 INSPECTOR HOURS ONSITE BY TWO NRC INSPECTORS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

Report Period JUL 1984

R E P O R T S F R O M L I C E N S E E

* BIG ROCK POINT 1 *

```
=====
```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-03	05/30/84	06/29/84	UNMONITORED LIQUID RELEASE TO SOIL.
84-04	05/30/84	06/29/84	UPSCALE/DOWNSCALE SCRAM.
84-05	05/31/84	06/29/84	UNPLANNED RPS TRIP DUE TO MSIV CLOSURE.
84-06	06/01/84	06/29/84	SPURIOUS RPS TRIP.
84-07	06/11/84	06/29/84	RADIO-INDUCED RPS TRIP.
84-08	06/27/84	07/27/84	UPSCALEE/DOWNSCALE RPS ACTUATION OF 6/27/84.

```
=====
```

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-259 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: TED THOM (205) 729-0834

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1065

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>87,673.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,629.0</u>	<u>54,434.8</u>
14. Rx Reserve Shtown Hrs	<u>.0</u>	<u>465.5</u>	<u>6,250.1</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,518.2</u>	<u>53,235.8</u>
16. Unit Reserve Shtown Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,383,044</u>	<u>13,696,039</u>	<u>152,253,718</u>
18. Gross Elec Ener (MWH)	<u>768,640</u>	<u>4,556,830</u>	<u>50,202,450</u>
19. Net Elec Ener (MWH)	<u>748,596</u>	<u>4,397,358</u>	<u>48,722,685</u>
20. Unit Service Factor	<u>100.0</u>	<u>88.4</u>	<u>60.7</u>
21. Unit Avail Factor	<u>100.0</u>	<u>88.4</u>	<u>60.7</u>
22. Unit Cap Factor (MDC Net)	<u>94.5</u>	<u>80.8</u>	<u>52.2</u>
23. Unit Cap Factor (DER Net)	<u>94.5</u>	<u>80.8</u>	<u>52.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>11.0</u>	<u>22.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>561.0</u>	<u>15,785.7</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* GROWNS FERRY 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
BROWNS FERRY 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* BROWNS FERRY 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
288	07/13/84	S	0.0	H	5				DERATED FOR CONTROL ROD SEQUENCE EXCHANGE.

* SUMMARY *

BROWNS FERRY 1 OPERATED WITH 1 REDUCTION DURING THE
REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BROWNS FERRY 1 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ALABAMA

COUNTY.....LIMESTONE

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI NW OF
 DECATUR, ALA

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...AUGUST 17, 1973
DATE ELEC ENER 1ST GENER...OCTOBER 15, 1973
DATE COMMERCIAL OPERATE...AUGUST 1, 1974

CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...TENNESSEE RIVER

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
 RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....TENNESSEE VALLEY AUTHORITY

CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II
 CHATTANOOGA, TENNESSEE 37401

CONTRACTOR
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. PAULK
LICENSING PROJ MANAGER.....R. CLARK
DOCKET NUMBER.....50-259

LICENSE & DATE ISSUANCE...DPR-33, DECEMBER 20, 1973

PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY
 SOUTH AND FORREST
 ATHENS, ALABAMA 35611

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 23-27 (84-25): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 11 INSPECTOR-HOURS ON SITE IN THE AREAS OF RADIOACTIVE LIQUID AND GASEOUS EFFLUENTS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 13 (84-29): THIS SPECIAL, ANNOUNCED INSPECTION INVOLVED 1 INSPECTOR-HOURS ON SITE IN THE AREA OF SECURITY. OF THE ONE AREA INSPECTED, ONE APPARENT VIOLATION WAS FOUND (FAILURE TO CONTROL ACCESS TO THE FUEL HANDLING AREA).

ENFORCEMENT SUMMARY

10 CFR 71.5(A) REQUIRES THAT EACH LICENSEE WHO DELIVERS LICENSED MATERIAL TO A CARRIER FOR TRANSPORT SHALL COMPLY WITH THE APPLICABLE REQUIREMENTS OF THE REGULATIONS APPROPRIATE TO THE MODE OF TRANSPORT OF DOT IN 49 CFR PARTS 170 THROUGH 189. 49 CFR 173.425(B)(B) REQUIRES THAT PACKAGED RADIOACTIVE MATERIAL SHIPMENTS MUST BE BRACED SO AS TO PREVENT SHIFTING OF LADING UNDER CONDITIONS NORMALLY INCIDENT TO TRANSPORTATION. CONTRARY TO THE ABOVE, A BOX OF LOW SPECIFIC ACTIVITY RADIOACTIVE WASTE SHIPMENT UNDER CONTROL NUMBER BSMP 84-20 ON APRIL 4, 1984, WAS DISCOVERED TO HAVE SHIFTED DURING TRANSPORT UPON ARRIVING AT THE DESTINATION ON APRIL 10, 1984.
(8419 4)

TECHNICAL SPECIFICATION 4.9.A.1.D REQUIRES THAT EACH DIESEL GENERATOR BE GIVEN AN ANNUAL INSPECTION IN ACCORDANCE WITH

ENFORCEMENT SUMMARY

INSTRUCTIONS BASED ON THE MANUFACTURER'S RECOMMENDATIONS. SURVEILLANCE INSTRUCTION 4.9.A.1.D, DIESEL GENERATOR ANNUAL INSPECTION, DATED JANUARY 25, 1984, STATES THAT THE MAINTENANCE PERFORMED BY MECHANICAL MAINTENANCE IS OUTLINED IN MECHANICAL MAINTENANCE INSTRUCTION (MMI-6) AND A REFERENCE TO THE MANUFACTURER'S RECOMMENDATION OF SCHEDULED MAINTENANCE IS GIVEN IN ELECTRO-MOTIVE DIVISION MAINTENANCE INSTRUCTION M.I. 1742 FOR 999 SYSTEM GENERATING PLANTS. CONTRARY TO THE ABOVE, THIS REQUIREMENT WAS NOT MET IN THAT MMI-6 DOES NOT ADDRESS THE ENGINE MAINTENANCE AS RECOMMENDED BY THE MANUFACTURER'S MAINTENANCE INSTRUCTION M.I. 1742. EXAMPLES OF THIS ARE AS FOLLOWS: (A) ANNUAL CHECK OF LASH ADJUSTER SETTINGS; (B) 500 HOUR CRANKSHAFT CHECK; (C) 500 HOUR CONNECTING ROD CHECK; AND (D) 500 HOUR PISTON TO HEAD CLEARANCE CHECK. UNITS ONE AND TWO DIESELS HAVE RUN TIMES OF GREATER THAN 500 HOURS.
(8423 4)

10 CFR 50, APPENDIX B, CRITERION XVI REQUIRES THAT MEASURES SHALL BE ESTABLISHED TO ASSURE THAT CONDITIONS ADVERSE TO QUALITY SUCH AS FAILURES, MALFUNCTIONS, DEFICIENCIES, DEVIATIONS, DEFECTIVE MATERIAL AND EQUIPMENT AND NONCONFORMANCES ARE PROMPTLY IDENTIFIED AND CORRECTED. THE IDENTIFICATION, THE CAUSE, AND THE CORRECTIVE ACTION TAKEN SHALL BE DOCUMENTED AND REPORTED TO APPROPRIATE LEVELS OF MANAGEMENT. CONTRARY TO THE ABOVE, THE REQUIREMENT WAS NOT MET IN THAT REVISION ONE TO NONCONFORMANCE REPORT BFNMEB8403 DATED MAY 12, 1984, WAS NOT INCORPORATED INTO EMERGENCY OPERATING INSTRUCTION 36, LOSS OF COOLANT ACCIDENT INSIDE DRYWELL, (EOI-36) UNTIL JUNE 15, 1984. REVISION ONE EXPANDED ON THE ORIGINAL REPORT DATED MAY 11, 1984 (INCORPORATED IN EOI-36 ON MAY 12, 1984), AND IDENTIFIED AN ADDITIONAL DESIGN ERROR FOR UNIT THREE. FURTHER, A RECOMMENDED STEP FOR THE TEMPORARY SOLUTION IN THE EVENT OF THE LOSS OF THE SHUTDOWN BOARD ROOM REDUNDANT COOLING SYSTEM WAS TO OPEN THE OUTSIDE DOOR TO THE FAN TOWER WHEN ESTABLISHING AN EXHAUST PATH FOR AIR FLOW FOR THE APPROPRIATE UNIT. AS STATED IN THE SAFETY EVALUATION, THE ANALYSIS WAS CONTINGENT UPON OPENING AN ACCESS DOOR UPSTREAM OF THE FAN AND THE CONCURRENT OPENING OF THE VENT TOWER DOORS. (UNIT ONE AND UNIT TWO WERE OPERATING DURING THIS PERIOD). THIS OVERSIGHT WAS BROUGHT TO THE ATTENTION OF THE LICENSEE AFTER THE INSPECTOR'S REVIEW ON JUNE 14, 1984, OF LER 84-22 DATED JUNE 8, 1984, WHICH STATED THAT UNITS ONE AND TWO WERE THE ONLY UNITS AFFECTED BY THIS EVENT.
(8423 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INTERGRANULAR STRESS CORROSION CRACKING (IGSCC) PROBLEMS IN RHR, CORE SPRAY AND OTHER PIPING HAS NECESSITATED WELD OVERLAY REPAIRS.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

THE OFFICE OF POWER AND OFFICE OF ENGINEERING, DESIGN AND CONSTRUCTION WERE COMBINED TO FORM THE OFFICE OF POWER AND ENGINEERING, H. G. PARRIS, MANAGER. A SEPARATE OFFICE OF NUCLEAR POWER WAS ESTABLISHED WITH J. P. DARLING, MANAGER, J. P. COFFEY WAS ASSIGNED AS SITE DIRECTOR, BROWNS FERRY REPORTING TO J. P. DARLING.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: MAY 26 - JUNE 25, 1984 +

INSPECTION REPORT NO: 50-259/84-23 +

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* BROWNS FERRY 1 *

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-025	06/15/84	07/03/84	ISOLATION BETWEEN TURBINE AND REACTOR BLDG HEAT SYS LINES INADEQUATE, FAILURE TO FOLLOW DESIGN CRITERIA MAIN PROBLEM.
84-026	06/20/84	07/17/84	HIGH DRYWELL LEAKAGE AND SUBSEQUENT MANUAL SCRAM, RECIRCULATION PUMP UPPER SEAL FAILED.
84-028	07/10/84	08/08/84	AUTOMATIC DISCHARGE TRANSFER LOGIC FAILED TO WORK, THIS EVENT WAS RANDOM.

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-260 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: TED THOM (205) 729-0834

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1065

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): 640

11. Reasons for Restrictions, If Any:
CABLE TRAY MODIFICATIONS

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>82,584.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,810.8</u>	<u>54,774.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>300.1</u>	<u>14,200.4</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,760.6</u>	<u>53,253.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,508,141</u>	<u>10,834,215</u>	<u>150,979,260</u>
18. Gross Elec Ener (MWH)	<u>463,030</u>	<u>3,465,920</u>	<u>50,063,208</u>
19. Net Elec Ener (MWH)	<u>447,449</u>	<u>3,366,978</u>	<u>48,625,581</u>
20. Unit Service Factor	<u>100.0</u>	<u>93.1</u>	<u>64.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>93.1</u>	<u>64.5</u>
22. Unit Cap Factor (MDC Net)	<u>56.5</u>	<u>61.9</u>	<u>55.3</u>
23. Unit Cap Factor (DER Net)	<u>56.5</u>	<u>61.9</u>	<u>55.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>5.0</u>	<u>23.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>249.4</u>	<u>16,304.4</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
SEPTEMBER 1984 - REFUELING & MAINTENANCE.

27. If Currently Shutdown Estimated Startup Date: N/A

* BROWNS FERRY 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BROWNS FERRY 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * BROWNS FERRY 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
296	07/01/84	S	0.0	H	5			DERATED TO EXTEND FUEL CYCLE AND ADMINISTRATIVE HOLD BECAUSE ALL ADS RELIEF VALVE CABLES ARE ROUTED THROUGH THE SAME CABLE TRAY.
297	07/13/84	S	0.0	H	5			DERATED TO EXTEND FUEL CYCLE.
298	07/16/84	S	0.0	H	5			FUEL CYCLE & CABLE TRAY.
299	07/16/84	S	0.0	H	5			FUEL CYCLE EXTENSION.
300	07/17/84	S	0.0	H	5			FUEL CYCLE & CABLE TRAY.
301	07/17/84	S	0.0	H	5			FUEL CYCLE EXTENSION.
302	07/18/84	S	0.0	H	5			FUEL CYCLE & CABLE TRAY.
303	07/18/84	S	0.0	H	5			FUEL CYCLE EXTENSION.
304	07/21/84	S	0.0	H	5			FUEL CYCLE & CABLE TRAY.

 * SUMMARY *

 BROWNS FERRY 2 OPERATED WITH NUMEROUS REDUCTIONS DURING THE REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BROWNS FERRY 2 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ALABAMA
COUNTY.....LIMESTONE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI NW OF
DECATUR, ALA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JULY 20, 1974
DATE ELEC ENER 1ST GENER...AUGUST 28, 1974
DATE COMMERCIAL OPERATE...MARCH 1, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...TENNESSEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....TENNESSEE VALLEY AUTHORITY
CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II
CHATTANOOGA, TENNESSEE 37401
CONTRACTOR
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. PAULK
LICENSING PROJ MANAGER.....R. CLARK
DOCKET NUMBER.....50-260
LICENSE & DATE ISSUANCE...DPR-52, AUGUST 2, 1974
PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY
SOUTH AND FORREST
ATHENS, ALABAMA 35611

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 23-27 (84-25): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 11 INSPECTOR-HOURS ON SITE IN THE AREAS OF RADIOACTIVE LIQUID AND GASEOUS EFFLUENTS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 13 (84-29): THIS SPECIAL, ANNOUNCED INSPECTION INVOLVED 1 INSPECTOR-HOURS ON SITE IN THE AREA OF SECURITY. OF THE ONE AREA INSPECTED, ONE APPARENT VIOLATION WAS FOUND (FAILURE TO CONTROL ACCESS TO THE FUEL HANDLING AREA).

ENFORCEMENT SUMMARY

10 CFR 71.5(A) REQUIRES THAT EACH LICENSEE WHO DELIVERS LICENSED MATERIAL TO A CARRIER FOR TRANSPORT SHALL COMPLY WITH THE APPLICABLE REQUIREMENTS OF THE REGULATIONS APPROPRIATE TO THE MODE OF TRANSPORT OF DOT IN 49 CFR PARTS 170 THROUGH 189. 49 CFR 173.425(B)(B) REQUIRES THAT PACKAGED RADIOACTIVE MATERIAL SHIPMENTS MUST BE BRACED SO AS TO PREVENT SHIFTING OF LADING UNDER CONDITIONS NORMALLY INCIDENT TO TRANSPORTATION. CONTRARY TO THE ABOVE, A BOX OF LOW SPECIFIC ACTIVITY RADIOACTIVE WASTE SHIPMENT UNDER CONTROL NUMBER BSMP 84-20 ON APRIL 4, 1984, WAS DISCOVERED TO HAVE SHIFTED DURING TRANSPORT UPON ARRIVING AT THE DESTINATION ON APRIL 10, 1984.
(8419 4)

TECHNICAL SPECIFICATION 4.9.A.1.D REQUIRES THAT EACH DIESEL GENERATOR BE GIVEN AN ANNUAL INSPECTION IN ACCORDANCE WITH

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* BROWNS FERRY 2 *

ENFORCEMENT SUMMARY

INSTRUCTIONS BASED ON THE MANUFACTURER'S RECOMMENDATIONS. SURVEILLANCE INSTRUCTION 4.9.A.1.D, DIESEL GENERATOR ANNUAL INSPECTION, DATED JANUARY 25, 1984, STATES THAT THE MAINTENANCE PERFORMED BY MECHANICAL MAINTENANCE IS OUTLINED IN MECHANICAL MAINTENANCE INSTRUCTION (MMI-6) AND A REFERENCE TO THE MANUFACTURER'S RECOMMENDATION OF SCHEDULED MAINTENANCE IS GIVEN IN ELECTRO-MOTIVE DIVISION MAINTENANCE INSTRUCTION M.I. 1742 FOR 999 SYSTEM GENERATING PLANTS. CONTRARY TO THE ABOVE, THIS REQUIREMENT WAS NOT MET IN THAT MMI-6 DOES NOT ADDRESS THE ENGINE MAINTENANCE AS RECOMMENDED BY THE MANUFACTURER'S MAINTENANCE INSTRUCTION M.I. 1742. EXAMPLES OF THIS ARE AS FOLLOWS: (A) ANNUAL CHECK OF LASH ADJUSTER SETTINGS; (B) 500 HOUR CRANKSHAFT CHECK; (C) 500 HOUR CONNECTING ROD CHECK; AND (D) 500 HOUR PISTON TO HEAD CLEARANCE CHECK. UNITS ONE AND TWO DIESELS HAVE RUN TIMES OF GREATER THAN 500 HOURS.
(8423 4)

10 CFR 50, APPENDIX B, CRITERION XVI REQUIRES THAT MEASURES SHALL BE ESTABLISHED TO ASSURE THAT CONDITIONS ADVERSE TO QUALITY SUCH AS FAILURES, MALFUNCTIONS, DEFICIENCIES, DEVIATIONS, DEFECTIVE MATERIAL AND EQUIPMENT AND NONCONFORMANCES ARE PROMPTLY IDENTIFIED AND CORRECTED. THE IDENTIFICATION, THE CAUSE, AND THE CORRECTIVE ACTION TAKEN SHALL BE DOCUMENTED AND REPORTED TO APPROPRIATE LEVELS OF MANAGEMENT. CONTRARY TO THE ABOVE, THE REQUIREMENT WAS NOT MET IN THAT REVISION ONE TO NONCONFORMANCE REPORT BFNMEB8403 DATED MAY 12, 1984, WAS NOT INCORPORATED INTO EMERGENCY OPERATING INSTRUCTION 36, LOSS OF COOLANT ACCIDENT INSIDE DRYWELL, (EOI-36) UNTIL JUNE 15, 1984. REVISION ONE EXPANDED ON THE ORIGINAL REPORT DATED MAY 11, 1984 (INCORPORATED IN EOI-36 ON MAY 12, 1984), AND IDENTIFIED AN ADDITIONAL DESIGN ERROR FOR UNIT THREE. FURTHER, A RECOMMENDED STEP FOR THE TEMPORARY SOLUTION IN THE EVENT OF THE LOSS OF THE SHUTDOWN BOARD ROOM REDUNDANT COOLING SYSTEM WAS TO OPEN THE OUTSIDE DOOR TO THE FAN TOWER WHEN ESTABLISHING AN EXHAUST PATH FOR AIR FLOW FOR THE APPROPRIATE UNIT. AS STATED IN THE SAFETY EVALUATION, THE ANALYSIS WAS CONTINGENT UPON OPENING AN ACCESS DOOR UPSTREAM OF THE FAN AND THE CONCURRENT OPENING OF THE VENT TOWER DOORS. (UNIT ONE AND UNIT TWO WERE OPERATING DURING THIS PERIOD). THIS OVERSIGHT WAS BROUGHT TO THE ATTENTION OF THE LICENSEE AFTER THE INSPECTOR'S REVIEW ON JUNE 14, 1984, OF LER 84-22 DATED JUNE 8, 1984, WHICH STATED THAT UNITS ONE AND TWO WERE THE ONLY UNITS AFFECTED BY THIS EVENT.
(8423 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

THE OFFICE OF POWER AND OFFICE OF ENGINEERING, DESIGN AND CONSTRUCTION WERE COMBINED TO FORM THE OFFICE OF POWER AND ENGINEERING, H. G. PARRIS, MANAGER. A SEPARATE OFFICE OF NUCLEAR POWER WAS ESTABLISHED WITH J. P. DARLING, MANAGER, J. P. COFFEY WAS ASSIGNED AS SITE DIRECTOR, BROWNS FERRY REPORTING TO J. P. DARLING.

PLANT STATUS:

OPERATING AT REDUCED OUTPUT (60%) TO STRETCH CYCLE THRU SEPTEMBER.

LAST IE SITE INSPECTION DATE: MAY 26 - JUNE 25, 1984 +

INSPECTION REPORT NO: 50-260/84-23 +

Report Period JUL 1984

R E P O R T S F R O M L I C E N S E E

XX
X BROWN FERRY 2 X
XX

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NONE.

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-296 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: TED THOM (205) 729-0834

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1065

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>65,039.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>43,088.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,878.1</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>42,194.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>126,285,520</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>41,597,620</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>40,376,156</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>64.9</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>64.9</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>58.3</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>58.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>10.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>5,091.4</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 08/15/84

* BROWNS FERRY 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
BROWNS FERRY 3



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* BROWNS FERRY 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
140	09/07/83	S	744.0	C	4				END-OF-CYCLE 5 REFUELING/MAINTENANCE OUTAGE CONTINUES (CONTROLLED SHUTDOWN 9/7/83).

* SUMMARY *

BROWNS FERRY 3 REMAINS SHUTDOWN IN A CONTINUING REFUELING/MAINTENANCE OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

* BROWNS FERRY 3 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ALABAMA

COUNTY.....LIMESTONE

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI NW OF
 DECATUR, ALA

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...AUGUST 8, 1976

DATE ELEC ENER 1ST GENER...SEPTEMBER 12, 1976

DATE COMMERCIAL OPERATE...MARCH 1, 1977

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER...TENNESSEE RIVER

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
 RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....TENNESSEE VALLEY AUTHORITY

CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II
 CHATTANOOGA, TENNESSEE 37401

CONTRACTOR
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....J. PAULK

LICENSING PROJ MANAGER.....R. CLARK
DOCKET NUMBER.....50-296

LICENSE & DATE ISSUANCE...DPR-68, AUGUST 18, 1976

PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY
 SOUTH AND FORREST
 ATHENS, ALABAMA 35611

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 23-27 (84-25): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 10 INSPECTOR-HOURS ON SITE IN THE AREAS OF RADIOACTIVE LIQUID AND GASEOUS EFFLUENTS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 13 (84-29): THIS SPECIAL, ANNOUNCED INSPECTION INVOLVED 1 INSPECTOR-HOURS ON SITE IN THE AREA OF SECURITY. OF THE ONE AREA INSPECTED, ONE APPARENT VIOLATION WAS FOUND (FAILURE TO CONTROL ACCESS TO THE FUEL HANDLING AREA).

ENFORCEMENT SUMMARY

10 CFR 71.5(A) REQUIRES THAT EACH LICENSEE WHO DELIVERS LICENSED MATERIAL TO A CARRIER FOR TRANSPORT SHALL COMPLY WITH THE APPLICABLE REQUIREMENTS OF THE REGULATIONS APPROPRIATE TO THE MODE OF TRANSPORT OF DOT IN 49 CFR PARTS 170 THROUGH 189. 49 CFR 173.425(B)(B) REQUIRES THAT PACKAGED RADIOACTIVE MATERIAL SHIPMENTS MUST BE BRACED SO AS TO PREVENT SHIFTING OF LADING UNDER CONDITIONS NORMALLY INCIDENT TO TRANSPORTATION. CONTRARY TO THE ABOVE, A BOX OF LOW SPECIFIC ACTIVITY RADIOACTIVE WASTE SHIPMENT UNDER CONTROL NUMBER BSMP 84-20 ON APRIL 4, 1984, WAS DISCOVERED TO HAVE SHIFTED DURING TRANSPORT UPON ARRIVING AT THE DESTINATION ON APRIL 10, 1984.
(8419 4)

TECHNICAL SPECIFICATION 4.9.A.1.D REQUIRES THAT EACH DIESEL GENERATOR BE GIVEN AN ANNUAL INSPECTION IN ACCORDANCE WITH

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* BROWNS FERRY 3 *

ENFORCEMENT SUMMARY

INSTRUCTIONS BASED ON THE MANUFACTURER'S RECOMMENDATIONS. SURVEILLANCE INSTRUCTION 4.9.A.1.D, DIESEL GENERATOR ANNUAL INSPECTION, DATED JANUARY 25, 1984, STATES THAT THE MAINTENANCE PERFORMED BY MECHANICAL MAINTENANCE IS OUTLINED IN MECHANICAL MAINTENANCE INSTRUCTION (MMI-6) AND A REFERENCE TO THE MANUFACTURER'S RECOMMENDATION OF SCHEDULED MAINTENANCE IS GIVEN IN ELECTRO-MOTIVE DIVISION MAINTENANCE INSTRUCTION M.I. 1742 FOR 999 SYSTEM GENERATING PLANTS. CONTRARY TO THE ABOVE, THIS REQUIREMENT WAS NOT MET IN THAT MMI-6 DOES NOT ADDRESS THE ENGINE MAINTENANCE AS RECOMMENDED BY THE MANUFACTURER'S MAINTENANCE INSTRUCTION M.I. 1742. EXAMPLES OF THIS ARE AS FOLLOWS: (A) ANNUAL CHECK OF LASH ADJUSTER SETTINGS; (B) 500 HOUR CRANKSHAFT CHECK; (C) 500 HOUR CONNECTING ROD CHECK; AND (D) 500 HOUR PISTON TO HEAD CLEARANCE CHECK. UNITS ONE AND TWO DIESELS HAVE RUN TIMES OF GREATER THAN 500 HOURS.
(8423 4)

10 CFR 50, APPENDIX B, CRITERION XVI REQUIRES THAT MEASURES SHALL BE ESTABLISHED TO ASSURE THAT CONDITIONS ADVERSE TO QUALITY SUCH AS FAILURES, MALFUNCTIONS, DEFICIENCIES, DEVIATIONS, DEFECTIVE MATERIAL AND EQUIPMENT AND NONCONFORMANCES ARE PROMPTLY IDENTIFIED AND CORRECTED. THE IDENTIFICATION, THE CAUSE, AND THE CORRECTIVE ACTION TAKEN SHALL BE DOCUMENTED AND REPORTED TO APPROPRIATE LEVELS OF MANAGEMENT. CONTRARY TO THE ABOVE, THE REQUIREMENT WAS NOT MET IN THAT REVISION ONE TO NONCONFORMANCE REPORT BFHMEB8403 DATED MAY 12, 1984, WAS NOT INCORPORATED INTO EMERGENCY OPERATING INSTRUCTION 36, LOSS OF COOLANT ACCIDENT INSIDE DRYWELL, (EOI-36) UNTIL JUNE 15, 1984. REVISION ONE EXPANDED ON THE ORIGINAL REPORT DATED MAY 11, 1984 (INCORPORATED IN EOI-36 ON MAY 12, 1984), AND IDENTIFIED AN ADDITIONAL DESIGN ERROR FOR UNIT THREE. FURTHER, A RECOMMENDED STEP FOR THE TEMPORARY SOLUTION IN THE EVENT OF THE LOSS OF THE SHUTDOWN BOARD ROOM REDUNDANT COOLING SYSTEM WAS TO OPEN THE OUTSIDE DOOR TO THE FAN TOWER WHEN ESTABLISHING AN EXHAUST PATH FOR AIR FLOW FOR THE APPROPRIATE UNIT. AS STATED IN THE SAFETY EVALUATION, THE ANALYSIS WAS CONTINGENT UPON OPENING AN ACCESS DOOR UPSTREAM OF THE FAN AND THE CONCURRENT OPENING OF THE VENT TOWER DOORS. (UNIT ONE AND UNIT TWO WERE OPERATING DURING THIS PERIOD).
(8423 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

THE OFFICE OF POWER AND OFFICE OF ENGINEERING, DESIGN AND CONSTRUCTION WERE COMBINED TO FORM THE OFFICE OF POWER AND ENGINEERING, H. G. PARRIS, MANAGER. A SEPARATE OFFICE OF NUCLEAR POWER WAS ESTABLISHED WITH J. P. DARLING, MANAGER, J. P. COFFEY WAS ASSIGNED AS SITE DIRECTOR, BROWNS FERRY REPORTING TO J. P. DARLING.

PLANT STATUS:

SHUTDOWN 9/6/83 TO PERFORM IGSCC INSPECTION.

LAST IE SITE INSPECTION DATE: MAY 26 - JUNE 25, 1984 +

INSPECTION REPORT NO: 50-296/84-23 +

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
X BROWNS FERRY 3 X
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

REPORTS FROM LICENSEE

Report Period JUL 1984

=====

NUMBER DATE OF DATE OF SUBJECT
EVENT REPORT

NONE.

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-325 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: FRANCES HARRISON (919) 457-9521

4. Licensed Thermal Power (MWt): 2436

5. Nameplate Rating (Gross MWe): 963 X 0.9 = 867

6. Design Electrical Rating (Net MWe): 821

7. Maximum Dependable Capacity (Gross MWe): 815

8. Maximum Dependable Capacity (Net MWe): 790

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>64,632.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,529.3</u>	<u>40,927.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,647.1</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,413.7</u>	<u>38,502.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,770,758</u>	<u>10,315,675</u>	<u>78,742,961</u>
18. Gross Elec Ener (MWH)	<u>583,100</u>	<u>3,436,066</u>	<u>25,983,114</u>
19. Net Elec Ener (MWH)	<u>566,740</u>	<u>3,336,827</u>	<u>24,950,658</u>
20. Unit Service Factor	<u>100.0</u>	<u>86.4</u>	<u>59.6</u>
21. Unit Avail Factor	<u>100.0</u>	<u>86.4</u>	<u>59.6</u>
22. Unit Cap Factor (MDC Net)	<u>96.4</u>	<u>82.6</u>	<u>48.9</u>
23. Unit Cap Factor (DER Net)	<u>92.8</u>	<u>79.5</u>	<u>47.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>10.6</u>	<u>19.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>522.1</u>	<u>9,441.3</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
LOCAL LEAK RATE TESTING- 10/31/84, SIX WEEKS

27. If Currently Shutdown Estimated Startup Date: N/A

* BRUNSWICK 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
BRUNSWICK 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* BRUNSWICK 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84055	07/20/84	S	0.0	B	5				REDUCED POWER FOR ROD IMPROVEMENT AND TURBINE VALVE TESTING.

* SUMMARY *

BRUNSWICK 1 OPERATED ROUTINELY WITH 1 REDUCTION DURING THE REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BRUNSWICK 1 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NORTH CAROLINA

COUNTY.....BRUNSWICK

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...3 MI N OF
SOUTHPORT, NC

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...OCTOBER 8, 1976
DATE ELEC ENER 1ST GENER...DECEMBER 4, 1976
DATE COMMERCIAL OPERATE...MARCH 18, 1977
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CAPE FEAR RIVER

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CAROLINA POWER & LIGHT

CORPORATE ADDRESS.....P. O. BOX 1551
RALEIGH, NORTH CAROLINA 27602

CONTRACTOR
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....BROWN & ROOT

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....D. MYERS

LICENSING PROJ MANAGER.....M. GROTENHUIS
DOCKET NUMBER.....50-325

LICENSE & DATE ISSUANCE...DPR-71, NOVEMBER 12, 1976

PUBLIC DOCUMENT ROOM.....SOUTHPORT-BRUNSWICK COUNTY LIBRARY
108 W. MOORE STREET
SOUTHPORT, NORTH CAROLINA 28461

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 18-20 (84-19): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 11 INSPECTOR-HOURS ON SITE IN THE AREAS OF REVIEW OF SURVEILLANCE TESTING OF REACTOR INSTRUMENTATION ISOLATION VALVES, REVIEW OF SURVEILLANCE TESTING OF SNUBBERS, AND FOLLOWUP OF A PREVIOUSLY IDENTIFIED INSPECTOR FOLLOWUP ITEM. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 30 - AUGUST 3 (84-21): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 15 INSPECTOR-HOURS ON SITE (2 HOURS ON BACK-SHIFT) INSPECTING: IMPLEMENTATION OF APPROVED SECURITY PLAN RELATIVE TO PLAN CHANGES AND IMPLEMENTING PROCEDURES; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AREA; PHYSICAL BARRIERS - VITAL AREA; SECURITY SYSTEM POWER KSUPPLY; ACCESS CONTROLS - PERSONNEL, PACKAGES, AND VEHICLES; DETECTION AIDS - PROTECTED AREA; AND DETECTION AIDS - VITAL AREAS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH REGULATORY REQUIREMENTS IN THE 11 AREAS INSPECTED.

INSPECTION JULY 18-20 (84-22): THIS SPECIAL, ANNOUNCED INSPECTION INVOLVED 7.5 INSPECTOR-HOURS ON SITE IN THE AREAS OF INSERVICE INSPECTION, OBSERVATION OF WORK ACTIVITIES, INSERVICE INSPECTION, REVIEW OF DATA, AND INDEPENDENT INSPECTION EFFORT. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NGNE

1. Docket: 50-324 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: FRANCES HARRISON (919) 457-9521

4. Licensed Thermal Power (MWt): 2436

5. Nameplate Rating (Gross MWe): 963 X 0.9 = 867

6. Design Electrical Rating (Net MWe): 821

7. Maximum Dependable Capacity (Gross MWe): 815

8. Maximum Dependable Capacity (Net MWe): 790

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>76,656.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>1,604.3</u>	<u>46,331.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>1,566.9</u>	<u>43,352.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>3,355,120</u>	<u>81,931,834</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>1,110,430</u>	<u>27,220,128</u>
19. Net Elec Ener (MWH)	<u>-4,613</u>	<u>1,054,660</u>	<u>26,082,278</u>
20. Unit Service Factor	<u>.0</u>	<u>30.7</u>	<u>56.6</u>
21. Unit Avail Factor	<u>.0</u>	<u>30.7</u>	<u>56.6</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>26.1</u>	<u>43.1</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>25.1</u>	<u>41.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>2.2</u>	<u>17.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>35.5</u>	<u>9,638.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 10/10/84

 * BRUNSWICK 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BRUNSWICK 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* BRUNSWICK 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-020	03/12/84	S	744.0	C	4		RC	FUELXX	REFUELING/MAINTENANCE OUTAGE CONTINUES.

* SUMMARY *

BRUNSWICK 2 REMAINS SHUTDOWN IN A CONTINUING REFUELING/MAINTENANCE OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BRUNSWICK 2 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NORTH CAROLINA
COUNTY.....BRUNSWICK
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...3 MI N OF
SOUTHPORT, NC
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MARCH 20, 1975
DATE ELEC ENER 1ST GENER...APRIL 29, 1975
DATE COMMERCIAL OPERATE...NOVEMBER 3, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CAPE FEAR RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CAROLINA POWER & LIGHT
CORPORATE ADDRESS.....411 FAYETTEVILLE STREET
RALEIGH, NORTH CAROLINA 27602
CONTRACTOR
ARCHITECT/ENGINEER..... UNITED ENG. & CONSTRUCTORS
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BROWN & ROOT
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....D. MYERS
LICENSING PROJ MANAGER.....M. GROTENHUIS
DOCKET NUMBER.....50-324
LICENSE & DATE ISSUANCE...DPR-62, DECEMBER 27, 1974
PUBLIC DOCUMENT ROOM.....SOUTHPORT-BRUNSWICK COUNTY LIBRARY
108 W. MOORE STREET
SOUTHPORT, NORTH CAROLINA 28461

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 18-20 (84-19): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 11 INSPECTOR-HOURS ON SITE IN THE AREAS OF REVIEW OF SURVEILLANCE TESTING OF REACTOR INSTRUMENTATION ISOLATION VALVES, REVIEW OF SURVEILLANCE TESTING OF SNUBBERS, AND FOLLOWUP OF A PREVIOUSLY IDENTIFIED INSPECTOR FOLLOWUP ITEM. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 30 - AUGUST 3 (84-21): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 15 INSPECTOR-HOURS ON SITE (2 HOURS ON BACK-SHIFT) INSPECTING: IMPLEMENTATION OF APPROVED SECURITY PLAN RELATIVE TO PLAN CHANGES AND IMPLEMENTING PROCEDURES; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AREA; PHYSICAL BARRIERS - VITAL AREA; SECURITY SYSTEM POWER KSUPPLY; ACCESS CONTROLS - PERSONNEL, PACKAGES, AND VEHICLES; DETECTION AIDS - PROTECTED AREA; AND DETECTION AIDS - VITAL AREAS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH REGULATORY REQUIREMENTS IN THE 11 AREAS INSPECTED.

INSPECTION JULY 18-20 (84-22): THIS SPECIAL, ANNOUNCED INSPECTION INVOLVED 7.5 INSPECTOR-HOURS ON SITE IN THE AREAS OF INSERVICE INSPECTION, OBSERVATION OF WORK ACTIVITIES, INSERVICE INSPECTION, REVIEW OF DATA, AND INDEPENDENT INSPECTION EFFORT. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* BRUNSWICK 2 *

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

REFUEL AND MAINTENANCE OUTAGE.

LAST IE SITE INSPECTION DATE: JULY 9-13, 1984 +

INSPECTION REPORT NO: 50-324/84-18 +

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NONE.			
=====			

1. Docket: 50-317 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: EVELYN BEWLEY (301) 787-5365

4. Licensed Thermal Power (Mwt): 2700

5. Nameplate Rating (Gross MWe): 1020 X 0.9 = 918

6. Design Electrical Rating (Net MWe): 845

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 825

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>80,940.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,348.9</u>	<u>64,315.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,887.9</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,317.1</u>	<u>63,063.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,989,208</u>	<u>11,471,414</u>	<u>155,613,709</u>
18. Gross Elec Ener (MWH)	<u>658,726</u>	<u>3,882,596</u>	<u>51,310,081</u>
19. Net Elec Ener (MWH)	<u>631,430</u>	<u>3,715,079</u>	<u>48,950,045</u>
20. Unit Service Factor	<u>100.0</u>	<u>84.5</u>	<u>77.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>84.5</u>	<u>77.9</u>
22. Unit Cap Factor (MDC Net)	<u>102.9</u>	<u>88.1</u>	<u>74.2*</u>
23. Unit Cap Factor (DER Net)	<u>100.4</u>	<u>86.0</u>	<u>71.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>15.5</u>	<u>8.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>793.9</u>	<u>5,456.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * CALVERT CLIFFS 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 CALVERT CLIFFS 1



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* CALVERT CLIFFS 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

 * SUMMARY *

 CALVERT CLIFFS 1 OPERATED AT FULL POWER DURING THE REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* CALVERT CLIFFS 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MARYLAND
COUNTY.....CALVERT
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI S OF
ANNAPOLIS, MD
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 7, 1974
DATE ELEC ENER 1ST GENER...JANUARY 3, 1975
DATE COMMERCIAL OPERATE...MAY 8, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CHESAPEAKE BAY
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....BALTIMORE GAS & ELEC
CORPORATE ADDRESS.....P.O. BOX 1475
BALTIMORE, MARYLAND 21203
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. FOLEY
LICENSING PROJ MANAGER....D. JAFFE
DOCKET NUMBER.....50-317
LICENSE & DATE ISSUANCE...DPR-53, JULY 31, 1974
PUBLIC DOCUMENT ROOM.....CALVERT COUNTY LIBRARY
FOURTH STREET
PRINCE FREDERICK, MARYLAND 20678

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* CALVERT CLIFFS 1 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-318 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: EVELYN BEWLEY (310) 787-5365

4. Licensed Thermal Power (Mwt): 2700

5. Nameplate Rating (Gross MWe): 1012 x 0.9 = 911

6. Design Electrical Rating (Net MWe): 845

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 825

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>64,295.0</u>
13. Hours Reactor Critical	<u>535.0</u>	<u>3,228.5</u>	<u>53,156.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>958.1</u>
15. Hrs Generator On-Line	<u>513.8</u>	<u>3,125.8</u>	<u>52,241.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,168,382</u>	<u>8,049,489</u>	<u>129,891,182</u>
18. Gross Elec Ener (MWH)	<u>377,426</u>	<u>2,641,188</u>	<u>42,710,474</u>
19. Net Elec Ener (MWH)	<u>355,655</u>	<u>2,519,836</u>	<u>40,723,598</u>
20. Unit Service Factor	<u>69.1</u>	<u>61.2</u>	<u>81.3</u>
21. Unit Avail Factor	<u>69.1</u>	<u>61.2</u>	<u>81.3</u>
22. Unit Cap Factor (MDC Net)	<u>57.9</u>	<u>59.8</u>	<u>77.3*</u>
23. Unit Cap Factor (DER Net)	<u>56.6</u>	<u>58.3</u>	<u>75.0</u>
24. Unit Forced Outage Rate	<u>29.4</u>	<u>7.6</u>	<u>5.9</u>
25. Forced Outage Hours	<u>213.8</u>	<u>256.1</u>	<u>3,301.3</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* CALVERT CLIFFS 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
CALVERT CLIFFS 2



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * CALVERT CLIFFS 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-05	04/21/84	S	16.4	C	4		XX	FUELXX	COMPLETION OF REFUELING AND GENERAL INSPECTION.
84-06	07/09/84	F	213.8	A	1		CB	PUMPXX	REPAIRED CRACK IN 22B REACTOR COOLANT PUMP.

 * SUMMARY *

 CALVERT CLIFFS 2 RETURNED ONLINE FROM REFUELING ON JULY 1ST AND OPERATED WITH 1 OUTAGE FOR EQUIPMENT FAILURE DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

* CALVERT CLIFFS 2 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MARYLAND

COUNTY.....CALVERT

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI S OF
ANNAPOLIS, MD

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...NOVEMBER 30, 1976
DATE ELEC ENER 1ST GENER...DECEMBER 7, 1976
DATE COMMERCIAL OPERATE....APRIL 1, 1977

CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER....CHESAPEAKE BAY

ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....BALTIMORE GAS & ELEC

CORPORATE ADDRESS.....P.O. BOX 1475
BALTIMORE, MARYLAND 21203

CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. FOLEY
LICENSING PROJ MANAGER.....D. JAFFE
DOCKET NUMBER.....50-318

LICENSE & DATE ISSUANCE....DPR-69, NOVEMBER 30, 1976

PUBLIC DOCUMENT ROOM.....CALVERT COUNTY LIBRARY
FOURTH STREET
PRINCE FREDERICK, MARYLAND 20678

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (C O N T I N U E D)

* C A L V E R T C L I F F S 2 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * COOK 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
225	07/27/84	S	97.0	B	1		ZZ	ZZZZZZ	THE UNIT WAS REMOVED FROM SERVICE TO PERFORM REQUIRED ICE CONDENSER SURVEILLANCE AND TO REPAIR LEAKING PRESSURIZER SAFETY VALVES. THE UNIT REMAINED OUT OF SERVICE AT THE END OF THE MONTH.

 * SUMMARY *

 COOK 1 OPERATED WITH 1 OUTAGE FOR MAINTENANCE IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* COOK 1 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MICHIGAN
COUNTY.....BERRIEN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI S OF
BENTON HARBOR, MI
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JANUARY 18, 1975
DATE ELEC ENER 1ST GENER...FEBRUARY 10, 1975
DATE COMMERCIAL OPERATE....AUGUST 27, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....INDIANA & MICHIGAN ELECTRIC
CORPORATE ADDRESS.....1 RIVERSIDE PLAZA
COLUMBUS, OHIO 43216
CONTRACTOR
ARCHITECT/ENGINEER.....AMERICAN ELEC. POWER SERVICE CORP.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....AMERICAN ELEC. POWER SERVICE CORP.
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....E. SWANSON
LICENSING PROJ MANAGER.....D. WIGGINTON
DOCKET NUMBER.....50-315
LICENSE & DATE ISSUANCE...DPR-58, OCTOBER 25, 1974
PUBLIC DOCUMENT ROOM.....MAUDE PRESTON PALENSKE MEMORIAL LIBRARY
500 MARKET STREET
ST. JOSEPH, MICHIGAN 49085

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MAY 1 - JUNE 10, (84-10): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; LICENSEE EVENT REPORTS; LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; I.E. BULLETINS; OPERATOR LICENSING; AND MANAGEMENT MEETING - REGULATORY PERFORMANCE IMPROVEMENT PROGRAM (RPIP). THE INSPECTION INVOLVED 279 INSPECTOR HOURS BY THREE NRC INSPECTORS INCLUDING 68 INSPECTOR HOURS OFF-SHIFT. NO ITEMS OF NONCOMPLIANCE, DEFICIENCIES, OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

 * COOK 2 *


AVERAGE DAILY POWER LEVEL (MWe) PLOT
 COOK 2

1. Docket: 50-316 OPERATING STATUS
2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0
3. Utility Contact: W. T. GILLET (616) 465-5901
4. Licensed Thermal Power (MWt): 3411
5. Nameplate Rating (Gross MWe): 1333 X 0.85 = 1133
6. Design Electrical Rating (Net MWe): 1100
7. Maximum Dependable Capacity (Gross MWe): 1100
8. Maximum Dependable Capacity (Net MWe): 1060
9. If Changes Occur Above Since Last Report, Give Reasons:
NONE
10. Power Level To Which Restricted, If Any (Net MWe):
11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>57,695.0</u>
13. Hours Reactor Critical	<u>546.9</u>	<u>2,183.7</u>	<u>39,968.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>484.5</u>	<u>2,112.5</u>	<u>38,912.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,417,277</u>	<u>6,822,461</u>	<u>125,275,429</u>
18. Gross Elec Ener (MWH)	<u>446,380</u>	<u>2,239,560</u>	<u>40,465,990</u>
19. Net Elec Ener (MWH)	<u>430,209</u>	<u>2,161,815</u>	<u>39,015,168</u>
20. Unit Service Factor	<u>65.1</u>	<u>41.3</u>	<u>70.2</u>
21. Unit Avail Factor	<u>65.1</u>	<u>41.3</u>	<u>70.2</u>
22. Unit Cap Factor (MDC Net)	<u>54.6</u>	<u>39.9</u>	<u>67.0</u>
23. Unit Cap Factor (DER Net)	<u>52.6</u>	<u>38.5</u>	<u>65.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.5</u>	<u>13.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>32.1</u>	<u>5,883.0</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * COOK 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
147	03/10/84	S	259.5	C	4		ZZ	ZZZZZZ	THE UNIT WAS REMOVED FROM SERVICE ON 840310 FOR SCHEDULED CYCLE IV - V REFUELING/MAINTENANCE OUTAGE. THE OUTAGE WORK HAS BEEN COMPLETED. LOW POWER PHYSICS TESTING WAS COMPLETED ON 840711 AND THE UNIT WAS PARALLELED TO THE SYSTEM THE SAME DAY.

 * SUMMARY *

 COOK 2 RETURNED ONLINE FROM REFUELING ON JULY 11TH AND OPERATED ROUTINELY THRU REMAINDER OF JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* COOK 2 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MICHIGAN
COUNTY.....BERRIEN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI S OF
BENTON HARBOR, MI
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MARCH 10, 1978
DATE ELEC ENER 1ST GENER...MARCH 22, 1978
DATE COMMERCIAL OPERATE...JULY 1, 1978
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....INDIANA & MICHIGAN ELECTRIC
CORPORATE ADDRESS.....1 RIVERSIDE FLAZA
COLUMBUS, OHIO 43216
CONTRACTOR
ARCHITECT/ENGINEER.....AMERICAN ELEC. POWER SERVICE CORP.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....J. A. JONES CONSTRUCTION
TURBINE SUPPLIER.....BROWN BOVERI

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....E. SWANSON
LICENSING PROJ MANAGER.....D. WIGGINTON
DOCKET NUMBER.....50-316
LICENSE & DATE ISSUANCE...DPR-74, DECEMBER 23, 1977
PUBLIC DOCUMENT ROOM.....MAUDE PRESTON PALENSKE MEMORIAL LIBRARY
500 MARKET STREET
ST. JOSEPH, MICHIGAN 49085

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MAY 1 - JUNE 10, (84-11): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; LICENSEE EVENT REPORTS; LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; I.E. BULLETINS; OPERATOR LICENSING; AND MANAGEMENT MEETING - REGULATORY PERFORMANCE IMPROVEMENT PROGRAM (RPIP). THE INSPECTION INVOLVED 279 INSPECTOR HOURS BY THREE NRC INSPECTORS INCLUDING 68 INSPECTOR HOURS OFF-SHIFT. NO ITEMS OF NONCOMPLIANCE, DEFICIENCIES, OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

1. Docket: 50-298 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. K. SALISBURY (402) 825-3811

4. Licensed Thermal Power (MWt): 2381

5. Nameplate Rating (Gross MWe): 983 X 0.85 = 836

6. Design Electrical Rating (Net MWe): 778

7. Maximum Dependable Capacity (Gross MWe): 787

8. Maximum Dependable Capacity (Net MWe): 764

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>88,416.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,888.0</u>	<u>71,891.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,846.8</u>	<u>70,765.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,568,976</u>	<u>9,112,503</u>	<u>139,625,661</u>
18. Gross Elec Ener (MWH)	<u>517,790</u>	<u>3,027,668</u>	<u>44,434,023</u>
19. Net Elec Ener (MWH)	<u>497,056</u>	<u>2,902,998</u>	<u>42,819,657</u>
20. Unit Service Factor	<u>100.0</u>	<u>94.8</u>	<u>80.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>94.8</u>	<u>80.0</u>
22. Unit Cap Factor (MDC Net)	<u>87.4</u>	<u>74.3</u>	<u>63.4</u>
23. Unit Cap Factor (DER Net)	<u>85.9</u>	<u>73.0</u>	<u>62.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.7</u>	<u>3.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>84.9</u>	<u>2,042.2</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING & MAINTENANCE- SEPT. 24, 1984 7 MONTHS

27. If Currently Shutdown Estimated Startup Date: N/A

* COOPER STATION *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

COOPER STATION



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* COOPER STATION *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

* SUMMARY *

COOPER STATION OPERATED WITH NO OUTAGES OR
REDUCTIONS DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* COOPER STATION *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEBRASKA
COUNTY.....HEMAHA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...23 MI S OF
NEBRASKA CITY, NEB
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...FEBRUARY 21, 1974
DATE LLEC ENER 1ST GENER...MAY 10, 1974
DATE COMMERCIAL OPERATE....JULY 1, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MISSOURI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NEBRASKA PUBLIC POWER DISTRICT
CORPORATE ADDRESS.....P.O. BOX 499
COLUMBUS, NEBRASKA 68601
CONTRACTOR
ARCHITECT/ENGINEER.....BURNS & ROE
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BURNS & ROE
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....D. DUBOIS
LICENSING PROJ MANAGER.....E. SYLVESTER
DOCKET NUMBER.....50-298
LICENSE & DATE ISSUANCE....DPR-46, JANUARY 18, 1974
PUBLIC DOCUMENT ROOM.....AUBURN PUBLIC LIBRARY
1118 15TH STREET
AUBURN, NEBRASKA 68305

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED MAY 7-11, 1984 (84-09): ROUTINE, UNANNOUNCED INSPECTION OF THE PROCUREMENT ACTIVITIES; RECEIPT, STORAGE; AND HANDLING PROGRAM AND PROCUREMENT CONTROL PROGRAM. ONE VIOLATION WAS IDENTIFIED (FAILURE TO TAG REJECTED MATERIAL).

INSPECTION CONDUCTED JUNE 25-29, 1984 (84-14): ROUTINE, UNANNOUNCED INSPECTION OF FACILITY MODIFICATION ACTIVITIES ASSOCIATED WITH RECIRCULATION CORE SPRAY LOOP, AND REACTOR WATER CLEAN-UP PIPING REPLACEMENT. NO VIOLATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* COOPER STATION *

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

ROUTINE POWER OPERATION

LAST IE SITE INSPECTION DATE: JUNE 25-29, 1984

INSPECTION REPORT NO: 50-298/8414

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-008	6/9/84	7/10/84	RADIOACTIVE LIQUID DISCHARGE NOT MONITORED

=====

1. Docket: 50-302 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: D. GRAHAM (904) 795-3802

4. Licensed Thermal Power (MWt): 2544

5. Nameplate Rating (Gross MWe): 989 X 0.9 = 890

6. Design Electrical Rating (Net MWe): 825

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 821

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>64,751.0</u>
13. Hours Reactor Critical	<u>734.9</u>	<u>4,796.0</u>	<u>42,366.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,275.5</u>
15. Hrs Generator On-Line	<u>731.7</u>	<u>4,754.3</u>	<u>41,373.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,786,676</u>	<u>11,436,851</u>	<u>93,401,186</u>
18. Gross Elec Ener (MWH)	<u>610,923</u>	<u>3,948,530</u>	<u>31,875,266</u>
19. Net Elec Ener (MWH)	<u>582,782</u>	<u>3,764,555</u>	<u>30,281,638</u>
20. Unit Service Factor	<u>98.3</u>	<u>93.0</u>	<u>63.9</u>
21. Unit Avail Factor	<u>98.3</u>	<u>93.0</u>	<u>63.9</u>
22. Unit Cap Factor (MDC Net)	<u>95.4</u>	<u>89.7</u>	<u>57.0</u>
23. Unit Cap Factor (DER Net)	<u>94.9</u>	<u>89.3</u>	<u>56.7</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.5</u>	<u>22.0</u>
25. Forced Outage Hours	<u>.0</u>	<u>73.9</u>	<u>11,689.2</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* CRYSTAL RIVER 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CRYSTAL RIVER 3



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * CRYSTAL RIVER 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-26	07/01/84	S	0.0	B	5		HC	HTEXCH	REDUCED POWER TO CLEAN AND SHOOT CONDENSER TUBES.
84-27	07/21/84	S	12.3	A	1		CB	MOTORX	SHUTDOWN BRIEFLY TO ADD OIL TO THE "C" REACTOR COOLANT PUMP OIL RESERVOIR.

 * SUMMARY *

 CRYSTAL RIVER OPERATED WITH 1 OUTAGE AND 1 REDUCTION DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* CRYSTAL RIVER 3 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....FLORIDA

COUNTY.....CITRUS

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...7 MI NW OF
CRYSTAL RIVER, FLA

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...JANUARY 14, 1977
DATE ELEC ENER 1ST GENER...JANUARY 30, 1977
DATE COMMERCIAL OPERATE...MARCH 13, 1977
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...GULF OF MEXICO

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER CORPORATION

CORPORATE ADDRESS.....3201 34TH STREET, SOUTH
ST PETERSBURG, FLORIDA 33733

CONTRACTOR
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES

NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX

CONSTRUCTOR.....J. A. JONES CONSTRUCTION

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....T. STETKA
LICENSING PROJ MANAGER....H. SILVER
DOCKET NUMBER.....50-302

LICENSE & DATE ISSUANCE...DPR-72, JANUARY 28, 1977

PUBLIC DOCUMENT ROOM.....CRYSTAL RIVER PUBLIC LIBRARY
668 N.W. FIRST
CRYSTAL RIVER, FLORIDA 32639

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 30 - AUGUST 3 (84-24): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 32 INSPECTOR-HOURS ON SITE DURING REGULAR HOURS INSPECTING: INTERNAL AND EXTERNAL EXPOSURE CONTROL; RADIATION WORK PERMIT PROGRAM; HEALTH PHYSICS TRAINING AND QUALIFICATIONS; RESPIRATORY PROTECTION PROGRAM; QUALITY ASSURANCE ASSURANCE SURVEILLANCE PROGRAM; ALARA PROGRAM; POSTING, LABELING, AND CONTROL OF RADIOLOGICAL AREAS; ROUTINE AND SPECIAL RADIATION SURVEYS; AND INSPECTOR FOLLOWUP ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TECHNICAL SPECIFICATION 6.8.1 PROCEDURES THAT COVER THE REVIEW AND APPROVAL OF PROCEDURES AND PROCEDURES THAT COVER SURVEILLANCE ACTIVITIES OF SAFETY-RELATED EQUIPMENT WERE NOT ADHERED TO.
(8416 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* CRYSTAL RIVER 3 *

OTHER ITEMS

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: JUNE 18-22, 1984 +

INSPECTION REPORT NO: 50-302/84-20 +

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-012	06/15/84	07/13/84	INSTRUMENT AIR SUPPLY LINE TO DAMPERS FOR AUX BLDG EXHAUST FANS WAS BROKEN, REPAIRED AND RETURNED TO SERVICE.
84-014	06/25/84	07/25/84	THE AUXILIARY BLDG EXHAUST FANS WERE TAKEN OUT OF SERVICE IN ORDER TO PERFORM MODIFICATIONS TO THE VENTILATION SYSTEM DAMPERS.
84-015	07/13/84	08/09/84	AUTO START OF EMERGENCY DIESEL GENERATOR-A DRAIN PETCOCK ON AN AIR FILTER IN THE 'B' EMERGENCY DIESEL GENERATOR AIR START SYSTEM FAILED.
84-016	07/20/84	08/15/84	THE ALARM/TRIP SETPOINT FOR THE FUEL STORAGE POOL AREA GASEOUS MONITOR WAS NOT IN ACCORDANCE WITH TECHNICAL SPECIFICATION, THIS EVENT REQUIRED NO IMMEDIATE CORRECTIVE ACTIONS.

=====

1. Docket: 50-346 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: BILAL SARSOUR (419) 259-5000 X384

4. Licensed Thermal Power (MWt): 2772

5. Nameplate Rating (Gross MWe): 1069 X 0.9 = 962

6. Design Electrical Rating (Net MWe): 906

7. Maximum Dependable Capacity (Gross MWe): 918

8. Maximum Dependable Capacity (Net MWe): 874

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>52,632.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,532.4</u>	<u>32,034.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>134.8</u>	<u>4,014.1</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,492.9</u>	<u>30,644.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,732.7</u>
17. Gross Therm Ener (MWH)	<u>1,907,358</u>	<u>11,563,897</u>	<u>72,607,711</u>
18. Gross Elec Ener (MWH)	<u>619,211</u>	<u>3,789,759</u>	<u>24,081,252</u>
19. Net Elec Ener (MWH)	<u>586,466</u>	<u>3,574,536</u>	<u>22,573,235</u>
20. Unit Service Factor	<u>100.0</u>	<u>87.9</u>	<u>58.2</u>
21. Unit Avail Factor	<u>100.0</u>	<u>87.9</u>	<u>61.5</u>
22. Unit Cap Factor (MDC Net)	<u>90.2</u>	<u>80.0</u>	<u>49.1</u>
23. Unit Cap Factor (DER Net)	<u>87.0</u>	<u>77.2</u>	<u>47.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>12.1</u>	<u>17.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>618.1</u>	<u>7,202.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING & MAINTENANCE - 9/1/84 THRU 11/9/84

27. If Currently Shutdown Estimated Startup Date: N/A

 * DAVIS-BESSE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

DAVIS-BESSE 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* DAVIS-BESSE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

* SUMMARY *

DAVIS-BESSE 1 OPERATED ROUTINELY DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

INSPECTION SUMMARY

INCLUDING, FIRE PROTECTION ENGINEER QUALIFICATIONS, EMERGENCY LIGHTING ANALYSIS, THREE HOUR FIRE BARRIER(S) AND KAOWOOL FIRE WRAPPING, DISCONNECTED FIRE DETECTORS, AND POSSIBLY DEFECTIVE DELUGE VALVES. THE INSPECTION INVOLVED 16 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR. IN THE SIX AREAS INSPECTED, NO APPARENT VIOLATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

10 CFR 50.72(B)(2)(II) REQUIRES THAT ANY EVENT OR CONDITION THAT RESULTS IN MANUAL OR AUTOMATIC ACTUATION OF ANY ENGINEERING SAFETY FEATURES (ESF), INCLUDING THE REACTOR PROTECTION SYSTEM (RPS) SHALL BE REPORTED TO THE NRC WITHIN FOUR-HOURS. CONTRARY TO THE ABOVE, THE LICENSEE EXPERIENCED RPS ACTUATIONS ON MAY 15, 1984 AND MAY 17, 1984 ON SHUTDOWN BYPASS HIGH PRESSURE AND DID NOT MAKE A FOUR-HOUR NOTIFICATION TO THE NRC. 10 CFR 50, APPENDIX B, CRITERION XVI, CORRECTIVE ACTIONS, STATES IN PART, "MEASURES SHALL BE ESTABLISHED TO ASSURE THAT CONDITIONS ADVERSE TO QUALITY, SUCH AS FAILURES, MALFUNCTIONS, DEFICIENCIES, DEVIATIONS, DEFECTIVE MATERIAL AND EQUIPMENT, AND NONCONFORMANCES ARE PROMPTLY IDENTIFIED AND CORRECTED." THE TOLEDO EDISON QA MANUAL SECTION 16.1.1 STATES, IN PART, "DIVISION DIRECTORS SHALL DEVELOP PROCEDURES TO ENSURE THAT CONDITIONS ADVERSE TO QUALITY SUCH AS EQUIPMENT FAILURES, EQUIPMENT MALFUNCTIONS, PROCEDURE DEVIATIONS, DEFECTIVE MATERIAL AND EQUIPMENT, AND DEVIATION TO REGULATORY RULES AND REQUIREMENTS ARE PROMPTLY IDENTIFIED, DOCUMENTED AND CORRECTED." CONTRARY TO THE ABOVE: (A) THE LICENSEE DID NOT TAKE PROMPT CORRECTIVE ACTION TO ESTABLISH PROCEDURES TO REPORT CONDITIONS ADVERSE OF QUALITY. IN THE RESPONSE TO INSPECTION REPORT 83-19, THE LICENSEE STATED ALL ORGANIZATIONS INVOLVED IN IMPLEMENTING THE QA MANUAL WOULD HAVE PROCEDURES IN-PLACE TO REPORT CONDITIONS ADVERSE TO QUALITY BY APRIL 1, 1984. AS OF APRIL 23, 1984, THE DIVISIONS OF ENGINEERING, NUCLEAR SERVICES, PROCUREMENT AND RECORDS MANAGEMENT DID NOT HAVE THESE PROCEDURES IN-PLACE. ALSO, THE LICENSEE HAD CLOSED THIS ITEM IN THEIR TRACKING SYSTEM EVEN THOUGH CORRECTIVE ACTION HAD NOT BEEN COMPLETED. (B) THE LICENSEE DID NOT PROMPTLY DECLARE 56 FIRE DOORS INOPERABLE AND ESTABLISH FIRE WATCHES WHEN A NONCONFORMANCE REPORT WAS EVALUATED BY ENGINEERING PERSONNEL DENOTING THE DOORS DID NOT CONFORM TO NATIONAL FIRE PROTECTION ASSOCIATION STANDARDS.
(8406 4)

10 CFR 50, APPENDIX B, CRITERION V, AS IMPLEMENTED BY TOLEDO EDISON QUALITY ASSURANCE PROGRAM AS DESCRIBED IN SECTION 17.2.5, INCLUDING A COMMITMENT TO ANSI N18.7-1972, REQUIRES THAT ACTIVITIES AFFECTING QUALITY BE PRESCRIBED BY DOCUMENTED INSTRUCTIONS AND PROCEDURES. SECTION 5.1.5 OF ANSI 18.7-1972, AND SECTION 1.C.6 OF NUREG-0737, REQUIRE INDEPENDENT VERIFICATION OF TAGGING ACTIVITIES RELATIVE TO REMOVAL FROM AND RETURN TO SERVICE OF PLANT EQUIPMENT. CONTRARY TO THE ABOVE, NO PROCEDURE OR REQUIREMENT EXISTED FOR INDEPENDENT VERIFICATION OF TAGGING PLANT EQUIPMENT OUT OF SERVICE. DAVIS-BESSE NUCLEAR POWER STATION TECHNICAL SPECIFICATION FOR REACTOR COOLANT SYSTEM CHEMISTRY, SECTION 3.4.7, REQUIRES THAT THE REACTOR COOLANT SYSTEM CHEMISTRY SHALL BE MAINTAINED WITHIN THE STEADY STATE LIMIT FOR CHLORIDES OF LESS THAN OR EQUAL TO 0.15 PPM. CONTRARY TO THE ABOVE, THE CHLORIDE CONCENTRATION IN THE REACTOR COOLANT SYSTEM EXCEEDED THE LIMIT, TO A MAXIMUM OF 0.26 PPM, FOR A TOTAL OF 22 HOURS. THE UNDERLYING CAUSE WAS DETERMINED TO BE THE PREMATURE BREAKDOWN OF RECENTLY INSTALLED RESIN IN THE PURIFICATION DEMINERALIZERS AS A RESULT OF THE FOLLOWING: (A) PURCHASE OF THE RESIN WAS UNCONTROLLED AS A NON-Q ITEM WITH NO RECEIPT INSPECTION OR TESTING, ALLOWING AN UNACCEPTABLE TYPE OF RESIN TO BE INSTALLED IN THE DEMINERALIZERS; (B) FAILURE TO FOLLOW PROCEDURE LI 4782 WHICH SPECIFIED THE RESIN CHEMICAL AND PHYSICAL REQUIREMENTS.
(8409 4)

TECHNICAL SPECIFICATION, SECTIONS 6.5.1.6.D AND 6.5.1.7.A, REQUIRE THE STATION REVIEW BOARD TO REVIEW ALL PROPOSED CHANGES OR MODIFICATIONS TO PLANT SYSTEMS OR EQUIPMENT THAT AFFECT NUCLEAR SAFETY AND RECOMMEND WRITTEN APPROVAL OR DISAPPROVAL OF CHANGES OR MODIFICATIONS TO THE STATION SUPERINTENDENT. CONTRARY TO THE ABOVE, TEMPORARY MODIFICATIONS ASSOCIATED WITH NONCONFORMANCE REPORTS NCR-232-81, (LIMITORQUE VALVE MODIFICATION), NCR 392-81 (SERVICE WATER VALVE MODIFICATION), AND NCR 83-01 (AUXILIARY FEEDWATER PUMP STEAM LINE MODIFICATION) WERE NOT REVIEWED BY THE STATION REVIEW BOARD AND A RECOMMENDATION CONCERNING THE MODIFICATION'S ACCEPTABILITY WAS NOT MADE TO THE STATION SUPERINTENDENT. 10 CFR 50, APPENDIX B, CRITERION XVII, AS IMPLEMENTED BY THE TOLEDO EDISON OPERATING QA PROGRAM AND THE FSAR SECTION 17.2, REQUIRE THAT THE APPLICANT SHALL PROVIDE RECORD STORAGE CONSISTENT WITH APPLICABLE REGULATORY REQUIREMENTS. THE TOLEDO EDISON QA PROGRAM COMMITS TO ANSI N45.2.9-1974 AND REGULATORY GUIDE 1.88, REVISION 2, OCTOBER 1976, WITH AN EXCEPTION SPECIFYING A TWO HOUR FIRE PROTECTION RATING FOR RECORD STORAGE FACILITIES. CONTRARY TO THE ABOVE, RECORDS OF AUDITS, AUDITOR AND QC INSPECTOR QUALIFICATION/CERTIFICATION AND CALIBRATIONS WERE

Report Period JUL 1984

R E P O R T S F R O M L I C E N S E E

* DAVIS-BESSE 1 *

```
=====
```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-03	03/02/84	07/26/84	TRIP DUE TO CLOSURE OF MAIN STEAM ISO. VALVE.
84-08	06/05/84	07/03/84	INOPERABLE DIESEL GENERATORS.
84-09	06/18/84	06/18/84	POTENTIAL PIPING BREAKS, STARTUP FEEDWATER PUMP PIPING.
84-10	06/24/84	07/24/84	UNPLANNED REACTOR SHUTDOWN DUE TO PERSONNEL ERROR.

```
=====
```

1. Docket: 50-237 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: BEN SCHROEDER (815) 942-2920

4. Licensed Thermal Power (MWt): 2527

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 794

7. Maximum Dependable Capacity (Gross MWe): 812

8. Maximum Dependable Capacity (Net MWe): 772

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>124,631.0</u>
13. Hours Reactor Critical	<u>720.9</u>	<u>4,923.3</u>	<u>97,148.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>700.8</u>	<u>4,821.2</u>	<u>92,722.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,454,064</u>	<u>11,312,560</u>	<u>188,050,156</u>
18. Gross Elec Ener (MWH)	<u>457,957</u>	<u>3,663,974</u>	<u>60,167,141</u>
19. Net Elec Ener (MWH)	<u>431,759</u>	<u>3,475,841</u>	<u>56,873,285</u>
20. Unit Service Factor	<u>94.2</u>	<u>94.3</u>	<u>74.4</u>
21. Unit Avail Factor	<u>94.2</u>	<u>94.3</u>	<u>74.4</u>
22. Unit Cap Factor (MDC Net)	<u>75.2</u>	<u>88.1</u>	<u>59.1</u>
23. Unit Cap Factor (DER Net)	<u>73.1</u>	<u>85.7</u>	<u>57.5</u>
24. Unit Forced Outage Rate	<u>5.8</u>	<u>5.7</u>	<u>11.6</u>
25. Forced Outage Hours	<u>43.2</u>	<u>289.8</u>	<u>4,710.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
SEPTEMBER 3, 1983 FOR REFUEL; @ 12 WEEKS.

27. If Currently Shutdown Estimated Startup Date: N/A

* DRESDEN 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
DRESDEN 2



JULY 1984

Report Period JUL 1984

UNI SHUTDOWNS / REDUCTIONS

 * DRESDEN 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
3	07/09/84	F	21.6	G	3				WHILE PERFORMING SURVEILLANCE THE INSTRUMENT MECHANIC IMPROPERLY PERFORMED THE REQUIRED SURVEILLANCE TEST. ACTION DISCUSSED WITH MECHANIC.
4	07/22/84	F	22.2	G	3				UNIT 3 R9 REQUESTED THAT A RECIRCULATION VALVE ON THE EHC OPERATOR OPENED. THE OPERATOR OPENED THE VALVE ON UNIT 2 BY MISTAKE. ACTION DISCUSSED WITH OPERATOR.

 * SUMMARY *

 DRESDEN 2 OPERATED WITH 2 OUTAGES DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* DRESDEN 2 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....GRUNDY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9 MI E OF
MORRIS, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JANUARY 7, 1970
DATE ELEC ENER 1ST GENER...APRIL 13, 1970
DATE COMMERCIAL OPERATE...JUNE 9, 1970
CONDENSER COOLING METHOD...COOLING LAKE
CONDENSER COOLING WATER...KANKAKEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....T. TONGUE
LICENSING PROJ MANAGER....R. GILBERT
DOCKET NUMBER.....50-237
LICENSE & DATE ISSUANCE...DPR-19, DECEMBER 22, 1969
PUBLIC DOCUMENT ROOM.....MORRIS PUELIC LIBRARY
604 LIBERTY STREET
MORRIS, ILLINOIS 60450

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 4-6, (84-10): ROUTINE ANNOUNCED INSPECTION OF THE DRESDEN EMERGENCY PREPAREDNESS EXERCISE INVOLVING OBSERVATIONS BY NINE NRC REPRESENTATIVES OF KEY FUNCTIONS AND LOCATIONS DURING THE EXERCISE. THE INSPECTION INVOLVED 150 INSPECTOR-HOURS ONSITE BY SIX NRC INSPECTORS AND THREE CONSULTANTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION DURING MAY 22 - JUNE 15, (84-11): ROUTINE UNANNOUNCED RESIDENT INSPECTION OF ACTION ON PREVIOUS INSPECTION FINDINGS, HQ REQUEST, REGIONAL REQUEST, OPERATIONAL SAFETY, FIRE PROTECTION PROGRAM, SURVEILLANCE PROGRAM, MAINTENANCE, LICENSEE EVENT REPORTS, I. E. INFORMATION NOTICES, UNIT 1 CHEMICAL CLEANING, SPENT FUEL SHIPMENTS, AND REPORT REVIEW. THE INSPECTION INVOLVED 122 INSPECTOR HOURS ONSITE BY TWO NRC INSPECTORS INCLUDING 22 INSPECTOR HOURS ONSITE DURING OFF-SHIFTS. OF THE 12 AREAS INSPECTED, ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN ONE AREA (INADEQUATE SURVEILLANCE TESTING OF CARDOX SYSTEM).

ENFORCEMENT SUMMARY

DRESDEN TECHNICAL SPECIFICATION 4.12.D.3 STATES IN PART "AT LEAST ONCE PER OPERATING CYCLE, THE (CARDOX) SYSTEM VALVES AND ASSOCIATED DAMPERS WILL BE VERIFIED TO ACTUATE AUTOMATICALLY AND MANUALLY." CONTRARY TO THE ABOVE, THE CARDOX SYSTEM DISCHARGE MASTER VALVE WAS NOT TESTED TO VERIFY ACTUATION IN THE AUTOMATIC MODE AND IT APPEARS THAT TESTING IN THE AUTOMATIC MODE WAS NOT INCLUDED IN THE SURVEILLANCE PROGRAM.
(8411 4)

1. Docket: 50-249 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: BEN SCHROEDER (815) 942-2920

4. Licensed Thermal Power (MWt): 2527

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 794

7. Maximum Dependable Capacity (Gross MWe): 812

8. Maximum Dependable Capacity (Net MWe): 773

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>114,216.0</u>
13. Hours Reactor Critical	<u>254.1</u>	<u>580.2</u>	<u>83,415.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>186.2</u>	<u>186.2</u>	<u>80,048.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>248,593</u>	<u>248,593</u>	<u>160,211,597</u>
18. Gross Elec Ener (MWH)	<u>74,541</u>	<u>74,541</u>	<u>52,027,450</u>
19. Net Elec Ener (MWH)	<u>64,412</u>	<u>34,559</u>	<u>49,265,142</u>
20. Unit Service Factor	<u>25.0</u>	<u>3.6</u>	<u>70.1</u>
21. Unit Avail Factor	<u>25.0</u>	<u>3.6</u>	<u>70.1</u>
22. Unit Cap Factor (MDC Net)	<u>11.2</u>	<u>.9</u>	<u>55.8</u>
23. Unit Cap Factor (DER Net)	<u>10.9</u>	<u>.9</u>	<u>54.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>12.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>6,415.2</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* D R E S D E N 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

D R E S D E N 3



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* DRESDEN 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
8	09/30/83	S	557.8	A	4				MAIN TURBINE REPAIR CONCLUDES.

* SUMMARY *

DRESDEN 3 RETURNED ONLINE FROM MAIN TURBINE REPAIRS
ON JULY 24TH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* DRESDEN 3 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....GRUNDY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9 MI E OF
MORRIS, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JANUARY 31, 1971
DATE ELEC ENER 1ST GENER...JULY 22, 1971
DATE COMMERCIAL OPERATE...NOVEMBER 16, 1971
CONDENSER COOLING METHOD...COOLING LAKE
CONDENSER COOLING WATER...KANKAKEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....T. TONGUE
LICENSING PROJ MANAGER.....R. GILBERT
DOCKET NUMBER.....50-249
LICENSE & DATE ISSUANCE....DPR-25, MARCH 2, 1971
PUBLIC DOCUMENT ROOM.....MORRIS PUBLIC LIBRARY
604 LIBERTY STREET
MORRIS, ILLINOIS 60450

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 4-6, (84-09): ROUTINE ANNOUNCED INSPECTION OF THE DRESDEN EMERGENCY PREPAREDNESS EXERCISE INVOLVING OBSERVATIONS BY NINE NRC REPRESENTATIVES OF KEY FUNCTIONS AND LOCATIONS DURING THE EXERCISE. THE INSPECTION INVOLVED 150 INSPECTOR-HOURS ONSITE BY SIX NRC INSPECTORS AND THREE CONSULTANTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION DURING MAY 22 - JUNE 15, (84-10): ROUTINE UNANNOUNCED RESIDENT INSPECTION OF ACTION ON PREVIOUS INSPECTION FINDINGS, HQ REQUEST, REGIONAL REQUEST, OPERATIONAL SAFETY, FIRE PROTECTION PROGRAM, SURVEILLANCE PROGRAM, MAINTENANCE, LICENSEE EVENT REPORTS, I. E. INFORMATION NOTICES, UNIT 1 CHEMICAL CLEANING, SPENT FUEL SHIPMENTS, AND REPORT REVIEW. THE INSPECTION INVOLVED 122 INSPECTOR HOURS ONSITE BY TWO NRC INSPECTORS INCLUDING 22 INSPECTOR HOURS ONSITE DURING OFF-SHIFTS. OF THE 12 AREAS INSPECTED, ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN ONE AREA (INADEQUATE SURVEILLANCE TESTING OF CARDOX SYSTEM).

ENFORCEMENT SUMMARY

DRESDEN TECHNICAL SPECIFICATION 4.12.D.3 STATES IN PART "AT LEAST ONCE PER OPERATING CYCLE, THE (CARDOX) SYSTEM VALVES AND ASSOCIATED DAMPERS WILL BE VERIFIED TO ACTUATE AUTOMATICALLY AND MANUALLY." CONTRARY TO THE ABOVE, THE CARDOX SYSTEM DISCHARGE MASTER VALVE WAS NOT TESTED TO VERIFY ACTUATION IN THE AUTOMATIC MODE AND IT APPEARS THAT TESTING IN THE AUTOMATIC MODE WAS NOT INCLUDED IN THE SURVEILLANCE PROGRAM.
(8410 4)

1. Docket: 50-331 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: MATT ANDERSON (319) 851-7308

4. Licensed Thermal Power (MWt): 1658

5. Nameplate Rating (Gross MWe): 663 X 0.9 = 597

6. Design Electrical Rating (Net MWe): 538

7. Maximum Dependable Capacity (Gross MWe): 545

8. Maximum Dependable Capacity (Net MWe): 515

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe):


11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>83,255.0</u>
13. Hours Reactor Critical	<u>705.0</u>	<u>3,723.4</u>	<u>59,658.4</u>
14. Rx Reserve Shtdwn Hrs	<u>0</u>	<u>130.3</u>	<u>130.3</u>
15. Hrs Generator On-Line	<u>691.1</u>	<u>3,621.6</u>	<u>58,064.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,031,560</u>	<u>5,300,216</u>	<u>73,048,778</u>
18. Gross Elec Ener (MWH)	<u>340,073</u>	<u>1,785,356</u>	<u>24,479,413</u>
19. Net Elec Ener (MWH)	<u>319,515</u>	<u>1,681,498</u>	<u>22,917,868</u>
20. Unit Service Factor	<u>92.9</u>	<u>70.9</u>	<u>69.7</u>
21. Unit Avail Factor	<u>92.9</u>	<u>70.9</u>	<u>69.7</u>
22. Unit Cap Factor (MDC Net)	<u>83.4</u>	<u>63.9</u>	<u>53.5</u>
23. Unit Cap Factor (DER Net)	<u>79.8</u>	<u>61.2</u>	<u>51.2</u>
24. Unit Forced Outage Rate	<u>7.1</u>	<u>17.9</u>	<u>17.3</u>
25. Forced Outage Hours	<u>52.9</u>	<u>789.9</u>	<u>12,124.2</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):	<u>MAINTENANCE OUTAGE-SEPTEMBER 28 TO OCTOBER 21, 1984</u>		
27. If Currently Shutdown Estimated Startup Date:	<u>N/A</u>		

 * DUANE ARNOLD *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

DUANE ARNOLD



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * DUANE ARNOLD *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
6	07/13/84	F	52.9	H	3	84-027	JC	JC-PS	JARRED INSTRUMENTS RESULTED IN SPURIOUS HIGH REACTOR PRESSURE SIGNALS AND RESULTANT SCRAM. DURING STARTUP DEGRADED VOLTAGE OFFSITE POWER GRID RESULTED IN A SECOND SCRAM.
7	07/29/84	S	0.0	H	5				ROD MANIPULATION REQUIRED REDUCTION IN POWER TO 50%. RATE OF INCREASE IN POWER WAS LIMITED BY THE PRECONDITIONING PROCESS. COMPUTER DIFFICULTIES WITH THE PERIODIC CORE PERFORMANCE SUMMARY REPORT DELAYED THE PRECONDITIONING PROCESS.

 * SUMMARY *

 DUANE ARNOLD OPERATED WITH 1 OUTAGE AND 1 REDUCTION DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* DUANE ARNOLD *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....IOWA
COUNTY.....LINN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...8 MI NW OF
CEDAR RAPIDS, IA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MARCH 23, 1974
DATE ELEC ENER 1ST GENER...MAY 19, 1974
DATE COMMERCIAL OPERATE...FEBRUARY 1, 1975
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...CEDAR RAPIDS RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....IOWA ELECTRIC POWER & LIGHT
CORPORATE ADDRESS.....I E TOWERS, P.O. BOX 351
CEDAR RAPIDS, IOWA 52406
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....L. CLARDY
LICENSING PROJ MANAGER.....M. THADANI
DOCKET NUMBER.....50-331
LICENSE & DATE ISSUANCE...DPR-49, FEBRUARY 22, 1974
PUBLIC DOCUMENT ROOM.....REFERENCE SERVICE
CEDAR RAPIDS PUBLIC LIBRARY
428 THIRD AVENUE, S.E.
CEDAR RAPIDS, IOWA 52401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON APRIL 1 - MAY 31, (84-07): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTOR OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; LICENSEE EVENT REPORTS; IE BULLETINS; TMI ITEMS; CONTAINMENT LEAK RATE TESTING; REGIONAL REQUESTS; AND INDEPENDENT INSPECTION. THE INSPECTION INVOLVED A TOTAL OF 140 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR INCLUDING 20 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS, AND 20 INSPECTOR-HOURS OFF-SITE. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

1. Docket: 50-348 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. D. WOODARD (205) 899-5156

4. Licensed Thermal Power (MWt): 2652

5. Nameplate Rating (Gross MWe): 1045 X 0.85 = 888

6. Design Electrical Rating (Net MWe): 829

7. Maximum Dependable Capacity (Gross MWe): 842

8. Maximum Dependable Capacity (Net MWe): 797

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>58,439.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,332.8</u>	<u>38,456.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,650.7</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,248.0</u>	<u>37,351.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,973,062</u>	<u>8,174,380</u>	<u>94,275,904</u>
18. Gross Elec Ener (MWH)	<u>637,754</u>	<u>2,628,216</u>	<u>29,870,080</u>
19. Net Elec Ener (MWH)	<u>605,750</u>	<u>2,466,846</u>	<u>28,167,908</u>
20. Unit Service Factor	<u>100.0</u>	<u>63.5</u>	<u>63.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>63.5</u>	<u>63.9</u>
22. Unit Cap Factor (MDC Net)	<u>102.2</u>	<u>60.1</u>	<u>60.5*</u>
23. Unit Cap Factor (DER Net)	<u>98.2</u>	<u>58.2</u>	<u>58.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>2.4</u>	<u>14.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>79.5</u>	<u>6,246.0</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* FARLEY 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FARLEY 1



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* FARLEY 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

* SUMMARY *

FARLEY 1 OPERATED AT FULL POWER DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* FARLEY 1 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ALABAMA
COUNTY.....HOUSTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...28 MI SE OF
DOTHAN, ALA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 9, 1977
DATE ELEC ENER 1ST GENER...AUGUST 18, 1977
DATE COMMERCIAL OPERATE....DECEMBER 1, 1977
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...CHATAHOOCHEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ALABAMA POWER CO.
CORPORATE ADDRESS.....600 NORTH 18TH STREET
BIRMINGHAM, ALABAMA 35203
CONTRACTOR
ARCHITECT/ENGINEER.....SOUTHERN SERVICES INCORPORATED
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....W. BRADFORD
LICENSING PROJ MANAGER.....E. REEVES
DOCKET NUMBER.....50-348
LICENSE & DATE ISSUANCE...NPF-2, JUNE 25, 1977
PUBLIC DOCUMENT ROOM.....G.S. HOUSTON MEMORIAL LIBRARY
212 W. BURDESHAW STREET
DOTHAN, ALABAMA 36301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JUNE 25-29 (84-18): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 37 INSPECTOR-HOURS ON SITE IN THE AREAS OF ORGANIZATION, TRAINING, INTERNAL EXPOSURE, EXTERNAL EXPOSURE, CONTROL OF RADIOACTIVE MATERIAL, ALARA, SOLID WASTES AND THE POST ACCIDENT SAMPLING SYSTEM. ONE VIOLATION WAS IDENTIFIED - THREE EXAMFLES OF FAILURE TO ADHERE TO RADIATION CONTROL PROCEDURES.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

1. Docket: 50-364 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. D. WOODARD (205) 899-5156

4. Licensed Thermal Power (MWt): 2652

5. Nameplate Rating (Gross MWe): 860

6. Design Electrical Rating (Net MWe): 829

7. Maximum Dependable Capacity (Gross MWe): 853

8. Maximum Dependable Capacity (Net MWe): 809

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>26,352.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,064.0</u>	<u>23,600.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>138.4</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,015.7</u>	<u>23,314.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,968,023</u>	<u>13,126,529</u>	<u>60,037,221</u>
18. Gross Elec Ener (MWH)	<u>624,866</u>	<u>4,248,756</u>	<u>19,235,604</u>
19. Net Elec Ener (MWH)	<u>595,036</u>	<u>4,044,822</u>	<u>18,244,848</u>
20. Unit Service Factor	<u>100.0</u>	<u>98.1</u>	<u>88.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>98.1</u>	<u>88.5</u>
22. Unit Cap Factor (MDC Net)	<u>98.9</u>	<u>97.3</u>	<u>85.6</u>
23. Unit Cap Factor (DER Net)	<u>96.5</u>	<u>95.5</u>	<u>83.5</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.9</u>	<u>4.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>95.3</u>	<u>1,127.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING/MAINTENANCE OUTAGE, 1/4/85, APPROX 6 WEEKS.

27. If Currently Shutdown Estimated Startup Date: N/A

* FARLEY 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FARLEY 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* FARLEY 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

* SUMMARY *

FARLEY 2 OPERATED AT FULL POWER DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* FARLEY 2 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ALABAMA

COUNTY.....HOUSTON

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...28 MI SE OF
DOTHAN, ALA

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...MAY 5, 1981

DATE ELEC ENER 1ST GENER...MAY 25, 1981

DATE COMMERCIAL OPERATE....JULY 30, 1981

CONDENSER COOLING METHOD...COOLING TOWER

CONDENSER COOLING WATER...CHATAHOOCHEE RIVER

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ALABAMA POWER CO.

CORPORATE ADDRESS.....600 NORTH 18TH STREET
BIRMINGHAM, ALABAMA 35203

CONTRACTOR
ARCHITECT/ENGINEER.....SOUTHERN SERVICES INCORPORATED

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....W. BRADFORD

LICENSING PROJ MANAGER.....E. REEVES
DOCKET NUMBER.....50-364

LICENSE & DATE ISSUANCE...NPF-8, MARCH 31, 1981

PUBLIC DOCUMENT ROOM.....G.S. HOUSTON MEMORIAL LIBRARY
212 W. BURDESHAW STREET
DOTHAN, ALABAMA 36301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JUNE 11 - JULY 10 (84-17): THIS ROUTINE INSPECTION INVOLVED 81 INSPECTOR-HOURS ON SITE IN THE AREAS OF MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, INDEPENDENT INSPECTION EFFORT AND STEAM GENERATOR TUBE LEAK. A VIOLATION WAS IDENTIFIED. INADEQUATE PROCEDURE AND FAILURE TO FOLLOW APPROVED PROCEDURES.

INSPECTION JUNE 25-29 (84-19): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 16 INSPECTOR-HOURS ON SITE INSPECTING: CHANGES TO APPROVED PHYSICAL SECURITY PLAN AND IMPLEMENTING PROCEDURES; SECURITY ORGANIZATION; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AREAS; PHYSICAL BARRIERS - VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROLS - PERSONNEL, PACKAGES, AND VEHICLES; DETECTION AIDS - PROTECTED AREAS; DETECTION AIDS VITAL AREAS; ALARM STATIONS; AND COMMUNICATIONS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH REGULATORY REQUIREMENTS IN THE 14 AREAS INSPECTED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

1. Docket: 50-333 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. COOK (315) 342-3840

4. Licensed Thermal Power (MWt): 2436

5. Nameplate Rating (Gross MWe): 981 X 0.9 = 883

6. Design Electrical Rating (Net MWe): 821

7. Maximum Dependable Capacity (Gross MWe): 830

8. Maximum Dependable Capacity (Net MWe): 810

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>79,008.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,726.6</u>	<u>57,255.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,619.4</u>	<u>55,819.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,715,976</u>	<u>10,659,120</u>	<u>118,395,706</u>
18. Gross Elec Ener (MWH)	<u>564,190</u>	<u>3,564,280</u>	<u>40,221,600</u>
19. Net Elec Ener (MWH)	<u>546,405</u>	<u>3,451,100</u>	<u>38,949,740</u>
20. Unit Service Factor	<u>100.0</u>	<u>90.4</u>	<u>70.7</u>
21. Unit Avail Factor	<u>100.0</u>	<u>90.4</u>	<u>70.7</u>
22. Unit Cap Factor (MDC Net)	<u>90.7</u>	<u>83.4</u>	<u>64.3%</u>
23. Unit Cap Factor (DER Net)	<u>89.5</u>	<u>82.2</u>	<u>60.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>3.1</u>	<u>13.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>145.4</u>	<u>9,028.6</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):

MAINTENANCE: 09/14/84 - 30 DAYS

27. If Currently Shutdown Estimated Startup Date: N/A

* FITZPATRICK *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
FITZPATRICK



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * FITZPATRICK *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
9	07/04/84	S	0.0	H	5				REDUCED POWER FOR ROD PATTERN ADJUSTMENT.
10	07/15/84	S	0.0	H	5		SD	COND	REDUCED POWER TO REPAIR A MAIN CONDENSER TUBE LEAK.

 * SUMMARY *

 THE FITZPATRICK PLANT OPERATED AT NEAR FULL THERMAL POWER FOR THIS REPORTING PERIOD WITH ONE POWER REDUCTION FOR ROD PATTERN ADJUSTMENT AND ONE POWER REDUCTION TO REPAIR A MAIN CONDENSER TUBE LEAK.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* FITZPATRICK *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....OSWEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...8 MI NE OF
OSWEGO, NY
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...NOVEMBER 17, 1974
DATE ELEC ENER 1ST GENER...FEBRUARY 1, 1975
DATE COMMERCIAL OPERATE....JULY 28, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE ONTARIO
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....POWER AUTHORITY OF STATE OF N.Y.
CORPORATE ADDRESS.....10 COLUMBUS CIRCLE
NEW YORK, NEW YORK 10019
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....L. DOERFLEIN
LICENSING PROJ MANAGER.....H. ABELSON
DOCKET NUMBER.....50-333
LICENSE & DATE ISSUANCE....DPR-59, OCTOBER 17, 1974
PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO
PENFIELD LIBRARY - GOVERNMENT DOCUMENTS COL
OSWEGO, NY 13126
(315) 341-2323

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

1. Docket: 50-285 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: T. P. MATTHEWS (402) 536-4733

4. Licensed Thermal Power (MWt): 1500

5. Nameplate Rating (Gross MWe): 591 X 0.85 = 502

6. Design Electrical Rating (Net MWe): 478

7. Maximum Dependable Capacity (Gross MWe): 501

8. Maximum Dependable Capacity (Net MWe): 478

9. If Changes Occur Above Since Last Report, Give Reasons:
TURBINE BLADING REPAIR

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>95,112.0</u>
13. Hours Reactor Critical	<u>543.9</u>	<u>2,034.1</u>	<u>72,648.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,309.5</u>
15. Hrs Generator On-Line	<u>442.2</u>	<u>1,931.7</u>	<u>71,284.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>457,374</u>	<u>2,610,171</u>	<u>89,369,885</u>
18. Gross Elec Ener (MWH)	<u>140,784</u>	<u>831,042</u>	<u>29,460,466</u>
19. Net Elec Ener (MWH)	<u>130,986</u>	<u>787,224</u>	<u>27,867,384</u>
20. Unit Service Factor	<u>59.4</u>	<u>37.8</u>	<u>74.9</u>
21. Unit Avail Factor	<u>59.4</u>	<u>37.8</u>	<u>74.9</u>
22. Unit Cap Factor (MDC Net)	<u>36.8</u>	<u>34.7</u>	<u>63.9*</u>
23. Unit Cap Factor (DER Net)	<u>36.8</u>	<u>32.2</u>	<u>61.3</u>
24. Unit Forced Outage Rate	<u>3.6</u>	<u>.8</u>	<u>3.5</u>
25. Forced Outage Hours	<u>16.3</u>	<u>16.3</u>	<u>1,414.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* FORT CALHOUN 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
FORT CALHOUN 1



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * FORT CALHOUN 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-01	03/03/84	S	285.5	C	4		XX	XXXXXX	1984 REFUELING OUTAGE COMMENCED MARCH 3, 1984. UNIT RETURNED TO SERVICE JULY 12, 1984.
84-02	07/22/84	F	16.3	H	3		XX	XXXXXX	THE REACTOR TRIPPED WHEN SPIKES ON TWO OF THE RPS CHANNELS WERE OF SUFFICIENT MAGNITUDE TO CAUSE TM/LP TRIPS. NOISE SUPPRESSORS AND ADMINISTRATIVE CONTROLS WERE IMPLEMENTED AS CORRECTIVE ACTION.

 * SUMMARY *

 FORT CALHOUN RETURNED ONLINE FROM REFUELING ON JULY 13
 AND OPERATED WITH 1 ADDITIONAL OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

 * FORT CALHOUN 1 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
 STATE.....NEBRASKA
 COUNTY.....WASHINGTON
 DIST AND DIRECTION FROM
 NEAREST POPULATION CTR...19 MI N OF
 OMAHA, NEB
 TYPE OF REACTOR.....PWR
 DATE INITIAL CRITICALITY...AUGUST 6, 1973
 DATE ELEC ENER 1ST GENER...AUGUST 25, 1973
 DATE COMMERCIAL OPERATE...JUNE 20, 1974
 CONDENSER COOLING METHOD...ONCE THRU
 CONDENSER COOLING WATER...MISSOURI RIVER
 ELECTRIC RELIABILITY
 COUNCIL.....MID-CONTINENT AREA
 RELIABILITY COORDINATION
 AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
 LICENSEE.....OMAHA PUBLIC POWER DISTRICT
 CORPORATE ADDRESS.....1623 HARNEY STREET
 OMAHA,, NEBRASKA 68102
 CONTRACTOR
 ARCHITECT/ENGINEER.....GIBBS, HILL, DURHAM & RICHARDSON
 NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
 CONSTRUCTOR.....GIBBS, HILL, DURHAM & RICHARDSON
 TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
 IE RESIDENT INSPECTOR.....L. YANDELL
 LICENSING PROJ MANAGER.....E. TOURIGNY
 DOCKET NUMBER.....50-285
 LICENSE & DATE ISSUANCE...DPR-40, AUGUST 9, 1973
 PUBLIC DOCUMENT ROOM.....W. DALE CLARK LIBRARY
 215 S. 15TH STREET
 OMAHA, NEBRASKA 68102

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED JUNE 1-30, 1984 (84-14): ROUTINE, ANNOUNCED INSPECTION OF OPERATIONAL SAFETY VERIFICATION, SURVEILLANCE TESTING, MAINTENANCE ACTIVITIES, FOLLOWUP OF NUREG 0737 (TMI) ITEMS, AND FOLLOWUP OF STEAM GENERATOR TUBE FAILURE INCIDENT. WITHIN THE FIVE AREAS INSPECTED, NO VIOLA-TIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED JUNE 23-27, 1984 (84-15): ROUTINE, UNANNOUNCED INSPECTION OF RECEIPT, STORAGE, AND HANDLING PROGRAM. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED (FAILURE TO FOLLOW PROCEDURES-INSPECTION OF MATERIAL RECEIVED).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

1. Docket: 50-267 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: C. H. FULLER (303) 785-2224

4. Licensed Thermal Power (MWt): 842

5. Nameplate Rating (Gross MWe): 403 X 0.85 = 343

6. Design Electrical Rating (Net MWe): 330

7. Maximum Dependable Capacity (Gross MWe): 342

8. Maximum Dependable Capacity (Net MWe): 330

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): 280

11. Reasons for Restrictions, If Any: _____
PENDING COMPLETION OF THE B-0 STARTUP TESTING.

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>44,592.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>1,324.1</u>	<u>27,151.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>660.1</u>	<u>18,463.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>340,047</u>	<u>9,709,799</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>95,438</u>	<u>3,248,888</u>
19. Net Elec Ener (MWH)	<u>-3,637</u>	<u>70,655</u>	<u>2,942,185</u>
20. Unit Service Factor	<u>.0</u>	<u>12.9</u>	<u>41.4</u>
21. Unit Avail Factor	<u>.0</u>	<u>12.9</u>	<u>41.4</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>4.2</u>	<u>20.0</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>4.2</u>	<u>20.0</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>59.7</u>	<u>40.7</u>
25. Forced Outage Hours	<u>744.0</u>	<u>979.5</u>	<u>12,656.5</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
CONTROL ROD INVESTIGATION: 8/1/84 THROUGH 11/1/84

27. If Currently Shutdown Estimated Startup Date: 11/01/84

* FORT ST VRAIN *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FORT ST VRAIN



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* FORT ST VRAIN *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-006	07/01/84	F	744.0	A	9		AA	JC	CONTROL ROD DRIVE INVESTIGATION CONTINUES.

* SUMMARY *

FORT ST VRAIN REMAINS OFFLINE FOR MAINTENANCE REPAIRS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* FORT ST VRAIN *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....COLORADO

COUNTY.....WELD

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...35 MI N OF
DENVER, COL

TYPE OF REACTOR.....HTGR

DATE INITIAL CRITICALITY...JANUARY 31, 1974

DATE ELEC ENER 1ST GENER...DECEMBER 11, 1976

DATE COMMERCIAL OPERATE....JULY 1, 1979

CONDENSER COOLING METHOD...COOLING TOWER

CONDENSER COOLING WATER....S. PLATTE RIVER

ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PUBLIC SERVICE OF COLORADO

CORPORATE ADDRESS.....P.O. BOX 840
DENVER, COLORADO 80201

CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...GENERAL ATOMIC CORP.

CONSTRUCTOR.....EBASCO

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV

IE RESIDENT INSPECTOR.....G. PLUMLEE

LICENSING PROJ MANAGER.....P. WAGNER
DOCKET NUMBER.....50-267

LICENSE & DATE ISSUANCE...DPR-34, DECEMBER 21, 1973

PUBLIC DOCUMENT ROOM.....GREELEY PUBLIC LIBRARY
CITY COMPLEX BUILDING
GREELEY, COLORADO 80631

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED APRIL 30 - MAY 4, 1984 (84-12): ROUTINE, UNANNOUNCED INSPECTION OF QUALITY ASSURANCE PROGRAM ANNUAL REVIEW, TESTS AND EXPERIMENTS PROGRAM, RECEIPT, STORAGE, AND HANDLING OF EQUIPMENT AND MATERIALS PROGRAM, RECORDS PROGRAM, DOCUMENT CONTROL PROGRAM, AND FIRE PROTECTION/PREVENTION PROGRAM IMPLEMENTATION. WITHIN THE SIX AREAS INSPECTED, TWO VIOLATIONS AND ONE DEVIATION WERE IDENTIFIED.

INSPECTION CONDUCTED APRIL 1-30, 1984, (84-13): ROUTINE/REACTIVE, ANNOUNCED INSPECTION OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, OPERATIONAL SAFETY VERIFICATION, SURVEILLANCE, SURVEILLANCE - REFUELING/MAINTENANCE, PLANT STARTUP FROM REFUELING, STARTUP TESTING - REFUELING, REVIEW OF PERIODIC AND SPECIAL REPORTS, AND IE BULLETIN FOLLOW UP. WITHIN THE EIGHT AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. FIVE OPEN ITEMS WERE IDENTIFIED.

INSPECTION CONDUCTED MAY 1-31, 1984 (84-14): ROUTINE, ANNOUNCED INSPECTION OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, OPERATIONAL SAFETY VERIFICATION, SURVEILLANCE, MAINTENANCE, PLANT STARTUP FROM REFUELING, STARTUP TESTING - REFUELING, INDEPENDENT INSPECTION, FOLLOWUP ON VIOLATIONS, REVIEW OF PERIODIC AND SPECIAL REPORTS, AND IE BULLETIN FOLLOW UP. WITHIN THE TEN AREAS INSPECTED, FIVE VIOLATIONS, ONE DEVIATION, ONE UNRESOLVED ITEM, AND FIVE OPEN ITEMS WERE IDENTIFIED.

INSPECTION CONDUCTED JUNE 4-8, 1984 (84-15): ROUTINE, UNANNOUNCED INSPECTION OF THE COLLECTION, STORAGE, AND MAINTENANCE OF QA RECORDS FOR NUCLEAR POWER PLANTS. WITHIN THE ONE AREA INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED JUNE 4-5, 1984 (84-16): SPECIAL UNANNOUNCED INSPECTION AND MEETING WITH PSC MANAGEMENT IN RESPONSE TO

Report Period JUL 1984

R E P O R T S F R O M L I C E N S E E

* FORT ST VRAIN *

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-006	5/4/84	6/26/84	OPERATORS BEGAN TO WITHDRAW CONTROL RODS TO ACHIEVE INITIAL CYCLE 4 CRITICALITY WHEN HIGH MOISTURE LEVELS IN THE PRIMARY COOLANT (HELIUM) WERE DETECTED BY THE PLANT PROTECTIVE SYSTEM MOISTURE MONITORING SYSTEM. LCO 4.4.1

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-244 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: ROBERT E. DODGE (315) 524-4446

4. Licensed Thermal Power (MWt): 1520

5. Nameplate Rating (Gross MWe): 608 X 0.85 = 517

6. Design Electrical Rating (Net MWe): 470

7. Maximum Dependable Capacity (Gross MWe): 490

8. Maximum Dependable Capacity (Net MWe): 470

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>128,687.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,175.7</u>	<u>96,775.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>56.2</u>	<u>1,687.7</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,107.3</u>	<u>94,618.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>8.5</u>
17. Gross Therm Ener (MWH)	<u>1,123,896</u>	<u>4,493,832</u>	<u>130,751,201</u>
18. Gross Elec Ener (MWH)	<u>371,297</u>	<u>1,492,902</u>	<u>42,657,273</u>
19. Net Elec Ener (MWH)	<u>353,248</u>	<u>1,418,056</u>	<u>40,444,300</u>
20. Unit Service Factor	<u>100.0</u>	<u>60.8</u>	<u>73.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>60.8</u>	<u>73.5</u>
22. Unit Cap Factor (MDC Net)	<u>101.0</u>	<u>59.0</u>	<u>68.6*</u>
23. Unit Cap Factor (DER Net)	<u>101.0</u>	<u>59.0</u>	<u>68.6*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>8.7</u>	<u>7.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>296.7</u>	<u>4,099.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

*****:*****
* GINNA *
*****:*****

AVERAGE DAILY POWER LEVEL (MWe) PLOT

GINNA



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* GINNA *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
	07/08/84	F	0.0	A	5				LOAD REDUCTION TO 79% REACTOR POWER LEVEL AT THE REQUEST OF POWER CONTROL. ON THE BULK TRANSMISSION SYSTEM, EQUIPMENT FAILURE LED TO AN OVERLOADED FACILITY WHICH COULD ONLY BE CORRECTED BY REDUCED GENERATION.

* SUMMARY *

GINNA OPERATED WITH 1 REDUCTION IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* GINNA *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....WAYNE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...15 MI NE OF
ROCHESTER, NY
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 8, 1969
DATE ELEC ENER 1ST GENER...DECEMBER 2, 1969
DATE COMMERCIAL OPERATE...JULY 1, 1970
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE ONTARIO
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ROCHESTER GAS & ELECTRIC
CORPORATE ADDRESS.....89 EAST AVENUE
ROCHESTER, NEW YORK 14604
CONTRACTOR
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....W. COOK
LICENSING PROJ MANAGER....G. DICK
DOCKET NUMBER.....50-244
LICENSE & DATE ISSUANCE...DPR-18, SEPTEMBER 19, 1969
PUBLIC DOCUMENT ROOM.....ROCHESTER PUBLIC LIBRARY
BUSINESS AND SOCIAL SCIENCE DIVISION
115 SOUTH AVENUE
ROCHESTER, NEW YORK 14604

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

1. Docket: 50-213 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: R.L. EPPINGER (203) 267-2556 X274

4. Licensed Thermal Power (MWt): 1825

5. Nameplate Rating (Gross MWe): 667 X 0.9 = 600

6. Design Electrical Rating (Net MWe): 582

7. Maximum Dependable Capacity (Gross MWe): 596

8. Maximum Dependable Capacity (Net MWe): 569

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>145,367.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,111.0</u>	<u>126,312.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,200.5</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,111.0</u>	<u>121,018.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>373.7</u>
17. Gross Therm Ener (MWH)	<u>1,086,170</u>	<u>8,856,153</u>	<u>210,228,713</u>
18. Gross Elec Ener (MWH)	<u>336,924</u>	<u>2,895,288</u>	<u>69,008,531</u>
19. Net Elec Ener (MWH)	<u>317,021</u>	<u>2,756,837</u>	<u>65,657,538</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>83.3</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>33.5</u>
22. Unit Cap Factor (MDC Net)	<u>74.9</u>	<u>94.8</u>	<u>83.1*</u>
23. Unit Cap Factor (DER Net)	<u>73.2</u>	<u>92.7</u>	<u>77.3*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>5.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>1,158.0</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING: 8-1-84, 10 WEEKS

27. If Currently Shutdown Estimated Startup Date: N/A

* HADDAM NECK *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

HADDAM NECK



JULY 1984

* Item calculated with a Weighted Average

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

 * SUMMARY *

 HADDAM NECK (CONNECTICUT YANKEE) OPERATED ROUTINELY DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* HADDAM NECK *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....CONNECTICUT
COUNTY.....MIDDLESEX
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...13 MI E OF
MERIDEN, CONN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JULY 24, 1967
DATE ELEC ENER 1ST GENER...AUGUST 7, 1967
DATE COMMERCIAL OPERATE....JANUARY 1, 1968
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CONNECTICUT RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CONNECTICUT YANKEE ATOMIC POWER
CORPORATE ADDRESS.....P.O. BOX 270
HARTFORD, CONNECTICUT 06101
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....P. SWETLAND
LICENSING PROJ MANAGER.....J. LYONS
DOCKET NUMBER.....50-213
LICENSE & DATE ISSUANCE....DPR-61, DECEMBER 27, 1974
PUBLIC DOCUMENT ROOM.....RUSSELL LIBRARY
119 BROAD STREET
MIDDLETOWN, CONNECTICUT 06457

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

FAILURE TO CONTROL AND CALIBRATE, HALON STORAGE BOTTLE AND REFUELING CAVITY LEVEL GAUGES IN ACCORDANCE WITH 10 CFR 50, APPENDIX B AND ANSI N18.7, 1976.

(8403 5)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

1. Docket: 50-321 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: P. J. NORTH (912) 367-7851

4. Licensed Thermal Power (MWt): 2436

5. Nameplate Rating (Gross MWe): 1000 X 0.85 = 850

6. Design Electrical Rating (Net MWe): 777

7. Maximum Dependable Capacity (Gross MWe): 801

8. Maximum Dependable Capacity (Net MWe): 752

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>75,239.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,261.7</u>	<u>53,767.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,131.3</u>	<u>50,524.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,641,541</u>	<u>9,316,409</u>	<u>106,451,524</u>
18. Gross Elec Ener (MWH)	<u>539,410</u>	<u>2,963,540</u>	<u>34,412,520</u>
19. Net Elec Ener (MWH)	<u>514,488</u>	<u>2,820,968</u>	<u>32,671,459</u>
20. Unit Service Factor	<u>100.0</u>	<u>80.8</u>	<u>67.2</u>
21. Unit Avail Factor	<u>100.0</u>	<u>80.8</u>	<u>67.2</u>
22. Unit Cap Factor (MDC Net)	<u>92.0</u>	<u>73.4</u>	<u>57.7</u>
23. Unit Cap Factor (DER Net)	<u>89.0</u>	<u>71.0</u>	<u>55.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>17.8</u>	<u>16.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>895.1</u>	<u>9,505.0</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
REFUELING: 10-1-84, 10 WEEK DURATION

27. If Currently Shutdown Estimated Startup Date: N/A

* HATCH 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
HATCH 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * HATCH 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-49	07/01/84	F	0.0	A	5		HA	TURBIN	13TH STAGE BUCKETS WERE DAMAGED AND OUT FOR THE DURATION OF JULY.
84-50	07/08/84	S	0.0	B	5		HA	TURBIN	LOAD REDUCTION FOR WEEKLY TURBINE TESTING.
84-51	07/11/84	F	0.0	A	5		HF	PUMPXX	LOAD REDUCTION TO INVESTIGATE PROBLEMS WITH 1A CIRC WATER PUMP.
84-52	07/12/84	S	0.0	H	5		IB	INSTRU	POWER INCREASE DISCONTINUED TO ADJUST APRM GAINS.
84-53	07/12/84	S	0.0	H	5		IF	INSTRU	POWER INCREASE DISCONTINUED FOR P-1 RUN.
84-54	07/13/84	S	0.0	B	5		HA	TURBIN	LOAD REDUCTION FOR WEEKLY TURBINE TESTING AND ROD PATTERN ADJUSTMENT.
84-55	07/14/84	S	0.0	H	5		RB	CONROD	ROD PATTERN ADJUSTMENT.
84-56	07/20/84	F	0.0	A	5		HF	HTEXCH	POWER REDUCTION TO COMPENSATE FOR 6 FANS TRIPPED ON "C" COOLING TOWER, 3 FANS TRIPPED ON "B" COOLING TOWER.
84-57	07/28/84	S	0.0	B	5		HA	TURBIN	LOAD REDUCTION FOR WEEKLY TURBINE TESTING.
84-58	07/28/84	S	0.0	B	5		RB	CONROD	LOAD REDUCTION FOR CONTROL ROD EXERCISE.

***** HATCH 1 OPERATED WITH NUMEROUS REDUCTIONS LISTED IN DETAIL ABOVE.
 * SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

* HATCH 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....GEORGIA
COUNTY.....APPLING
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI N OF
BAXLEY, GA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...SEPTEMBER 12, 1974
DATE ELEC ENER 1ST GENER...NOVEMBER 11, 1974
DATE COMMERCIAL OPERATE...DECEMBER 31, 1975
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...ALTAMAHA RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....GEORGIA POWER
CORPORATE ADDRESS.....333 PIEDMONT AVENUE
ATLANTA, GEORGIA 30308
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....GEORGIA POWER CO.
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....R. CRLENJAK
LICENSING PROJ MANAGER....G. RIVENBARK
DOCKET NUMBER.....50-321
LICENSE & DATE ISSUANCE...DPR-57, OCTOBER 13, 1974
PUBLIC DOCUMENT ROOM.....APPLING COUNTY PUBLIC LIBRARY
301 CITY HALL DRIVE
BAXLEY, GEORGIA 31563

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JUNE 21 - JULY 20 (84-24): THIS INSPECTION INVOLVED 84 INSPECTOR-HOURS ON SITE IN THE AREAS OF TECHNICAL SPECIFICATION COMPLIANCE, OPERATOR PERFORMANCE, OVERALL PLANT OPERATIONS, QUALITY ASSURANCE PRACTICES, STATION AND CORPORATE MANAGEMENT PRACTICES, CORRECTIVE AND PREVENTIVE MAINTENANCE ACTIVITIES, SITE SECURITY PROCEDURES, RADIATION CONTROL ACTIVITIES, AND SURVEILLANCE ACTIVITIES. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 16-20 (84-26): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 34 INSPECTOR-HOURS ON SITE IN THE AREAS OF REVIEW OF TEST PROCEDURE NO. HNP-2-10183, INTEGRATED ECCS TEST II, REVIEW OF TEST PROCEDURE FOR THE ROD BLOCK MONITORING SYSTEM ARTS MODIFICATION FOR DCR 84-105, VERIFICATION OF AS-BUILTS, INDEPENDENT INSPECTION, REVIEW OF THE SNUBBER SURVEILLANCE PROGRAM, AND PLANT TOUR. OF THE FIVE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. INSPECTION JULY 16-20 (84-28): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 16 INSPECTOR-HOURS ON SITE IN THE AREAS OF RADIATION PROTECTION TRAINING, INTERNAL EXPOSURE, EXTERNAL EXPOSURE FOR RECIRCULATION PIPING REPLACEMENT, SOLID WASTE, TRANSPORTATION, LIQUID AND GASEOUS WASTES. ONE VIOLATION WAS IDENTIFIED - FAILURE TO POST A RADIATION AREA.

ENFORCEMENT SUMMARY

FAILURE TO CONTROL ACCESS TO THE PROTECTED AREA. FAILURE TO CONTROL ACCESS TO THE PROTECTED AREA.
(8418 3)

1. Docket: 50-366 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: P. J. NORTH (912) 367-7851

4. Licensed Thermal Power (MWt): 2436

5. Nameplate Rating (Gross MWe): 1000 X 0.85 = 850

6. Design Electrical Rating (Net MWe): 784

7. Maximum Dependable Capacity (Gross MWe): 804

8. Maximum Dependable Capacity (Net MWe): 748

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>43,008.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>308.2</u>	<u>27,547.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>308.2</u>	<u>26,241.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>726,912</u>	<u>56,293,208</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>242,640</u>	<u>18,547,990</u>
19. Net Elec Ener (MWH)	<u>-3,414</u>	<u>218,343</u>	<u>17,636,585</u>
20. Unit Service Factor	<u>.0</u>	<u>6.0</u>	<u>61.0</u>
21. Unit Avail Factor	<u>.0</u>	<u>6.0</u>	<u>61.0</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>5.7</u>	<u>54.8</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>5.4</u>	<u>52.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>11.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>3,425.8</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 08/19/84

* HATCH 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
HATCH 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* HATCH 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-5	01/13/84	S	744.0	H	4		CB	PIPEXX	RECIRC PIPE REPLACEMENT OUTAGE CONTINUES.

***** NONE
* SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* HATCH 2 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....GEORGIA
COUNTY.....APPLING
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI N OF
BAXLEY, GA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JULY 4, 1978
DATE ELEC ENER 1ST GENER...SEPTEMBER 22, 1978
DATE COMMERCIAL OPERATE...SEPTEMBER 5, 1979
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...ALTAMAHA RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....GEORGIA POWER
CORPORATE ADDRESS.....333 PIEDMONT AVENUE
ATLANTA, GEORGIA 30308
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....GEORGIA POWER CO.
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....R. CRLENJAK
LICENSING PROJ MANAGER.....G. RIVENBARK
DOCKET NUMBER.....50-366
LICENSE & DATE ISSUANCE...NPF-5, JUNE 13, 1978
PUBLIC DOCUMENT ROOM.....APPLING COUNTY PUELIC LIBRARY
301 CITY HALL DRIVE
BAXLEY, GEORGIA 31563

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JUNE 21 - JULY 20 (84-24): THIS INSPECTION INVOLVED 83 INSPECTOR-HOURS ON SITE IN THE AREAS OF TECHNICAL SPECIFICATION COMPLIANCE, OPERATOR PERFORMANCE, OVERALL PLANT OPERATIONS, QUALITY ASSURANCE PRACTICES, STATION AND CORPORATE MANAGEMENT PRACTICES, CORRECTIVE AND PREVENTIVE MAINTENANCE ACTIVITIES, SITE SECURITY PROCEDURES, RADIATION CONTROL ACTIVITIES, AND SURVEILLANCE ACTIVITIES. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 16-20 (84-26): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED K34 INSPECTOR-HOURS ON SITE IN THE AREAS OF REVIEW OF TEST PROCEDURE NO. HNP-2-10183, INTEGRATED ECCS TEST II, REVIEW OF TEST PROCEDURE FOR THE ROD BLOCK MONITORING SYSTEM ARTS MODIFICATION FOR DCR 84-105, VERIFICATION OF AS-BUILTS, INDEPENDENT INSPECTION, REVIEW OF THE SNUBBER SURVEILLANCE PROGRAM, AND PLANT TOUR. OF THE FIVE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. INSPECTION JULY 16-20 (84-28): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 16 INSPECTOR-HOURS ON SITE IN THE AREAS OF RADIATION PROTECTION TRAINING, INTERNAL EXPOSURE, EXTERNAL EXPOSURE FOR RECIRCULATION PIPING REPLACEMENT, SOLID WASTE, TRANSPORTATION, LIQUID AND GASEOUS WASTES. ONE VIOLATION WAS IDENTIFIED - FAILURE TO POST A RADIATION AREA.

ENFORCEMENT SUMMARY

NONE

1. Docket: 50-247 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: E. EICH (914) 694-6000 @ I.P.

4. Licensed Thermal Power (MWt): 2758

5. Nameplate Rating (Gross MWe): 1126 X 0.9 = 1013

6. Design Electrical Rating (Net MWe): 873

7. Maximum Dependable Capacity (Gross MWe): 885

8. Maximum Dependable Capacity (Net MWe): 849

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>88,416.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>3,228.6</u>	<u>59,176.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,119.1</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>3,204.7</u>	<u>57,400.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>8,228,228</u>	<u>149,268,727</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>2,579,530</u>	<u>46,237,106</u>
19. Net Elec Ener (MWH)	<u>-1,459</u>	<u>1,867,570</u>	<u>43,494,662</u>
20. Unit Service Factor	<u>.0</u>	<u>62.7</u>	<u>64.9</u>
21. Unit Avail Factor	<u>.0</u>	<u>62.7</u>	<u>64.9</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>42.7</u>	<u>58.0*</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>41.9</u>	<u>56.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>12.7</u>	<u>9.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>466.5</u>	<u>5,842.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 09/15/84

* INDIAN POINT 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

INDIAN POINT 2



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * INDIAN POINT 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
4	06/02/84	S	744.0	C	4		RC	FUELXX	CYCLE 6/7 REFUELING OUTAGE CONTINUED FROM JUNE.

***** INDIAN POINT 2 REMAINS OFFLINE IN A CONTINUING REFUELING OUTAGE.
 * SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* INDIAN POINT 2 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....WESTCHESTER
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI N OF
NEW YORK CITY, NY
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 22, 1973
DATE ELEC ENER 1ST GENER...JUNE 26, 1973
DATE COMMERCIAL OPERATE...AUGUST 1, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...HUDSON RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CONSOLIDATED EDISON
CORPORATE ADDRESS.....4 IRVING PLACE
NEW YORK, NEW YORK 10003
CONTRACTOR
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....WESTINGHOUSE DEVELOPMENT CORP
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....P. KOLTAY
LICENSING PROJ MANAGER.....P. POLK
DOCKET NUMBER.....50-247
LICENSE & DATE ISSUANCE...DPR-26, SEPTEMBER 28, 1973
PUBLIC DOCUMENT ROOM.....WHITE PLAINS PUBLIC LIBRARY
100 MARTINE AVENUE
WHITE PLAINS, NEW YORK 10601

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

FAILURE TO TAKE CORRECTIVE ACTION TO PRECLUDE THE RECURRENCE OF NONCONFORMANCES IN THE AREA OF STORAGE AND HANDLING OF SAFETY RELATED COMPONENTS.
(8403 5)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

1. Docket: 50-286 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: L. KELLY (914) 739-8200

4. Licensed Thermal Power (MWt): 3025

5. Nameplate Rating (Gross MWe): 1126 X 0.9 = 1013

6. Design Electrical Rating (Net MWe): 965

7. Maximum Dependable Capacity (Gross MWe): 1000

8. Maximum Dependable Capacity (Net MWe): 965

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>69,432.0</u>
13. Hours Reactor Critical	<u>724.9</u>	<u>4,360.8</u>	<u>38,785.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>719.7</u>	<u>4,222.4</u>	<u>37,364.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,157,237</u>	<u>12,049,933</u>	<u>96,419,769</u>
18. Gross Elec Ener (MWH)	<u>699,090</u>	<u>3,942,525</u>	<u>30,309,136</u>
19. Net Elec Ener (MWH)	<u>673,567</u>	<u>3,794,888</u>	<u>29,039,066</u>
20. Unit Service Factor	<u>96.7</u>	<u>82.6</u>	<u>53.8</u>
21. Unit Avail Factor	<u>96.7</u>	<u>82.6</u>	<u>53.8</u>
22. Unit Cap Factor (MDC Net)	<u>93.8</u>	<u>76.9</u>	<u>43.3</u>
23. Unit Cap Factor (DER Net)	<u>93.8</u>	<u>76.9</u>	<u>43.3</u>
24. Unit Forced Outage Rate	<u>3.3</u>	<u>16.7</u>	<u>22.9</u>
25. Forced Outage Hours	<u>24.3</u>	<u>848.1</u>	<u>11,044.9</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
STEAM GENERATOR INSPECTION - 10/16/84 - 4 WEEKS

27. If Currently Shutdown Estimated Startup Date: N/A

* INDIAN POINT 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

INDIAN POINT 3



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* INDIAN POINT 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
09	07/12/84	F	24.3	A	3	84-011-00	EB	TRANSF	UNIT TRIP DUE TO BROKEN INSULATOR WHICH CAUSED THE 345 KV FEEDER W96 TO FAULT TO GROUND.

* SUMMARY *

INDIAN POINT 3 OPERATED WITH 1 OUTAGE DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

* INDIAN POINT 3 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....WESTCHESTER
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI N OF
NEW YORK CITY, NY
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 6, 1976
DATE ELEC ENER 1ST GENER...APRIL 27, 1976
DATE COMMERCIAL OPERATE...AUGUST 30, 1976
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...HUDSON RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....POWER AUTHORITY OF STATE OF N.Y.
CORPORATE ADDRESS.....10 COLUMBUS CIRCLE
NEW YORK, NEW YORK 10019
CONTRACTOR
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....WESTINGHOUSE DEVELOPMENT CORP
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. KENNY
LICENSING PROJ MANAGER.....P. POLK
DOCKET NUMBER.....50-286
LICENSE & DATE ISSUANCE....DPR-64, APRIL 5, 1976
PUBLIC DOCUMENT ROOM.....WHITE PLAINS PUBLIC LIBRARY
100 MARTINE AVENUE
WHITE PLAINS, NEW YORK 10601

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

1. Docket: 50-305 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: G.RUITER (414) 388-2560 X207

4. Licensed Thermal Power (MWt): 1650

5. Nameplate Rating (Gross MWe): 622 X 0.9 = 560

6. Design Electrical Rating (Net MWe): 535

7. Maximum Dependable Capacity (Gross MWe): 529

8. Maximum Dependable Capacity (Net MWe): 503

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>88,776.0</u>
13. Hours Reactor Critical	<u>739.8</u>	<u>3,897.5</u>	<u>75,077.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,330.5</u>
15. Hrs Generator On-Line	<u>736.6</u>	<u>3,855.4</u>	<u>73,667.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>10.0</u>
17. Gross Therm Ener (MWH)	<u>1,199,335</u>	<u>6,079,531</u>	<u>115,050,617</u>
18. Gross Elec Ener (MWH)	<u>398,400</u>	<u>2,007,400</u>	<u>37,865,500</u>
19. Net Elec Ener (MWH)	<u>379,308</u>	<u>1,911,913</u>	<u>36,043,949</u>
20. Unit Service Factor	<u>99.0</u>	<u>75.4</u>	<u>83.0</u>
21. Unit Avail Factor	<u>99.0</u>	<u>75.4</u>	<u>83.0</u>
22. Unit Cap Factor (MDC Net)	<u>101.4</u>	<u>74.4</u>	<u>78.1*</u>
23. Unit Cap Factor (DER Net)	<u>95.3</u>	<u>69.9</u>	<u>75.9</u>
24. Unit Forced Outage Rate	<u>1.0</u>	<u>.4</u>	<u>3.7</u>
25. Forced Outage Hours	<u>7.4</u>	<u>15.7</u>	<u>2,745.4</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* KEWAUNEE *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

KEWAUNEE



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* KEWAUNEE *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	07/03/84	F	7.4	A	3	84-14	ED	INSTRU	AN INSTRUMENT BUS INVERTER FAILED CAUSING LOW VOLTAGE ON ONE INSTRUMENT BUS; THIS RESULTED IN A REACTOR /TURBINE TRIP ON LOW STEAM GENERATOR LEVEL COINCIDENT WITH FEED FLOW / STEAM FLOW MISMATCH.

* SUMMARY *

KEWAUNEE OPERATED WITH 1 OUTAGE FOR EQUIPMENT FAILURE DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* Kewaunee *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....WISCONSIN
COUNTY.....KEWAUNEE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...27 MI E OF
GREEN BAY, WI.
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MARCH 7, 1974
DATE ELEC ENER 1ST GENER...APRIL 8, 1974
DATE COMMERCIAL OPERATE...JUNE 16, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....WISCONSIN PUBLIC SERVICE
CORPORATE ADDRESS.....P.O. BOX 19002
GREEN BAY, WISCONSIN 54307
CONTRACTOR
ARCHITECT/ENGINEER.....PIONEER SERVICES & ENGINEERING
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....PIONEER SERVICES & ENGINEERING
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....R. NELSON
LICENSING PROJ MANAGER.....M. FAIRTILE
DOCKET NUMBER.....50-305
LICENSE & DATE ISSUANCE...DPR-43, DECEMBER 21, 1973
PUBLIC DOCUMENT ROOM.....UNIVERSITY OF WISCONSIN
LIBRARY LEARNING CENTER
2420 NICOLET DRIVE
GREEN BAY, WISCONSIN 54301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON APRIL 16 - JUNE 15, (84-04): ROUTINE, UNANNOUNCED INSPECTION BY RESIDENT INSPECTOR OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; INDEPENDENT INSPECTION; IE BULLETINS; PLANT STARTUP AND REFUELING TYPE B&C LEAK RATE TESTING; TMI-2 ITEMS; AND RESPONSE TO REGIONAL REQUESTS. THE INSPECTION INVOLVED A TOTAL OF 135 INSPECTOR HOURS BY ONE INSPECTOR INCLUDING 26 INSPECTOR HOURS ONSITE DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON MAY 7-11, (84-06): INCLUDED A REVIEW OF SITE ORGANIZATION, SECURITY PLAN AND IMPLEMENTING PROCEDURES; SECURITY ORGANIZATION - MANAGEMENT, PERSONNEL AND RESPONSE; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL, PACKAGES, AND VEHICLES; DETECTION AIDS - PROTECTED AND VITAL AREAS; AND ALARM STATIONS AND COMMUNICATIONS. THE INSPECTION INVOLVED 74 INSPECTOR-HOURS BY TWO NRC INSPECTORS. TWENTY OF THE 74 INSPECTOR-HOURS WERE ACCOMPLISHED DURING OFFSHIFT PERIODS. THIS INSPECTION BEGAN DURING AN OFF-SHIFT PERIOD. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED DURING THE INSPECTION EXCEPT FOR THE FOLLOWING ITEMS: PHYSICAL BARRIERS - VITAL AREAS: A PORTION OF THE VITAL AREA BARRIER WAS INADEQUATE. ACCESS CONTROL - PACKAGES: SOME PACKAGES WERE INADEQUATELY SEARCHED. IN ADDITION, TWO WEAKNESSES IN THE LICENSEE'S SECURITY PROGRAM WERE IDENTIFIED.

1. Docket: 50-409 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: G. R. GADOW (608) 689-2331

4. Licensed Thermal Power (MWt): 165

5. Nameplate Rating (Gross MWe): 76.8 X 0.85 = 65

6. Design Electrical Rating (Net MWe): 50

7. Maximum Dependable Capacity (Gross MWe): 50

8. Maximum Dependable Capacity (Net MWe): 48

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>129,290.0</u>
13. Hours Reactor Critical	<u>423.4</u>	<u>4,214.8</u>	<u>84,959.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>478.0</u>
15. Hrs Generator On-Line	<u>368.9</u>	<u>3,962.2</u>	<u>78,798.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>79.0</u>
17. Gross Therm Ener (MWH)	<u>55,886</u>	<u>598,209</u>	<u>10,880,513</u>
18. Gross Elec Ener (MWH)	<u>17,258</u>	<u>190,204</u>	<u>3,247,432</u>
19. Net Elec Ener (MWH)	<u>15,882</u>	<u>179,072</u>	<u>3,006,307</u>
20. Unit Service Factor	<u>49.6</u>	<u>77.5</u>	<u>60.9</u>
21. Unit Avail Factor	<u>49.6</u>	<u>77.5</u>	<u>61.0</u>
22. Unit Cap Factor (MDC Net)	<u>44.5</u>	<u>73.0</u>	<u>48.4</u>
23. Unit Cap Factor (DER Net)	<u>42.7</u>	<u>70.1</u>	<u>46.5</u>
24. Unit Forced Outage Rate	<u>50.4</u>	<u>19.2</u>	<u>10.0</u>
25. Forced Outage Hours	<u>375.1</u>	<u>942.6</u>	<u>7,785.9</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


REFUELING, NOVEMBER 1, 1984, 6 WEEKS

27. If Currently Shutdown Estimated Startup Date: N/A

* LA CROSSE *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

LA CROSSE



JULY 1984

Report F od JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * LA CROSSE *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-05	07/14/84	F	23.8	A	1		WB	VALVEX	SEAL INJECT FLOW TO THE CONTROL ROD DRIVE MECHANISMS DECREASED AND THE FLOW CONTROL VALVE DID NOT CONTROL FLOW. THE REACTOR WAS SHUTDOWN IN ORDER TO ISOLATE AND FLUSH THE CRD SEAL INJECTION HEADER. THIS ACTION RESTORED FLOW CONTROL.
84-06	07/16/84	F	351.3	A	1	84-010	RB	CRDRVE	THE REACTOR WAS MANUALLY SHUTDOWN TO PERFORM MAINTENANCE ON CONTROL ROD DRIVE MECHANISM NO. 13, WHICH WOULD NOT WITHDRAW BEYOND 44 INCHES. DURING THE SHUTDOWN, ROD 29 WOULD NOT INSERT. MAINTENANCE AND INSPECTIONS WERE PERFORMED ON SEVERAL CRDM'S DURING THE SHUTDOWN.

 * SUMMARY *

 LA CROSSE OPERATED WITH 2 OUTAGES DUE TO EQUIPMENT FAILURE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* LA CROSSE *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....WISCONSIN
COUNTY.....VERNON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...19 MI S OF
LACROSSE, WISC
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JULY 11, 1967
DATE ELEC ENER 1ST GENER...APRIL 26, 1968
DATE COMMERCIAL OPERATE...NOVEMBER 1, 1969
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DAIRYLAND POWER
CORPORATE ADDRESS.....2615 EAST AVENUE SOUTH
LACROSSE, WISCONSIN 54601
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...ALLIS-CHALMERS
CONSTRUCTOR.....MAXON CONSTRUCTION COMPANY
TURBINE SUPPLIER.....ALLIS-CHALMERS

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. WIEBE
LICENSING PROJ MANAGER....R. DUDLEY
DOCKET NUMBER.....50-409
LICENSE & DATE ISSUANCE...DPR-45, AUGUST 28, 1973
PUBLIC DOCUMENT ROOM.....LA CROSSE PUBLIC LIBRARY
800 MAIN STREET
LA CROSSE, WISCONSIN 54601

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 18-19, (84-06): ROUTINE, ANNOUNCED INSPECTION OF THE LACROSSE BOILING WATER REACTOR EMERGENCY PREPAREDNESS EXERCISE INVOLVING OBSERVATION BY SIX NRC REPRESENTATIVES OF KEY FUNCTIONS AND LOCATIONS DURING THE EXERCISE; AND LICENSEE ACTIONS ON PREVIOUSLY IDENTIFIED EXERCISE WEAKNESSES. THE INSPECTION INVOLVED 56 INSPECTOR HOURS ONSITE BY THREE NRC INSPECTORS AND THREE CONSULTANTS. ALTHOUGH NO ITEMS OF NONCOMPLIANCE, DEFICIENCIES OR DEVIATIONS WERE IDENTIFIED, THREE EXERCISE WEAKNESSES WERE IDENTIFIED.

INSPECTION ON MAY 12 THROUGH JUNE 18, (84-14; 84-18): ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY RESIDENT INSPECTORS OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MONTHLY MAINTENANCE; MONTHLY SURVEILLANCE; STARTUP TESTING WITNESSING;

ENFORCEMENT SUMMARY

10 CFR PART 50.54(Q) STATES IN PART: "A LICENSEE AUTHORIZED TO POSSESS AND/OR OPERATE A NUCLEAR POWER REACTOR SHALL FOLLOW AND MAINTAIN IN EFFECT EMERGENCY PLANS WHICH MEET THE STANDARDS IN 50.47(B) OF THIS PART AND THE REQUIREMENTS IN APPENDIX E TO THIS PART. 10 CFR PART 50.47(B)(7) STATES IN PART: "INFORMATION IS MADE AVAILABLE TO THE PUBLIC ON A PERIODIC BASIS.... 10 CFR PART 50, APPENDIX E, PARAGRAPH IV.D.2 STATES IN PART: "SIGNS OR OTHER MEASURES SHALL ALSO BE USED TO DISSEMINATE TO ANY TRANSIENT POPULATION WITHIN THE PLUME EXPOSURE PATHWAY EPZ APPROPRIATE INFORMATION THAT WOULD BE HELPFUL IF AN ACCIDENT OCCURS. SECTION

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* LA CROSSE *

OTHER ITEMS

INSPECTION REPORT NO: 84-10

R E P O R T S F R O M L I C E N S E E

```
=====
```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-07	05/29/84	06/27/84	REACTOR SCRAM DUE TO HI POWER/RECIRC. FLOW SIGNAL.
84-08	06/09/84	07/05/84	EMERG. SERVICE WATER SUPPLY SYSTEM SUCTION HOSE HYDRO FAILURE.
84-09	06/11/84	07/10/84	LACK OF HOURLY FIRE PATROL WHILE FIRE DOOR WAS OPEN.

```
=====
```

THIS PAGE INTENTIONALLY LEFT BLANK

1. Locket: 50-373 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: DIANA L. LIN (815) 357-6761 X481

4. Licensed Thermal Power (MWt): 3323

5. Nameplate Rating (Gross MWe): 1078

6. Design Electrical Rating (Net MWe): 1078

7. Maximum Dependable Capacity (Gross MWe): 1078

8. Maximum Dependable Capacity (Net MWe): 1078

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>5,111.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,001.8</u>	<u>4,001.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>1,076.3</u>	<u>1,076.3</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,841.7</u>	<u>3,841.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>1.0</u>	<u>1.0</u>
17. Gross Therm Ener (MWH)	<u>2,328,797</u>	<u>17,038,940</u>	<u>17,038,940</u>
18. Gross Elec Ener (MWH)	<u>756,661</u>	<u>3,569,784</u>	<u>3,569,784</u>
19. Net Elec Ener (MWH)	<u>725,819</u>	<u>3,402,863</u>	<u>3,402,863</u>
20. Unit Service Factor	<u>100.0</u>	<u>75.2</u>	<u>75.2</u>
21. Unit Avail Factor	<u>100.0</u>	<u>75.2</u>	<u>75.2</u>
22. Unit Cap Factor (MDC Net)	<u>90.5</u>	<u>61.8</u>	<u>61.8</u>
23. Unit Cap Factor (DER Net)	<u>90.5</u>	<u>61.8</u>	<u>61.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>20.7</u>	<u>20.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>1,005.4</u>	<u>1,005.4</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


SURVEILLANCES & INSPECTIONS: 10/01/84 - 4 WEEKS

27. If Currently Shutdown Estimated Startup Date: N/A

* LASALLE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

LASALLE 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* LASALLE 1 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

***** LASALLE 1 OPERATED WITH NO OUTAGES OR REDUCTIONS DURING JULY.
* SUMMARY *

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System & Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

* LASALLE 1 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....LA SALLE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI SE OF
OTTAWA, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JUNE 21, 1982
DATE ELEC ENER 1ST GENER...SEPTEMBER 4, 1982
DATE COMMERCIAL OPERATE...JANUARY 1, 1984
CONDENSER COOLING METHOD...POND
CONDENSER COOLING WATER...RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....M. JORDAN
LICENSING PROJ MANAGER.....A. BOURNIA
DOCKET NUMBER.....50-373
LICENSE & DATE ISSUANCE...NPF-11, AUGUST 13, 1982
PUBLIC DOCUMENT ROOM.....ILLINOIS VALLEY COMMUNITY COLLEGE
RURAL ROUTE NO. 1
OGLESBY, ILLINOIS 16348

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MAY 12 THROUGH JUNE 18, (84-14): ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY RESIDENT INSPECTORS OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MONTHLY MAINTENANCE; MONTHLY SURVEILLANCE; STARTUP TESTING WITNESSING; PLANT TRIPS; FOLLOWUP ON REGIONAL REQUESTS; I.E. BULLETINS; REVIEW OF PERIODIC AND SPECIAL REPORTS, AND LICENSEE EVENT REPORTS. THE INSPECTION INVOLVED A TOTAL OF 210 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS INCLUDING 30 INSPECTOR HOURS ONSITE DURING OFF-SHIFTS. IN THE TEN AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN EIGHT AREAS. TWO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN THE REMAINING TWO AREAS (FAILURE TO CONTROL ACCESS TO HIGH RADIATION AREA; FAILURE TO FOLLOW PROCEDURES).

INSPECTION ON JUNE 18-22, (84-16): INCLUDED A REVIEW OF SECURITY PLAN AND IMPLEMENTING PROCEDURES; SECURITY ORGANIZATION - PERSONNEL; RECORDS AND REPORTS, PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; DETECTION AIDS - PROTECTED AND VITAL AREAS; AND LICENSEE CORRECTIVE ACTIONS ON PREVIOUSLY IDENTIFIED ITEMS OF NONCOMPLIANCE. THE INSPECTION INVOLVED 34 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED DURING THIS INSPECTION. ONE PREVIOUS ITEM OF NONCOMPLIANCE WAS CLOSED.

ENFORCEMENT SUMMARY

NONE

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
* LASALLE 1
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

Report Period JUL 1984 R E P O R T S F R O M L I C E N S E E - (CONTINUED)

84-41	06/28/84	07/23/84	MECHANICAL FIRE PENETRATIONS.
84-43	06/27/84	07/25/84	REACTOR WATER CLEANUP DIFFERENTIAL FLOW ISO.

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-374 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: RANDY S. DUS (815) 357-6761

4. Licensed Thermal Power (MWt): 3323

5. Nameplate Rating (Gross MWe): 1078

6. Design Electrical Rating (Net MWe): 1078

7. Maximum Dependable Capacity (Gross MWe): 1078

8. Maximum Dependable Capacity (Net MWe): 1036

9. If Changes Occur Above Since Last Report, Give Reasons: _____

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>2,453.9</u>	<u>2,453.9</u>
13. Hours Reactor Critical	<u>608.0</u>	<u>1,945.8</u>	<u>1,945.8</u>
14. Rx Reserve Shtdwn Hrs	<u>136.0</u>	<u>508.1</u>	<u>508.1</u>
15. Hrs Generator On-Line	<u>566.5</u>	<u>1,704.9</u>	<u>1,704.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,324,810</u>	<u>2,805,490</u>	<u>2,805,490</u>
18. Gross Elec Ener (MWH)	<u>400,934</u>	<u>777,450</u>	<u>777,450</u>
19. Net Elec Ener (MWH)	<u>382,416</u>	<u>730,509</u>	<u>730,509</u>
20. Unit Service Factor			
21. Unit Avail Factor		NOT IN	
22. Unit Cap Factor (MDC Net)		COMMERCIAL	
23. Unit Cap Factor (DER Net)		OPERATION	
24. Unit Forced Outage Rate			
25. Forced Outage Hours	<u>.0</u>	<u>255.5</u>	<u>255.5</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): _____


NONE

27. If Currently Shutdown Estimated Startup Date: 08/01/84

 * LASALLE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

LASALLE 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * LASALLE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
21	07/06/84	S	68.8	B	2			TURBINE/GENERATOR MANUALLY TRIPPED AND REACTOR SHUTDOWN PER STP-27-2
AUTO	07/09/84	S	33.9	B	2			UNIT SHUTDOWN TO TROUBLESHOOT PROBLEM WITH TURBINE/GENERATOR INTERCEPT VALVE.
23	07/21/84	S	0.0	H	5			POWER REDUCTION FOR FLUX SHAPING.
24	07/28/84	S	74.8	B	2			UNIT SHUTDOWN TO REPAIR STEAM LEAKS ON THE MOISTURE SEPARATOR REHEATER.

 * SUMMARY *

 LA SALLE 2 SHUTDOWN ON JULY 28TH FOR REPAIRS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* LASALLE 2 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....LA SALLE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI SE OF
OTTAWA, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MARCH 10, 1984
DATE ELEC ENER 1ST GENER...APRIL 20, 1984
DATE COMMERCIAL OPERATE...*****
CONDENSER COOLING METHOD...POND
CONDENSER COOLING WATER...RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....M. JORDAN
LICENSING PROJ MANAGER.....A. BOURNIA
DOCKET NUMBER.....50-374
LICENSE & DATE ISSUANCE...NPF-18, MARCH 23, 1984
PUBLIC DOCUMENT ROOM.....ILLINOIS VALLEY COMMUNITY COLLEGE
RURAL ROUTE NO. 1
OGLESBY, ILLINOIS 16348

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MAY 12 THROUGH JUNE 18, (84-18): ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY RESIDENT INSPECTORS OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MONTHLY MAINTENANCE; MONTHLY SURVEILLANCE; STARTUP TESTING WITNESSING; PLANT TRIPS; FOLLOWUP ON REGIONAL REQUESTS; I.E. BULLETINS; REVIEW OF PERIODIC AND SPECIAL REPORTS, AND LICENSEE EVENT REPORTS. THE INSPECTION INVOLVED A TOTAL OF 210 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS INCLUDING 30 INSPECTOR HOURS ONSITE DURING OFF-SHIFTS. IN THE TEN AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN EIGHT AREAS. TWO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN THE REMAINING TWO AREAS (FAILURE TO CONTROL ACCESS TO HIGH RADIATION AREA; FAILURE TO FOLLOW PROCEDURES).

INSPECTION ON JUNE 18-22, (84-20): INCLUDED A REVIEW OF SECURITY PLAN AND IMPLEMENTING PROCEDURES; SECURITY ORGANIZATION - PERSONNEL; RECORDS AND REPORTS, PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; DETECTION AIDS - PROTECTED AND VITAL AREAS; AND LICENSEE CORRECTIVE ACTIONS ON PREVIOUSLY IDENTIFIED ITEMS OF NONCOMPLIANCE. THE INSPECTION INVOLVED 34 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED DURING THIS INSPECTION. ONE PREVIOUS ITEM OF NONCOMPLIANCE WAS CLOSED.

INSPECTION ON JUNE 19 THROUGH 29, (84-21): ROUTINE, UNANNOUNCED INSPECTION OF STARTUP TEST RESULTS REVIEW AND FOLLOWUP OF PREVIOUSLY OPENED ITEMS. THE INSPECTION INVOLVED A TOTAL OF 79 INSPECTOR-HOURS ONSITE BY TWO INSPECTORS AND INCLUDING 11 INSPECTOR-HOURS DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JUNE 6 THROUGH 22, (84-23): SPECIAL INSPECTION BY THE RESIDENT INSPECTOR OF ACTIVITIES SURROUNDING THE BYPASSING OF
PAGE 2-52

Report Period JUL 1984

R E P O R T S F R O M L I C E N S E E

* LASALLE 2 *

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-25	06/06/84	06/21/84	REACTOR SCRAM.
84-26	06/09/84	07/02/84	RWCU HI DIFF. TEMP. PUMP ROOM AND HX ROOM ISO.
84-27	06/04/84	06/28/84	LOSS OF REACTOR WATER CLEANUP ISO. LEAK DETECTION.
84-28	06/17/84	07/05/84	REACTOR WATER CLEANUP HI AMBIENT TEMP ISO.
84-29	06/11/84	07/05/84	REACTOR WATER CLEANUP HI DIFF. FLOW ISO.
84-30	06/15/84	07/09/84	HPCS DISCHARGE RELIEF VALVE FAILURE.
84-31	06/22/84	07/16/84	REACTOR CLEANUP DIFF. TEMP. ISO.
84-32	06/26/84	07/19/84	REACTOR WATER CLEANUP ISOLATION.
84-33	06/08/84	07/23/84	FAILURE OF ISOLATION VALVE TO CLOSE.
84-34	07/03/84	07/24/84	HI RAD. AREA UNSECURED AND UNPOSTED.
84-35	07/09/84	07/24/84	SCRAM ON REACTOR VESSEL HI PRESSURE.

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-309 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: S. BIEMILLER (617) 827-8100

4. Licensed Thermal Power (MWt): 2630

5. Nameplate Rating (Gross MWe): 864

6. Design Electrical Rating (Net MWe): 825

7. Maximum Dependable Capacity (Gross MWe): 850

8. Maximum Dependable Capacity (Net MWe): 810

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>102,803.6</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,106.4</u>	<u>81,717.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>2,988.0</u>	<u>79,067.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,862,187</u>	<u>7,158,987</u>	<u>176,270,775</u>
18. Gross Elec Ener (MWH)	<u>613,180</u>	<u>2,337,420</u>	<u>57,690,570</u>
19. Net Elec Ener (MWH)	<u>592,887</u>	<u>2,254,875</u>	<u>54,956,577</u>
20. Unit Service Factor	<u>100.0</u>	<u>58.5</u>	<u>76.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>58.5</u>	<u>76.9</u>
22. Unit Cap Factor (MDC Net)	<u>98.4</u>	<u>54.5</u>	<u>68.1*</u>
23. Unit Cap Factor (DER Net)	<u>96.6</u>	<u>53.5</u>	<u>66.2*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>2.7</u>	<u>7.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>83.8</u>	<u>5,497.2</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* MAINE YANKEE *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
MAINE YANKEE



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* MAINE YANKEE *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
	07/28/84	S	0.0	B	5		HA	VALVEX	REDUCED POWER FOR ROUTINE TURBINE VALVE TESTING AND MUSSEL CONTROL.

* SUMMARY *

MAINE YANKEE OPERATED WITH 1 REDUCTION FOR TESTING
IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* MAINE YANKEE *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MAINE
COUNTY.....LINCOLN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI N OF
BATH, ME
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 23, 1972
DATE ELEC ENER 1ST GENER...NOVEMBER 8, 1972
DATE COMMERCIAL OPERATE...DECEMBER 28, 1972
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...BACK RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....MAINE YANKEE ATOMIC POWER
CORPORATE ADDRESS.....83 EDISON DRIVE
AUGUSTA, MAINE 04366
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....C. HOLDEN
LICENSING PROJ MANAGER....K. HEITNER
DOCKET NUMBER.....50-309
LICENSE & DATE ISSUANCE...DPR-36, JUNE 29, 1973
PUBLIC DOCUMENT ROOM.....WISCASSET PUBLIC LIBRARY
HIGH STREET
WISCASSET, MAINE 04578

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* MAINE YANKEE *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NO INPUT PROVIDED.			
=====			

1. Docket: 50-369 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-8552

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1305

6. Design Electrical Rating (Net MWe): 1180

7. Maximum Dependable Capacity (Gross MWe): 1225

8. Maximum Dependable Capacity (Net MWe): 1180

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>23,375.0</u>
13. Hours Reactor Critical	<u>698.3</u>	<u>3,374.7</u>	<u>15,903.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>695.4</u>	<u>3,315.4</u>	<u>15,264.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,319,518</u>	<u>10,693,268</u>	<u>38,130,337</u>
18. Gross Elec Ener (MWH)	<u>802,409</u>	<u>3,745,376</u>	<u>13,262,500</u>
19. Net Elec Ener (MWH)	<u>771,332</u>	<u>3,582,496</u>	<u>12,538,751</u>
20. Unit Service Factor	<u>93.5</u>	<u>64.9</u>	<u>65.3</u>
21. Unit Avail Factor	<u>93.5</u>	<u>64.9</u>	<u>65.3</u>
22. Unit Cap Factor (MDC Net)	<u>87.9</u>	<u>59.4</u>	<u>45.5</u>
23. Unit Cap Factor (DER Net)	<u>87.9</u>	<u>59.4</u>	<u>45.5</u>
24. Unit Forced Outage Rate	<u>6.5</u>	<u>5.0</u>	<u>17.6</u>
25. Forced Outage Hours	<u>48.6</u>	<u>174.9</u>	<u>3,260.4</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* MCGUIRE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MCGUIRE 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * MCGUIRE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
26P	07/01/84	S	0.0	F	5		ZZ	ZZZZZZ	ECONOMIC DISPATCH REDUCTION.
27P	07/02/84	S	0.0	F	5		ZZ	ZZZZZZ	ECONOMIC DISPATCH REDUCTION.
28P	07/03/84	S	0.0	F	5		ZZ	ZZZZZZ	ECONOMIC DISPATCH REDUCTION.
7	07/23/84	F	9.7	A	3		CC	VALVEX	MAIN FEEDWATER ISOLATION VALVE FAILED CLOSED.
7A	07/23/84	F	38.9	A	2		CH	VALVEX	REPAIR STEAM GENERATOR INLET CHECK VALVE DUE TO LEAKAGE.
9P	07/25/84	F	0.0	i	5		PC	ZZZZZ	SECONDARY CHEMISTRY RESTRICTIONS.
30P	07/25/84	F	0.0	H	5		RC	FUELXX	AXIAL FLUX DIFFERENCE PENALTY TIME.
31P	07/30/84	S	0.0	B	5		IB	INSTRU	INCORE & EXCORE CALIBRATIONS.

 * SUMMARY *

 MCGUIRE 1 OPERATED ROUTINELY DURING THE REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

* MCGUIRE 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NORTH CAROLINA
COUNTY.....MECKLENBURG
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI N OF
CHARLOTTE, NC
TYFF OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 8, 1981
DATE ELEC ENER 1ST GENER...SEPTEMBER 12, 1981
DATE COMMERCIAL OPERATE...DECEMBER 1, 1981
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE NORMAN
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
CHARLOTTE, NORTH CAROLINA 28242
CONTRACTOR
ARCHITECT/ENGINEER.....DUKE POWER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....W. ORDERS
LICENSING PROJ MANAGER.....R. BIRKEL
DOCKET NUMBER.....50-369
LICENSE & DATE ISSUANCE...NPF-9, JULY 8, 1981
PUBLIC DOCUMENT ROOM.....MS. DAWN HUBBS
ATKINS LIBRARY
UNIVERSITY OF NORTH CAROLINA - CHARLOTTE
UNCC STATION,
CHARLOTTE, NC 28223

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION MAY 20 - JUNE 20 (84-17): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 122 INSPECTOR-HOURS ON SITE IN THE AREAS OF OPERATIONS SAFETY VERIFICATION, SURVEILLANCE TESTING, MAINTENANCE ACTIVITIES AND OPEN ITEMS REVIEW. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.12.2 REQUIRES THAT HIGH RADIATION AREAS GREATER THAN 1000 MR/HR WHICH ARE WITHIN LARGE AREAS SUCH AS PWR CONTAINMENT, WHERE NO ENCLOSURE EXISTS FOR PURPOSES OF LOCKING SHALL BE ROPED OFF, CONSPICUOUSLY POSTED A FLASHING LIGHT SHALL BE ACTIVATED AS A WARNING DEVICE. CONTRARY TO THE ABOVE, DURING FEBRUARY-MARCH 1984 THE REQUIREMENT TO MARK HIGH RADIATION AREAS GREATER THAN 1000 MR/HR WITH A FLASHING LIGHT WHEN THE AREA IS NOT READILY LOCKED WAS NOT MET IN THAT DURING WORK ON STEAM GENERATORS B, C, AND D FOR UNIT 1 THE MANWAYS WERE NOT MARKED WITH A FLASHING LIGHT. THE RADIATION DOSE RATE AT THE STEAM GENERATOR MANWAYS AND INSIDE THE STEAM GENERATOR WERE GREATER THAN 1000 MR/HR. 10 CFR 20.201(B) REQUIRES THAT EACH LICENSEE SHALL MAKE OR CAUSE TO BE MADE SUCH SURVEYS AS MAY BE NECESSARY FOR THE LICENSEE TO COMPLY WITH THE REGULATIONS IN THIS PART. A "SURVEY" IS DEFINED IN 10 CFR 20.201(B) AS EVALUATION OF THE RADIATION HAZARDS INCIDENT TO THE PRODUCTION, USE, RELEASE, DISPOSAL, OR PRESENCE OF RADIOACTIVE MATERIALS OR OTHER SOURCES OF RADIATION UNDER A SPECIFIC SET OF CIRCUMSTANCES. 10 CFR 20.202 REQUIRES

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-370 OPERATING STATUS
 2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0
 3. Utility Contact: J. A. REAVIS EXT (704) 373-7567
 4. Licensed Thermal Power (MWt): 3411
 5. Nameplate Rating (Gross MWe): 1450 X .9 = 1305
 6. Design Electrical Rating (Net MWe): 1180
 7. Maximum Dependable Capacity (Gross MWe): 1225
 8. Maximum Dependable Capacity (Net MWe): 1180
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____
 11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>3,671.0</u>	<u>3,671.0</u>
13. Hours Reactor Critical	<u>499.4</u>	<u>3,256.3</u>	<u>3,256.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>492.9</u>	<u>3,234.3</u>	<u>3,234.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,558,900</u>	<u>10,681,629</u>	<u>10,681,629</u>
18. Gross Elec Ener (MWH)	<u>545,101</u>	<u>3,800,131</u>	<u>3,800,131</u>
19. Net Elec Ener (MWH)	<u>517,564</u>	<u>3,655,155</u>	<u>3,655,155</u>
20. Unit Service Factor	<u>66.3</u>	<u>88.1</u>	<u>88.1</u>
21. Unit Avail Factor	<u>66.3</u>	<u>88.1</u>	<u>88.1</u>
22. Unit Cap Factor (MDC Net)	<u>59.0</u>	<u>84.4</u>	<u>84.4</u>
23. Unit Cap Factor (DER Net)	<u>59.0</u>	<u>84.4</u>	<u>84.4</u>
24. Unit Forced Outage Rate	<u>33.8</u>	<u>9.8</u>	<u>9.8</u>
25. Forced Outage Hours	<u>251.1</u>	<u>350.1</u>	<u>350.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING - JANUARY, 1985 - 8 WEEKS

27. If Currently Shutdown Estimated Startup Date: 08/20/84

 * MCGUIRE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MCGUIRE 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * MCGUIRE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
32P	07/03/84	S	0.0	F	5		ZZ	ZZZZZZ	ECONOMIC DISPATCH REDUCTION.
9	07/03/84	F	0.2	G	3		CD	VALVEX	MAIN STEAM ISOLATION VALVE CLOSED DURING IAE TESTING.
9A	07/03/84	F	107.4	A	1		IB	ZZZZZZ	TROUBLESHOOT SOURCE RANGE DETECTOR.
9B	07/08/84	F	26.8	A	1		CH	VALVEX	REPAIR STEAM GENERATOR INLET CHECK VALVE
33P	07/09/84	F	0.0	H	5		ZZ	ZZZZZZ	STEAM GENERATOR CHEMISTRY PROBLEMS.
34P	07/09/84	F	0.0	A	5		CD	VALVEX	REPAIR STEAM GENERATOR CONTAINMENT ISOLATION VALVE.
35P	07/13/84	S	0.0	B	5		HA	TURBIN	TURBINE ACCEPTANCE TEST.
36P	07/15/84	S	0.0	B	5		HA	TURBIN	TURBINE ACCEPTANCE TEST.
10	07/19/84	F	21.7	A	2		HI	VALVEX	REPAIR LEAKING STEAM GENERATOR BLOWDOWN VALVE.
37P	07/20/84	F	0.0	H	5		ZZ	ZZZZZZ	STEAM GENERATOR CHEMISTRY PROBLEMS.
38P	07/21/84	S	0.0	B	5		HA	TURBIN	TURBINE ACCEPTANCE TEST.
39P	07/22/84	S	0.0	F	5		ZZ	ZZZZZZ	ECONOMIC DISPATCH REDUCTION.
40P	07/23/84	S	0.0	B	5		HA	TURBIN	TURBINE ACCEPTANCE TEST.
11	07/28/84	F	34.5	A	1		HI	VALVEX	REPAIR LEAKING STEAM GENERATOR BLOWDOWN VALVE.
11A	07/29/84	F	60.5	A	9		CI	PUMPXX	REPLACE LEAKING REACTOR COOLANT PUMP SEAL.

***** MCGUIRE 2 SHUTDOWN ON JULY 28TH FOR EQUIPMENT REPAIR.
 * SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

1. Docket: 50-245 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: GEORGE HARRAN (203) 447-1791 X4194

4. Licensed Thermal Power (MWt): 2011

5. Nameplate Rating (Gross MWe): 735 X 0.9 = 662

6. Design Electrical Rating (Net MWe): 660

7. Maximum Dependable Capacity (Gross MWe): 684

8. Maximum Dependable Capacity (Net MWe): 654

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>119,855.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,317.2</u>	<u>90,081.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,775.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,287.8</u>	<u>87,305.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>26.5</u>
17. Gross Therm Ener (MWH)	<u>1,449,646</u>	<u>6,377,696</u>	<u>159,426,564</u>
18. Gross Elec Ener (MWH)	<u>488,700</u>	<u>2,174,500</u>	<u>53,537,696</u>
19. Net Elec Ener (MWH)	<u>467,003</u>	<u>2,069,261</u>	<u>51,050,518</u>
20. Unit Service Factor	<u>100.0</u>	<u>64.3</u>	<u>72.8</u>
21. Unit Avail Factor	<u>100.0</u>	<u>64.3</u>	<u>72.9</u>
22. Unit Cap Factor (MDC Net)	<u>96.0</u>	<u>61.9</u>	<u>65.1</u>
23. Unit Cap Factor (DER Net)	<u>95.1</u>	<u>61.3</u>	<u>64.5</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>13.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>5,673.7</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * MILLSTONE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MILLSTONE 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* MILLSTONE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
3	07/21/84	S	0.0	H	5				REDUCED REACTOR POWER TO ADJUST THE CONTROL ROD PATTERN.

* SUMMARY *

MILLSTONE 1 OPERATED WITH 1 REDUCTION DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* MILLSTONE 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....CONNECTICUT
COUNTY.....NEW LONDON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI SW OF
NEW LONDON, CONN
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...OCTOBER 26, 1970
DATE ELEC ENER 1ST GENER...NOVEMBER 29, 1970
DATE COMMERCIAL OPERATE....MARCH 1, 1971
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LONG ISLAND SOUND
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHEAST NUCLEAR ENERGY
CORPORATE ADDRESS.....P.O. BOX 270
HARTFORD, CONNECTICUT 06101
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....J. SHEDLOSKY
LICENSING PROJ MANAGER.....J. SHEA
DOCKET NUMBER.....50-245
LICENSE & DATE ISSUANCE...DPR-21, OCTOBER 26, 1970
PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LI.
45 ROPE FERRY ROAD
ROUTE 156
WATERFORD, CONNECTICUT 06385

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

1. Docket: 50-336 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. GIBSON (203) 447-1791 X 4419

4. Licensed Thermal Power (MWt): 2700

5. Nameplate Rating (Gross MWe): 1011 X 0.9 = 910

6. Design Electrical Rating (Net MWe): 870

7. Maximum Dependable Capacity (Gross MWe): 895

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):


11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>75,383.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,987.9</u>	<u>53,352.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,166.9</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,685.1</u>	<u>50,867.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>468.2</u>
17. Gross Therm Ener (MWH)	<u>1,903,852</u>	<u>12,004,265</u>	<u>128,320,641</u>
18. Gross Elec Ener (MWH)	<u>604,700</u>	<u>3,874,201</u>	<u>41,671,573</u>
19. Net Elec Ener (MWH)	<u>582,230</u>	<u>3,719,788</u>	<u>39,936,536</u>
20. Unit Service Factor	<u>100.0</u>	<u>91.7</u>	<u>67.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>91.7</u>	<u>68.1</u>
22. Unit Cap Factor (MDC Net)	<u>91.0</u>	<u>84.6</u>	<u>63.0*</u>
23. Unit Cap Factor (DER Net)	<u>90.0</u>	<u>83.7</u>	<u>62.1*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>3.6</u>	<u>17.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>173.4</u>	<u>9,796.2</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>NONE</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

* MILLSTONE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MILLSTONE 2



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* MILLSTONE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	07/02/84	F	0.0	A	5		AA	ROD	WHILE AT 100% POWER AND DURING CEA POWER SUPPLY VOLTAGE MEASUREMENT, CEA DROPPED INTO CORE. POWER WAS REDUCED TO < 70% POWER AND CEA RECOVERED.

* SUMMARY *

MILLSTONE 2 OPERATED WITH 1 REDUCTION DUE TO EQUIPMENT FAILURE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-R-fueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* MILLSTONE 2 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....CONNECTICUT
COUNTY.....NEW LONDON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI SW OF
NEW LONDON, CONN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 17, 1975
DATE ELEC ENER 1ST GENER...NOVEMBER 9, 1975
DATE COMMERCIAL OPERATE...DECEMBER 26, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LONG ISLAND SOUND
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHEAST NUCLEAR ENERGY
CORPORATE ADDRESS.....P.O. BOX 270
HARTFORD, CONNECTICUT 06101
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....J. SHEDLOSKY
LICENSING PROJ MANAGER.....D. OSBORNE
DOCKET NUMBER.....50-336
LICENSE & DATE ISSUANCE...DPR-65, SEPTEMBER 30, 1975
PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LIBRARY
45 ROPE FERRY ROAD
ROUTE 156
WATERFORD, CONNECTICUT 06385

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

1. Docket: 50-263 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: A. L. Myrabo (612) 295-5151

4. Licensed Thermal Power (MWt): 1670

5. Nameplate Rating (Gross MWe): 632 X 0.9 = 569

6. Design Electrical Rating (Net MWe): 545

7. Maximum Dependable Capacity (Gross MWe): 553

8. Maximum Dependable Capacity (Net MWe): 525

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>114,720.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>810.5</u>	<u>89,915.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>940.7</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>808.8</u>	<u>88,003.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>897,898</u>	<u>141,233,814</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>296,117</u>	<u>45,185,053</u>
19. Net Elec Ener (MWH)	<u>-1,218</u>	<u>273,139</u>	<u>43,185,445</u>
20. Unit Service Factor	<u>.0</u>	<u>15.8</u>	<u>76.7</u>
21. Unit Avail Factor	<u>.0</u>	<u>15.8</u>	<u>76.7</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>10.2</u>	<u>71.7</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>9.8</u>	<u>69.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>5.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>1,288.8</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
FEBRUARY 3, 1984 - REFUELING - 286 DAYS

27. If Currently Shutdown Estimated Startup Date: 11/15/84

* MONTICELLO *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MONTICELLO



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* MONTICELLO *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
2	02/03/84	S	744.0	C	4		RC	FUELXX	CONTINUATION OF 1984 REFUELING/MAINTENANCE OUTAGE.

* SUMMARY *

MONTICELLO REMAINS SHUTDOWN IN A CONTINUING REFUELING/MAINTENANCE
OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	* License Examination	9-Other	(LER) File (NUREG-0161)

* MONTICELLO *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MINNESOTA
COUNTY.....WRIGHT
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI NW OF
MINNEAPOLIS, MINN
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...DECEMBER 10, 1970
DATE ELEC ENER 1ST GENER...MARCH 5, 1971
DATE COMMERCIAL OPERATE...JUNE 30, 1971
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHERN STATES POWER
CORPORATE ADDRESS.....414 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....C. BROWN
LICENSING PROJ MANAGER....V. ROONEY
DOCKET NUMBER.....50-263
LICENSE & DATE ISSUANCE...DPR-22, JANUARY 9, 1981
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY
MINNEAPOLIS PUBLIC LIBRARY
300 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MAY 2 - JUNE 16, (84-09): A ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTOR OF PREVIOUS INSPECTION FINDINGS; VENTILATION SYSTEM DAMPER ACTUATORS; UNISTRUT BRACKET P-2073A INSPECTION; LICENSEE EVENT REPORTS; ONSITE REVIEW COMMITTEE; AND LONG TERM SHUTDOWN. THE INSPECTION INVOLVED A TOTAL OF 143 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR INCLUDING 43 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

1. Docket: 50-220 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: THOMAS W. ROMAN (315) 349-2422

4. Licensed Thermal Power (MWt): 1850

5. Nameplate Rating (Gross MWe): 755 X 0.85 = 642

6. Design Electrical Rating (Net MWe): 620

7. Maximum Dependable Capacity (Gross MWe): 630

8. Maximum Dependable Capacity (Net MWe): 610

9. If Changes Occur Above Since Last Report, Give Reasons: _____

NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>129,287.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>2,825.0</u>	<u>89,127.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,204.2</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>2,762.5</u>	<u>86,250.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>20.2</u>
17. Gross Therm Ener (MWH)	<u>1,371,612</u>	<u>4,710,383</u>	<u>142,804,740</u>
18. Gross Elec Ener (MWH)	<u>455,246</u>	<u>1,578,644</u>	<u>47,210,426</u>
19. Net Elec Ener (MWH)	<u>441,955</u>	<u>1,530,098</u>	<u>45,724,857</u>
20. Unit Service Factor	<u>100.0</u>	<u>54.1</u>	<u>66.7</u>
21. Unit Avail Factor	<u>100.0</u>	<u>54.1</u>	<u>66.7</u>
22. Unit Cap Factor (MDC Net)	<u>97.4</u>	<u>49.1</u>	<u>58.0</u>
23. Unit Cap Factor (DER Net)	<u>95.8</u>	<u>48.3</u>	<u>57.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>16.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>12,940.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): _____


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * NINE MILE POINT 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

NINE MILE POINT 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* NINE MILE POINT 1 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

NINE MILE POINT 1 OPERATED AT FULL POWER WITH NO OUTAGES DURING THE REPORT PERIOD.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System & Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* NINE MILE POINT 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....OSWEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...8 MI NE OF
OSWEGO, NY
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...SEPTEMBER 5, 1969
DATE ELEC ENER 1ST GENER...NOVEMBER 9, 1969
DATE COMMERCIAL OPERATE...DECEMBER 1, 1969
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE ONTARIO
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NIAGARA MOHAWK POWER CORP.
CORPORATE ADDRESS.....300 ERIE BOULEVARD WEST
SYRACUSE, NEW YORK 13202
CONTRACTOR
ARCHITECT/ENGINEER.....NIAGARA MOHAWK POWER CORP.
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....S. HUDSON
LICENSING PROJ MANAGER.....R. HERMANN
DOCKET NUMBER.....50-220
LICENSE & DATE ISSUANCE...DPR-63, DECEMBER 26, 1974
PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO
PENFIELD LIBRARY - DOCUMENTS
OSWEGO, NY 13126
(315) 341-2323

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.11 REQUIRES THAT PROCEDURES FOR PERSONNEL RADIATION PROTECTION BE PREPARED AND ADHERED TO FOR ALL OPERATIONS INVOLVING PERSONNEL RADIATION EXPOSURE. RADIATION PROTECTION PROCEDURE RP-2, REVISION 2 STATES IN SECTION 5.4 THAT THE LEADMAN IS RESPONSIBLE FOR INSURING THAT THE INSTRUCTIONS ON THE RADIATION WORK PERMIT (RWP) ARE STRICTLY ADHERED TO. RADIATION WORK PERMIT NO. 4209, DATED APRIL 11, 1984 REQUIRES THAT RADIATION PROTECTION PERSONNEL SURVEY ALL ITEMS PRIOR TO REMOVAL FROM THE REACTOR VESSEL OR SPENT FUEL POOL. CONTRARY TO THE ABOVE, ON APRIL 11, 1984 AT ABOUT 2:30 P.M., THE LEADMAN FOR RWP NO. 4209 DID NOT INSURE THAT THE INSTRUCTIONS FOR THIS RWP WERE STRICTLY ADHERED TO. AT THAT TIME A TELEVISION CAMERA, LIGHTING CABLE AND LOW POWER RANGE MONITOR (LPRM) HANDLING TOOL CABLES WERE REMOVED FROM THE REACTOR VESSEL AND WERE NOT SURVEYED. RADIATION PROTECTION PROCEDURE RP-10 REQUIRES IN PART IN SECTION 7.4 THAT THE REGULATOR FOR THE SCOTT FULL FACE RESPIRATOR WITH AIRLINE BE SET A 75 (5 PSIG. CONTRARY TO THE ABOVE, ON APRIL 11, 1984, AT ABOUT 3:30 P.M., TWO INDIVIDUALS, CLEANING REACTOR STUD BOLTS, WERE USING SCOTT FULL FACE RESPIRATORS WITH AIRLINES WITH THE REGULATOR SET AT 100 PSIG.
(8405 4)

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* NINE MILE POINT 1 *

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

1. Docket: 50-338 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: JOAN N. LEE (703) 894-5151 X2527

4. Licensed Thermal Power (MWt): 2775

5. Nameplate Rating (Gross MWe): 947

6. Design Electrical Rating (Net MWe): 907

7. Maximum Dependable Capacity (Gross MWe): 937

8. Maximum Dependable Capacity (Net MWe): 890

9. If Changes Occur Above Since Last Report, Give Reasons:
CHANGES IN GROSS AND NET

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>53,952.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>2,442.3</u>	<u>36,029.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>7.1</u>	<u>2,182.8</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>2,420.0</u>	<u>35,081.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>6,596,736</u>	<u>91,652,513</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>2,238,267</u>	<u>29,622,453</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>2,126,605</u>	<u>27,957,819</u>
20. Unit Service Factor	<u>.0</u>	<u>47.3</u>	<u>65.0</u>
21. Unit Avail Factor	<u>.0</u>	<u>47.3</u>	<u>65.0</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>47.1</u>	<u>58.2</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>45.9</u>	<u>57.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>23.7</u>	<u>13.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>752.2</u>	<u>5,320.4</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
FALL MAINTENANCE, 11-23-84, SCHEDULED 10 DAYS.

27. If Currently Shutdown Estimated Startup Date: 08/17/84

 * NORTH ANNA 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

NORTH ANNA 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* NORTH ANNA 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-14	05/11/84	S	744.0	C	4				REFUELING OUTAGE CONTINUED THROUGH THE MONTH.

* SUMMARY *

NORTH ANNA 1 REMAINED SHUT DOWN FOR REFUELING THROUGHOUT JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

* NORTH ANNA 1 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....VIRGINIA
COUNTY.....LOUISA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MT NW OF
RICHMOND, VA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 5, 1978
DATE ELEC ENER 1ST GENER...APRIL 17, 1978
DATE COMMERCIAL OPERATE...JUNE 6, 1978
CONDENSER COOLING METHOD...DNCE THRU
CONDENSER COOLING WATER...LAKE ANNA
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VIRGINIA ELECTRIC & POWER
CORPORATE ADDRESS.....P.O. BOX 26666
RICHMOND, VIRGINIA 23261
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....D. JOHNSON
LICENSING PROJ MANAGER....L. ENGLE
DOCKET NUMBER.....50-338
LICENSE & DATE ISSUANCE...NPF-4, APRIL 1, 1978
PUBLIC DOCUMENT ROOM.....ALDERMAN LIBRARY/MANUSCRIPTS DEPT.
UNIV. OF VIRGINIA/CHARLOTTESVILLE VA 22901
& LOUISA COUNTY COURTHOUSE,
LOUISA, VA 23093

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 19 (84-26): THIS REACTIVE, ANNOUNCED INSPECTION INVOLVED 7.5 INSPECTOR-HOURS ON SITE IN THE AREAS OF FUEL PERFORMANCE, AND FOLLOWUP OF OUTSTANDING ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.
INSPECTION JULY 12-13 (84-28): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 7 INSPECTOR-HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

VIOLATION OF 10CFR71.5 FOR FAILURE TO INCLUDE THE PROPER SHIPPING NAME AND IDENTIFICATION NUMBER ON LSA SHIPMENTS. THE SHIPPING NAME, IDENTIFICATION NUMBER AND TRANSPORT INDEX WERE LEFT OFF SHIPMENTS OF RADIOACTIVE MATERIAL LABELED RADIOACTIVE YELLOW II.
(8421 4)
CONSTRUCTION AND MAINTENANCE PERSONNEL CREATING DEGRADATION OF A VITAL AREA BARRIER WITHOUT PRIOR NOTIFICATION TO SECURITY REFERENCE UNIT 1.
(8425 4)

1. Docket: 50-339 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: JOAN N. LEE (703) 894-5151 X2527

4. Licensed Thermal Power (MWt): 2775

5. Nameplate Rating (Gross MWe): 947

6. Design Electrical Rating (Net MWe): 907

7. Maximum Dependable Capacity (Gross MWe): 939

8. Maximum Dependable Capacity (Net MWe): 890

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____


11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>31,823.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,766.5</u>	<u>24,413.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>14.6</u>	<u>2,254.6</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,666.7</u>	<u>23,944.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,778,681</u>	<u>12,092,978</u>	<u>62,514,008</u>
18. Gross Elec Ener (MWH)	<u>591,462</u>	<u>3,986,170</u>	<u>20,722,537</u>
19. Net Elec Ener (MWH)	<u>556,397</u>	<u>3,774,242</u>	<u>19,626,324</u>
20. Unit Service Factor	<u>100.0</u>	<u>91.3</u>	<u>75.2</u>
21. Unit Avail Factor	<u>100.0</u>	<u>91.3</u>	<u>75.2</u>
22. Unit Cap Factor (MDC Net)	<u>84.0</u>	<u>83.0</u>	<u>69.3</u>
23. Unit Cap Factor (DER Net)	<u>82.5</u>	<u>81.4</u>	<u>68.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>3.1</u>	<u>13.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>148.6</u>	<u>3,596.1</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):	<u>REFUELING OUTAGE SCHEDULED 08-29-84, 52 DAYS.</u>		
27. If Currently Shutdown Estimated Startup Date:	<u>N/A</u>		

 * NORTH ANNA 2 *

 AVERAGE DAILY POWER LEVEL (MWe) PLOT

NORTH ANNA 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * NORTH ANNA 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
84-33	07/14/84	S	0.0	B	5			RAMPED DOWN FOR TURBINE VALVE FREEDOM TEST. TEST COMPLETE AND UNIT AT 860 MW - 90% POWER. CONTINUING RAMP-DOWN TO 75% POWER TO ALLOW UNIT 2 TO OPERATE DURING SUMMER PEAK FOR FUEL CONSERVATION UNTIL UNIT 1 IS RETURNED ON-LINE.

 * SUMMARY *

NORTH ANNA 2 OPERATED ROUTINELY IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* NORTH ANNA 2 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....VIRGINIA
COUNTY.....LOUISA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI NW OF
RICHMOND, VA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JUNE 12, 1980
DATE ELEC ENER 1ST GENER...AUGUST 25, 1980
DATE COMMERCIAL OPERATE...DECEMBER 14, 1980
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE ANNA
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VIRGINIA ELECTRIC & POWER
CORPORATE ADDRESS.....P.O. BOX 26666
RICHMOND, VIRGINIA 23261
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....D. JOHNSON
LICENSING PROJ MANAGER.....L. ENGLE
DOCKET NUMBER.....50-339
LICENSE & DATE ISSUANCE...NPF-7, AUGUST 21, 1980
PUBLIC DOCUMENT ROOM.....ALDERMAN LIBRARY/MANUSCRIPTS DEPT.
UNIV. OF VIRGINIA/CHARLOTTESVILLE VA 22901
& LOUISA COUNTY COURTHOUSE,
LOUISA, VA 23093

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 19 (84-26): THIS REACTIVE, ANNOUNCED INSPECTION INVOLVED 7.5 INSPECTOR-HOURS ON SITE IN THE AREAS OF FUEL PERFORMANCE, AND FOLLOWUP OF OUTSTANDING ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.
INSPECTION JULY 12-13 (84-28): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 7 INSPECTOR-HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

X NORTH ANNA 2 X

OTHER ITEMS

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

+ REFUELING.

LAST IE SITE INSPECTION DATE: JUNE 18-22, 1984 +

INSPECTION REPORT NO: 50-339/84-24 +

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NONE.			

=====

1. Docket: 50-269 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (MWt): 2568

5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934

6. Design Electrical Rating (Net MWe): 887

7. Maximum Dependable Capacity (Gross MWe): 899

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>96,816.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,086.1</u>	<u>69,627.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,078.0</u>	<u>66,467.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,911,321</u>	<u>13,000,866</u>	<u>159,298,898</u>
18. Gross Elec Ener (MWH)	<u>664,050</u>	<u>4,557,790</u>	<u>55,426,020</u>
19. Net Elec Ener (MWH)	<u>634,379</u>	<u>4,360,672</u>	<u>52,526,223</u>
20. Unit Service Factor	<u>100.0</u>	<u>99.4</u>	<u>68.7</u>
21. Unit Avail Factor	<u>100.0</u>	<u>99.4</u>	<u>68.7</u>
22. Unit Cap Factor (MDC Net)	<u>99.1</u>	<u>99.2</u>	<u>62.9*</u>
23. Unit Cap Factor (DER Net)	<u>96.1</u>	<u>96.2</u>	<u>61.2*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.6</u>	<u>16.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>33.0</u>	<u>12,080.6</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING - OCTOBER 1984 - 7 WEEKS.

27. If Currently Shutdown Estimated Startup Date: N/A

* OCONEE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
OCONEE 1



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* OCONEE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
12P	07/13/84	S	0.0	B	5		CC	VALVEX	TURBINE & CONTROL VALVE AND CONTROL ROD DRIVE PT'S.

***** OCONEE 1 OPERATED ROUTINELY IN JULY.
* SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* OCONEE 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....OCONEE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI W OF
GREENVILLE, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 19, 1973
DATE ELEC ENER 1ST GENER...MAY 6, 1973
DATE COMMERCIAL OPERATE...JULY 15, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE KEOWEE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
CHARLOTTE, NORTH CAROLINA 28242
CONTRACTOR
ARCHITECT/ENGINEER.....DUKE & BECTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. BRYANT
LICENSING PROJ MANAGER.....H. NICOLARAS
DOCKET NUMBER.....50-269
LICENSE & DATE ISSUANCE...DPR-3^c, FEBRUARY 6, 1973
PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY
501 W. SOUTH BROAD ST.
WALHALLA, SOUTH CAROLINA 29691

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 16-20 (84-17): THIS ROUTINE UNANNOUNCED INSPECTION ENTAILED 12 INSPECTOR-HOURS ON SITE (SIX HOURS ON BACKSHIFT) INSPECTING: SECURITY ORGANIZATION - PERSONNEL/RESPONSE; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL/ PACKAGES/VEHICLES; DETECTION AIDS - PROTECTED AND VITAL AREAS; ALARM STATION; AND COMMUNICATIONS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

10 CFR 71.87(G) REQUIRES THAT PRIOR TO EACH SHIPMENT OF LICENSED MATERIAL THE LICENSEE SHALL ENSURE THAT THE PACKAGE WITH ITS CONTENTS SATISFIES THE APPLICABLE REQUIREMENTS OF THIS PART AND OF THE LICENSE. THE LICENSEE SHALL DETERMINE THAT, FOR FISSILE MATERIAL, ANY MODERATOR OR NEUTRON ABSORBER, IF REQUIRED, IS PRESENT AND IN PROPER CONDITION. NRC CERTIFICATE OF COMPLIANCE NUMBER 9010 FOR THE NLI1/2 FUEL SHIPPING CASK REQUIRES THAT THE NEUTRON SHIELDING TANK BE FILLED WITH A MIXTURE OF WATER AND ETHYLENE GLYCOL. CONTRARY TO THE ABOVE, THE MODERATOR FOR THE NLI1/2 CASK WAS NOT DETERMINED TO BE PRESENT AND IN PROPER CONDITION PRIOR TO USING THE CASK TO SHIP SIXTEEN IRRADIATED FUEL PINS, A FISSILE CLASS III SHIPMENT, TO THE BABCOCK AND WILCOX LYNCHBURG RESEARCH CENTER ON FEBRUARY 3, 1984, UNDER SHIPMENT CONTROL NUMBER 84-19.
(8412 4)

10 CFR 20.201(B) REQUIRES EACH LICENSEE TO MAKE OR CAUSE TO BE MADE SUCH SURVEYS AS MAY BE NECESSARY FOR THE LICENSEE TO COMPLY

1. Docket: 50-270 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (MWt): 2568

5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934

6. Design Electrical Rating (Net MWe): 887

7. Maximum Dependable Capacity (Gross MWe): 399

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>86,736.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,111.0</u>	<u>62,424.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,111.0</u>	<u>61,271.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,872,582</u>	<u>13,078,021</u>	<u>145,568,687</u>
18. Gross Elec Ener (MWH)	<u>650,260</u>	<u>4,512,680</u>	<u>49,617,536</u>
19. Net Elec Ener (MWH)	<u>622,468</u>	<u>4,328,173</u>	<u>47,139,742</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>70.6</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>70.6</u>
22. Unit Cap Factor (MDC Net)	<u>97.3</u>	<u>98.5</u>	<u>63.0*</u>
23. Unit Cap Factor (DER Net)	<u>94.3</u>	<u>95.5</u>	<u>61.3*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>15.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>10,256.1</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* OCONEE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

OCONEE 2



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * OCONEE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
8P	07/03/84	S	0.0	F	5		ZZ	ZZZZZZ	ECONOMIC DISPATCH REDUCTION.
9P	07/06/84	S	0.0	B	5		CC	VALVEX	CONTROL AND STOP VALVE PT'S.

***** OCONEE 2 OPERATED ROUTINELY IN JULY.
 * SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* OCONEE 2 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....OCONEE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI W OF
GREENVILLE, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 11, 1973
DATE ELEC ENER 1ST GENER...DECEMBER 5, 1973
DATE COMMERCIAL OPERATE...SEPTEMBER 9, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER....LAKE KEOWEE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
CHARLOTTE, NORTH CAROLINA 28242
CONTRACTOR
ARCHITECT/ENGINEER.....DUKE & BECHTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. BRYANT
LICENSING PROJ MANAGER.....H. NICOLARAS
DOCKET NUMBER.....50-270
LICENSE & DATE ISSUANCE...DPR-47, OCTOBER 6, 1973
PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY
501 W. SOUTH BROAD ST.
WALHALLA, SOUTH CAROLINA 29691

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 16-20 (84-16): THIS ROUTINE UNANNOUNCED INSPECTION ENTAILED 11 INSPECTOR-HOURS ON SITE (SIX HOURS ON BACKSHIFT) INSPECTING: SECURITY ORGANIZATION - PERSONNEL/RESPONSE; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL/ PACKAGES/VEHICLES; DETECTION AIDS - PROTECTED AND VITAL AREAS; ALARM STATION; AND COMMUNICATIONS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

10 CFR 71.87(G) REQUIRES THAT PRIOR TO EACH SHIPMENT OF LICENSED MATERIAL THE LICENSEE SHALL ENSURE THAT THE PACKAGE WITH ITS CONTENTS SATISFIES THE APPLICABLE REQUIREMENTS OF THIS PART AND OF THE LICENSE. THE LICENSEE SHALL DETERMINE THAT, FOR FISSILE MATERIAL, ANY MODERATOR OR NEUTRON ABSORBER, IF REQUIRED, IS PRESENT AND IN PROPER CONDITION. NRC CERTIFICATE OF COMPLIANCE NUMBER 9010 FOR THE NLI1/2 FUEL SHIPPING CASK REQUIRES THAT THE NEUTRON SHIELDING TANK BE FILLED WITH A MIXTURE OF WATER AND ETHYLENE GLYCOL. CONTRARY TO THE ABOVE, THE MODERATOR FOR THE NLI1/2 CASK WAS NOT DETERMINED TO BE PRESENT AND IN PROPER CONDITION PRIOR TO USING THE CASK TO SHIP SIXTEEN IRRADIATED FUEL PINS, A FISSILE CLASS III SHIPMENT, TO THE BABCOCK AND WILCOX LYNCHBURG RESEARCH CENTER ON FEBRUARY 3, 1984, UNDER SHIPMENT CONTROL NUMBER 84-19.
(8412 4)

10 CFR 20.201(B) REQUIRES EACH LICENSEE TO MAKE OR CAUSE TO BE MADE SUCH SURVEYS AS MAY BE NECESSARY FOR THE LICENSEE TO COMPLY

1. Docket: 50-287 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (Mwt): 2568

5. Nameplate Rating (Gross MWe): 1035 X 0.9 = 934

6. Design Electrical Rating (Net MWe): 887

7. Maximum Dependable Capacity (Gross MWe): 899

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____


11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>84,383.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,207.8</u>	<u>59,917.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,171.9</u>	<u>58,755.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,923,123</u>	<u>7,859,450</u>	<u>143,352,013</u>
18. Gross Elec Ener (MWH)	<u>659,780</u>	<u>2,713,970</u>	<u>49,528,564</u>
19. Net Elec Ener (MWH)	<u>632,164</u>	<u>2,588,968</u>	<u>47,156,086</u>
20. Unit Service Factor	<u>100.0</u>	<u>62.1</u>	<u>69.6</u>
21. Unit Avail Factor	<u>100.0</u>	<u>62.1</u>	<u>69.6</u>
22. Unit Cap Factor (MDC Net)	<u>98.8</u>	<u>58.9</u>	<u>64.8*</u>
23. Unit Cap Factor (DER Net)	<u>95.8</u>	<u>57.1</u>	<u>63.1*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.1</u>	<u>14.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>35.8</u>	<u>10,177.8</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>NONE</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

* OCONEE 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

OCONEE 3



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * OCONEE 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
10P	07/06/84	S	0.0	B	5		CC	VALVEX	TURBINE VALVE PT'S
11P	07/07/84	S	0.0	F	5		ZZ	ZZZZZZ	ECONOMIC DISPATCH REDUCTION

 * SUMMARY *

 OCONEE 3 OPERATED ROUTINELY IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Aut. Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

* OCONEE 3 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....OCONEE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI W OF
GREENVILLE, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...SEPTEMBER 5, 1974
DATE ELEC ENER 1ST GENER...SEPTEMBER 18, 1974
DATE COMMERCIAL OPERATE....DECEMBER 16, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE KEOWEE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
CHARLOTTE, NORTH CAROLINA 28242
CONTRACTOR
ARCHITECT/ENGINEER.....DUKE & BECHTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WYLCOX
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. BRYANT
LICENSING PROJ MANAGER.....H. NICOLARAS
DOCKET NUMBER.....50-287
LICENSE & DATE ISSUANCE...DPR-55, JULY 19, 1974
PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY
501 W. SOUTH BROAD ST.
WALHALLA, SOUTH CAROLINA 29691

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 16-20 (84-19): THIS ROUTINE UNANNOUNCED INSPECTION ENTAILED 11 INSPECTOR-HOURS ON SITE (SIX HOURS ON BACKSHIFT) INSPECTING: SECURITY ORGANIZATION - PERSONNEL/RESPONSE; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL/ PACKAGES/VEHICLES; DETECTION AIDS - PROTECTED AND VITAL AREAS; ALARM STATION; AND COMMUNICATIONS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

10 CFR 71.87(G) REQUIRES THAT PRIOR TO EACH SHIPMENT OF LICENSED MATERIAL THE LICENSEE SHALL ENSURE THAT THE PACKAGE WITH ITS CONTENTS SATISFIES THE APPLICABLE REQUIREMENTS OF THIS PART AND OF THE LICENSE. THE LICENSEE SHALL DETERMINE THAT, FOR FISSILE MATERIAL, ANY MODERATOR OR NEUTRON ABSORBER, IF REQUIRED, IS PRESENT AND IN PROPER CONDITION. NRC CERTIFICATE OF COMPLIANCE NUMBER 9010 FOR THE NLI1/2 FUEL SHIPPING CASK REQUIRES THAT THE NEUTRON SHIELDING TANK BE FILLED WITH A MIXTURE OF WATER AND ETHYLENE GLYCOL. CONTRARY TO THE ABOVE, THE MODERATOR FOR THE NLI1/2 CASK WAS NOT DETERMINED TO BE PRESENT AND IN PROPER CONDITION PRIOR TO USING THE CASK TO SHIP SIXTEEN IRRADIATED FUEL PINS, A FISSILE CLASS III SHIPMENT, TO THE BABCOCK AND WILCOX LYNCHBURG RESEARCH CENTER ON FEBRUARY 3, 1984, UNDER SHIPMENT CONTROL NUMBER 84-19.
(8414 4)

10 CFR 20.201(B) REQUIRES EACH LICENSEE TO MAKE OR CAUSE TO BE MADE SUCH SURVEYS AS MAY BE NECESSARY FOR THE LICENSEE TO COMPLY

1. Docket: 50-219 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: JOSEPH R. MOLNAR (609) 971-4699

4. Licensed Thermal Power (MWt): 1930

5. Nameplate Rating (Gross MWe): 722 X .9 = 650

6. Design Electrical Rating (Net MWe): 650

7. Maximum Dependable Capacity (Gross MWe): 650

8. Maximum Dependable Capacity (Net MWe): 620

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE


10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

* OYSTER CREEK 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
OYSTER CREEK 1

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>128,039.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>696.0</u>	<u>85,319.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>468.2</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>82,693.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>136,301,260</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>46,056,905</u>
19. Net Elec Ener (MWH)	<u>-2,663</u>	<u>-12,750</u>	<u>44,272,933</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>64.6</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>64.6</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>55.8*</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>53.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>11.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>8,916.8</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>NONE</u>			



JULY 1984

27. If Currently Shutdown Estimated Startup Date: 09/09/84

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* OYSTER CREEK 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
31	02/11/83	S	744.0	C	4		ZZ	ZZZZZ	REFUELING AND MAINTENANCE OUTAGE CONTINUES.

***** OYSTER CREEK 1 REMAINS SHUT DOWN FOR REFUELING AND MAINTENANCE.
* SUMMARY *

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

* OYSTER CREEK 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEW JERSEY
COUNTY.....OCEAN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9 MI S OF
TOMS RIVER, NJ
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MAY 3, 1969
DATE ELEC ENER 1ST GENER...SEPTEMBER 23, 1969
DATE COMMERCIAL OPERATE...DECEMBER 1, 1969
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...BARNEGAT BAY
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....GPU NUCLEAR CORPORATION
CORPORATE ADDRESS.....100 INTERPACE PARKWAY
PARSIPPANY, NEW JERSEY 07054
CONTRACTOR
ARCHITECT/ENGINEER.....BURNS & ROE
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BURNS & ROE
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....C. COWGILL
LICENSING PROJ MANAGER.....J. LOMBARDO
DOCKET NUMBER.....50-219
LICENSE & DATE ISSUANCE...DPR-16, AUGUST 1, 1969
PUBLIC DOCUMENT ROOM.....OCEAN COUNTY LIBRARY
101 WASHINGTON STREET
TOMS RIVER, NEW JERSEY 08753

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION VI, MECHANICAL INSTALLATION SPECIFICATION OCIS-402017-002 WERE REVISED, BUT NUMEROUS CHANGES WERE NEVER INCORPORATED AS REQUIRED BY PROJECT PROCEDURE PI-19 WHICH LIMITED THE NUMBER OF OUTSTANDING CHANGES AGAINST A SPECIFICATION TO TWO. MECHANICAL INSTALLATION SPECIFICATION OCIS-40217-001, WAS ORIGINATED BY STONE & WEBSTER (S&W), BUT WAS REVISED AND ISSUED BY GPUN AS REVISION 0 WITHOUT PROPER REVIEW FOR ADEQUACY BY S&W, THE LOCATION WHERE DESIGN WAS PERFORMED, FOR THEIR USE. AS A RESULT, S&W CONTINUED TO USE OUT-OF-DATE DESIGN INFORMATION IN DISPOSITIONING OTHER CHANGES SUCH AS FIELD CHANGE REQUESTS. MECHANICAL INSTALLATION SPECIFICATION OCIS-40217-001, REVISION 1 WAS ISSUED WITHOUT PROPER APPROVALS. PROJECT PROCEDURES REQUIRED THAT THE REVISION BE REVIEWED AND APPROVED BY THE SAME ORGANIZATION THAT REVIEWED AND APPROVED THE ORIGINAL ISSUE. HOWEVER, THE REVISION WAS ISSUED WITHOUT THE REVIEW AND APPROVAL OF QA WHICH HAD REVIEWED AND APPROVED THE ORIGINAL ISSUE. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION III, AS OF APRIL 3, 1984: APPROPRIATE MEASURES HAD NOT BEEN APPLIED TO CONTROL THE DESIGN INTERFACE BETWEEN GPUN AND STONE AND WEBSTER IN THE GPUN APPROVED AND RELEASED REVISED DESIGN DOCUMENTS SUCH AS MECHANICAL INSTALLATION SPECIFICATION OCIS-402071-001 WITHOUT OBTAINING THE APPROVAL OF THE ORIGINAL DESIGN ORGANIZATION (STONE AND WEBSTER). THIS RESULTED IN DESIGN CHANGES, SUCH AS CHANGES IN THE CODES APPLIED TO DESIGN/INSTALLATION, WHERE THE REVIEW OF THE IMPACT OF THE CHANGE WAS NOT COMMENSURATE WITH THE REVIEW OF THE ORIGINAL DESIGN. DURING THE PROCESS OF MAKING A DESIGN CHANGE TO MODIFY

Report Period JUL 1984

R E P O R T S F R O M L I C E N S E E

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
* OYSTER CREEK 1
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-255 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: A. F. DIENES (616) 764-8913

4. Licensed Thermal Power (MWt): 2530

5. Nameplate Rating (Gross MWe): 955 X 0.85 = 812

6. Design Electrical Rating (Net MWe): 805

7. Maximum Dependable Capacity (Gross MWe): 675

8. Maximum Dependable Capacity (Net MWe): 635

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>110,606.0</u>
13. Hours Reactor Critical	<u>146.7</u>	<u>146.7</u>	<u>59,406.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>18.7</u>	<u>18.7</u>	<u>56,297.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>9,816</u>	<u>9,816</u>	<u>115,370,040</u>
18. Gross Elec Ener (MWH)	<u>2,460</u>	<u>2,460</u>	<u>35,752,900</u>
19. Net Elec Ener (MWH)	<u>1,442</u>	<u>1,442</u>	<u>33,629,456</u>
20. Unit Service Factor	<u>2.5</u>	<u>.4</u>	<u>50.9</u>
21. Unit Avail Factor	<u>2.5</u>	<u>.4</u>	<u>50.9</u>
22. Unit Cap Factor (MDC Net)	<u>.3</u>	<u>.0</u>	<u>47.9</u>
23. Unit Cap Factor (DER Net)	<u>.2</u>	<u>.0</u>	<u>37.8</u>
24. Unit Forced Outage Rate	<u>49.0</u>	<u>49.0</u>	<u>32.1</u>
25. Forced Outage Hours	<u>18.0</u>	<u>18.0</u>	<u>12,543.6</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 08/17/84

* PALISADES *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PALISADES



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * PALISADES *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	08/12/83	S	707.3	C	4				REFUELING OUTAGE CONCLUDES.
2	07/31/84	F	18.0	B	1				TURBINE BEARING HIGH VIBRATION.

 * SUMMARY *

 PALISADES CONCLUDED A REFUELING SHUT DOWN ON JULY 30.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* PALISADES *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MICHIGAN

COUNTY.....VANBUREN

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S OF
SOUTH HAVEN, MI

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...MAY 24, 1971

DATE ELEC ENER 1ST GENER...DECEMBER 31, 1971

DATE COMMERCIAL OPERATE...DECEMBER 31, 1971

CONDENSER COOLING METHOD...COOLING TOWERS

CONDENSER COOLING WATER...LAKE MICHIGAN

ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CONSUMERS POWER

CORPORATE ADDRESS.....212 WEST MICHIGAN AVENUE
JACKSON, MICHIGAN 49201

CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....P. JORGENSON

LICENSING PROJ MANAGER.....W. PAULSON
DOCKET NUMBER.....50-255

LICENSE & DATE ISSUANCE...DPR-20, OCTOBER 16, 1972

PUBLIC DOCUMENT ROOM.....KALAMAZOO PUBLIC LIBRARY
315 SOUTH ROSE STREET
REFERENCE DEPARTMENT
KALAMAZOO, MICHIGAN 49007

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON APRIL 25 - MAY 17, (84-09): ROUTINE, ANNOUNCED INSPECTION BY REGIONAL INSPECTORS OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS, DESIGN CHANGE AND MODIFICATION PROGRAM AND IMPLEMENTATION; PROCUREMENT PROGRAM AND IMPLEMENTATION; SURVEILLANCE PROGRAM AND IMPLEMENTATION; TRAINING; AND Q LIST CONTROL. THE INSPECTION INVOLVED 244 INSPECTOR HOURS ONSITE BY FIVE INSPECTORS. OF THE 11 AREAS INSPECTED, THREE ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN FOUR AREAS (FAILURE TO PROVIDE ACCEPTANCE CRITERIA IN SURVEILLANCE PROCEDURE; FAILURE TO ESTABLISH MEASURES TO PREVENT INADVERTENT USE OR INSTALLATION OF NONCONFORMING ITEMS WITHOUT TECHNICAL JUSTIFICATION; FAILURE TO SPECIFY ADEQUATE TECHNICAL AND QUALITY REQUIREMENTS FOR A SAFETY-RELATED PROCUREMENT; AND FAILURE TO FOLLOW PROCEDURES.

INSPECTION ON JULY 13, (84-12): ROUTINE ANNOUNCED INSPECTION OF FOLLOW-UP OF VALVE SHAFT INSPECTION AND REPLACEMENT ON MAIN STEAM LINE ISOLATION VALVES. THIS INSPECTION INVOLVED A TOTAL OF 7 INSPECTOR-HOURS ONSITE BY 1 NRC INSPECTOR. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

10 CFR 50, APPENDIX B, CRITERION XV, AS IMPLEMENTED BY SECTION 15 OF CONSUMERS POWER QUALITY ASSURANCE PROGRAM DESCRIPTION FOR OPERATIONAL NUCLEAR POWER PLANT (CPC-2A) REQUIRES MEASURES TO BE ESTABLISHED TO CONTROL MATERIALS, PARTS OR COMPONENTS WHICH DO

Report Period JUL 1984

R E P O R T S F R O M L I C E N S E E

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
* PALISADES *
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

```
=====
```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-06	06/12/84	06/28/84	RADIOACTIVE WASTE SHIPMENT. .
84-07	06/22/84	07/20/84	SPURIOUS LOW TEMP. OVERPRESSURE PROTECTION ACTUATION.
84-08	06/28/84	07/26/84	PERSONNEL AIRLOCK LEAKAGE.

```
=====
```


THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-277 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: W. M. Alden (215) 841-5022

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1051

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>88,319.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>2,583.9</u>	<u>62,283.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>2,544.8</u>	<u>60,556.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>7,865,391</u>	<u>178,420,001</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>2,547,570</u>	<u>58,718,660</u>
19. Net Elec Ener (MWH)	<u>-5,243</u>	<u>2,448,104</u>	<u>56,284,534</u>
20. Unit Service Factor	<u>.0</u>	<u>49.8</u>	<u>68.6</u>
21. Unit Avail Factor	<u>.0</u>	<u>49.8</u>	<u>68.6</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>45.6</u>	<u>60.6</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>45.0</u>	<u>59.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.4</u>	<u>12.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>116.4</u>	<u>8,628.6</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 02/04/85

* PEACH BOTTOM 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
PEACH BOTTOM 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* PEACH BOTTOM 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
5	04/27/84	S	744.0	C	4		RC	FUELXX	SHUTDOWN FOR ITS SIXTH REFUELING & MAINTENANCE OUTAGE.

* SUMMARY *

PEACH BOTTOM 2 REMAINED SHUT DOWN FOR REFUELING AND MAINTENANCE DURING THE ENTIRE MONTH OF JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	C-Refueling	4-Continued	Data Entry Sheet
	H-Other	5-Reduced Load	Licensee Event Report
	D-Regulatory Restriction	9-Other	(LER) File (NUREG-0161)
	E-Operator Training & License Examination		

* PEACH BOTTOM 2 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....YORK
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...19 MI S OF
LANCASTER, PA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...SEPTEMBER 16, 1973
DATE ELEC EMER 1ST GENER...FEBRUARY 18, 1974
DATE COMMERCIAL OPERATE....JULY 5, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...SUSQUEHANNA RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PHILADELPHIA ELECTRIC
CORPORATE ADDRESS.....2301 MARKET STREET
PHILADELPHIA, PENNSYLVANIA 19105
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....A. BLOUGH
LICENSING PROJ MANAGER....G. GEARS
DOCKET NUMBER.....50-277
LICENSE & DATE ISSUANCE...DPR-44, DECEMBER 14, 1973
PUBLIC DOCUMENT ROOM.....GOVERNMENT PUBLICATIONS SECTION
STATE LIBRARY OF PENNSYLVANIA
FORUM BUILDING
COMMONWEALTH AND WALNUT STREET
HARRISBURG, PENNSYLVANIA 17105

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* PEACH BOTTOM 2 *

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T ' S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-278 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: W. M. Alden (215) 841-5022

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1035

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>84,215.0</u>
13. Hours Reactor Critical	<u>670.9</u>	<u>4,268.0</u>	<u>61,068.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>655.9</u>	<u>4,210.1</u>	<u>59,526.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,082,708</u>	<u>13,366,383</u>	<u>174,404,688</u>
18. Gross Elec Ener (MWH)	<u>693,820</u>	<u>4,452,320</u>	<u>57,267,440</u>
19. Net Elec Ener (MWH)	<u>670,462</u>	<u>4,311,604</u>	<u>54,975,389</u>
20. Unit Service Factor	<u>88.2</u>	<u>82.4</u>	<u>70.7</u>
21. Unit Avail Factor	<u>88.2</u>	<u>82.4</u>	<u>70.7</u>
22. Unit Cap Factor (MDC Net)	<u>87.1</u>	<u>81.5</u>	<u>63.1</u>
23. Unit Cap Factor (DER Net)	<u>84.6</u>	<u>79.2</u>	<u>61.3</u>
24. Unit Forced Outage Rate	<u>11.8</u>	<u>14.0</u>	<u>7.8</u>
25. Forced Outage Hours	<u>88.1</u>	<u>687.4</u>	<u>5,018.3</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* PEACH BOTTOM 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PEACH BOTTOM 3



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* PEACH BOTTOM 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
6	07/11/84	F	88.1	H	3		IA	INSTRU	APRM HIGH FLUX SCRAM OCCURRED FOLLOWING A LIGHTNING STRIKE ON 500KV BUS TIE LINE.

* SUMMARY *

PEACH BOTTOM 3 EXPERIENCED A TRIP DUE TO LIGHTNING ON JULY 11.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

* PEACH BOTTOM 3 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....YORK
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...19 MI S OF
LANCASTER, PA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...AUGUST 7, 1974
DATE ELEC ENER 1ST GENER...SEPTEMBER 1, 1974
DATE COMMERCIAL OPERATE...DECEMBER 23, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...SUSQUEHANNA RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PHILADELPHIA ELECTRIC
CORPORATE ADDRESS.....2301 MARKET STREET
PHILADELPHIA, PENNSYLVANIA 19105
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IC REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....A. BLOUGH
LICENSING PROJ MANAGER....G. GEARS
DOCKET NUMBER.....50-278
LICENSE & DATE ISSUANCE...DPR-56, JULY 2, 1974
PUBLIC DOCUMENT ROOM.....GOVERNMENT PUBLICATIONS SECTION
STATE LIBRARY OF PENNSYLVANIA
FORUM BUILDING
COMMONWEALTH AND WALNUT STREET
HARRISBURG, PENNSYLVANIA 17105

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (C O N T I N U E D)

* P E A C H B O T T O M 3 *

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

1. Docket: 50-293 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: P. HAMILTON (617) 746-7905

4. Licensed Thermal Power (MWt): 1998

5. Nameplate Rating (Gross MWe): 780 X 0.87 = 678

6. Design Electrical Rating (Net MWe): 655

7. Maximum Dependable Capacity (Gross MWe): 690

8. Maximum Dependable Capacity (Net MWe): 670

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>102,071.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>69,733.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>67,521.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>116,932,632</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>39,228,314</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>37,693,409</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>66.2</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>66.2</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>55.1</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>56.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>9.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>6,842.5</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 10/16/84

* PILGRIM 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PILGRIM 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

X PILGRIM 1 X

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
16	12/10/83	S	744.0	C	4				SHUTDOWN FOR REFUELING AND RECIRCULATION PIPE REPLACEMENT.

* SUMMARY *

PILGRIM 1 CONTINUES SHUTDOWN FOR REFUELING AND RECIRCULATION
PIPING REPLACEMENT.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* PILGRIM 1 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MASSACHUSETTS
COUNTY.....PLYMOUTH
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...4 MI SE OF
PLYMOUTH, MASS
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JUNE 16, 1972
DATE ELEC ENER 1ST GENER...JULY 19, 1972
DATE COMMERCIAL OPERATE...DECEMBER 1, 1972
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CAPE COD BAY
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....BOSTON EDISON
CORPORATE ADDRESS.....80th BOYLSTON STREET
BOSTON, MASSACHUSETTS 02199
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....J. JOHNSON
LICENSING PROJ MANAGER....P. LEECH
DOCKET NUMBER.....50-293
LICENSE & DATE ISSUANCE...DPR-35, SEPTEMBER 15, 1972
PUBLIC DOCUMENT ROOM.....PLYMOUTH PUBLIC LIBRARY
11 NORTH STREET
PLYMOUTH, MASSACHUSETTS 02360

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

1. Docket: 50-266 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: C. W. KRAUSE (414) 277-2001

4. Licensed Thermal Power (MWt): 1518

5. Nameplate Rating (Gross MWe): 582 X 0.9 = 524

6. Design Electrical Rating (Net MWe): 497

7. Maximum Dependable Capacity (Gross MWe): 519

8. Maximum Dependable Capacity (Net MWe): 485

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>120,407.0</u>
13. Hours Reactor Critical	<u>728.7</u>	<u>2,747.1</u>	<u>96,825.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.4</u>	<u>4.3</u>	<u>629.7</u>
15. Hrs Generator On-Line	<u>722.5</u>	<u>2,707.0</u>	<u>94,314.5</u>
16. Unit Reserve Shtdwn Hrs	<u>3.2</u>	<u>9.0</u>	<u>802.5</u>
17. Gross Therm Ener (MWH)	<u>1,053,610</u>	<u>3,924,040</u>	<u>127,459,352</u>
18. Gross Elec Ener (MWH)	<u>363,670</u>	<u>1,354,950</u>	<u>42,750,930</u>
19. Net Elec Ener (MWH)	<u>347,637</u>	<u>1,294,171</u>	<u>40,662,053</u>
20. Unit Service Factor	<u>97.1</u>	<u>53.0</u>	<u>78.3</u>
21. Unit Avail Factor	<u>97.5</u>	<u>53.1</u>	<u>79.0</u>
22. Unit Cap Factor (MDC Net)	<u>96.3</u>	<u>52.2</u>	<u>69.1*</u>
23. Unit Cap Factor (DER Net)	<u>94.0</u>	<u>50.9</u>	<u>67.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>2.7</u>
25. Forced Outage Hours	<u>.1</u>	<u>.0</u>	<u>2,406.3</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * POINT BEACH 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

POINT BEACH 1



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* POINT BEACH 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
3	07/21/84	S	21.5	B	1		XX	ELECON	UNIT SHUTDOWN TO PERFORM IN CONTAINMENT MAINTENANCE ON THE REACTOR COOLANT LOOSE PARTS MONITORING SYSTEM.

* SUMMARY *

POINT BEACH 1 OPERATED ROUTINELY IN JULY WITH 1 SHUTDOWN FOR MAINTENANCE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* POINT BEACH 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....WISCONSIN
COUNTY.....MANITOWOC
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...15 MI N OF
MANITOWOC, WISC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 2, 1970
DATE ELEC ENER 1ST GENER...NOVEMBER 6, 1970
DATE COMMERCIAL OPERATE...DECEMBER 21, 1970
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....WISCONSIN ELECTRIC POWER COMPANY
CORPORATE ADDRESS.....231 WEST MICHIGAN STREET
MILWAUKEE, WISCONSIN 53201
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....R. HAGUE
LICENSING PROJ MANAGER.....T. COLBURN
DOCKET NUMBER.....50-266
LICENSE & DATE ISSUANCE...DPR-24, OCTOBER 5, 1970
PUBLIC DOCUMENT ROOM.....JOSEPH MANN PUBLIC LIBRARY
1516 16TH ST.
TWO RIVERS, WISCONSIN 54241

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON APRIL 1 - MAY 31, (84-06): ROUTINE, UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; LICENSEE EVENT REPORTS; INDEPENDENT INSPECTION; REGIONAL REQUESTS; STARTUP TESTING - REFUELING. THE INSPECTION INVOLVED 402 INSPECTOR HOURS ONSITE BY TWO INSPECTORS INCLUDING 46 INSPECTOR HOURS ON OFFSHIFTS. ONE ITEM OF NON COMPLIANCE WAS FOUND IN TWO AREAS (FAILURE TO FOLLOW PROCEDURES, AND FAILURE TO MEET COMMITMENT TO ANSI N45.2.1-1973).

INSPECTION ON JUNE 11-15, (84-08): INCLUDED A REVIEW OF THE LICENSEE'S ACTION ON PREVIOUS INSPECTION FINDINGS; SECURITY PLAN AND IMPLEMENTING PROCEDURES; MANAGEMENT EFFECTIVENESS - SECURITY PROGRAM; SECURITY ORGANIZATION, SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; TESTING AND MAINTENANCE; SECURITY SYSTEM POWER SUPPLY; COMPENSATORY MEASURES; ACCESS CONTROL - PERSONNEL DETECTION AIDS - PROTECTED AND VITAL AREAS; ALARM STATIONS; COMMUNICATIONS; AND INDEPENDENT INSPECTION. THE INSPECTION INVOLVED 64 INSPECTOR-HOURS BY TWO NRC INSPECTORS. EIGHT OF THE 64 INSPECTOR-HOURS WERE CONDUCTED OFFSITE DURING OFF-SHIFT PERIODS. THE INSPECTION BEGAN DURING THE DAY SHIFT. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED, EXCEPT FOR THE FOLLOWING ITEM. ALARM STATION: A COMPUTER CAPABILITY REQUIRED BY THE SECURITY PLAN COULD BE CIRCUMVENTED. AN AREA OF CONCERN WAS NOTED REGARDING WRITTEN GUIDANCE BY THE SECURITY CONTRACTOR PERTAINING TO THE REPORTING OF POSSIBLE VIOLATIONS TO THE NRC. FOUR COMMITMENTS DID NOT CONSTITUTE VIOLATIONS OF NRC REQUIREMENTS.

INSPECTION ON JULY 11, (84-12): ROUTINE, ANNOUNCED INSPECTION OF FOLLOWUP OF VALVE SHAFT INSPECTIONS ON MAIN STEAM LINE ISOLATION SWING CHECK AND SWING STOP VALVES. THIS INSPECTION INVOLVED A TOTAL OF 4 INSPECTION-HOURS ONSITE BY ONE NRC INSPECTOR. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-301 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: C. W. KRAUSE (414) 277-2001

4. Licensed Thermal Power (MWt): 1518

5. Nameplate Rating (Gross MWe): 582 X 0.9 = 524

6. Design Electrical Rating (Net MWe): 497

7. Maximum Dependable Capacity (Gross MWe): 519

8. Maximum Dependable Capacity (Net MWe): 485

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE


10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>105,192.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,085.6</u>	<u>93,513.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>8.8</u>	<u>207.1</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,021.9</u>	<u>91,924.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>15.4</u>	<u>198.1</u>
17. Gross Therm Ener (MWH)	<u>1,119,374</u>	<u>7,494,418</u>	<u>128,389,195</u>
18. Gross Elec Ener (MWH)	<u>381,040</u>	<u>2,534,380</u>	<u>43,494,210</u>
19. Net Elec Ener (MWH)	<u>364,174</u>	<u>2,421,941</u>	<u>41,427,206</u>
20. Unit Service Factor	<u>100.0</u>	<u>98.3</u>	<u>87.4</u>
21. Unit Avail Factor	<u>100.0</u>	<u>98.6</u>	<u>87.6</u>
22. Unit Cap Factor (MDC Net)	<u>100.9</u>	<u>96.0</u>	<u>80.1*</u>
23. Unit Cap Factor (DER Net)	<u>98.5</u>	<u>95.3</u>	<u>79.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>1.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>692.2</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>REFUELING SEPTEMBER 28, 1984 - 5 WEEKS.</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

* POINT BEACH 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
POINT BEACH 2



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* POINT BEACH 2 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

POINT BEACH 2 EXPERIENCED NO SHUTDOWNS OR POWER
REDUCTIONS IN JULY.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System & Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* POINT BEACH 2 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....WISCONSIN
COUNTY.....MANITOWOC
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...15 MI N OF
MANITOWOC, WISC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 30, 1972
DATE ELEC ENER 1ST GENER...AUGUST 2, 1972
DATE COMMERCIAL OPERATE...OCTOBER 1, 1972
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....WISCONSIN ELECTRIC POWER COMPANY
CORPORATE ADDRESS.....231 WEST MICHIGAN STREET
MILWAUKEE, WISCONSIN 53201
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....R. HAGUE
LICENSING PROJ MANAGER.....T. COLBURN
DCKET NUMBER.....50-301
LICENSE & DATE ISSUANCE...DPR-27, MARCH 8, 1973
PUBLIC DOCUMENT ROOM.....JOSEPH MANN PUBLIC LIBRARY
1516 16TH ST.
TWO RIVERS, WISCONSIN 54241

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON APRIL 1 - MAY 31, (84-04): ROUTINE, UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; LICENSEE EVENT REPORTS; INDEPENDENT INSPECTION; REGIONAL REQUESTS; STARTUP TESTING - REFUELING. THE INSPECTION INVOLVED 402 INSPECTOR HOURS ONSITE BY TWO INSPECTORS INCLUDING 46 INSPECTOR HOURS ON OFFSHIFTS. ONE ITEM OF NON COMPLIANCE WAS FOUND IN TWO AREAS (FAILURE TO FOLLOW PROCEDURES, AND FAILURE TO MEET COMMITMENT TO ANSI N45.2.1-1973).

INSPECTION ON JUNE 11-15, (84-06): INCLUDED A REVIEW OF THE LICENSEE'S ACTION ON PREVIOUS INSPECTION FINDINGS; SECURITY PLAN AND IMPLEMENTING PROCEDURES; MANAGEMENT EFFECTIVENESS - SECURITY PROGRAM; SECURITY ORGANIZATION, SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; TESTING AND MAINTENANCE; SECURITY SYSTEM POWER SUPPLY; COMPENSATORY MEASURES; ACCESS CONTROL - PERSONNEL DETECTION AIDS - PROTECTED AND VITAL AREAS; ALARM STATIONS; COMMUNICATIONS; AND INDEPENDENT INSPECTION. THE INSPECTION INVOLVED 64 INSPECTOR-HOURS BY TWO NRC INSPECTORS. EIGHT OF THE 64 INSPECTOR-HOURS WERE CONDUCTED OFFSITE DURING OFF-SHIFT PERIODS. THE INSPECTION BEGAN DURING THE DAY SHIFT. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED, EXCEPT FOR THE FOLLOWING ITEM. ALARM STATION: A COMPUTER CAPABILITY REQUIRED BY THE SECURITY PLAN COULD BE CIRCUMVENTED. AN AREA OF CONCERN WAS NOTED REGARDING WRITTEN GUIDANCE BY THE SECURITY CONTRACTOR PERTAINING TO THE REPORTING OF POSSIBLE VIOLATIONS TO THE NRC. FOUR COMMITMENTS DID NOT CONSTITUTE VIOLATIONS OF NRC REQUIREMENTS.

INSPECTION ON JULY 11, (84-10): ROUTINE, ANNOUNCED INSPECTION OF FOLLOWUP OF VALVE SHAFT INSPECTIONS ON MAIN STEAM LINE ISOLATION SWING CHECK AND SWING STOP VALVES. THIS INSPECTION INVOLVED A TOTAL OF 4 INSPECTION-HOURS ONSITE BY ONE NRC INSPECTOR. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

POINT BEACH NUCLEAR PLANT PROCEDURE, PBNP 3.4.8, TRANSIENT COMBUSTIBLE CONTROL, STATES IN PART, "IN GENERAL, TRANSIENT COMBUSTIBLES SHOULD NOT REMAIN IN SAFE SHUTDOWN AREAS FOR LONGER THAN A SINGLE WORKSHIFT. TRANSIENT COMBUSTIBLES WHICH MUST REMAIN FOR A LONGER PERIOD SHOULD BE MONITORED THROUGH THE TRANSIENT COMBUSTIBLES CONTROL SYSTEM". CONTRARY TO THE ABOVE, DURING MAINTENANCE ON THE 3D DIESEL GENERATOR, BARRELS OF OIL, SOLVENTS, AND OILY RAGS WERE LEFT UNATTENDED AND UNMONITORED THROUGH THE TRANSIENT COMBUSTIBLES CONTROL SYSTEM IN THE DIESEL GENERATOR ROOM WHICH IS DESIGNATED AS A SAFE SHUTDOWN AREA.
(8404 5)

A SECURITY COMPUTER SAFEGUARDS CAPABILITY REQUIRED BY THE SECURITY PLAN COULD BE CIRCUMVENTED.
(8406 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: AUGUST 6-10, 1984

INSPECTION REPORT NO: 84-12

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE			

1. Docket: 50-282 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: DALE DUGSTAD (612) 388-1121

4. Licensed Thermal Power (MWt): 1650

5. Nameplate Rating (Gross MWe): 659 X 0.9 = 593

6. Design Electrical Rating (Net MWe): 530

7. Maximum Dependable Capacity (Gross MWe): 534

8. Maximum Dependable Capacity (Net MWe): 503

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

* PRAIRIE ISLAND 1 *


AVERAGE DAILY POWER LEVEL (MWe) PLOT

PRAIRIE ISLAND 1

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>93,143.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,061.4</u>	<u>76,734.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>5,571.1</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,040.0</u>	<u>75,421.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,212,731</u>	<u>8,161,552</u>	<u>118,472,714</u>
18. Gross Elec Ener (MWH)	<u>396,460</u>	<u>2,702,460</u>	<u>38,582,260</u>
19. Net Elec Ener (MWH)	<u>372,502</u>	<u>2,551,449</u>	<u>36,142,878</u>
20. Unit Service Factor	<u>100.0</u>	<u>98.6</u>	<u>81.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>98.6</u>	<u>81.0</u>
22. Unit Cap Factor (MDC Net)	<u>99.5</u>	<u>99.2</u>	<u>77.1</u>
23. Unit Cap Factor (DER Net)	<u>94.5</u>	<u>94.2</u>	<u>73.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>8.0</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>2,920.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
TEN YEAR OV_RHAUL IN JANUARY 1985

27. If Currently Shutdown Estimated Startup Date: N/A



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * PRAIRIE ISLAND 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
	07/08/84	S	0.0	B	5			TURBINE VALVES TEST.
	07/14/84	S	0.0	B	5			ADD OIL TO RCP, TURBINE VALVES TEST.
	07/22/84	S	0.0	B	5			AXIAL OFFSET CALIBRATION.

***** PRAIRIE ISLAND 1 OPERATED ROUTINELY IN JULY.
 * SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* PRAIRIE ISLAND 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MINNESOTA
COUNTY.....GOODHUE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...28 MI SE OF
MINNEAPOLIS, MINN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 1, 1973
DATE ELEC ENER 1ST GENER...DECEMBER 4, 1973
DATE COMMERCIAL OPERATE...DECEMBER 16, 1973
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHERN STATES POWER
CORPORATE ADDRESS.....414 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401
CONTRACTOR
ARCHITECT/ENGINEER.....FLUOR PIONEER, INC.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....NORTHERN STATES POWER COMPANY
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. HARD
LICENSING PROJ MANAGER.....D. DIANNI
DOCKET NUMBER.....50-282
LICENSE & DATE ISSUANCE...DPR-42, APRIL 5, 1974
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY
MINNEAPOLIS PUBLIC LIBRARY
300 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON APRIL 11, 1984 - JUNE 10, (84-04): ROUTINE RESIDENT INSPECTION OF PLANT OPERATIONAL SAFETY, MAINTENANCE, SURVEILLANCE, TMI-2 ITEMS FOLLOW UP, ATWS PROCEDURE REVIEW, LICENSEE EVENT REPORT. THE INSPECTION INVOLVED A TOTAL 267 OF INSPECTOR-HOURS ONSITE BY 2 NRC INSPECTORS INCLUDING 30 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. ONE ITEM OF DEVIATION WAS IDENTIFIED IN ONE AREA (FAILURE TO MEET AMENDMENT COMMITMENT).

INSPECTION ON MAY 7-11, (84-06): ROUTINE UNANNOUNCED INSPECTION OF MAINTENANCE WITH EMPHASIS ON ADMINISTRATIVE CONTROLS, LIMITORQUE CORPORATION VALVE OPERATORS, REACTOR COOLANT PRESSURE BOUNDARY FASTENERS, AND MAINTENANCE TRAINING. THE INSPECTION INVOLVED A TOTAL OF 96 INSPECTOR-HOURS ONSITE BY 4 NRC INSPECTORS. OF THE 4 AREAS INSPECTED NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JUNE 20-21, (84-08): SPECIAL, ANNOUNCED INSPECTION OF TEST PROCEDURES AND DATA FOR THE INSERVICE TESTING OF VALVES, AND LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS. THE INSPECTION INVOLVED 20 INSPECTOR HOURS ONSITE BY TWO INSPECTORS. OF THE TWO AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN ONE AREA. IN THE OTHER AREA ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED (FAILURE TO LEAK TEST VALVES).

Report Period JUL 1984

INSPECTION STATUS - (CONTINUED)

* PRAIRIE ISLAND 1 *

ENFORCEMENT SUMMARY

10 CFR 50.59(A)(1) STATES, IN PART, THAT "THE HOLDER OF A LICENSE AUTHORIZING OPERATION OF A PRODUCTION OR UTILIZATION FACILITY MAY... (II) MAKE CHANGES IN THE PROCEDURES AS DESCRIBED IN THE SAFETY ANALYSIS REPORT..., WITHOUT PRIOR COMMISSION APPROVAL, UNLESS THE PROPOSED CHANGE INVOLVES A CHANGE IN THE TECHNICAL SPECIFICATIONS INCORPORATED IN THE LICENSE OR AN UNREVIEWED SAFETY QUESTION." 10 CFR 50.59(B) STATES, IN PART, THAT "THE LICENSEE SHALL MAINTAIN RECORDS OF CHANGES... IN PROCEDURES MADE PURSUANT TO THIS SECTION, TO THE EXTENT THAT SUCH CHANGES... CONSTITUTE CHANGES IN PROCEDURES AS DESCRIBED IN THE SAFETY ANALYSIS REPORT. THESE RECORDS SHALL INCLUDE A WRITTEN SAFETY EVALUATION WHICH PROVIDES THE BASES FOR THE DETERMINATION THAT THE CHANGE DOES NOT INVOLVE AN UNREVIEWED SAFETY QUESTION." THE LICENSEE'S JULY 17, 1981, ANALYSIS OF THE ADEQUACY OF THE STATION ELECTRICAL DISTRIBUTION SYSTEM WHICH WAS INCORPORATED BY REFERENCE IN THE UPDATED SAFETY ANALYSIS REPORT (REFERENCE 2 OF SECTION 8.10, PAGE 8.10-1) ASSUMED A MINIMUM PRE-TRIP 345 KV BUS VOLTAGE OF 348 KV. CONTRARY TO THE ABOVE, ON SOME OCCASIONS IN 1983 THE PLANT WAS OPERATED AT BUS VOLTAGES BETWEEN 342 KV AND 345 KV WITHOUT A PRIOR SAFETY EVALUATION. ALTHOUGH A SUBSEQUENT LICENSEE ANALYSIS INDICATES THAT OPERATING VOLTAGES SUBSTANTIALLY LOWER THAN 342 KV ARE ACCEPTABLE, THE LICENSEE DID NOT CONDUCT A SAFETY EVALUATION IN ADVANCE TO DETERMINE IF SUCH OPERATING VOLTAGES INVOLVED A UNREVIEWED SAFETY QUESTION.
(8322 4)

THE PRAIRIE ISLAND NUCLEAR GENERATING STATION, UNIT 1 TECHNICAL SPECIFICATION 4.2 STATES: "INSERVICE TESTING OF ASME CODE CLASS 1, CLASS 2 AND CLASS 3 PUMPS AND VALVES SHALL BE PERFORMED IN ACCORDANCE WITH SECTION XI OF THE ASME BOILER AND PRESSURE VESSEL CODE AND APPLICABLE ADDENDA AS REQUIRED BY 10 CFR 50, SECTION 50.55A(G)." CONTRARY TO THE ABOVE, FIVE MOTOR OPERATED, CATEGORY A RESIDUAL HEAT REMOVAL SYSTEM VALVES ARE NOT LEAK TESTED OR TRENDED PER THE REQUIREMENTS OF IWB-3420 OF SECTION XI OF THE ASME CODE.
(8408 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: JULY 9-13, 1984

INSPECTION REPORT NO: 84-10

Report Period JUL 1984

R E P O R T S F R O M L I C E N S E E

* PRAIRIE ISLAND 1 *

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-03	05/31/84	06/29/84	CAUSTIC ADDITION STANDPIPE LEVEL BELOW SPEC.

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-306 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: DALE DUGSTAD (612) 388-1121

4. Licensed Thermal Power (MWt): 1650

5. Nameplate Rating (Gross MWe): 659 X 0.9 = 593

6. Design Electrical Rating (Net MWe): 530

7. Maximum Dependable Capacity (Gross MWe): 531

8. Maximum Dependable Capacity (Net MWe): 500

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>84,261.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,111.0</u>	<u>73,361.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,516.1</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,111.0</u>	<u>72,404.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,216,519</u>	<u>8,246,844</u>	<u>113,978,702</u>
18. Gross Elec Ener (MWH)	<u>400,480</u>	<u>2,738,160</u>	<u>36,845,560</u>
19. Net Elec Ener (MWH)	<u>377,898</u>	<u>2,594,802</u>	<u>34,569,685</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>85.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>85.9</u>
22. Unit Cap Factor (MDC Net)	<u>101.6</u>	<u>101.5</u>	<u>82.1</u>
23. Unit Cap Factor (DER Net)	<u>95.8</u>	<u>95.8</u>	<u>77.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>4.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>3,315.5</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING OUTAGE IN AUGUST OF 1984.

27. If Currently Shutdown Estimated Startup Date: N/A

* PRAIRIE ISLAND 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PRAIRIE ISLAND 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* PRAIRIE ISLAND 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
	07/15/84	S	0.0	B	5				TURBINE VALVES TEST.

* SUMMARY *

PRAIRIE ISLAND 2 OPERATED ROUTINELY IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

* PRAIRIE ISLAND 2 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MINNESOTA
COUNTY.....GOODHUE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...28 MI SE OF
MINNEAPOLIS, MINN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 17, 1974
DATE ELEC ENER 1ST GENER...DECEMBER 21, 1974
DATE COMMERCIAL OPERATE...DECEMBER 21, 1974
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHERN STATES POWER
CORPORATE ADDRESS.....414 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401
CONTRACTOR
ARCHITECT/ENGINEER.....FLUOR PIONEER, INC.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....NORTHERN STATES POWER COMPANY
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. HARD
LICENSING PROJ MANAGER....D. DIANNI
DOCKET NUMBER.....50-306
LICENSE & DATE ISSUANCE...DPR-60, OCTOBER 29, 1974
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY
MINNEAPOLIS PUBLIC LIBRARY
300 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON APRIL 11, 1984 - JUNE 10, (84-04): ROUTINE RESIDENT INSPECTION OF PLANT OPERATIONAL SAFETY, MAINTENANCE, SURVEILLANCE, TMI-2 ITEMS FOLLOW UP, ATWS PROCEDURE REVIEW, LICENSEE EVENT REPORT. THE INSPECTION INVOLVED A TOTAL 267 OF INSPECTOR-HOURS ONSITE BY 2 NRC INSPECTORS INCLUDING 30 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. ONE ITEM OF DEVIATION WAS IDENTIFIED IN ONE AREA (FAILURE TO MEET AMENDMENT COMMITMENT).

INSPECTION ON MAY 7-11, (84-06): ROUTINE UNANNOUNCED INSPECTION OF MAINTENANCE WITH EMPHASIS ON ADMINISTRATIVE CONTROLS, LIMITORQUE CORPORATION VALVE OPERATORS, REACTOR COOLANT PRESSURE BOUNDARY FASTENERS, AND MAINTENANCE TRAINING. THE INSPECTION INVOLVED A TOTAL OF 96 INSPECTOR-HOURS ONSITE BY 4 NRC INSPECTORS. OF THE 4 AREAS INSPECTED NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JUNE 20-21, (84-07): SPECIAL, ANNOUNCED INSPECTION OF TEST PROCEDURES AND DATA FOR THE INSERVICE TESTING OF VALVES, AND LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS. THE INSPECTION INVOLVED 20 INSPECTOR HOURS ONSITE BY TWO INSPECTORS. OF THE TWO AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN ONE AREA. IN THE OTHER AREA ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED (FAILURE TO LEAK TEST VALVES).

ENFORCEMENT SUMMARY

10 CFR 50.59(A)(1) STATES, IN PART, THAT "THE HOLDER OF A LICENSE AUTHORIZING OPERATION OF A PRODUCTION OR UTILIZATION FACILITY MAY... (II) MAKE CHANGES IN THE PROCEDURES AS DESCRIBED IN THE SAFETY ANALYSIS REPORT..., WITHOUT PRIOR COMMISSION APPROVAL, UNLESS THE PROPOSED CHANGE INVOLVES A CHANGE IN THE TECHNICAL SPECIFICATIONS INCORPORATED IN THE LICENSE OR AN UNREVIEWED SAFETY QUESTION." 10 CFR 50.59(B) STATES, IN PART, THAT "THE LICENSEE SHALL MAINTAIN RECORDS OF CHANGES... IN PROCEDURES MADE PURSUANT TO THIS SECTION, TO THE EXTENT THAT SUCH CHANGES... CONSTITUTE CHANGES IN PROCEDURES AS DESCRIBED IN THE SAFETY ANALYSIS REPORT. THESE RECORDS SHALL INCLUDE A WRITTEN SAFETY EVALUATION WHICH PROVIDES THE BASES FOR THE DETERMINATION THAT THE CHANGE DOES NOT INVOLVE AN UNREVIEWED SAFETY QUESTION." THE LICENSEE'S JULY 17, 1981, ANALYSIS OF THE ADEQUACY OF THE STATION ELECTRICAL DISTRIBUTION SYSTEM WHICH WAS INCORPORATED BY REFERENCE IN THE UPDATED SAFETY ANALYSIS REPORT (REFERENCE 2 OF SECTION 8.10, PAGE 8.10-1) ASSUMED A MINIMUM PRE-TRIP 345 KV BUS VOLTAGE OF 348 KV. CONTRARY TO THE ABOVE, ON SOME OCCASIONS IN 1983 THE PLANT WAS OPERATED AT BUS VOLTAGES BETWEEN 342 KV AND 345 KV WITHOUT A PRIOR SAFETY EVALUATION. ALTHOUGH A SUBSEQUENT LICENSEE ANALYSIS INDICATES THAT OPERATING VOLTAGES SUBSTANTIALLY LOWER THAN 342 KV ARE ACCEPTABLE, THE LICENSEE DID NOT CONDUCT A SAFETY EVALUATION IN ADVANCE TO DETERMINE IF SUCH OPERATING VOLTAGES INVOLVED A UNREVIEWED SAFETY QUESTION.
(8322 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: JULY 9-13, 1984

INSPECTION REPORT NO: 84-09

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE			

1. Docket: 50-254 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: DAVE KIMLER (309) 654-2241 X192

4. Licensed Thermal Power (MWt): 2511

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 789

7. Maximum Dependable Capacity (Gross MWe): 813

8. Maximum Dependable Capacity (Net MWe): 769

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>107,135.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>1,562.1</u>	<u>85,117.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,421.9</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>1,561.2</u>	<u>81,908.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>909.2</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>3,659,732</u>	<u>166,766,438</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>1,213,148</u>	<u>54,471,876</u>
19. Net Elec Ener (MWH)	<u>-3,423</u>	<u>1,144,207</u>	<u>50,749,467</u>
20. Unit Service Factor	<u>.0</u>	<u>30.5</u>	<u>76.5</u>
21. Unit Avail Factor	<u>.0</u>	<u>30.5</u>	<u>77.3</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>29.1</u>	<u>61.6</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>28.4</u>	<u>60.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>5.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>2,728.0</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 08/11/84

* QUAD CITIES 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

QUAD CITIES 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* QUAD CITIES 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-14	03/06/84	S	744.0	C	4		RC	FUELXX	UNIT ONE REMAINS SHUTDOWN FOR END OF CYCLE SEVEN REFUELING AND MAINTENANCE.

* SUMMARY *

QUAD CITIES 1 REMAINED SHUT DOWN FOR REFUELING AND MAINTENANCE DURING ALL OF JULY.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

* QUAD CITIES 1 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....ROCK ISLAND
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI NE OF
MOLINE, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY ..OCTOBER 18, 1971
DATE ELEC ENER 1ST GENER...APRIL 12, 1972
DATE COMMERCIAL OPERATE...FEBRUARY 18, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....A. MADISON
LICENSING PROJ MANAGER.....R. BEVAN
DOCKET NUMBER.....50-254
LICENSE & DATE ISSUANCE...DPR-29, DECEMBER 14, 1972
PUBLIC DOCUMENT ROOM.....MOLINE PUBLIC LIBRARY
504 17TH STREET
MOLINE, ILLINOIS 61265

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON APRIL 18, MAY 3-4, 16-17, 24, JUNE 6-7 AND 29, (84-06): REVIEW OF INSERVICE INSPECTION (ISI) ACTIVITIES; INSPECTION AND REPAIR OF STAINLESS STEEL PIPING IN THE UNIT 1 DRYWELL, TORUS MODIFICATION; IE BULLETIN AND JET PUMP INSTRUMENTAL PENETRATION ACTIVITIES. THE INSPECTION INVOLVED A TOTAL OF 69 INSPECTOR-HOURS BY TWO NRC INSPECTORS INCLUDING 11 INSPECTOR-HOURS DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* QUAD CITIES 1 *

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS SHUT DOWN FOR REFUELING. EXPECTED STARTUP 8/06/84.

LAST IE SITE INSPECTION DATE: AUGUST 6-31, 1984

INSPECTION REPORT NO: 84-14

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-10	05/03/84	06/25/84	REACTOR SCRAM.

=====

1. Docket: 50-265 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: DAVE KIMLER (309) 654-2241 X192

4. Licensed Thermal Power (Mwt): 2511

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 789

7. Maximum Dependable Capacity (Gross MWe): 813

8. Maximum Dependable Capacity (Net MWe): 769

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>106,245.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,565.1</u>	<u>81,482.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,985.8</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,455.0</u>	<u>78,664.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>702.9</u>
17. Gross Therm Ener (MWH)	<u>1,820,040</u>	<u>8,100,023</u>	<u>163,482,111</u>
18. Gross Elec Ener (MWH)	<u>580,384</u>	<u>2,619,090</u>	<u>52,054,848</u>
19. Net Elec Ener (MWH)	<u>554,452</u>	<u>2,494,629</u>	<u>48,829,503</u>
20. Unit Service Factor	<u>100.0</u>	<u>67.6</u>	<u>74.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>67.6</u>	<u>74.7</u>
22. Unit Cap Factor (MDC Net)	<u>96.9</u>	<u>63.5</u>	<u>59.8</u>
23. Unit Cap Factor (DER Net)	<u>94.5</u>	<u>61.9</u>	<u>58.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.1</u>	<u>8.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>148.1</u>	<u>3,338.2</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>NONE</u>			

27. If Currently Shutdown Estimated Startup Date: N/A

* QUAD CITIES 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

QUAD CITIES 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * QUAD CITIES 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-29	07/03/84	S	0.0	B	5		CH	DEMINX	REDUCED LOAD TO PERFORM CONDENSATE DEMINERALIZER CHANGEOVER.
84-30	07/04/84	S	0.0	H	5		IB	INSTRU	REDUCED LOAD DUE TO HIGH LPRM READING.
84-31	07/06/84	S	0.0	H	5		IB	INSTRU	REDUCED LOAD DUE TO HIGH LPRM READING.
84-32	07/07/84	S	0.0	B	5		HA	TURBIN	REDUCED LOAD TO PERFORM WEEKLY TURBINE TESTS.
84-33	07/15/84	S	0.0	B	5		HA	TURBIN	REDUCED LOAD TO PERFORM WEEKLY TURBINE TESTS.
84-34	07/17/84	S	0.0	B	5		CH	PUMPXX	REDUCED LOAD TO PERFORM TEST ON 2B REACTOR FEEDWATER PUMP.
84-35	07/22/84	S	0.0	B	5		HA	TURBIN	REDUCED LOAD TO PERFORM WEEKLY TURBINE TESTS.
84-36	07/29/84	S	0.0	B	5		HA	TURBIN	REDUCED LOAD TO PERFORM WEEKLY TURBINE TESTS.

 * QUAD CITIES 2 OPERATED ROUTINELY IN JULY. *
 * SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* QUAD CITIES 2 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....ROCK ISLAND
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI NE OF
MOLINE, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...APRIL 26, 1972
DATE ELEC ENER 1ST GENER...MAY 23, 1972
DATE COMMERCIAL OPERATE...MARCH 10, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....A. MADISON
LICENSING PROJ MANAGER....R. BEVAN
DOCKET NUMBER.....50-265
LICENSE & DATE ISSUANCE...DPR-30, DECEMBER 14, 1972
PUBLIC DOCUMENT ROOM.....MOLINE PUBLIC LIBRARY
504 17TH STREET
MOLINE, ILLINOIS 61265

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON APRIL 18, MAY 3-4, 16-17, 24, JUNE 6-7 AND 29, (84-05): REVIEW OF INSERVICE INSPECTION (ISI) ACTIVITIES; INSPECTION AND REPAIR OF STAINLESS STEEL PIPING IN THE UNIT 1 DRYWELL, TORUS MODIFICATION; IE BULLETIN AND JET PUMP INSTRUMENTAL PENETRATION ACTIVITIES. THE INSPECTION INVOLVED A TOTAL OF 69 INSPECTOR-HOURS BY TWO NRC INSPECTORS INCLUDING 11 INSPECTOR-HOURS DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* QUAD CITIES 2 *

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: AUGUST 6-31, 1984

INSPECTION REPORT NO: 84-12

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-06	06/01/84	06/25/84	WEEKLY POWER OPERATION SURV. INTERVAL EXCEEDED.
84-08	07/04/84	07/20/84	HPCI COOLING WATER RETURN VALVE FAILURE.

=====

1. Docket: 50-312 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: RON COLOMBO (916) 452-3211

4. Licensed Thermal Power (MWt): 2772

5. Nameplate Rating (Gross MWe): 1070 X 0.9 = 963

6. Design Electrical Rating (Net MWe): 918

7. Maximum Dependable Capacity (Gross MWe): 917

8. Maximum Dependable Capacity (Net MWe): 873

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>81,432.0</u>
13. Hours Reactor Critical	<u>62.0</u>	<u>3,631.9</u>	<u>47,983.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>790.9</u>	<u>10,104.7</u>
15. Hrs Generator On-Line	<u>59.8</u>	<u>3,504.6</u>	<u>46,046.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,210.2</u>
17. Gross Therm Ener (MWH)	<u>142,221</u>	<u>8,549,909</u>	<u>114,461,251</u>
18. Gross Elec Ener (MWH)	<u>46,940</u>	<u>2,852,014</u>	<u>38,248,086</u>
19. Net Elec Ener (MWH)	<u>37,346</u>	<u>2,672,919</u>	<u>36,047,243</u>
20. Unit Service Factor	<u>8.0</u>	<u>68.6</u>	<u>56.5</u>
21. Unit Avail Factor	<u>8.0</u>	<u>68.6</u>	<u>58.0</u>
22. Unit Cap Factor (MDC Net)	<u>5.7</u>	<u>59.9</u>	<u>50.7</u>
23. Unit Cap Factor (DER Net)	<u>5.5</u>	<u>57.0</u>	<u>48.2</u>
24. Unit Forced Outage Rate	<u>92.0</u>	<u>31.4</u>	<u>28.2</u>
25. Forced Outage Hours	<u>684.2</u>	<u>1,606.4</u>	<u>18,016.4</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING - JANUARY 1985, THREE MONTHS

27. If Currently Shutdown Estimated Startup Date: 08/15/84

* RANCHO SECO 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

RANCHO SECO 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* RANCHO SECO 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
8	07/03/84	F	684.2	A	1	84-20	CI	HTEXCH	"B" OTSG TUBE LEAK.

 * SUMMARY *

 RANCHO SECO 1 SHUT DOWN ON JULY 3 FOR A STEAM
 GENERATOR TUBE LEAK AND REMAINED SHUT DOWN THE
 REMAINDER OF THE MONTH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* RANCHO SECO 1 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....CALIFORNIA
COUNTY.....SACRAMENTO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI SE OF
SACRAMENTO, CA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...SEPTEMBER 16, 1974
DATE ELEC ENER 1ST GENER...OCTOBER 13, 1974
DATE COMMERCIAL OPERATE....APRIL 17, 1975
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...FOLSOM CANAL
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....SACRAMENTO MUN. UTIL. DISTRICT
CORPORATE ADDRESS.....6201 S STREET P.O. BOX 15830
SACRAMENTO, CALIFORNIA 95813
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTORBECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....J. ECKHARD
LICENSING PROJ MANAGER.....S. MINER
DOCKET NUMBER.....50-312
LICENSE & DATE ISSUANCE....DPR-54, AUGUST 16, 1974
PUBLIC DOCUMENT ROOM.....BUSINESS AND MUNICIPAL DEPARTMENT
SACRAMENTO CITY - COUNTY LIBRARY
828 I STREET
SACRAMENTO, CALIFORNIA 95814

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON MAY 21-25, AND TELEPHONE DISCUSSION ON JUNE 12, 1984 (REPORT NO. 50-312/84-08) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION BY A REGIONALLY BASED INSPECTOR OF UNRESOLVED ITEMS (NUREG-0737, II.B.3, PASS AND OFFSITE DOSE CALCULATION CODE ERRORS), NUREG-0737, II.F.1 FOLLOWUP ITEMS; LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; OFFSITE DOSE CALCULATIONS; CONTROL OF RADIOACTIVE MATERIALS; FOLLOWUP OF REPORTABLE OCCURRENCES; FOLLOWUP ON INFORMATION NOTICE; COMPLIANCE WITH 10 CFR 61 AND A FACILITY TOUR. THE INSPECTION INVOLVED 36 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED. TWO PREVIOUSLY IDENTIFIED UNRESOLVED ITEMS WERE EXAMINED BUT REMAIN UNRESOLVED.

+ INSPECTION ON APRIL 27 - JUNE 15, 1984 (REPORT NO. 50-312/84-09) AREAS INSPECTED: THIS ROUTINE INSPECTION WAS IN THE AREAS OF FOLLOWUP OF PLANT OPERATIONS; LICENSEE'S COMMITMENTS; OPERATION SAFETY VERIFICATION; AND PLANT MAINTENANCE. THE INSPECTION INVOLVED 236 INSPECTOR-HOURS ONSITE BY THE NRC RESIDENT INSPECTORS.

RESULTS: OF THE AREAS INSPECTED, ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN THE AREA OF CALIBRATION OF NUCLEAR INSTRUMENTATION.

+ INSPECTION ON JUNE 18-22, 1984 (REPORT NO. 50-312/84-11) AREAS INSPECTED: AN ANNOUNCED, ROUTINE INSPECTION OF THE EMERGENCY PREPAREDNESS PROGRAM INCLUDING CORRECTIVE ACTION ON A NOTICE OF VIOLATION; EMERGENCY DETECTION AND CLASSIFICATION; PROTECTIVE ACTION DECISION MAKING NOTIFICATIONS AND COMMUNICATIONS; CHANGES TO THE EMERGENCY PREPAREDNESS PROGRAM; TRAINING; AUDITS OF THE

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* RANCHO SECO 1 *

OTHER ITEMS

LAST IE SITE INSPECTION DATE: 07/19-08/24/84+

INSPECTION REPORT NO: 50-312/84-19+

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE			

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-261 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: A. E. SCOTT (803) 383-4524

4. Licensed Thermal Power (MWt): 2300

5. Nameplate Rating (Gross MWe): 254 X 0.9 = 769

6. Design Electrical Rating (Net MWe): 700

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 665

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>117,557.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>616.1</u>	<u>84,196.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>38.9</u>	<u>1,675.5</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>615.8</u>	<u>82,065.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>23.2</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>783,895</u>	<u>162,875,180</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>246,010</u>	<u>52,344,876</u>
19. Net Elec Ener (MWH)	<u>-1,497</u>	<u>211,961</u>	<u>49,431,585</u>
20. Unit Service Factor	<u>.0</u>	<u>12.0</u>	<u>69.8</u>
21. Unit Avail Factor	<u>.0</u>	<u>12.0</u>	<u>69.8</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>6.2</u>	<u>63.2</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>5.9</u>	<u>60.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>17.2</u>	<u>14.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>128.2</u>	<u>8,233.5</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):	<u>NONE</u>		

27. If Currently Shutdown Estimated Startup Date: 10/25/84

 * ROBINSON 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ROBINSON 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* ROBINSON 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
0701	01/26/84	S	744.0	C	4		CJ	HTEXCH	CONTINUATION OF REFUELING AND STEAM GENERATOR REPLACEMENT OUTAGE.

* SUMMARY *

ROBINSON 2 CONTINUED IN A REFUELING AND MAINTENANCE SHUTDOWN FOR THE ENTIRE MONTH OF JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* ROBINSON 2 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....DARLINGTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI NW OF
HARTSVILLE, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...SEPTEMBER 20, 1970
DATE ELEC ENER 1ST GENER...SEPTEMBER 26, 1970
DATE COMMERCIAL OPERATE...MARCH 7, 1971
CONDENSER COOLING METHOD...RECIRCULATION
CONDENSER COOLING WATER...ROBINSON IMPOUNDMENT
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CAROLINA POWER & LIGHT
CORPORATE ADDRESS.....411 FAYETTEVILLE STREET
RALEIGH, NORTH CAROLINA 27601
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....S. WEISE
LICENSING PROJ MANAGER.....G. REQUA
DOCKET NUMBER.....50-261
LICENSE & DATE ISSUANCE....DPR-23, SEPTEMBER 23, 1970
PUBLIC DOCUMENT ROOM.....HARTSVILLE MEMORIAL LIBRARY
220 N. FIFTH ST.
HARTSVILLE, SOUTH CAROLINA 29550

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 11 - AUGUST 10 (84-26): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 48 RESIDENT INSPECTOR-HOURS ON SITE IN THE AREAS OF TECHNICAL SPECIFICATION COMPLIANCE, PLANT TOUR, OPERATIONS PERFORMANCE, REPORTABLE OCCURRENCES, HOUSEKEEPING, SITE SECURITY, SURVEILLANCE ACTIVITIES, MAINTENANCE ACTIVITIES, QUALITY ASSURANCE PRACTICES, RADIATION CONTROL ACTIVITIES, OUTSTANDING ITEMS REVIEW, IE BULLETIN, AND NOTICE FOLLOWUP, ORGANIZATION AND ADMINISTRATION, AND ENFORCEMENT ACTION FOLLOWUP. OF THE 15 AREAS INSPECTED, NO VIOLATION OR DEVIATIONS WERE IDENTIFIED IN 14 AREAS; ONE VIOLATION WAS FOUND IN ONE AREA (FAILURE TO ESTABLISH SUITABLE CONTROLS). NO APPARENT DEVIATION WAS FOUND IN ANY AREA.

INSPECTION JULY 25-27 (84-27): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 23 INSPECTOR-HOURS ON SITE IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, STEAM GENERATOR REPLACEMENT PROJECT, PRESERVICE INSPECTION/INSERVICE INSPECTION AND INSPECTOR FOLLOWUP ITEMS. TWO VIOLATIONS: FAILURE TO IDENTIFY VALVE STATUS, AND FAILURE TO FOLLOW RT CODE. NO DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

FAILURE TO MAINTAIN SECURITY RELATED EQUIPMENT INOPERABLE CONDITION.
(8421 5)

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * SALEM 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-174	04/02/84	S	192.0	C	4		RC	FUELXX	NUCLEAR NORMAL REFUELING.
84-176	07/09/84	F	552.0	A	9		HA	GENERA	GENERATOR LIQUID COOLING SYSTEM.

 * SUMMARY *

 SALEM 1 COMPLETED REFUELING IN JULY AND REMAINED SHUT DOWN FOR A GENERATOR COOLING SYSTEM PROBLEM.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SALEM 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEW JERSEY
COUNTY.....SALEM
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI S OF
WILMINGTON, DEL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 11, 1976
DATE ELEC ENER 1ST GENER...DECEMBER 25, 1976
DATE COMMERCIAL OPERATE...JUNE 30, 1977
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...DELAWARE RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PUBLIC SERVICE ELECTRIC & GAS
CORPORATE ADDRESS.....80 PARK PLACE
NEWARK, NEW JERSEY 07101
CONTRACTOR
ARCHITECT/ENGINEER.....PUBLIC SERVICES & GAS CO.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. LINVILLE
LICENSING PROJ MANAGER.....D. FISCHER
DOCKET NUMBER.....50-272
LICENSE & DATE ISSUANCE...DPR-70, DECEMBER 1, 1976
PUBLIC DOCUMENT ROOM.....SALEM FREE PUBLIC LIBRARY
112 WEST BROADWAY
SALEM, NEW JERSEY 08079

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

CRITERION VI, APPENDIX B, 10 CFR 50 REQUIRES THAT MEASURES BE ESTABLISHED TO CONTROL THE ISSUANCE OF PROCEDURES. FURTHER CRITERION VI REQUIRES THAT THESE MEASURES SHALL ASSURE THAT DOCUMENTS ARE REVIEWED FOR ADEQUACY AND APPROVED FOR RELEASE BY AUTHORIZED PERSONNEL. THE LICENSEE'S ENGINEERING DEPARTMENT ORGANIZATION AND DESIGN PROCEDURES DATED DECEMBER 1, 1980 STATES THAT THE DESIGN PROCEDURES PROVIDE COMPLIANCE WITH THE INTENT OF NRC REGULATORY GUIDE 1.64 FOR THE DESIGN OF NUCLEAR POWER PLANTS. THIS GUIDE ESTABLISHES OVERALL QUALITY ASSURANCE REQUIREMENTS FOR THE DESIGN OF NUCLEAR POWER PLANTS IN ACCORDANCE WITH APPENDIX B OF 10 CFR 50. THE LICENSEE ENGINEERING DEPARTMENT PROCEDURE ON DOCUMENT CONTROL REQUIRES THAT DESIGN DOCUMENTS BE CONTROLLED. CONTRARY TO THE ABOVE PSE&G PROCEDURE, "CRITERIA FOR CALCULATING EXPANSION BOLT LOADS WITH FLAT PLATE SUPPORTS", DATED AUGUST 3, 1979 IS NOT A CONTROLLED DOCUMENT MEETING THE LICENSEE'S STANDARD FORMAT, NOR DOES IT SHOW RELEASE BY AUTHORIZED PERSONNEL. THIS IS A SEVERITY LEVEL V VIOLATION (SUPPLEMENT I) APPLICABLE TO DPR-70 AND SEVERITY LEVEL V (SUPPLEMENT II) APPLICABLE TO DPR-75. CRITERION VI, APPENDIX B, 10 CFR 50 REQUIRES THAT MEASURES BE ESTABLISHED TO CONTROL THE ISSUANCE OF PROCEDURES. FURTHER CRITERION VI REQUIRES THAT THESE MEASURES SHALL ASSURE THAT DOCUMENTS ARE REVIEWED FOR ADEQUACY AND APPROVED FOR RELEASE BY AUTHORIZED PERSONNEL. THE LICENSEE'S ENGINEERING DEPARTMENT ORGANIZATION AND DESIGN PROCEDURES DATED DECEMBER 1, 1980 STATES THAT

1. Docket: 50-311 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: L. K. MILLER (609) 935-6000 X4455

4. Licensed Thermal Power (MWT): 3411

5. Nameplate Rating (Gross MWe): 1162

6. Design Electrical Rating (Net MWe): 1115

7. Maximum Dependable Capacity (Gross MWe): 1149

8. Maximum Dependable Capacity (Net MWe): 1106

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>24,552.0</u>
13. Hours Reactor Critical	<u>136.8</u>	<u>2,055.1</u>	<u>13,763.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>1,443.0</u>	<u>3,533.6</u>
15. Hrs Generator On-Line	<u>129.8</u>	<u>1,899.4</u>	<u>13,316.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>399,636</u>	<u>6,143,345</u>	<u>39,614,417</u>
18. Gross Elec Ener (MWH)	<u>133,290</u>	<u>2,038,100</u>	<u>12,906,390</u>
19. Net Elec Ener (MWH)	<u>119,910</u>	<u>1,904,068</u>	<u>12,221,319</u>
20. Unit Service Factor	<u>17.4</u>	<u>37.2</u>	<u>54.2</u>
21. Unit Avail Factor	<u>17.4</u>	<u>37.2</u>	<u>54.2</u>
22. Unit Cap Factor (MDC Net)	<u>14.6</u>	<u>33.7</u>	<u>45.0</u>
23. Unit Cap Factor (DER Net)	<u>14.5</u>	<u>33.4</u>	<u>44.6</u>
24. Unit Forced Outage Rate	<u>82.6</u>	<u>62.8</u>	<u>35.7</u>
25. Forced Outage Hours	<u>614.2</u>	<u>3,211.6</u>	<u>7,394.7</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 08/08/84

* SALEM 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SALEM 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * SALEM 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-214	07/05/84	F	459.5	A	1		SF	PIPEXX	NUCLEAR HIGH PRESSURE PIPING CORE COOLING.
84-216	07/25/84	F	0.0	B	5		CG	INSTRU	FEEDWATER REGULATING BOILER LEVEL CONTROL VALVE.
84-218	07/25/84	F	154.7	A	3		CJ	VALVEX	POWER OPERATED RELIEF AND SAFETY/RELIEF VALVES REACTOR.

 * SUMMARY *

 SALEM 2 EXPERIENCED 2 SHUTDOWNS IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SALEM 2 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEW JERSEY
COUNTY.....SALEM
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI S OF
WILMINGTON, DEL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 8, 1980
DATE ELEC ENER 1ST GENER...JUNE 3, 1981
DATE COMMERCIAL OPERATE...OCTOBER 13, 1981
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...DELAWARE RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PUBLIC SERVICE ELECTRIC & GAS
CORPORATE ADDRESS.....80 PARK PLACE
NEWARK, NEW JERSEY 07101
CONTRACTOR
ARCHITECT/ENGINEER.....PUBLIC SERVICES & GAS CO.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. LINVILLE
LICENSING PROJ MANAGER.....D. FISCHER
DOCKET NUMBER.....50-311
LICENSE & DATE ISSUANCE...DPR-75, MAY 20, 1981
PUBLIC DOCUMENT ROOM.....SALEM FREE PUBLIC LIBRARY
112 WEST BROADWAY
SALEM, NEW JERSEY 08079

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

1. Docket: 50-206 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: L. I. MAYWEATHER (714) 492-7700 X56223

4. Licensed Thermal Power (MWt): 1347

5. Nameplate Rating (Gross MWe): 500 X 0.9 = 450

6. Design Electrical Rating (Net MWe): 436

7. Maximum Dependable Capacity (Gross MWe): 456

8. Maximum Dependable Capacity (Net MWe): 436

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>150,151.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>88,440.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>84,821.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>108,263,946</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>36,906,434</u>
19. Net Elec Ener (MWH)	<u>-1,111</u>	<u>-12,217</u>	<u>34,929,542</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>56.5</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>56.5</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>53.3</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>53.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>21.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>11,178.3</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 10/01/84

* SAN ONOFRE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
SAN ONOFRE 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* SAN ONOFRE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
78	02/27/82	S	744.0	B	4		ZZ	ZZZZZZ	EXTENDED OUTAGE TO ACCOMPLISH SEISMIC BACKFIT AND MISCELLANEOUS MAINTENANCE ITEMS.

* SUMMARY *

SAN ONOFRE 1 REMAINS SHUTDOWN FOR SEISMIC BACKFIT AND MISCELLANEOUS MAINTENANCE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SAN ONOFRE 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....CALIFORNIA
COUNTY.....SAN DIEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S OF
SAN CLEMENTE, CA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JUNE 14, 1967
DATE ELEC ENER 1ST GENER...JULY 16, 1967
DATE COMMERCIAL OPERATE...JANUARY 1, 1968
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...PACIFIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....SOUTHERN CALIFORNIA EDISON
CORPORATE ADDRESS.....2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....A. DANGELO
LICENSING PROJ MANAGER.....E. MCKENNA
DOCKET NUMBER.....50-206
LICENSE & DATE ISSUANCE...DPR-13, MARCH 27, 1967
PUBLIC DOCUMENT ROOM.....SAN CLEMENTE BRANCH LIBRARY
242 AVENIDA DEL MAR
SAN CLEMENTE, CALIFORNIA 92672

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON JUNE 4-8, 1984 (REPORT NO. 50-206/84-12) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S PROGRAMS FOR PROCUREMENT; HANDLING; STORAGE; AND PRESERVATION OF SAFETY-RELATED MATERIALS. THE INSPECTION INCLUDED FOLLOWUP ACTIONS REQUIRED BY TEMPORARY INSTRUCTION 2730/1 AND FOLLOWUP ON UNRESOLVED ITEM 50-362/80-06-01. THE INSPECTION INVOLVED 51 INSPECTOR-HOURS ON-SITE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

- + INSPECTION ON APRIL 30 - JUNE 10, 1984 (REPORT NO. 50-206/84-13) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JUNE 12 - JULY 24, 1984 (REPORT NO. 50-206/84-14) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JULY 9-20, 1984 (REPORT NO. 50-206/84-16) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JUNE 26-29, 1984 (REPORT NO. 50-206/84-17) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JULY 23-27, 1984 (REPORT NO. 50-206/84-18) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JULY 27 - SEPTEMBER 7, 1984 (REPORT NO. 50-206/84-19) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

1. Docket: 50-361 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: L. I. MAYWEATHER (714) 492-7700 X 223

4. Licensed Thermal Power (MWt): 3410

5. Nameplate Rating (Gross MWe): 1127

6. Design Electrical Rating (Net MWe): 1070

7. Maximum Dependable Capacity (Gross MWe): 1127

8. Maximum Dependable Capacity (Net MWe): 1070

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>8,616.0</u>
13. Hours Reactor Critical	<u>150.0</u>	<u>3,379.5</u>	<u>5,992.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>131.0</u>	<u>3,285.8</u>	<u>5,847.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>377,677</u>	<u>10,691,317</u>	<u>19,184,852</u>
18. Gross Elec Ener (MWH)	<u>120,323</u>	<u>3,605,252</u>	<u>6,517,216</u>
19. Net Elec Ener (MWH)	<u>102,468</u>	<u>3,401,818</u>	<u>6,177,462</u>
20. Unit Service Factor	<u>17.6</u>	<u>64.3</u>	<u>67.9</u>
21. Unit Avail Factor	<u>17.6</u>	<u>64.3</u>	<u>67.9</u>
22. Unit Cap Factor (MDC Net)	<u>12.9</u>	<u>62.1</u>	<u>67.0</u>
23. Unit Cap Factor (DER Net)	<u>12.9</u>	<u>62.1</u>	<u>67.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.6</u>	<u>4.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>156.8</u>	<u>257.7</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING, NOVEMBER 1984, 4 MONTH DURATION

27. If Currently Shutdown Estimated Startup Date: N/A

 * SAN ONOFRE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SAN ONOFRE 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* SAN ONOFRE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
5	06/20/84	S	613.0	B	4				REPLACEMENT OF REACTOR COOLANT PUMP SEALS.

* SUMMARY *

SAN ONOFRE EXPERIENCED 1 SHUTDOWN IN JULY FOR RCS PUMP SEAL REPLACEMENT.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SAN ONOFRE 2 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....CALIFORNIA
COUNTY.....SAN DIEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S OF
SAN CLEMENTE, CA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JULY 26, 1982
DATE ELEC ENER 1ST GENER...SEPTEMBER 20, 1982
DATE COMMERCIAL OPERATE...AUGUST 8, 1983
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...PACIFIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....SOUTHERN CALIFORNIA EDISON
CORPORATE ADDRESS.....P.O. BOX 800
ROSEMEAD, CALIFORNIA 91770
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC COM (ENG VERSION)

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....A. CHAFFEE
LICENSING PROJ MANAGER.....H. ROOD
DOCKET NUMBER.....50-361
LICENSE & DATE ISSUANCE...., SEPTEMBER 7, 1982
PUBLIC DOCUMENT ROOM.....SAN CLEMENTE LIBRARY
242 AVENIDA DEL MAR
SAN CLEMENTE, CALIFORNIA

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON JUNE 4-8, 1984 (REPORT NO. 50-361/84-15) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S PROGRAMS FOR PROCUREMENT; HANDLING; STORAGE; AND PRESERVATION OF SAFETY-RELATED MATERIALS. THE INSPECTION INCLUDED FOLLOWUP ACTIONS REQUIRED BY TEMPORARY INSTRUCTION 2730/1 AND FOLLOWUP ON UNRESOLVED ITEM 50-362/80-06-01. THE INSPECTION INVOLVED 51 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON APRIL 30 - JUNE 10, 1984 (REPORT NO. 50-361/84-16) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON MAY 14, 1984 (REPORT NO. 50-361/84-17) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JUNE 12 - JULY 24, 1984 (REPORT NO. 50-361/84-18) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JUNE 5-8, 1984 (REPORT NO. 50-361/84-19) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF PRECRITICAL, LOW POWER, AND POWER ASCENSION TEST RESULTS DATA FOR UNITS 2 AND 3. THE INSPECTION INVOLVED 32 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

Report Period JUL 1984

R E P O R T S F R O M L I C E N S E E

* SAN ONOFRE 2 *

```
=====
```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
04-28-84	04-28-84	05-10-84	SPEC RPT-CONDENSER MONITOR RE-7818 005 2RE-7870 REMOVED FROM SERVICE FOR SURVEILLANCE
05-14-84	05-14-84	05-25-84	SPEC RPT-PURGE/VENT MONITOR RE-7865 INOPERABLE-RETURNED TO SERVICE 5/21/84
31-44-L1	12-02-83	06-18-84	FOLLOWUP RPT-OXYGEN INLEAKAGE IN WASTE GAS SYSTEM DUE TO COMPRESSION FITTINGS-CORRECTIVE ACTION
84-23-L0	05-24-84	06-21-84	ACTUATION OF CONTROL RM ISOLATION SYSTEM (CRIS) DUE TO MONITOR RE-78-25 NOISE SPIKE-REV1 TO RPT
84-27-L0	05-02-84	06-01-84	GAS RELEASE DUE TO WASTE GAS COMPRESSOR CHECK VALVE FAILURE AND RUPTURE DISC FAIL-FIX W/ 2/3 DOWN
84-28-L0	05-05-84	06-04-84	GAS RELEASE-WASTE GAS SYSTEM PRESSURE CONTROL VALVE FAILURE-VALVE FAILED MECHANICALLY-REPLACED

```
=====
```

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-362 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: L. I. MAYWEATHER (714) 492-7700 X56223

4. Licensed Thermal Power (Mwt): 3390

5. Nameplate Rating (Gross MWe): 1127

6. Design Electrical Rating (Net MWe): 1080

7. Maximum Dependable Capacity (Gross MWe): 1127

8. Maximum Dependable Capacity (Net MWe): 1080

9. If Changes Occur Above Since Last Report, Give Reasons:
MDC NET & DER REFLECT AUXILIARY STATION LOADS.

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>2,927.0</u>	<u>2,927.0</u>
13. Hours Reactor Critical	<u>304.7</u>	<u>1,799.7</u>	<u>1,799.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>287.9</u>	<u>1,592.5</u>	<u>1,592.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>638,154</u>	<u>4,735,759</u>	<u>4,735,759</u>
18. Gross Elec Ener (MWH)	<u>266,226</u>	<u>1,635,312</u>	<u>1,635,312</u>
19. Net Elec Ener (MWH)	<u>242,494</u>	<u>1,522,799</u>	<u>1,522,799</u>
20. Unit Service Factor	<u>38.7</u>	<u>54.4</u>	<u>54.4</u>
21. Unit Avail Factor	<u>38.7</u>	<u>54.4</u>	<u>54.4</u>
22. Unit Cap Factor (MDC Net)	<u>30.2</u>	<u>48.2</u>	<u>48.2</u>
23. Unit Cap Factor (DER Net)	<u>30.2</u>	<u>48.2</u>	<u>48.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.0</u>	<u>1.0</u>
25. Forced Outage Hours	<u>.0</u>	<u>16.7</u>	<u>16.7</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 08/15/84

 * S A N O N O F R E 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 SAN ONOFRE 3



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * SAN ONOFRE 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
5	06/11/84	S	151.8	A	4				CONTINUATION OF SCHEDULED OUTAGE FOR REPLACEMENT OF REACTOR COOLANT PUMP SEALS.
6	07/19/84	S	304.3	B	2		AB	SG	REPAIR OF PRIMARY TO SECONDARY LEAK IN STEAM GENERATOR E-089.

 * SUMMARY *

 SAN ONOFRE 3 INCURRED 2 SHUTDOWNS IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SAN ONOFRE 3 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....CALIFORNIA
COUNTY.....SAN DIEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S OF
SAN CLEMENTE, CA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 29, 1983
DATE ELEC ENER 15% CENER...SEPTEMBER 25, 1983
DATE COMMERCIAL OPERATE...APRIL 1, 1984
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...PACIFIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....SOUTHERN CALIFORNIA EDISON
CORPORATE ADDRESS.....P.O. BOX 800
ROSEMEAD, CALIFORNIA 91770
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC COM (ENG VERSION)

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....A. CHAFFEE
LICENSING PROJ MANAGER.....H. ROOD
DOCKET NUMBER.....50-362
LICENSE & DATE ISSUANCE...NPF-15, NOVEMBER 15, 1982
PUBLIC DOCUMENT ROOM.....SAN CLEMENTE LIBRARY
242 AVENIDA DEL MAR
SAN CLEMENTE, CALIFORNIA

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON JUNE 4-8, 1984 (REPORT NO. 50-362/84-15) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S PROGRAMS FOR PROCUREMENT; HANDLING; STORAGE; AND PRESERVATION OF SAFETY-RELATED MATERIALS. THE INSPECTION INCLUDED FOLLOWUP ACTION REQUIRED BY TEMPORARY INSTRUCTION 2730/1 AND FOLLOWUP ON UNRESOLVED ITEM 50-362/80-06-01. THE INSPECTION INVOLVED 51 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON APRIL 30 - JUNE 10, 1984 (REPORT NO. 50-362/84-17) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JUNE 12 - JULY 24, 1984 (REPORT NO. 50-362/84-18) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JUNE 5-8, 1984 (REPORT NO. 50-362/84-19) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF PRECRITICAL, LOW POWER, AND POWER ASCENSION TEST RESULTS DATA FOR UNITS 2 AND 3. THE INSPECTION INVOLVED 32 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JUNE 18-21, 1984 (REPORT NO. 50-362/84-20) AREAS INSPECTED: THIS WAS A ROUTINE, ANNOUNCED, CONFIRMATORY MEASUREMENTS INSPECTION INVOLVING THE REGION V MOBILE LABORATORY. THE INSPECTION INVOLVED 68 INSPECTOR-HOURS ONSITE BY TWO NRC

Report Period JUL 1984

R E P O R T S F R O M L I C E N S E E

* SAN ONOFRE 3 *

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
05-24-84	05-24-84	06-07-84	SPEC RPT-WITH CONDENSER MONITOR 3RE-7818 DOS 3RE-7870 REMOVED FROM SERVICE FOR SURVEILLANCE
84-10-L0	04-24-84	05-22-84	CONTAINMENT PURGE ISO SYS ACTUATION CAUSED BY NOISE SPIKES CONTAINMENT MONITOR 3RT-7804
84-11-L0	02-27-84	03-28-84	DISCONNECTED LEADS IN PPS CABINETS
84-12-L0	03-30-84	04-30-84	MAIN STEAM ISOLATION VALVES INOPERABLE
84-14-L0	04-15-84	05-15-84	CHARGING PUMPS INOPERABLE
84-15-L0	04-27-84	05-29-84	DOSE EQUIVALENT IODINE LIMITS EXCEEDED
84-16-L0	04-28-84	05-23-84	RX TRIP BKR UNDERVOLTAGE DEVICE ANOMALY
84-17-L0	05-05-84	05-21-84	HIGH SG LEVEL TRIPS
84-18-L0	05-25-84	06-21-84	REACTOR TRIP BREAKER-SERIAL NO. 29 UNDERVOLTAGE DEVICE ANOMALY
84-19-L0	05-05-84	05-31-84	CONTAINMENT ISO VALVES SURVEILLANCE MISSED
84-20-L0	05-27-84	06-26-84	FAILURE TO COLLECT TIMELY SAMPLE CONDENSER EVAC MONITORS RT-7818 & 7870 005-DUE TO ISOL SAMP PUMP

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-327 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: MIKE EDDINGS (615) 870-6248

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1220

6. Design Electrical Rating (Net MWe): 1148

7. Maximum Dependable Capacity (Gross MWe): 1183

8. Maximum Dependable Capacity (Net MWe): 1148

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>27,043.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>2,676.1</u>	<u>17,117.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>2,521.8</u>	<u>16,634.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWh)	<u>2,533,527</u>	<u>7,634,989</u>	<u>53,126,789</u>
18. Gross Elec Ener (MWh)	<u>831,710</u>	<u>2,499,950</u>	<u>17,881,086</u>
19. Net Elec Ener (MWh)	<u>803,282</u>	<u>2,391,807</u>	<u>17,168,735</u>
20. Unit Service Factor	<u>100.0</u>	<u>49.3</u>	<u>61.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>49.3</u>	<u>61.5</u>
22. Unit Cap Factor (MDC Net)	<u>94.0</u>	<u>40.8</u>	<u>55.3</u>
23. Unit Cap Factor (DER Net)	<u>94.0</u>	<u>40.8</u>	<u>55.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>32.7</u>	<u>21.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>1,227.7</u>	<u>4,608.4</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimate Startup Date: N/A

* SEQUOYAH 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
SEQUOYAH 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* SEQUOYAH 1 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

THERE WERE NO SHUTDOWNS OR POWER REDUCTIONS AT SEQUOYAH 1 IN JULY.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System & Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

* SEQUOYAH 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....TENNESSEE
COUNTY.....HAMILTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9.5 MI NE OF
CHATTANOOGA, TN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JULY 5, 1980
DATE ELEC ENER 1ST GENER...JULY 22, 1980
DATE COMMERCIAL OPERATE...JULY 1, 1981
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CHICKAMAUGA LAKE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....TENNESSEE VALLEY AUTHORITY
CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II
CHATTANOOGA, TENNESSEE 37401
CONTRACTOR
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....E. FORD
LICENSING PROJ MANAGER.....C. STAHL
DOCKET NUMBER.....50-327
LICENSE & DATE ISSUANCE...DPR-77, SEPTEMBER 17, 1980
PUBLIC DOCUMENT ROOM.....CHATTANOOGA - HAMILTON BICENTENNIAL LIBRARY
1001 BROAD STREET
CHATTANOOGA, TENNESSEE 37402

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 18-20 (84-15): THIS ROUTINE ANNOUNCED INSPECTION INVOLVED 62 INSPECTOR-HOURS ON SITE IN THE AREAS OF AN EMERGENCY EXERCISE. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 9-13 (84-16): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 21 INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT CHEMISTRY AND INSERVICE INSPECTION OF PUMPS AND VALVES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 6 - JULY 5 (84-17): THIS ROUTINE INSPECTION INVOLVED 69 INSPECTOR-HOURS ON SITE IN THE AREAS OF OPERATIONAL SAFETY VERIFICATION, ESF SYSTEM OPERABILITY VERIFICATION, INDEPENDENT INSPECTION EFFORT, SURVEILLANCE AND MAINTENANCE, AND LER REVIEW. OF THE SIX AREAS INSPECTED NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN FIVE AREAS; TWO WERE FOUND IN ONE AREA (FAILURE TO LOCK CONTAINMENT ISOLATION VALVE 1-33-704, AND FAILURE TO MAINTAIN CONTAINMENT CLEAR OF DEBRIS).

INSPECTION JULY 22-26 (84-19): THIS ROUTINE UNANNOUNCED INSPECTION ENTAILED 18 INSPECTOR-HOURS ON-SITE (SIX HOURS ON BACK SHIFT) INSPECTING: SECURITY ORGANIZATION - PERSONNEL AND RESPONSE; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; ACCESS CONTROL - PERSONNEL AND VEHICLES; DETECTION AIDS - PROTECTED AND VITAL AREAS AND COMMUNICATIONS. THREE VIOLATIONS WERE IDENTIFIED - FAILURE TO ESCORT VISITORS WHILE IN THE PROTECTED AREA, FAILURE TO PROPERLY SEARCH VEHICLES PRIOR TO ENTERING THE PROTECTED AREA AND FAILURE TO SECURE A DESIGNATED VEHICLE IN THE PROTECTED AREA.

1. Docket: 50-328 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: DAVID DUPREE (615) 870-6543

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1220

6. Design Electrical Rating (Net MWe): 1148

7. Maximum Dependable Capacity (Gross MWe): 1183

8. Maximum Dependable Capacity (Net MWe): 1148

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>19,008.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,035.4</u>	<u>15,396.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>704.8</u>	<u>4,959.0</u>	<u>15,113.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,105,415</u>	<u>16,351,509</u>	<u>48,769,576</u>
18. Gross Elec Ener (MWH)	<u>699,640</u>	<u>5,600,290</u>	<u>16,632,230</u>
19. Net Elec Ener (MWH)	<u>673,665</u>	<u>5,397,464</u>	<u>16,015,202</u>
20. Unit Service Factor	<u>94.7</u>	<u>97.0</u>	<u>79.5</u>
21. Unit Avail Factor	<u>94.7</u>	<u>97.0</u>	<u>79.5</u>
22. Unit Cap Factor (MDC Net)	<u>78.9</u>	<u>92.0</u>	<u>73.4</u>
23. Unit Cap Factor (DER Net)	<u>78.9</u>	<u>92.0</u>	<u>73.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.9</u>	<u>7.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>94.4</u>	<u>1,196.2</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING/MODIFICATION- SEPT. 7, 1984-57 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

* SEQUOYAH 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SEQUOYAH 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * SEQUOYAH 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
5	06/29/84	S	39.2	B	4				MANUALLY SHUTDOWN TO REPAIR FEEDWATER DRAIN VALVE 3-526. REACTOR AT 2%.

 * SUMMARY *

 SEQUOYAH 2 CONTINUED SHUTDOWN FOR FEEDWATER DRAIN VALVE REPAIR UNTIL JULY 2.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

1. Docket: 50-335 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: N. W. GRANT (305) 552-3675

4. Licensed Thermal Power (MWt): 2700

5. Nameplate Rating (Gross MWe): 1000 X 0.39 = 890

6. Design Electrical Rating (Net MWe): 830

7. Maximum Dependable Capacity (Gross MWe): 867

8. Maximum Dependable Capacity (Net MWe): 822

9. If Changes Occur Above Since Last Report, Give Reasons:

6&7 INCREASED 5/25/83 BASED ON WATER TEMPS

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>66,719.0</u>
13. Hours Reactor Critical	<u>740.2</u>	<u>1,933.8</u>	<u>46,400.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>205.3</u>
15. Hrs Generator On-Line	<u>658.8</u>	<u>1,737.8</u>	<u>45,314.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>39.3</u>
17. Gross Therm Ener (MWH)	<u>1,732,947</u>	<u>4,415,111</u>	<u>113,083,049</u>
18. Gross Elec Ener (MWH)	<u>579,010</u>	<u>1,469,480</u>	<u>36,843,355</u>
19. Net Elec Ener (MWH)	<u>547,296</u>	<u>1,370,862</u>	<u>34,700,562</u>
20. Unit Service Factor	<u>88.5</u>	<u>34.0</u>	<u>67.9</u>
21. Unit Avail Factor	<u>88.5</u>	<u>34.0</u>	<u>68.0</u>
22. Unit Cap Factor (MDC Net)	<u>89.5</u>	<u>32.6</u>	<u>63.3</u>
23. Unit Cap Factor (DER Net)	<u>88.6</u>	<u>32.3</u>	<u>62.7</u>
24. Unit Forced Outage Rate	<u>11.5</u>	<u>5.2</u>	<u>4.6</u>
25. Forced Outage Hours	<u>85.2</u>	<u>94.7</u>	<u>2,199.4</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* ST LUCIE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ST LUCIE 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * ST LUCIE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
06	07/18/84	F	73.9	A	1		HH	HTEXCH	THE UNIT WAS SHUTDOWN TO REPAIR A LEAKING CONDENSER TUBE PLUG. THE UNIT REMAINED SHUT DOWN UNTIL THE SECONDARY CHEMISTRY CONDITIONS RESULTING FROM THE TUBE PLUG LEAK WERE CORRECTED. FULL POWER OPERATION WAS ALSO DELAYED DUE TO SECONDARY CHEMISTRY CONDITIONS.
07	07/26/84	F	11.3	A	3	84-006	HH	INSTRU	A MALFUNCTION OF A CONDENSER VACUUM INSTRUMENT CAUSED A TURBINE AND REACTOR TRIP. THE UNIT WAS RETURNED TO POWER FOLLOWING THE MOST TRIP REVIEW.

***** ST LUCIE 1 INCURRED 2 SHUTDOWNS IN JULY AS DISCUSSED ABOVE.
 * SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

X ST LUCIE 1 X

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....FLORIDA
COUNTY.....ST LUCIE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...12 MI SE OF
FT. PIERCE, FLA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 22, 1976
DATE ELEC ENER 1ST GENER...MAY 7, 1976
DATE COMMERCIAL OPERATE...DECEMBER 21, 1976
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...ATLANTIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER & LIGHT
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 529100
MIAMI, FLORIDA 33152
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....C. FEIERABEND
LICENSING PROJ MANAGER.....D. SELLS
DOCKET NUMBER.....50-335
LICENSE & DATE ISSUANCE...DPR-67, MARCH 1, 1976
PUBLIC DOCUMENT ROOM.....INDIAN RIVER COMMUNITY COLLEGE LIBRARY
3209 VIRGINIA AVENUE
FT. PIERCE, FLORIDA 33450

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 15 - AUGUST 11 (84-23): THIS ROUTINE RESIDENT INSPECTION INVOLVED 74 RESIDENT INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT OPERATION, SURVEILLANCE OBSERVATION, MAINTENANCE OBSERVATION, I.E. BULLETINS, UNIT 1 REACTOR TRIP, AND PREVIOUSLY IDENTIFIED ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ DURING REFUELING OUTAGE, THE THERMAL SHIELD WITHIN THE REACTOR VESSEL WAS FOUND TO BE BROKEN. THE SHIELD HAS BEEN REMOVED.

FACILITY ITEMS (PLANS AND PROCEDURES):

1. Docket: 50-389 OPERATING STATUS
2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0
3. Utility Contact: N. W. GRANT (305) 552-3675
4. Licensed Thermal Power (MWt): 2560
5. Nameplate Rating (Gross MWe): 0850
6. Design Electrical Rating (Net MWe): 804
7. Maximum Dependable Capacity (Gross MWe): 832
8. Maximum Dependable Capacity (Net MWe): 786
9. If Changes Occur Above Since Last Report, Give Reasons:
10. Power Level To Which Restricted, If Any (Net MWe): _____
11. Reasons for Restrictions, If Any: _____


NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>8,616.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,092.4</u>	<u>8,319.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,956.6</u>	<u>8,087.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,900,263</u>	<u>12,564,694</u>	<u>20,222,638</u>
18. Gross Elec Ener (MWH)	<u>632,850</u>	<u>4,207,510</u>	<u>6,750,730</u>
19. Net Elec Ener (MWH)	<u>599,375</u>	<u>3,981,029</u>	<u>6,378,615</u>
20. Unit Service Factor	<u>100.0</u>	<u>97.0</u>	<u>93.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>97.0</u>	<u>93.9</u>
22. Unit Cap Factor (MDC Net)	<u>102.5</u>	<u>99.1</u>	<u>94.2</u>
23. Unit Cap Factor (DER Net)	<u>100.2</u>	<u>96.9</u>	<u>92.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>2.4</u>	<u>5.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>124.3</u>	<u>498.9</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):	<u>REFUELING, OCTOBER 1984, 7 WEEKS</u>		
27. If Currently Shutdown Estimated Startup Date:	<u>N/A</u>		

 * ST LUCIE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ST LUCIE 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* ST LUCIE 2 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

ST LUCIE 2 OPERATED IN JULY WITH NO SHUTDOWNS OR
SIGNIFICANT POWER REDUCTIONS REPORTED.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System & Component</u>	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

* ST LUCIE 2 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....FLORIDA
COUNTY.....ST LUCIE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...12 MI SE OF
FT. PIERCE, FLA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JUNE 2, 1983
DATE ELEC ENER 1ST GENER...JUNE 13, 1983
DATE COMMERCIAL OPERATE...AUGUST 8, 1983
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...ATLANTIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER & LIGHT
CORPORATE ADDRESS.....9250 WEST FLAGLER ST., P.O. BOX 529100
MIAMI, FLORIDA 33152
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....C. FEIERABEND
LICENSING PROJ MANAGER.....D. SELLS
DOCKET NUMBER.....50-389
LICENSE & DATE ISSUANCE...NPF-16, JUNE 10, 1983
PUBLIC DOCUMENT ROOM.....INDIAN RIVER COMMUNITY COLLEGE LIBRARY
3209 VIRGINIA AVENUE
FT. PIERCE, FLORIDA 33450

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 15 - AUGUST 11 (84-25): THIS ROUTINE RESIDENT INSPECTION INVOLVED 73 RESIDENT INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT OPERATION, SURVEILLANCE OBSERVATION, MAINTENANCE OBSERVATION, I.E. BULLETINS, UNIT 1 REACTOR TRIP, AND PREVIOUSLY IDENTIFIED ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

PERFORMING STARTUP TESTING.
SYSTEMS AND COMPONENT PROBLEMS:
NONE.

1. Docket: 50-395 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: G. A. LOIGNON (803) 345-5209

4. Licensed Thermal Power (MWt): 2775

5. Nameplate Rating (Gross MW): 0900

6. Design Electrical Rating (Net MWe): 900

7. Maximum Dependable Capacity (Gross MWe): 900

8. Maximum Dependable Capacity (Net MWe): 885

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>5,111.0</u>
13. Hours Reactor Critical	<u>450.9</u>	<u>3,857.2</u>	<u>3,857.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>416.4</u>	<u>3,707.4</u>	<u>3,707.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>333,316</u>	<u>9,626,900</u>	<u>9,626,900</u>
18. Gross Elec Ener (MWH)	<u>267,820</u>	<u>3,202,533</u>	<u>3,202,533</u>
19. Net Elec Ener (MWH)	<u>247,805</u>	<u>3,051,029</u>	<u>3,051,029</u>
20. Unit Service Factor	<u>56.0</u>	<u>72.5</u>	<u>72.5</u>
21. Unit Avail Factor	<u>56.0</u>	<u>72.5</u>	<u>72.5</u>
22. Unit Cap Factor (MDC Net)	<u>37.6</u>	<u>67.1</u>	<u>67.5</u>
23. Unit Cap Factor (DER Net)	<u>37.0</u>	<u>66.3</u>	<u>66.3</u>
24. Unit Forced Outage Rate	<u>44.0</u>	<u>14.3</u>	<u>14.3</u>
25. Forced Outage Hours	<u>327.6</u>	<u>618.2</u>	<u>618.8</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING, SEPTEMBER 1984, 60 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

 * SUMMER 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SUMMER 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * SUMMER 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	07/14/84	F	321.2	A	1				SHUTDOWN TO REPAIR STEAM GENERATOR TUBE LEAK.
8	07/29/84	F	6.4	A	3				TRIP ON LO-LO STEAM GENERATOR LEVEL CAUSED BY FEEDWATER REG. VALVE ERRATIC OPERATION.

 * SUMMARY *

 THERE WERE 2 SHUTDOWNS AT SUMMER IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SUMMER 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....FAIRFIELD
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...26 MI NW OF
COLUMBIA, SC
TYPE OF REACTOR.....P.JR
DATE INITIAL CRITICALITY...OCTOBER 22, 1982
DATE ELEC ENER 1ST GENER...NOVEMBER 16, 1982
DATE COMMERCIAL OPERATE...JANUARY 1, 1984
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MONTICELLO RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....SOUTH CAROLINA ELECTRIC & GAS CO.
CORPORATE ADDRESS.....P.O. BOX 764
COLUMBIA, SOUTH CAROLINA 29202
CONTRACTOR
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DANIEL INTERNATIONAL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....C. HEHL
LICENSING PROJ MANAGER.....J. HOPKINS
DOCKET NUMBER.....50-395
LICENSE & DATE ISSUANCE...NPF-12, NOVEMBER 12, 1982
PUBLIC DOCUMENT ROOM.....FAIRFIELD COUNTY LIBRARY
GARDEN & WASHINGTON STREETS
WINNSBORO, SOUTH CAROLINA 29180

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 9-13 (84-17): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 32 INSPECTOR-HOURS ON SITE IN THE AREA OF EMERGENCY PREPAREDNESS. OF THE AREA INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 9-13 (84-18): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 98 INSPECTOR-HOURS ON SITE IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS; QA PROGRAM REVIEW; QA/QC ADMINISTRATION; AUDITS; PROCUREMENT CONTROL; RECEIPT, STORAGE, AND HANDLING OF EQUIPMENT AND MATERIALS; INDEPENDENT INSPECTION; AND LICENSEE ACTION ON PREVIOUSLY IDENTIFIED INSPECTION FINDINGS. OF THE EIGHT AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 23-27 (84-19): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 26 INSPECTOR-HOURS ON SITE (TWO HOURS ON BACK-SHIFT) AND SIX INSPECTOR-HOURS AT THE CORPORATE OFFICE INSPECTING: SECURITY ORGANIZATION-PERSONNEL/RESPONSE, SECURITY PROGRAM AUDIT, TESTING AND MAINTENANCE, PHYSICAL BARRIERS-PROTECTED AREA/VITAL AREAS, SECURITY SYSTEM POWER SUPPLY, ASSESSMENT AIDS, ACCESS CONTROL-PERSONNEL/PACKAGES/ VEHICLES, AND ALARM STATIONS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 23-27 (84-21): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 32 INSPECTOR-HOURS ON SITE IN THE AREAS OF STEAM GENERATOR TUBE LEAKAGE, INSERVICE INSPECTION, INSERVICE TESTING OF PUMPS AND VALVES, AND INSPECTOR FOLLOWUP ITEMS - RELATED TO AIR HANDLING UNITS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

1. Docket: 50-289 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: VIVIAN H. JONES (804) 357-3184

4. Licensed Thermal Power (MWt): 2441

5. Nameplate Rating (Gross MWe): 942 X 0.9 = 846

6. Design Electrical Rating (Net MWe): 788

7. Maximum Dependable Capacity (Gross MWe): 811

8. Maximum Dependable Capacity (Net MWe): 775

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>101,759.0</u>
13. Hours Reactor Critical	<u>566.1</u>	<u>3,806.8</u>	<u>62,905.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>9.3</u>	<u>3,774.5</u>
15. Hrs Generator On-Line	<u>553.0</u>	<u>3,733.8</u>	<u>61,600.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,736.2</u>
17. Gross Therm Ener (MWH)	<u>1,032,229</u>	<u>8,416,246</u>	<u>142,816,859</u>
18. Gross Elec Ener (MWH)	<u>321,605</u>	<u>2,706,160</u>	<u>46,026,003</u>
19. Net Elec Ener (MWH)	<u>300,179</u>	<u>2,562,327</u>	<u>43,640,063</u>
20. Unit Service Factor	<u>74.3</u>	<u>73.1</u>	<u>60.5</u>
21. Unit Avail Factor	<u>74.3</u>	<u>73.1</u>	<u>64.2</u>
22. Unit Cap Factor (MDC Net)	<u>52.1</u>	<u>64.7</u>	<u>55.3</u>
23. Unit Cap Factor (DER Net)	<u>51.2</u>	<u>63.6</u>	<u>54.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>5.4</u>	<u>20.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>212.3</u>	<u>12,424.1</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* SURRY 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
SURRY 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* SURRY 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-8	07/21/84	S	191.0	B	1				UNIT WAS SHUT DOWN FOR SCHEDULED SNUBBER OUTAGE.

* SUMMARY *

SURRY 1 INCURRED 1 SHUTDOWN IN JULY FOR A SCHEDULED
SNUBBER OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SURRY 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....VIRGINIA
COUNTY.....SURRY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI NW OF
NEWPORT NEWS, VA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JULY 1, 1972
DATE ELEC ENER 1ST GENER...JULY 4, 1972
DATE COMMERCIAL OPERATE...DECEMBER 22, 1972
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...JAMES RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VIRGINIA ELECTRIC & POWER
CORPORATE ADDRESS.....P.O. BOX 26666
RICHMOND, VIRGINIA 23261
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONF & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....D. BURKE
LICENSING PROJ MANAGER.....D. NEIGHBORS
DOCKET NUMBER.....50-280
LICENSE & DATE ISSUANCE...DPR-32, MAY 25, 1972
PUBLIC DOCUMENT ROOM.....SWEM LIBRARY
COLLEGE OF WILLIAM AND MARY
WILLIAMSBURG, VIRGINIA 23185

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 16-18 (84-21): THIS REACTIVE UNANNOUNCED INSPECTION INVOLVED 19 INSPECTOR-HOURS ON SITE IN THE FOLLOWUP OF LICENSEE EVENTS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 1-31 (84-22): THIS INSPECTION INVOLVED 110 INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT OPERATIONS AND OPERATING RECORDS, PLANT MAINTENANCE AND SURVEILLANCE, PLANT SECURITY, FOLLOWUP OF EVENTS, AND LICENSEE EVENT REPORTS. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 9-11 (84-23): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 10 INSPECTOR-HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

10 CFR 20.311(D)(3) REQUIRES THAT ANY LICENSEE WHO TRANSFERS RADIOACTIVE WASTE TO A LAND DISPOSAL FACILITY CONDUCT A QUALITY CONTROL PROGRAM TO ASSURE COMPLIANCE WITH 10 CFR 61.55 AND 61.56. THE QUALITY CONTROL PROGRAM MUST INCLUDE AUDITS. CONTRARY TO THE ABOVE, THE REQUIREMENT TO CONDUCT A QUALITY CONTROL PROGRAM WHICH INCLUDE AUDITS WAS NOT MET, IN THAT NO AUDITS WHICH EVALUATED LICENSEE COMPLIANCE WITH THE REQUIREMENTS OF 10 CFR 61 HAD BEEN PERFORMED OR SCHEDULED.
(8418 5)

1. Docket: 50-281 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: VIVIAN H. JONES (804) 357-3184

4. Licensed Thermal Power (MWt): 2441

5. Nameplate Rating (Gross MWe): 942 X 0.9 = 848

6. Design Electrical Rating (Net MWe): 788

7. Maximum Dependable Capacity (Gross MWe): 811

8. Maximum Dependable Capacity (Net MWe): 775

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____


11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>98,639.0</u>
13. Hours Reactor Critical	<u>730.9</u>	<u>4,358.3</u>	<u>62,928.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>23.8</u>	<u>23.8</u>
15. Hrs Generator On-Line	<u>725.7</u>	<u>4,304.6</u>	<u>61,880.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>0</u>	<u>0</u>
17. Gross Therm Ener (MWH)	<u>1,734,983</u>	<u>10,149,620</u>	<u>144,865,492</u>
18. Gross Elec Ener (MWH)	<u>549,485</u>	<u>3,239,005</u>	<u>47,028,864</u>
19. Net Elec Ener (MWH)	<u>520,129</u>	<u>3,068,743</u>	<u>44,575,803</u>
20. Unit Service Factor	<u>97.5</u>	<u>84.2</u>	<u>62.7</u>
21. Unit Avail Factor	<u>97.5</u>	<u>84.2</u>	<u>62.7</u>
22. Unit Cap Factor (MDC Net)	<u>90.2</u>	<u>77.5</u>	<u>58.3</u>
23. Unit Cap Factor (DER Net)	<u>88.7</u>	<u>76.2</u>	<u>57.3</u>
24. Unit Forced Outage Rate	<u>2.5</u>	<u>9.5</u>	<u>13.8</u>
25. Forced Outage Hours	<u>18.3</u>	<u>449.9</u>	<u>7,276.5</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>FALL MAINTENANCE-11/13/84- 10 DAYS</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

* S U R R Y 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SURRY 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * SURRY 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-19	07/18/84	F	18.3	A	1				UNIT WAS SHUTDOWN TO BALANCE THE #2 L.P. TURBINE DUE TO EXCESSIVE VIBRATION. THREE ONE POUND BALANCING WEIGHTS WERE ADDED TO THE #2 L.P. TURBINE AND THE UNIT WAS RETURNED TO POWER. TURBINE WILL BE INSPECTED DURING REFUELING OUTAGE FOR REASON THAT CAUSED INITIAL VIBRATIONS.

 * SUMMARY *

 SURRY 2 EXPERIENCED 1 SHUTDOWN IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-C161)

* SURRY 2 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....VIRGINIA
COUNTY.....SURRY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR... 17 MI NW OF
NEWPORT NEWS, VA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MARCH 7, 1973
DATE ELEC ENER 1ST GENER...MARCH 10, 1973
DATE COMMERCIAL OPERATE...MAY 1, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...JAMES RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VIRGINIA ELECTRIC & POWER
CORPORATE ADDRESS.....P.O. BOX 26666
RICHMOND, VIRGINIA 23261
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....D. BURKE
LICENSING PROJ MANAGER.....D. NEIGHBORS
DOCKET NUMBER.....50-281
LICENSE & DATE ISSUANCE...DPR-37, JANUARY 29, 1973
PUBLIC DOCUMENT ROOM..... SWEM LIBRARY
COLLEGE OF WILLIAM AND MARY
WILLIAMSBURG, VIRGINIA 23185

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

10 CFR 20.311(D)(3) REQUIRES THAT ANY LICENSEE WHO TRANSFERS RADIOACTIVE WASTE TO A LAND DISPOSAL FACILITY CONDUCT A QUALITY CONTROL PROGRAM TO ASSURE COMPLIANCE WITH 10 CFR 61.55 AND 61.56. THE QUALITY CONTROL PROGRAM MUST INCLUDE AUDITS. CONTRARY TO THE ABOVE, THE REQUIREMENT TO CONDUCT A QUALITY CONTROL PROGRAM WHICH INCLUDE AUDITS WAS NOT MET, IN THAT NO AUDITS WHICH EVALUATED LICENSEE COMPLIANCE WITH THE REQUIREMENTS OF 10 CFR 61 HAD BEEN PERFORMED OR SCHEDULED.
(8419 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

1. Docket: 50-387 OPERATING STATUS
 2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0
 3. Utility Contact: L. A. KUCZYNSKI (71.) 542-2181
 4. Licensed Thermal Power (MWt): 3293
 5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152
 6. Design Electrical Rating (Net MWe): 1065
 7. Maximum Dependable Capacity (Gross MWe): 1068
 8. Maximum Dependable Capacity (Net MWe): 1032
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>10,080.0</u>
13. Hours Reactor Critical	<u>563.4</u>	<u>3,151.4</u>	<u>6,996.7</u>
14. Rx Reserve Shtdwn Hrs	<u>180.6</u>	<u>209.6</u>	<u>366.3</u>
15. Hrs Generator On-Line	<u>523.9</u>	<u>3,026.7</u>	<u>6,795.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,491,021</u>	<u>9,079,656</u>	<u>20,329,427</u>
18. Gross Elec Ener (MWH)	<u>481,250</u>	<u>2,965,470</u>	<u>6,632,020</u>
19. Net Elec Ener (MWH)	<u>461,555</u>	<u>2,853,780</u>	<u>6,390,153</u>
20. Unit Service Factor	<u>70.4</u>	<u>59.2</u>	<u>67.4</u>
21. Unit Avail Factor	<u>70.4</u>	<u>59.2</u>	<u>67.4</u>
22. Unit Cap Factor (MDC Net)	<u>60.1</u>	<u>54.1</u>	<u>61.4</u>
23. Unit Cap Factor (DER Net)	<u>58.3</u>	<u>52.4</u>	<u>59.5</u>
24. Unit Forced Outage Rate	<u>29.6</u>	<u>21.5</u>	<u>16.4</u>
25. Forced Outage Hours	<u>220.1</u>	<u>828.8</u>	<u>1,337.3</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * SUSQUEHANNA 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SUSQUEHANNA 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * SUSQUEHANNA 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
6	07/03/84	F	134.6	H	3	84-029	CH	INSTRU	THE UNIT SCRAMMED ON LOW VESSEL LEVEL CAUSED BY A MOMENTARY LOSS OF SIGNAL TO FEEDWATER AND REACTOR RECIRCULATION CIRCUITRY FOLLOWING A LIGHTNING STRIKE TO A TRANSMISSION LINE WHICH SUPPLIES THE STATION.
7	07/15/84	F	30.4	H	3	84-034	EA	ELECON	THE UNIT SCRAMMED ON TURBINE CONTROL VALVE FAST CLOSURES AS A RESULT OF A PHASE-TO-PHASE FAULT ON THE 230KV TRANSMISSION LINE.
8	07/16/84	F	26.4	A	3	84-033	HC	VALVEX	THE UNIT SCRAMMED ON TURBINE CONTROL VALVE FAST CLOSURE BY LOSS OF CONDENSER VACUUM.
9	07/18/84	F	28.7	G	3	84-035	HC	VALVEX	THE UNIT SCRAMMED DUE TO LOSS OF CONDENSER VACUUM.

 * SUMMARY *

 THERE WERE SEVERAL SHUTDOWNS AT SUSQUEHANNA 1 IN JULY AS DETAILED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& license Examination	9-Other	(LER) File (NUREG-0161)

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* SUSQUEHANNA 1 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NO INPUT PROVIDED.			
=====			


1. Docket: 50-388 O P E R A T I N G S T A T U S
2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0
3. Utility Contact: L. A. KUCZYNSKI (717) 542-3759
4. Licensed Thermal Power (MWt): 3293
5. Nameplate Rating (Gross MWe): 1152
6. Design Electrical Rating (Net MWe): 1065
7. Maximum Dependable Capacity (Gross MWe): 1065
8. Maximum Dependable Capacity (Net MWe): 1065
9. If Changes Occur Above Since Last Report, Give Reasons:
-
10. Power Level To Which Restricted, . . Any (Net MWe): _____
11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>683.0</u>	<u>683.0</u>	<u>683.0</u>
13. Hours Reactor Critical	<u>458.7</u>	<u>458.7</u>	<u>458.7</u>
14. Rx Reserve Shtdwn Hrs	<u>180.3</u>	<u>180.3</u>	<u>180.3</u>
15. Hrs Generator On-Line	<u>392.9</u>	<u>392.9</u>	<u>392.9</u>
16. Unit Reserve Shtdwn Hrs	<u>142.4</u>	<u>142.4</u>	<u>142.4</u>
17. Gross Therm Ener (MWH)	<u>474,034</u>	<u>474,034</u>	<u>474,034</u>
18. Gross Elec Ener (MWH)	<u>121,330</u>	<u>121,330</u>	<u>121,330</u>
19. Net Elec Ener (MWH)	<u>110,281</u>	<u>110,281</u>	<u>110,281</u>
20. Unit Service Factor			
21. Unit Avail Factor		NO IN	
22. Unit Cap Factor (MDC Net)		COMMERCIAL	
23. Unit Cap Factor (DER Net)		OPERATION	
24. Unit Forced Outage Rate			
25. Forced Outage Hours	<u>60.2</u>	<u>60.2</u>	<u>60.2</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):	<u>MAINTENANCE OUTAGE 10/27/84, 7 WEEKS.</u>		
27. If Currently Shutdown Estimated Startup Date:	<u>08/03/84</u>		

 * SUSQUEHANNA 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 SUSQUEHANNA 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * SUSQUEHANNA 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	07/03/84	S	1.9	B	1				STARTUP TESTING.
2	07/05/84	S	85.6	B	2		ZZ	ZZZZZZ	REACTOR SCRAM FOR SCHEDULED STARTUP TESTING.
3	07/15/84	F	60.2	A	3	84-034	HC	RECOMB	REACTOR SCRAM DUE TO TURBINE TRIP CAUSED BY LOW CONDENSER VACUUM.
4	07/26/84	S	142.4	B	3	84-013	ZZ	ZZZZZZ	REACTOR SCRAM FOR SCHEDULED STARTUP TESTING. DUE TO AN INCORRECTLY COMPLETED ELECTRICAL LINEUP, THE DIESEL GENERATORS WERE PREVENTED FROM STARTING AND AN UNUSUAL EVENT WAS DECLARED. THE STARTUP TEST WAS SUBSEQUENTLY REPEATED AND COMPLETED SUCCESSFULLY.

 * SUMMARY *

 SUSQUEHANNA 2 GENERATED INITIAL ELECTRICITY ON JULY 3, 1984.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

* SUSQUEHANNA 2 *

F A C I L I T Y D A T A

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....LUZERNE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...7 MI NE OF
BERWICK, PA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MAY 8, 1984
DATE ELEC ENER 1ST GEHER...JULY 3, 1984
DATE COMMERCIAL OPERATE....*****
CONDENSER COOLING METHOD...CC,HNDCT
CONDENSER COOLING WATER...SUSQUEHANNA RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PENNSYLVANIA POWER & LIGHT
CORPORATE ADDRESS.....2 NORTH NINTH STREET
ALLENTOWN, PENNSYLVANIA 18101
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....L. PLISCO
LICENSING PROJ MANAGER....R. PERCH
DOCKET NUMBER.....50-388
LICENSE & DATE ISSUANCE...NPF-22, JUNE 27, 1984
PUBLIC DOCUMENT ROOM.....

WILKES-BARRE, PENNSYLVANIA 18701

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

1. Docket: 50-289 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: C. W. SMYTH (717) 948-8551

4. Licensed Thermal Power (Mwt): 2535

5. Nameplate Rating (Gross MWe): 968 X 0.9 = 871

6. Design Electrical Rating (Net MWe): 819

7. Maximum Dependable Capacity (Gross MWe): 840

8. Maximum Dependable Capacity (Net MWe): 776

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>86,904.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>31,731.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>839.5</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>31,180.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>.0</u>	<u>.0</u>	<u>76,531,071</u>
18. Gross Elec Ener (MWH)	<u>.0</u>	<u>.0</u>	<u>25,484,330</u>
19. Net Elec Ener (MWH)	<u>.0</u>	<u>.0</u>	<u>23,840,053</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>35.9</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>35.9</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>35.1*</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>33.5</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>60.8</u>
25. Forced Outage Hours	<u>744.0</u>	<u>5,111.0</u>	<u>48,236.5</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* THREE MILE ISLAND 1 *

AVERAGE DAILY POWER LEVEL (Mwe) PLOT

THREE MILE ISLAND 1



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* THREE MILE ISLAND 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
1	02/17/79	F	744.0	D	4			REGULATORY RESTRAINT ORDER CONTINUES.

* SUMMARY *

THREE MILE ISLAND 1 REMAINS SHUT DOWN FOLLOWING THE
ACCIDENT AT TMI-2.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& license Examination		

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* THREE MILE ISLAND 1 *

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

1. Docket: 50-344 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: G. G. BAIR (503) 556-3713 X234

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1280 X 0.95 = 1216

6. Design Electrical Rating (Net MWe): 1130

7. Maximum Dependable Capacity (Gross MWe): 1122

8. Maximum Dependable Capacity (Net MWe): 1080

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>69,383.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>2,793.6</u>	<u>41,643.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,875.4</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>2,776.2</u>	<u>40,330.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,237.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>9,111,746</u>	<u>127,675,599</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>2,940,315</u>	<u>41,515,806</u>
19. Net Elec Ener (MWH)	<u>-1,886</u>	<u>2,812,593</u>	<u>39,226,619</u>
20. Unit Service Factor	<u>.0</u>	<u>54.3</u>	<u>58.1</u>
21. Unit Avail Factor	<u>.0</u>	<u>54.3</u>	<u>62.8</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>51.0</u>	<u>52.3</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>48.7</u>	<u>50.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.8</u>	<u>17.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>50.3</u>	<u>8,352.1</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 08/28/84

* TROJAN *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
TROJAN



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* TROJAN *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-07	04/27/84	S	744.0	C	4	84-06	TA	ZZZZZ	CONTINUED ANNUAL REFUELING/MAINTENANCE OUTAGE.

* SUMMARY *

TROJAN CONTINUES IN A REFUELING AND MAINTENANCE OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* TROJAN *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....OREGON

COUNTY.....COLUMBIA

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...42 MI N OF
PORTLAND, ORE

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...DECEMBER 15, 1975
DATE ELEC ENER 1ST GENER...DECEMBER 23, 1975
DATE COMMERCIAL OPERATE...MAY 20, 1976
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...COLUMBIA RIVER
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PORTLAND GENERAL ELECTRIC

CORPORATE ADDRESS.....121 S.W. SALMON STREET
PORTLAND, OREGON 97204

CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....G. JOHNSTON
LICENSING PROJ MANAGER.....C. TRAMMELL
DOCKET NUMBER.....50-344

LICENSE & DATE ISSUANCE...NPF-1, NOVEMBER 21, 1975

PUBLIC DOCUMENT ROOM.....MULTNOMAH COUNTY LIBRARY
SOCIAL SCIENCES & SCIENCE DEPARTMENT
801 SW 10TH AVENUE
PORTLAND, OREGON 97205

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON MAY 14-18, AND MAY 29 - JUNE 1, 1984 (REPORT NO. 50-344/84-13) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION BY A REGIONALLY BASED INSPECTOR OF THE RADIATION PROTECTION PROGRAM DURING A REFUELING OUTAGE, INCLUDING: GENERAL EMPLOYEE TRAINING; CHEMISTRY AND RADIATION PROTECTION TECHNICIAN QUALIFICATION AND TRAINING; ORGANIZATION AND STAFFING; RECORDS AND REPORTS; PROCEDURES; CALIBRATION OF PORTABLE RADIATION SURVEY INSTRUMENTS; CONTROL OF RADIOACTIVE MATERIAL; RADIATION MONITORING SURVEYS; RESPIRATORY PROTECTION PROGRAM; EXTERNAL AND INTERNAL MONITORING PROGRAM; RADIOACTIVE WASTE MANAGEMENT PURSUANT TO RECENT NRC AND DOT REGULATORY REQUIREMENT CHANGES; POSTING AND LABELING; IE INFORMATION NOTICES; REVIEW OF ANNUAL AND SEMI-ANNUAL ENVIRONMENTAL SURVEILLANCE AND RADIOACTIVE EFFLUENT RELEASE REPORTS; ENVIRONMENTAL TECHNICAL SPECIFICATION MONITORING SURVEILLANCE PROGRAM; LICENSEE EVENT REPORTS; AND A TOUR OF ONSITE FACILITIES AND OF ENVIRONMENTAL MONITORING STATIONS. THE INSPECTION INVOLVED 56 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JUNE 4-8, 1984 (REPORT NO. 50-344/84-15) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF PLANT OPERATIONS, INCLUDING REACTOR INTERNALS MODIFICATIONS TO REVERSE THE BYPASS FLOW DIRECTION AND LICENSEE ACTION ON PREVIOUS INSPECTION ITEMS REGARDING THE SCOPE OF THE CORPORATE QUALITY ASSURANCE AUDIT PROGRAM AND PROVISIONS FOR ASSESSING THE ADEQUACY OF THE QUALITY ASSURANCE PROGRAM. THE INSPECTION INVOLVED 64 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

Report Period JUL 1984

R E P O R T S F R O M L I C E N S E E

* TROJAN *

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-06-L0	04-27-84	05-25-84	AN AUTO REACTOR TRIP OCCURRED DUE TO 'C' SG LOW-LOW LEVEL FOL PLANT TEST THAT TRIPPED NO. MNFWPP
84-10-L0	05-04-84	06-01-84	RHR COOLING WAS LOST DUE TO AIR IN SUCTION OF A PUMP.
84-11-L0	05-08-84	06-07-84	WHILE RECALIBRATING DURING REFUELING ON SSPS INADVERTENT SAFETY INJECTION OCCURRED

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-250 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: N. W. GRANT (305) 552-3675

4. Licensed Thermal Power (MWt): 2200

5. Nameplate Rating (Gross MWe): 894 X 0.85 = 760

6. Design Electrical Rating (Net MWe): 693

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 666

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>102,176.6</u>
13. Hours Reactor Critical	<u>637.9</u>	<u>4,163.7</u>	<u>72,189.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>844.3</u>
15. Hrs Generator On-Line	<u>631.8</u>	<u>4,053.3</u>	<u>69,980.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>121.8</u>
17. Gross Therm Ener (MWH)	<u>1,386,143</u>	<u>8,713,493</u>	<u>144,202,085</u>
18. Gross Elec Ener (MWH)	<u>442,225</u>	<u>2,806,765</u>	<u>46,017,330</u>
19. Net Elec Ener (MWH)	<u>418,797</u>	<u>2,657,621</u>	<u>43,570,638</u>
20. Unit Service Factor	<u>84.9</u>	<u>79.4</u>	<u>68.5</u>
21. Unit Avail Factor	<u>84.9</u>	<u>79.4</u>	<u>68.6</u>
22. Unit Cap Factor (MDC Net)	<u>84.5</u>	<u>78.1</u>	<u>65.8*</u>
23. Unit Cap Factor (DER Net)	<u>81.2</u>	<u>75.0</u>	<u>61.5</u>
24. Unit Forced Outage Rate	<u>15.1</u>	<u>10.7</u>	<u>5.7</u>
25. Forced Outage Hours	<u>112.2</u>	<u>484.3</u>	<u>3,664.4</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* TURKEY POINT 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
TURKEY POINT 3



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * TURKEY POINT 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
14	07/12/84	F	112.2	A	1	84-21	CB	VALVEX	RCS LEAKAGE FROM AN INSTRUMENT ISOLATION VALVE GLAND REQUIRED SHUTDOWN PER TECH SPECS. THE VALVE WAS REPAIRED AND THE UNIT RETURNED TO POWER.

 * SUMMARY *

 TURKEY POINT 3 EXPERIENCED 1 SHUTDOWN IN JULY FOR INSTRUMENT ISOLATION VALVE GLAND LEAKAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* TURKEY POINT 3 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE... FLORIDA
COUNTY... DADE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR... 25 MI S OF
MIAMI, FLA
TYPE OF REACTOR... PWR
DATE INITIAL CRITICALITY... OCTOBER 20, 1972
DATE ELEC ENER: 1ST GENER... NOVEMBER 2, 1972
DATE COMMERCIAL OPERATE... DECEMBER 14, 1972
CONDENSER COOLING METHOD... CLOSED CANAL
CONDENSER COOLING WATER... CLOSED CYCLE CANAL
ELECTRIC RELIABILITY
COUNCIL... SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE... FLORIDA POWER & LIGHT
CORPORATE ADDRESS... 9250 WEST FLAGLER STREET P.O. BOX 013100
MIAMI, FLORIDA 33174
CONTRACTOR
ARCHITECT/ENGINEER... BECHTEL
NUC STEAM SYS SUPPLIER... WESTINGHOUSE
CONSTRUCTOR... BECHTEL
TURBINE SUPPLIER... WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE... II
IE RESIDENT INSPECTOR... T. PEBBLES
LICENSING PROJ MANAGER... D. MCDONALD
DOCKET NUMBER... 50-250
LICENSE & DATE ISSUANCE... DPR-31, JULY 19, 1972
PUBLIC DOCUMENT ROOM... ENVIRONMENTAL AND URBAN AFFAIRS LIBRARY
FLORIDA INTERNATIONAL UNIVERSITY
MIAMI, FLORIDA 33199

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION JANUARY 8-26 (84-04): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 49 INSPECTOR-HOURS ON SITE INCLUDING 22 HOURS ON BACKSHIFT, IN THE AREAS OF FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS, MONTHLY SURVEILLANCE, MONTHLY MAINTENANCE, OPERATIONAL SAFETY VERIFICATION, ENGINEERED SAFETY FEATURES WALKDOWN, INDEPENDENT INSPECTION AND EXIT INTERVIEW. IN ADDITION, A MANAGEMENT MEETING WAS HELD ON SITE ON JANUARY 26, 1984, THE PERSONNEL IN ATTENDANCE AND THE SUBJECT MATTER ARE ADDRESSED IN PARAGRAPH 10. OF THE SIX AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN ONE AREA; TWO VIOLATIONS WERE FOUND IN FIVE AREAS (FAILURE TO IMPLEMENT MANAGEMENT CONTROL; INOPERABLE AUXILIARY FEEDWATER PUMPS) AND ONE DEVIATION FROM A COMMITMENT WAS FOUND IN ONE AREA (FAILURE TO IMPLEMENT TMI TASK ACTION PLAN ITEM I.C.6 - INDEPENDENT VERIFICATION).

INSPECTION MAY 7 - JUNE 9 (84-18): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 131 INSPECTOR-HOURS ON SITE, INCLUDING 53 HOURS OF BACKSHIFT, IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT ITEMS, IE BULLETIN FOLLOWUP, IE CIRCULAR FOLLOWUP, LER FOLLOWUP, ANNUAL AND MONTHLY SURVEILLANCE, ANNUAL AND MONTHLY MAINTENANCE, OPERATIONAL SAFETY, EMERGENCY SAFETY FEATURES WALKDOWN, PLANT TRIPS, REFUELING, FIRE PROTECTION, SPENT FUEL POOL ACTIVITIES, INDEPENDENT INSPECTION AND EXIT INTERVIEW. OF THE FOURTEEN AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN THIRTEEN AREAS; AND ONE VIOLATION WAS FOUND IN THE AREA OF OPERATIONAL SAFETY (FAILURE TO ESTABLISH AND IMPLEMENT AN ADEQUATE PROCEDURE).

INSPECTION JUNE 4-8 (84-19): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 39 INSPECTOR-HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 25-29 (84-21): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 20 INSPECTOR-HOURS ONSITE (8 HOURS ON BACKSHIFT)

Report Period JUL 1984

R E P O R T S F R O M L I C E N S E E

* TURKEY POINT 3 *

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-018	07/17/84	07/24/84	TURKEY POINT PLANT WAS NOTIFIED BY BECHTEL POWER CORPORATION AND POWER PLANT ENGINEERING OF A 10 CFR PART 21 DEFICIENCY CONCERNING THE CONTROL CIRCUITRY FOR PRESSURE CONTROLLERS.
84-020	07/12/84	08/10/84	REACTOR COOLANT SYSTEM LEAK OF APPROXIMATELY 13.5 GPM, THE CAUSE WAS LEAKAGE DUE TO A BROKEN GLAND FLANGE.

IMAGE EVALUATION
TEST TARGET (MT-3)















IMAGE EVALUATION
TEST TARGET (MT-3)



THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-251 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: N. W. GRANT (305) 552-3675

4. Licensed Thermal Power (MWt) 2200

5. Nameplate Rating (Gross MWe): 894 X 0.85 = 760

6. Design Electrical Rating (Net MWe): 693

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 666

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>95,904.0</u>
13. Hours Reactor Critical	<u>472.9</u>	<u>2,518.2</u>	<u>67,157.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>166.4</u>
15. Hrs Generator On-Line	<u>470.2</u>	<u>2,359.1</u>	<u>14,827.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>31.2</u>
17. Gross Therm Ener (MWH)	<u>1,012,203</u>	<u>5,187,030</u>	<u>136,942,771</u>
18. Gross Elec Ener (MWH)	<u>324,255</u>	<u>1,592,755</u>	<u>43,514,117</u>
19. Net Elec Ener (MWH)	<u>306,744</u>	<u>1,496,925</u>	<u>41,204,033</u>
20. Unit Service Factor	<u>63.2</u>	<u>46.2</u>	<u>67.6</u>
21. Unit Avail Factor	<u>63.2</u>	<u>46.2</u>	<u>67.6</u>
22. Unit Cap Factor (MDC Net)	<u>61.9</u>	<u>44.0</u>	<u>66.3*</u>
23. Unit Cap Factor (DER Net)	<u>59.5</u>	<u>42.3</u>	<u>62.0</u>
24. Unit Forced Outage Rate	<u>36.8</u>	<u>23.0</u>	<u>5.3</u>
25. Forced Outage Hours	<u>273.2</u>	<u>705.8</u>	<u>3,247.6</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* TURKEY POINT 4 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

TURKEY POINT 4



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* TURKEY POINT 4 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
18	07/06/84	F	273.8	A	1		CB	PUMPXX	THE UNIT SHUT DOWN TO REPAIR 4A REACTOR COOLANT PUMP NUMBER 2 SEAL. THE UNIT WAS THEN RETURNED TO POWER.

 * SUMMARY *

 TURKEY POINT 3 INCURRED 1 SHUTDOWN IN JULY FOR
 RCS PUMP SEAL REPAIR.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* TURKEY POINT 4 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....FLORIDA
COUNTY.....DADE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI S OF
MIAMI, FLA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JUNE 11, 1973
DATE ELEC ENER 1ST GENER...JUNE 21, 1973
DATE COMMERCIAL OPERATE...SEPTEMBER 7, 1973
CONDENSER COOLING METHOD...CLOSED CANAL
CONDENSER COOLING WATER...CLOSED CYCLE CANAL
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER & LIGHT
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 013100
MIAMI, FLORIDA 33174
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....T. PEEBLES
LICENSING PROJ MANAGER.....D. MCDONALD
DOCKET NUMBER.....50-251
LICENSE & DATE ISSUANCE...DPR-41, APRIL 10, 1973
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL AND URBAN AFFAIRS LIBRARY
FLORIDA INTERNATIONAL UNIVERSITY
MIAMI, FLORIDA 33199

I N S P E C T I O N . S T A T U S

INSPECTION SUMMARY

+ INSPECTION JANUARY 8-26 (84-04): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 49 INSPECTOR-HOURS ON SITE INCLUDING 22 HOURS ON BACKSHIFT, IN THE AREAS OF FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS, MONTHLY SURVEILLANCE, MONTHLY MAINTENANCE, OPERATIONAL SAFETY VERIFICATION, ENGINEERED SAFETY FEATURES WALKDOWN, INDEPENDENT INSPECTION AND EXIT INTERVIEW. IN ADDITION, A MANAGEMENT MEETING WAS HELD ON SITE ON JANUARY 26, 1984. THE PERSONNEL IN ATTENDANCE AND THE SUBJECT MATTER ARE ADDRESSED IN PARAGRAPH 10. OF THE SIX AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN ONE AREA; TWO VIOLATIONS WERE FOUND IN FIVE AREAS (FAILURE TO IMPLEMENT MANAGEMENT CONTROL; INOPERABLE AUXILIARY FEEDWATER PUMPS) AND ONE DEVIATION FROM A COMMITMENT WAS FOUND IN ONE AREA (FAILURE TO IMPLEMENT TMI TASK ACTION PLAN ITEM I.C.6 - INDEPENDENT VERIFICATION).

INSPECTION MAY 7 - JUNE 9 (84-18): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 131 INSPECTOR-HOURS ON SITE, INCLUDING 53 HOURS OF BACKSHIFT, IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT ITEMS, IE BULLETIN FOLLOWUP, IE CIRCULAR FOLLOWUP, LER FOLLOWUP, ANNUAL AND MONTHLY SURVEILLANCE, ANNUAL AND MONTHLY MAINTENANCE, OPERATIONAL SAFETY, EMERGENCY SAFETY FEATURES WALKDOWN, PLANT TRIPS, REFUELING, FIRE PROTECTION, SPENT FUEL POOL ACTIVITIES, INDEPENDENT INSPECTION AND EXIT INTERVIEW. OF THE FOURTEEN AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN THIRTEEN AREAS; AND ONE VIOLATION WAS FOUND IN THE AREA OF OPERATIONAL SAFETY (FAILURE TO ESTABLISH AND IMPLEMENT AN ADEQUATE PROCEDURE).

INSPECTION JUNE 4-8 (84-19): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 39 INSPECTOR-HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 4-6 (84-21): THIS SPECIAL UNANNOUNCED INSPECTION INVOLVED 20 INSPECTOR-HOURS ON SITE IN THE AREA OF EVENT

Report Period JUL 1984

R E P O R T S F R O M L I C E N S E E

* TURKEY POINT 4 *

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-013	06/24/84	07/24/84	AUTOMATIC INITIATION OF AUXILIARY FEEDWATER OCCURRED. THE ROOT CAUSE WAS DETERMINED TO STEM FROM THE TRIP OF THE 4B STEAM GENERATOR FEEDWATER PUMP DUE TO INADEQUATE SUCTION PRESSURE.
84-014	06/26/84	07/25/84	REACTOR TRIP WHILE AT HOT SHUTDOWN CONDITIONS, DUE TO SOURCE RANGE DETECTOR FAILED HIGH ABOVE REACTOR TRIP SETPOINT N-32.
84-015	07/16/84	08/10/84	UNIT 4 EXPERIENCED AN UNEXPECTED START OF THE 4A HIGH HEAD SAFETY INJECTION PUMP. CONSTRUCTION PERSONNEL INADVERTENTLY STRIKING THE LOCAL CONTROL SWITCH.

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-271 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: F. J. BURGER (802) 257-7711 X136

4. Licensed Thermal Power (MWt): 1593

5. Nameplate Rating (Gross MWe): 626 X 0.9 = 563

6. Design Electrical Rating (Net MWe): 514

7. Maximum Dependable Capacity (Gross MWe): 535

8. Maximum Dependable Capacity (Net MWe): 504

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level to Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>103,969.8</u>
13. Hours Reactor Critical	<u>.0</u>	<u>3,886.4</u>	<u>83,584.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>3,854.2</u>	<u>81,346.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>5,932,770</u>	<u>118,093,442</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>2,012,268</u>	<u>39,305,346</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>1,928,790</u>	<u>37,293,806</u>
20. Unit Service Factor	<u>.0</u>	<u>75.4</u>	<u>78.2</u>
21. Unit Avail Factor	<u>.0</u>	<u>75.4</u>	<u>78.2</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>74.9</u>	<u>71.2</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>73.4</u>	<u>69.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>3.8</u>	<u>7.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>150.6</u>	<u>5,041.8</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 08/06/84

* V E R M O N T Y A N K E E 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
VERMONT YANKEE 1



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* VERMONT YANKEE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-12	07/01/84	S	744.0	C	4		RC	FUELXX	REFUELING & MAINTENANCE CONTINUES.

 * SUMMARY *

 A REFUELING AND MAINTENANCE SHUTDOWN CONTINUED AT
 VERMONT YANKEE THROUGHOUT JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) file (NUREG-0161)

* VERMONT YANKEE 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....VERMONT

COUNTY.....WINDHAM

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S OF
BRATTLEBORO, VT

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...MARCH 24, 1972

DATE ELEC ENER 1ST GENER...SEPTEMBER 20, 1972

DATE COMMERCIAL OPERATE...NOVEMBER 30, 1972

CONDENSER COOLING METHOD...COOLING TOWER

CONDENSER COOLING WATER...CONNECTICUT RIVER

ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VERMONT YANKEE NUCLEAR POWER

CORPORATE ADDRESS.....1671 WORCESTER ROAD
FRAMINGHAM, MASSACHUSETTS 01701

CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....EBASCO

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....W. RAYMOND

LICENSING PROJ MANAGER....V. ROONEY
DOCKET NUMBER.....50-271

LICENSE & DATE ISSUANCE...DPR-28, FEBRUARY 28, 1973

PUBLIC DOCUMENT ROOM.....BROOKS MEMORIAL LIBRARY
224 MAIN STREET
BRATTLEBORO, VERMONT 05301

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION (TS) 6.5.A REQUIRES THAT DETAILED WRITTEN PROCEDURES, INCLUDING APPLICABLE CHECK-OFF LISTS, BE PREPARED AND REVIEWED AND APPROVED BY THE PLANT MANAGER AND THE MANAGER OF OPERATIONS. TECHNICAL SPECIFICATION 6.5.D STATES THAT TEMPORARY CHANGES MAY BE MADE TO PROCEDURES PREPARED IN ACCORDANCE WITH TS SECTION 6.5.A PROVIDED THE CHANGES ARE MADE WITH THE CONCURRENCE OF TWO INDIVIDUALS HOLDING A SENIOR REACTOR OPERATOR LICENSE. SUCH CHANGES SHALL BE DOCUMENTED AND SUBSEQUENTLY REVIEWED BY THE PORC AND APPROVED BY THE PLANT MANAGER. PLANT ADMINISTRATIVE PROCEDURES AP 0831 AND AP 0832 WERE WRITTEN PURSUANT TO THE ABOVE TO IMPLEMENT THE REQUIREMENTS OF TECHNICAL SPECIFICATIONS 6.5.A AND 6.5.D. CONTRARY TO THE ABOVE, AS OF MARCH 22, 1984, SECTION A.3 OF ADMINISTRATIVE PROCEDURE AP 0155, REVISION 7, PROMULGATED CONTROLS THAT WERE INCONSISTENT WITH THE REQUIREMENTS OF TECHNICAL SPECIFICATION 6.5 BY ALLOWING CHANGES TO THE PLANT OPERATIONAL STATUS WITHOUT THE LEVEL OF PRE-IMPLEMENTATION REVIEWS OF SUCH CHANGES OTHERWISE REQUIRED BY THE SPECIFICATIONS. SPECIFICALLY, AP 0155 ALLOWED CHANGES TO BE MADE TO SAFETY SYSTEM VALVE LINEUPS DESCRIBED AS CHECK-OFF LISTS IN APPROVED OPERATING PROCEDURES, WITHOUT REQUIRING A REVISION TO THE APPROVED OPERATING PROCEDURE BE MADE FOR THOSE CHANGES THAT CONSTITUTED A CHANGE OF INTENT FROM THE ORIGINAL PROCEDURE, OR REQUIRING THAT A DEPARTMENT INSTRUCTION BE PROCESSED IN ACCORDANCE WITH AP 0832 FOR THOSE CHANGES THAT DO NOT INVOLVE A CHANGE IN INTENT. ACTIONS IMPLEMENTED UNDER THE CONTROLS OF AP 0155 ON AUGUST 22, 1983, CONTRIBUTED TO THE CONCERN DESCRIBED ABOVE REGARDING THE RCIC SYSTEM VALVE LINEUP. IN

1. Docket: 50-397 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: LEONARD HUTCHISON (509) 377-250* X2486

4. Licensed Thermal Power (MWt): 3323

5. Nameplate Rating (Gross MWe): 1100

6. Design Electrical Rating (Net MWe): 1100

7. Maximum Dependable Capacity (Gross MWe): 1100

8. Maximum Dependable Capacity (Net MWe): 1100

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>1,562.2</u>	<u>1,562.2</u>
13. Hours Reactor Critical	<u>243.9</u>	<u>652.1</u>	<u>652.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>198.9</u>	<u>427.4</u>	<u>427.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>259,168</u>	<u>466,245</u>	<u>466,245</u>
18. Gross Elec Ener (MWH)	<u>67,713</u>	<u>102,480</u>	<u>102,480</u>
19. Net Elec Ener (MWH)	<u>61,120</u>	<u>92,686</u>	<u>92,686</u>

20. Unit Service Factor

21. Unit Avail Factor NOT IN

22. Unit Cap Factor (MDC Net) COMMERCIAL

23. Unit Cap Factor (DER Net) OPERATION

24. Unit Forced Outage Rate

25. Forced Outage Hours 545.1 1,118.4 1,118.4

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 08/02/84

 * WASHINGTON NUCLEAR 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

WASHINGTON NUCLEAR 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * WASHINGTON NUCLEAR 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-11	06/19/84	F	36.3	A	4		HE	VALVEX	PLANT SHUTDOWN TO REPAIR A TURBINE BY PASS VALVE WHICH STUCK OPEN FOLLOWING A PLANNED TRIP OF GENERATOR. THE VALVE WAS REPAIRED HOWEVER THE OUTAGE WAS EXTENDED DUE TO REAPIR ON RHR PUMP "B".
84-12	07/10/84	F	508.8	A	1	84-075	EB	GENERA	DURING MONTHLY SURVEILLANCE TESTING OF STANDBY DIESEL GENERATOR 1B (DG1B) THE SLIP RING END BEARING TURNED ON THE SHAFT INSULATION, THUS DESTROYING THE INSULATION AND ALLOWING THE SHAFT TO DROP SLIGHTLY AND RUB ON BEARING HOUSING. MODIFICATIONS, TO IMPROVE RELIABILITY, WERE MADE BY MOUNTING THE BEARINGS DIRECTLY TO SHAFT AND INSULATING THE BEARING HOUSING. (SEE LER 84-075)

 * SUMMARY *

 WNP 2 CONTINUES WITH STARTUP AND POWER ASCENSION TESTING.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* WASHINGTON NUCLEAR 2 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....WASHINGTON
COUNTY.....BENTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI NW OF
RICHLAND, WASH
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JANUARY 16, 1984
DATE ELEC ENER 1ST GENER...MAY 27, 1984
DATE COMMERCIAL OPERATE...*****
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...MECHANICAL TOWERS
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....WASHINGTON PUBLIC POWER SUPPLY SYSTEM
CORPORATE ADDRESS.....P.O. BOX 968
RICHLAND, WASHINGTON 99352
CONTRACTOR
ARCHITECT/ENGINEER.....BURNS & ROE
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....R. FEIL
LICENSING PROJ MANAGER.....R. AULUCK
DOCKET NUMBER.....50-397
LICENSE & DATE ISSUANCE...NPF-21, APRIL 13, 1984
PUBLIC DOCUMENT ROOM.....RICHLAND PUBLIC LIBRARY
SWIFT AND NORTHGATE STREETS
RICHLAND, WA 99352

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON MAY 29 - JUNE 8, 1984 (REPORT NO. 50-397/84-15) AREAS INSPECTED: SPECIAL TEAM INSPECTION OF THE OPERATING CREWS; INFORMATION TURNOVER/EXCHANGE BETWEEN CREWS; AWARENESS OF PLANT/SYSTEM STATUS; LIMITING CONDITIONS OF OPERATION AND TECHNICAL SPECIFICATION COMPLIANCE; ADHERENCE TO PROCEDURES AND ADMINISTRATIVE CONTROLS; REMOVAL AND RESTORATION OF SYSTEM/COMPONENTS FROM/TO SERVICE DURING MAINTENANCE AND SURVEILLANCE ACTIVITIES. THE ORGANIZATIONAL INTEGRATION AND UTILIZATION OF TECHNICAL ADVISORS (STA'S) ON SHIFT AND MANAGEMENT'S INVOLVEMENT AND AWARENESS OF PLANT STATUS AND PROBLEMS WERE ALSO INSPECTED. THE INSPECTION INVOLVED 278 INSPECTOR-HOURS ONSITE BY FOUR NRC INSPECTORS AND 68 INSPECTION HOURS BY ONE NRC CONSULTANT.

RESULTS: OF THE SEVEN AREAS INSPECTED NO VIOLATIONS WERE IDENTIFIED. THE TEAM FOUND THE OPERATING STAFF'S PERFORMANCE TO BE ADEQUATE. HOWEVER, THE FOLLOWING SPECIFIC WEAKNESSES WERE IDENTIFIED FOR MANAGEMENT CONSIDERATION: A) INCONSISTENCY IN THE IMPLEMENTATION OF WALK-DOWN AND CHECKLIST TURNOVERS AT SHIFT CHANGE, INCLUDING FAILURE TO INFORM RELIEF OF AN EXISTING LIMITING CONDITION FOR OPERATION. B) AN OPERATOR WAS NOT AT-THE-CONTROLS AS DEFINED BY PLANT PROCEDURES FOR A BRIEF PERIOD OF TIME WHEN THE REACTOR WAS IN MODE 4. C) LACK OF AWARENESS OF PLANT STATUS ANNUNCIATORS. D) INDEPENDENT VERIFICATION NOT PERFORMED ON DIESEL-GENERATOR EMERGENCY BYPASS SWITCH POSITION. E) LACK OF VISIBILITY OF SENIOR MANAGEMENT IN THE CONTROL ROOM. F) SOME SHIFT DETAILS AND EVENTS WERE NOT ROUTINELY BEING RECORDED IN EITHER THE CONTROL OPERATOR'S OR SHIFT MANAGER'S LOGS. G) WORK PRACTICES WERE NOT CONSISTENT WITH RELIABLE AND PRUDENT OPERATION.

+ INSPECTION ON JUNE 6-30, 1984 (REPORT NO. 50-397/84-18) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JULY 2-31, 1984 (REPORT NO. 50-397/84-19) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* WASHINGTON NUCLEAR 2 *

INSPECTION SUMMARY

- + INSPECTION ON JULY 31 - AUGUST 3, 1984 (REPORT NO. 50-397/84-20) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JUNE 25 - JULY 20, 1984 (REPORT NO. 50-397/84-21) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

MODE 4

LAST IE SITE INSPECTION DATE: 07/31-08/03/84+

INSPECTION REPORT NO: 50-397/84-20+

R E P O R T S F R O M L I C E N S E E

```

=====
NUMBER    DATE OF    DATE OF    SUBJECT
          EVENT    REPORT
-----
84-26-01 04-19-84    -    DELUGE SYSTEM ADMITTED WATER IN STANDBY GAS SYSTEM
=====

```

1. Docket: 50-029 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: S. WHIPPLE (617) 872-8100

4. Licensed Thermal Power (MWt): 600

5. Nameplate Rating (Gross MWe): 185 X 1.0 = 185

6. Design Electrical Rating (Net MWe): 175

7. Maximum Dependable Capacity (Gross MWe): 180

8. Maximum Dependable Capacity (Net MWe): 167

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>207,812.0</u>
13. Hours Reactor Critical	<u>560.9</u>	<u>3,114.5</u>	<u>164,638.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>554.4</u>	<u>3,024.7</u>	<u>159,937.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>320,679</u>	<u>1,729,162</u>	<u>86,612,756</u>
18. Gross Elec Ener (MWH)	<u>97,518</u>	<u>529,908</u>	<u>26,252,774</u>
19. Net Elec Ener (MWH)	<u>91,276</u>	<u>496,289</u>	<u>24,564,678</u>
20. Unit Service Factor	<u>74.5</u>	<u>59.2</u>	<u>77.0</u>
21. Unit Avail Factor	<u>74.5</u>	<u>59.2</u>	<u>77.0</u>
22. Unit Cap Factor (MDC Net)	<u>73.5</u>	<u>58.1</u>	<u>72.8*</u>
23. Unit Cap Factor (DER Net)	<u>70.1</u>	<u>55.5</u>	<u>69.4*</u>
24. Unit Forced Outage Rate	<u>25.5</u>	<u>12.0</u>	<u>5.3</u>
25. Forced Outage Hours	<u>189.6</u>	<u>413.8</u>	<u>7,900.2</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* YANKEE-ROWE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

YANKEE-ROWE 1



JULY 1984

* Item calculated with a Weighted Average

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

* YANKEE-ROWE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-5	07/12/84	F	189.6	H	3	84-12			THE REACTOR TRIPPED WHILE I&C WAS RUNNING HIGH RISK TESTING.

* SUMMARY *

ON JULY 12 YANKEE ROWE TRIPPED DURING HIGH RISK TESTING
BY INSTRUMENTATION AND CONTROL.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* YANKEE-ROWE 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MASSACHUSETTS
COUNTY.....FRANKLIN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI NE OF
PITTSFIELD, MASS
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 19, 1960
DATE ELEC ENER 1ST GENER...NOVEMBER 10, 1960
DATE COMMERCIAL OPERATE...JULY 1, 1961
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...DEERFIELD RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....YANKEE ATOMIC ELECTRIC
CORPORATE ADDRESS.....1671 WORCESTER RD.
FRAMINGHAM, MASSACHUSETTS 01701
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....H. EICHENHOLZ
LICENSING PROJ MANAGER.....P. ERICKSON
DOCKET NUMBER.....50-029
LICENSE & DATE ISSUANCE...DPR-3, DECEMBER 24, 1963
PUBLIC DOCUMENT ROOM.....GREENFIELD COMMUNITY COLLEGE
1 COLLEGE DRIVE
GREENFIELD, MASSACHUSETTS 01301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* YANKEE-ROWE 1 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NO INPUT PROVIDED.			
=====			

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * ZION 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
9	07/18/84	F	316.8		2	84-021		SHUTDOWN THE REACTOR IN ORDER TO PERFORM A CONTAINMENT INTEGRATED LEAK RATE TEST.

 * SUMMARY *

 ZION 1 WAS SHUT DOWN ON JULY 18 FOR AN INTEGRATED LEAK TEST AND REMAINED SHUT DOWN THE REMAINDER OF THE MONTH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* ZION 1 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....LAKE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI N OF
CHICAGO, ILL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JUNE 19, 1973
DATE ELEC ENER 1ST GENER...JUNE 28, 1973
DATE COMMERCIAL OPERATE....DECEMBER 31, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER....LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. WATERS
LICENSING PROJ MANAGER.....J. NORRIS
DOCKET NUMBER.....50-295
LICENSE & DATE ISSUANCE....DPR-39, OCTOBER 19, 1973
PUBLIC DOCUMENT ROOM.....ZION - BENTON PUBLIC LIBRARY
2400 GABRIEL AVENUE
ZION, ILLINOIS 60099

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MAY 12 THROUGH JUNE 29, (84-07): ROUTINE UNANNOUNCED RESIDENT INSPECTION OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, CONDUCT OF MAINTENANCE ON NUCLEAR INSTRUMENTATION, OPERATIONAL SAFETY AND ESF WALCDOWN, MAINTENANCE, SURVEILLANCE, LER FOLLOWUP, SITE VISIT BY COMMISSIONER GILINSKY, MEETING WITH LOCAL PUBLIC OFFICIALS. THESE INSPECTIONS INVOLVED A TOTAL OF 147 HOURS BY TWO NRC INSPECTORS INCLUDING 72 HOURS ONSITE DURING OFF-SHIFTS. OF THE EIGHT AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON MAY 31, JUNE 4-8, 12-13 AND JULY 2, (84-08): ROUTINE, UNANNOUNCED INSPECTION OF THE RADIATION PROTECTION PROGRAM INCLUDING: ORGANIZATION AND MANAGEMENT CONTROLS; EXTERNAL EXPOSURE CONTROL; TRAINING; ALARA; RADIOACTIVE MATERIAL AND CONTAMINATION CONTROL; SPECIFIC IMPROVEMENTS TO THE RADIATION PROTECTION PROGRAM; DIVING OPERATIONS; LICENSEE ACTIONS REGARDING PREVIOUS INSPECTION FINDINGS; AND CERTAIN TMI ACTION PLAN ITEMS. THE INSPECTION INVOLVED 84 INSPECTOR-HOURS ON SITE BY TWO NRC INSPECTORS. OF THE NINE AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED IN EIGHT AREAS. ONE VIOLATION WAS IDENTIFIED IN ONE AREA (UNAUTHORIZED TRANSFER OF BYPRODUCT MATERIAL).

INSPECTION ON JUNE 4-8, (84-09): INCLUDED A REVIEW OF SECURITY ORGANIZATION (PERSONNEL AND RESPONSE); SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS (PROTECTED AND VITAL); SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; ACCESS CONTROLS (PERSONNEL/PACKAGES/VEHICLES); DETECTION AIDS (PROTECTED AND VITAL); ALARM STATIONS; AND COMMUNICATIONS. THE INSPECTION INVOLVED 64 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS AND WAS BEGUN DURING THE DAY SHIFT. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED DURING THE INSPECTION.

1. Docket: 50-304 OPERATING STATUS

2. Reporting Period: 07/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: GERRI AUSTIN (312) 746-2084

4. Licensed Thermal Power (MWt): 3250

5. Nameplate Rating (Gross MWe): 1220 X 0.9 = 1098

6. Design Electrical Rating (Net MWe): 1040

7. Maximum Dependable Capacity (Gross MWe): 1085

8. Maximum Dependable Capacity (Net MWe): 1040

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>86,496.0</u>
13. Hours Reactor Critical	<u>598.5</u>	<u>2,630.5</u>	<u>61,855.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>226.1</u>
15. Hrs Generator On-Line	<u>510.5</u>	<u>2,528.1</u>	<u>60,054.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,334,642</u>	<u>7,539,565</u>	<u>172,455,648</u>
18. Gross Elec Ener (MWH)	<u>425,180</u>	<u>2,455,003</u>	<u>55,159,040</u>
19. Net Elec Ener (MWH)	<u>400,791</u>	<u>2,331,349</u>	<u>52,408,294</u>
20. Unit Service Factor	<u>68.6</u>	<u>49.5</u>	<u>69.4</u>
21. Unit Avail Factor	<u>68.6</u>	<u>49.5</u>	<u>69.4</u>
22. Unit Cap Factor (MDC Net)	<u>51.8</u>	<u>43.9</u>	<u>58.3</u>
23. Unit Cap Factor (DER Net)	<u>51.8</u>	<u>43.9</u>	<u>58.3</u>
24. Unit Forced Outage Rate	<u>31.4</u>	<u>22.0</u>	<u>17.8</u>
25. Forced Outage Hours	<u>233.5</u>	<u>713.6</u>	<u>13,090.3</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* ZION 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
ZION 2



JULY 1984

Report Period JUL 1984

UNIT SHUTDOWNS / REDUCTIONS

 * ZION 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
4	06/13/84	F	83.3	H	4				CONTD FROM ENVIRONMENTAL QUALIFICATION MODIFICATION OUTAGE.
5	07/04/84	F	28.2	G	3	84-017			AN OPERATOR OVERSIGHT IN NOT REALIZING THAT BISTABLES WERE TRIPPED WHILE TRANSFERRING AN INSTRUMENT BUS.
6	07/05/84	F	58.0	A	3				TRIP CAUSED BY A WIRING PROBLEM WITH THE RTD CROSS-CALIBRATION TEST CART.
7	07/08/84	F	46.1	G	3	84-018			IMPROPER USE OF AN INSTRUMENT. PROCEDURE CAUSED A BISTABLE ALIGNMENT THAT STIMULATED THE TURBINE AT >10% POWER WITH THE TURBINE STOP VALVE SHUT.
8	07/09/84	F	17.9	A	3	84-016			LOSS OF POWER TO THE INTERMEDJATE RANGE PRIOR TO REACHING A POWER LEVEL HIGH ENOUGH TO ALLOW BLOCKING OF THE TRIP.

 * SUMMARY *

 THERE WERE 5 SHUTDOWNS AT ZION 2 IN JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* ZION 2 *

FACILITY DATA

Report Period JUL 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....ILLINOIS

COUNTY.....LAKE

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI N OF
CHICAGO, ILL

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...DECEMBER 24, 1973
DATE ELEC ENER 1ST GENER...DECEMBER 26, 1973
DATE COMMERCIAL OPERATE....SEPTEMBER 17, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER....LAKE MICHIGAN

ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY
LICENSEE.....COMMONWEALTH EDISON

CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690

CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....COMMONWEALTH EDISON

TURBINE SUPPLIER.....NONE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. WATERS
LICENSING PROJ MANAGER.....J. NORRIS
DOCKET NUMBER.....50-304

LICENSE & DATE ISSUANCE....DPR-48, NOVEMBER 14, 1973

PUBLIC DOCUMENT ROOM.....ZION - BENTON PUBLIC LIBRARY
2400 GABRIEL AVENUE
ZION, ILLINOIS 60099

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MAY 12 THROUGH JUNE 29, (84-07): ROUTINE UNANNOUNCED RESIDENT INSPECTION OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, CONDUCT OF MAINTENANCE ON NUCLEAR INSTRUMENTATION, OPERATIONAL SAFETY AND ESF WALKDOWN, MAINTENANCE, SURVEILLANCE, LER FOLLOWUP, SITE VISIT BY COMMISSIONER GILINSKY, MEETING WITH LOCAL PUBLIC OFFICIALS. THESE INSPECTIONS INVOLVED A TOTAL OF 147 HOURS BY TWO NRC INSPECTORS INCLUDING 72 HOURS ONSITE DURING OFF-SHIFTS. OF THE EIGHT AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON MAY 31, JUNE 4-8, 12-13 AND JULY 2, (84-08): ROUTINE, UNANNOUNCED INSPECTION OF THE RADIATION PROTECTION PROGRAM INCLUDING: ORGANIZATION AND MANAGEMENT CONTROLS; EXTERNAL EXPOSURE CONTROL; TRAINING; ALARA; RADIOACTIVE MATERIAL AND CONTAMINATION CONTROL; SPECIFIC IMPROVEMENTS TO THE RADIATION PROTECTION PROGRAM; DIVING OPERATIONS; LICENSEE ACTIONS REGARDING PREVIOUS INSPECTION FINDINGS; AND CERTAIN TMI ACTION PLAN ITEMS. THE INSPECTION INVOLVED 84 INSPECTOR-HOURS ON SITE BY TWO NRC INSPECTORS. OF THE NINE AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED IN EIGHT AREAS. ONE VIOLATION WAS IDENTIFIED IN ONE AREA (UNAUTHORIZED TRANSFER OF BYPRODUCT MATERIAL).

INSPECTION ON JUNE 4-8, (84-09): INCLUDED A REVIEW OF SECURITY ORGANIZATION (PERSONNEL AND RESPONSE); SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS (PROTECTED AND VITAL); SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; ACCESS CONTROLS (PERSONNEL/PACKAGES/VEHICLES); DETECTION AIDS (PROTECTED AND VITAL); ALARM STATIONS; AND COMMUNICATIONS. THE INSPECTION INVOLVED 64 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS AND WAS BEGUN DURING THE DAY SHIFT. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED DURING THE INSPECTION.

THIS PAGE INTENTIONALLY LEFT BLANK

SECTION 3

APPENDIX

 * PRESSURIZED *
 * WAWER *
 * REACTORS *

STATUS OF SPENT FUEL STORAGE CAPABILITY

FACILITY *****	(a)		NO. OF ASSEMBLIES STORED *****	REMAINING CAPACITY (NO. OF ASSEMBLIES) *****	REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) *****	NEXT REFUEL SCHD. DATE *****	(b) WILL FILL PRESENT AUTH. CAPACITY *****
	CORE SIZE (NO. OF ASSEMBLIES) *****	PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) *****					
ARKANSAS 1	177	988	316	672		10-84	1998
ARKANSAS 2	177	988	168	820		05-85	2003
BEAVER VALLEY 1	157	833	52	781		10-84	1995
CALVERT CLIFFS 1	217	1830(c)	868(c)	961(c)(m)	1098	03-85	1991
CALVERT CLIFFS 2	217					10-85	1991
COOK 1	193	2050(c)	553(c)	1497(c)		N/S	1994
COOK 2	193					N/S	
CRYSTAL RIVER 3	177	1163	171	992		N/S	1997
DAVIS-BESSE 1	177	735	140	595		09-84	1993
DIABLO CANYON 1							
FARLEY 1	157	675	114	561	1293	N/S	1991
FARLEY 2	157	675	62	613	1345	01-85	1994
FORT CALHOUN 1	133	729	305	424		10-85	1996
GINNA	121	595	340	255		N/S	1992
HADDAM NECK	157	1168	493	675		08-84	1994
INDIAN POINT 1	0	288	160	128		N/S	
INDIAN POINT 2	193	482	332	150	916	N/S	1986
INDIAN POINT 3	193	837	140	697		N/S	1993
KEWAUNEE	121	990	268	722(m)		N/S	1991
MAINE YANKEE	217	953	577	376	1678	N/S	1987
MCGUIRE 1	193	500	91	409(n)	1781	N/S	1990
MCGUIRE 2						01-85	
MILLSTONE 2	217	667	376	291		N/S	1987
NORTH ANNA 1	157	966(c)	168(c)	798		N/S	1991
NORTH ANNA 2	157					08-84	1990
OCONEE 1	177	1312(1)	1086	226(1)(n)		10-84	1991
OCONEE 2	177					03-85	
OCONEE 3	177	825	104	721		09-85	
PALISADES	204	784	480	304		N/S	1988
POINT BEACH 1	121	1058(c)	484(c)	1078(c)		N/S	1995
POINT BEACH 2	121					09-84	
PRAIRIE ISLAND 1	121	1017(c)	561(c)	456(c)(m)	720	N/S	1988
PRAIRIE ISLAND 2	121					08-84	
RANCHO SECO 1	177	579	280	299		01-85	1987
ROBINSON 2	157	276	152	124(e)	431	N/S	1985(g)
SALEM 1	193	1170	212	958		N/S	1996
SALEM 2	193	1170	72	1098		N/S	2000
SAN ONOFRE 1	157	216	94	122		N/S	1985
SAN ONOFRE 2	217	800	0	800		11-84	
SAN ONOFRE 3	217	800	0	800		N/S	
SEQUOYAH 1	193	800	65	735		N/S	1993
SEQUOYAH 2(d)	193	800	65	735		09-84	1994
ST LUCIE 1	217	728	352	376		N/S	1990
ST LUCIE 2						10-84	
SUMMER 1	157	682	0	682	1276	09-84	
SURRY 1	157	1044(c)	556(c)	484(c)		N/S	1987
SURRY 2	157					09-84	

 * PRESSURIZED*
 * WATER *
 * REACTORS *

STATUS OF SPENT FUEL STORAGE CAPABILITY

FACILITY *****	(a)		NO. OF ASSEMBLIES STORED *****	REMAINING CAPACITY *****	REMAINING CAPACITY IF PENDING REQUEST APPROVED *****	NEXT REFUEL SCHED. DATE *****	WILL FILL PRESENT AUTH. CAPACITY *****
	CORE SIZE (NO. OF ASSEMBLIES) *****	PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) *****					
THREE MILE ISLAND 1	177	752	208	544		N/S	1986
THREE MILE ISLAND 2	177	442	0	442		N/S	1986
TROJAN	193	651	312	339		N/S	1990
TURKEY POINT 3	157	621	445	175(m)		N/S	1987
TURKEY POINT 4	157	621	430	191		N/S	1988
YANKEE-ROWE 1	76	391	250	141	471	N/S	1988
ZION 1	193	2112(c)	863(c)	1249(c)		12-84	1995
ZION 2	193					09-85	1995

INDEPENDENT SPENT FUEL STORAGE INSTALLATIONS(h)

MORRIS OPERATIONS	750 MTU(j)	315	385 MTU(j)	1490 MTU(j)
NFS(i)	250 MTU	170 MTU	80 MTU	

- (a) At each refueling outage approximately 1/3 of a PWR core and 1/4 of a BWR core is off-loaded.
- (b) Some of these dates have been adjusted by staff assumptions.
- (c) This is the total for both units.
- (d) Plant not in commercial operation.
- (e) Some spent fuel stored at Brunswick.
- (f) Authorized a total 2772 BWR and 1232 PWR assemblies for both pools.
- (g) Robinson 2 assemblies being shipped to Brunswick for storage.
- (h) Capacity is in metric tons of uranium; 1 MTU = 2 PWR assemblies or 5 BWR assemblies.
- (i) No longer accepting spent fuel.
- (j) Racked for 700 MTU.
- (k) Reserved.
- (l) This is the station total.
- (m) Installed capacity is less than that authorized.
- (n) McGuire 1 authorized to accept Oconee fuel assemblies.

 N/S = Not Scheduled

* BOILING * STATUS OF SPENT FUEL STORAGE CAPABILITY

* WATER *

* REACTORS * (a)

FACILITY	(a)		NO. OF ASSEMBLIES STORED	NO. OF ASSEMBLIES REMAINING CAPACITY	REMAINING CAPACITY IF PENDING REQUEST		NEXT REFUEL SCHED. DATE	WILL FILL PRESENT AUTH. CAPACITY
	CORE SIZE (NO. OF ASSEMBLIES)	PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES)			APPROVED	(NO. OF ASSEMBLIES)		
BIG ROCK POINT 1	84	193	172	21	269	N/S	1986	
BROWNS FERRY 1	764	3471	1068	2403		03-85	1985	
BROWNS FERRY 2	764	3471	889	61(m)	2582	09-84	1985	
BROWNS FERRY 3	764	3471	1768	150(m)	1703	N/S	1985	
BRUNSWICK 1	560	(f)	160PWR+656BWR	2116		N/S	1986	
BRUNSWICK 2	560		144PWR+564BWR	2208		N/S	1986	
COOPER STATION	548	2366	848	1518		09-84	1996	
DRESDEN 1	464	672	221	451		N/S	1970	
DRESDEN 2	724	2659(c)	2014 (c)	996(c)	6129(c)	09-84	1985	
DRESDEN 3	724					N/S		
DUANE ARNOLD	368	2050	576	1474		N/S	1998	
FITZPATRICK	560	2244	816	1428		N/S	1991	
HATCH 1	560	3021	0	3021		10-84	1999	
HATCH 2	560	2750	1284	1466		N/S	1999	
HUMBOLDT BAY	172	487	251	236		N/S		
LA CROSSE	72	440	207	233		11-84	1990	
LASALLE 1								
LASALLE 2								
MILLSTONE 1	580	2184	1281	903		N/S	1991	
MONTICELLO	484	2237	1137	1100		N/S	1991	
NINE MILE POINT 1	532	1984	1177	807	1788	N/S	1990	
OYSTER CREEK 1	560	1800	1375	425	1225	N/S	1987	
PEACH BOTTOM 2	764	2816	1361	1455		N/S	1990	
PEACH BOTTOM 3	764	2816	1212	1604		N/S	1991	

* BOILING * STATUS OF SPENT FUEL STORAGE CAPABILITY

* WATER *

* REACTORS * (a)

FACILITY *****	(a)		NO. OF ASSEMBLIES STORED *****	REMAINING CAPACITY (NO. OF ASSEMBLIES) *****	(b)	
	CORE SIZE (NO. OF ASSEMBLIES) *****	PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) *****			REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) *****	NEXT REFUEL SCHED. DATE *****
PILGRIM 1	580	2320	1708	62(m)	N/S	1990
QUAD CITIES 1	724	3657	1730	1927	N/S	2003
QUAD CITIES 2	724	3897	412	3485	N/S	2003
SUSQUEHANNA 1	764	2840	0	2840	N/S	1997
SUSQUEHANNA 2						
VERMONT YANKEE 1	368	2000	1174	826	N/S	1992
WASHINGTON NUCLEAR*						

INDEPENDENT SPENT FUEL STORAGE INSTALLATIONS(h)

MORRIS OPERATIONS	750 MTU(j)	315	385 MTU(j)	1490 MTU(j)
NFS(i)	250 MTU	170 MTU	80 MTU	

- (a) At each refueling outage approximately 1/3 of a PWR core and 1/4 of a BWR core is off-loaded.
- (b) Some of these dates have been adjusted by staff assumptions.
- (c) This is the total for both units.
- (d) Plant not in commercial operation.
- (e) Some spent fuel stored at Brunswick.
- (f) Authorized a total 2772 BWR and 1232 PWR assemblies for both pools.
- (g) Robinson 2 assemblies being shipped to Brunswick for storage.
- (h) Capacity is in metric tons of uranium; 1 MTU = 2 PWR assemblies or 5 BWR assemblies.
- (i) No longer accepting spent fuel.
- (j) Racked for 700 MTU.
- (k) Reserved.
- (l) This is the station total.
- (m) Installed capacity is less than that authorized.
- (n) McGuire 1 authorized to accept Oconee fuel assemblies.

N/S = Not Scheduled

(INCLUDES BOTH LICENSED
AND NON-LICENSED UNITS)

REACTOR YEARS OF EXPERIENCE

*****				*****				*****			
YEARS	1ST ELEC GENERATE	UNIT		YEARS	1ST ELEC GENERATE	UNIT		YEARS	1ST ELEC GENERATE	UNIT	
* LICENSED *	10.00	08/01/74	ARKANSAS 1	5.60	12/26/78	ARKANSAS 2		8.13	06/14/76	BEAVER VALLEY 1	
* OPERATING *	21.65	12/08/62	BIG ROCK POINT 1	10.80	10/15/73	BROWNS FERRY 1		9.93	08/28/74	BROWNS FERRY 2	
* ELECTRICAL *	7.89	09/12/76	BROWNS FERRY 3	7.66	12/04/76	BRUNSWICK 1		9.26	04/29/75	BRUNSWICK 2	
* PRODUCING *	9.58	01/03/75	CALVERT CLIFFS 1	7.65	12/07/76	CALVERT CLIFFS 2		9.47	02/10/75	COOK 1	
* UNITS *	6.36	03/22/78	COOK 2	10.23	05/10/74	COOPER STATION		7.50	01/30/77	CRYSTAL RIVER 3	
*****	6.93	08/28/77	DAVIS-BESSE 1	14.30	04/13/70	DRESDEN 2		13.03	07/22/71	DRESDEN 3	
	10.20	05/19/74	DUANE ARNOLD	6.95	08/18/77	FARLEY 1		3.19	05/25/81	FARLEY 2	
	9.50	02/01/75	FITZPATRICK	10.93	08/25/73	FORT CALHOUN 1		7.64	12/11/76	FORT ST VRAIN	
	14.66	12/02/69	GINNA	16.99	08/07/67	HADDAM NECK		9.72	11/11/74	HATCH 1	
	5.86	09/22/78	HATCH 2	11.10	06/26/73	INDIAN POINT 2		8.26	04/27/76	INDIAN POINT 3	
	10.32	04/08/74	KEWAUNEE	16.27	04/26/68	LA CROSSE		1.91	09/04/82	LASALLE 1	
	.28	04/20/84	LASALLE 2	11.73	11/08/72	MAINE YANKEE		3.09	06/30/81	MCGUIRE 1	
	1.19	05/23/83	MCGUIRE 2	13.67	11/29/70	MILLSTONE 1		8.73	11/09/75	MILLSTONE 2	
	13.41	03/05/71	MONTICELLO	14.73	11/09/69	NINE MILE POINT 1		6.29	04/17/78	NORTH ANNA 1	
	3.93	08/25/80	NORTH ANNA 2	11.24	05/06/73	OCONEE 1		10.66	12/05/73	OCONEE 2	
	9.92	09/01/74	OCONEE 3	14.86	09/23/69	OYSTER CREEK 1		12.59	12/31/71	PALISADES	
	10.45	02/18/74	PEACH BOTTOM 2	9.92	09/01/74	PEACH BOTTOM 3		12.04	07/19/72	PILGRIM 1	
	13.74	11/06/70	POINT BEACH 1	12.00	08/02/72	POINT BEACH 2		10.66	12/04/73	PRAIRIE ISLAND 1	
	9.61	12/21/74	PRAIRIE ISLAND 2	12.30	04/12/72	QUAD CITIES 1		12.19	05/23/72	QUAD CITIES 2	
	9.80	10/13/74	RANCHO SECO 1	13.85	09/26/70	ROBINSON 2		7.60	12/25/76	SALEM 1	
	3.16	06/03/81	SALEM 2	17.05	07/16/67	SAN ONOFRE 1		1.86	09/20/82	SAN ONOFRE 2	
	.85	09/25/83	SAN ONOFRE 3	4.03	07/22/80	SEQUOYAH 1		2.61	12/23/81	SEQUOYAH 2	
	8.24	05/07/76	ST LUCIE 1	1.14	06/13/83	ST LUCIE 2		1.71	11/16/82	SUMMER 1	
	12.08	07/04/72	SURRY 1	11.39	03/10/73	SURRY 2		1.71	11/16/82	SUSQUEHANNA 1	
	.08	07/03/84	SUSQUEHANNA 2	10.12	06/19/74	THREE MILE ISLAND 1		8.61	12/23/75	TROJAN	
	11.75	11/02/72	TURKEY POINT 3	11.11	06/21/73	TURKEY POINT 4		11.86	09/20/72	VERMONT YANKEE 1	
	.18	05/27/84	WASHINGTON NUCLEAR 2	23.72	11/10/60	YANKEE-ROWE 1		11.09	06/28/73	ZION 1	
	10.60	12/26/73	ZION 2								
TOTAL 754.86 YRS											

*****				*****			
YEARS	1ST ELEC GENERATE	SHUTDOWN DATE	UNIT	YEARS	1ST ELEC GENERATE	SHUTDOWN DATE	UNIT
* PERMANENTLY *	3.80	08/14/64	BONUS	3.04	12/18/63	01/01/67	CVTR
* OR *	18.54	04/15/60	DRESDEN 1	4.44	08/24/63	02/01/68	ELK RIVER
* INDEFINITELY*	6.32	08/05/66	FERMI 1	1.26	05/29/63	09/01/64	HALLAM
* SHUTDOWN *	13.21	04/18/63	HUMBOLDT BAY	12.12	09/16/62	10/31/74	INDIAN POINT 1
* UNITS *	1.19	07/25/66	PATHFINDER	7.76	01/27/67	11/01/74	PEACH BOTTOM 1
*****	2.16	11/04/63	PIQUA	.93	04/21/78	03/28/79	THREE MILE ISLAND 2
TOTAL 74.77 YRS							

The total reactor years of experience is as the sum of all calendar days for each unit, from the date that electricity was first generated until a final shutdown date or the status date, whichever comes first, divided by 365.25 days/year. If a date is unknown, the first day of the first month of operation is substituted. Units which have not yet generated electricity but which are licensed are listed but not included in the computation.

 * RESEARCH *
 * REACTORS *

NON-POWER REACTORS IN THE U. S.

STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	LICENSE NUMBER	DATE OF ISSUED	AUTHORIZED POWER LEVEL (KW)
ALABAMA	TUSKEGEE	TUSKEGEE INSTITUTE	AGN-201 #102	50-406	R-122	08-30-74	0.0001
ARIZONA	TUCSON	UNIVERSITY OF ARIZONA	TRIGA MARK I	50-113	R-52	12-05-58	100.0
CALIFORNIA	BERKELEY	UNIVERSITY OF CALIFORNIA, BERKELEY COLLEGE	TRIGA MK. III	50-224	R-101	08-10-66	1000.0
	CANOGA PARK	ROCKWELL INTERNATIONAL CORP.	L-85	50-375	R-188	01-05-72	0.003
	HAWTHORNE	NORTHROP CORP. LABORATORIES	TRIGA MARK F	50-187	R-90	03-04-63	1000.0
	IRVINE	UNIVERSITY OF CALIFORNIA, IRVINE	TRIGA MARK I	50-326	R-116	11-24-69	250.0
	LOS ANGELES	UNIVERSITY OF CALIFORNIA, L.A.	ARGONAUT	50-142	R-71	10-03-60	100.0
	SAN DIEGO	GENERAL ATOMIC COMPANY	TRIGA MARK F	50-163	R-67	07-01-60	1500.0
	SAN DIEGO	GENERAL ATOMIC COMPANY	TRIGA MARK I	50-089	R-38	05-03-58	250.0
	SAN JOSE	GENERAL ELECTRIC COMPANY	NTR	50-073	F-33	10-31-57	100.0
	SAN LUIS OBISPO	CALIFORNIA STATE POLYTECHNIC COLLEGE	AGN-201 #100	50-394	R-121	05-16-73	0.0001
	SAN RAMON	AEROTEST OPERATIONS, INC.	TRIGA (INDUS)	50-228	R-98	07-02-65	250.0
SANTA BARBARA	UNIVERSITY OF CALIFORNIA, SANTA BARBARA	L-77	50-433	R-124	12-03-74	0.01	
COLORADO	DENVER	U.S. GEOLOGICAL SURVEY DEPARTMENT	TRIGA MARK I	50-274	R-113	02-24-69	1000.0
DELAWARE	NEWARK	UNIVERSITY OF DELAWARE	AGN-201 #113	50-098	R-43	07-03-58	0.0001
DIST OF COLUMBIA	WASHINGTON	THE CATHOLIC UNIVERSITY OF AMERICA	AGN-201 #101	50-077	R-31	11-15-67	0.0001
FLORIDA	GAINESVILLE	UNIVERSITY OF FLORIDA	ARGONAUT	50-083	R-56	05-21-59	100.0
GEORGIA	ATLANTA	GEORGIA INSTITUTE OF TECHNOLOGY	AGN-201 #104	50-276	R-111	04-19-68	0.0001
	ATLANTA	GEORGIA INSTITUTE OF TECHNOLOGY	HEAVY WATER	50-160	R-97	12-29-64	5000.0
IDAHO	POCATELLO	IDAHO STATE UNIVERSITY	AGN-201 #103	50-284	R-110	10-11-67	0.0001
ILLINOIS	URBANA	UNIVERSITY OF ILLINOIS	LOPRA	50-356	R-117	12-27-71	10.0
	URBANA	UNIVERSITY OF ILLINOIS	TRIGA	50-151	R-115	07-22-69	1500.0
	ZION	WESTINGHOUSE ELECTRIC CORP.	NTR	50-087	R-119	01-28-72	10.0
INDIANA	LAFAYETTE	PURDUE UNIVERSITY	LOCKHEED	50-182	R-87	08-16-62	10.0
IOWA	AMES	IOWA STATE UNIVERSITY	UTR-10	50-116	R-59	10-16-59	10.0
KANSAS	LAWRENCE	UNIVERSITY OF KANSAS	LOCKHEED	50-148	R-78	06-23-61	250.0
	MANHATTAN	KANSAS STATE UNIVERSITY	TRIGA	50-188	R-88	10-16-62	250.0
MARYLAND	BETHESDA	ARMED FORCES RADIOBIOLOGY RESEARCH INSTITUTE	TRIGA	50-170	R-84	06-26-62	1000.0
	COLLEGE PARK	UNIVERSITY OF MARYLAND	TRIGA	50-166	R-70	10-14-60	250.0

 * RESEARCH *
 * REACTORS *

NON-POWER REACTORS IN THE U. S.

STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	LICENSE NUMBER	DATE OF ISSUED	AUTHORIZED POWER LEVEL (KW)
MASSACHUSETTS	CAMBRIDGE	MASSACHUSETTS INSTITUTE OF TECHNOLOGY	HWR REFLECTED	50-020	R-37	06-09-58	5000.0
	LOWELL	UNIVERSITY OF LOWELL	GE	50-223	R-125	12-24-74	1000.0
	WORCESTER	WORCESTER POLYTECHNIC INSTITUTE	GE	50-134	R-61	12-16-59	10.0
MICHIGAN	ANN ARBOR	UNIVERSITY OF MICHIGAN	POOL	50-002	R-28	09-13-57	2000.0
	EAST LANSING	MICHIGAN STATE UNIVERSITY	TRIGA MARK I	50-294	R-114	03-21-69	250.0
	MIDLAND	DOW CHEMICAL COMPANY	TRIGA	50-264	R-108	07-03-67	100.0
MISSOURI	COLUMBIA	UNIVERSITY OF MISSOURI, COLUMBIA	TANK	50-186	R-103	10-11-66	10000.0
	ROLLA	UNIVERSITY OF MISSOURI	POOL	50-123	R-79	11-21-61	200.0
NEBRASKA	OMAHA	THE VETERANS ADMINISTRATION HOSPITAL	TRIGA	50-131	R-57	06-26-59	18.0
NEW MEXICO	ALBUQUERQUE	UNIVERSITY OF NEW MEXICO	AGN-201M #112	50-252	R-102	09-17-66	0.005
NEW YORK	BRONX	MANHATTAN COLLEGE - PYHSICS DEPT.	TANK	50-199	R-94	03-24-64	0.0001
	BUFFALO	STATE UNIVERSITY OF NEW YORK	PULSTAR	50-057	R-77	03-24-61	2000.0
	ITHACA	CORNELL UNIVERSITY	TRIGA MARK II	50-157	R-80	01-11-62	500.0
	ITHACA	CORNELL UNIVERSITY	ZPR	50-097	R-89	12-11-62	0.1
	NEW YORK	COLUMBIA UNIVERSITY IN THE CITY OF NEW YORK	TRIGA MARK II	50-208	R-128	04-14-77	250.0
	TUXEDO	UNION CARBIDE CORP	POOL	50-054	R-81	09-07-61	5000.0
NORTH CAROLINA	RALEIGH	NORTH CAROLINA STATE UNIVERSITY AT RALEIGH	PULSTAR	50-297	R-120	08-25-72	1000.0
OHIO	COLUMBUS	OHIO STATE UNIVERSITY	POOL	50-150	R-75	02-24-61	10.0
OKLAHOMA	NORMAN	THE UNIVERSITY OF OKLAHOMA	AGN-211 #102	50-112	R-53	12-29-58	0.100
OREGON	CORVALLIS	OREGON STATE UNIVERSITY	TRIGA MARK II	50-243	R-106	03-07-67	1000.0
	PORTLAND	REED COLLEGE	TRIGA MARK I	50-288	R-112	07-02-68	250.0
PENNSYLVANIA	UNIVERSITY PARK	PENNSYLVANIA STATE UNIVERSITY	TRIGA MK. III	50-005	R-2	07-08-55	1000.0
RHODE ISLAND	NARRAGANSETT	RHODE ISLAND NUCLEAR SCIENCE CENTER	GE POOL	50-193	R-95	07-21-64	2000.0
TENNESSEE	MEMPHIS	MEMPHIS STATE UNIVERSITY	AGN-201 #108	50-538	R-127	12-10-76	0.0001
TEXAS	AUSTIN	UNIVERSITY OF TEXAS	TRIGA MARK I	50-192	R-92	08-02-63	250.0
	COLLEGE STATION	TEXAS A&M UNIVERSITY	AGN-201M #106	50-059	R-23	08-26-57	0.005
	COLLEGE STATION	TEXAS A&M UNIVERSITY	TRIGA	50-128	R-83	12-07-61	1000.0
UTAH	PROVO	BRIGHAM YOUNG UNIVERSITY	L-77	50-262	R-109	09-07-67	0.01

 * RESEARCH *
 * REACTORS *

NON - POWER REACTORS IN THE U. S.

STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	LICENSE NUMBER	DATE OL ISSUED	AUTHORIZED POWER LEVEL (KW)
UTAH	SALT LAKE CITY	THE UNIVERSITY OF UTAH	TRIGA MARK I	50-407	R-126	09-30-75	100.0
			AGN-201M #107	50-072	R-25	09-12-57	0.005
VIRGINIA	BLACKSBURG	VIRGINIA POLYTECHNIC INSTITUTE	UTR-10	50-124	R-62	12-18-59	100.0
			CAVALIER	50-396	R-123	09-24-74	0.1
			POOL	50-062	R-66	06-27-60	2000.0
			LPR	50-099	R-47	09-05-58	1000.0
WASHINGTON	PULLMAN	WASHINGTON STATE UNIVERSITY	TRIGA	50-027	R-76	03-06-61	1000.0
			ARGONAUT	50-139	R-73	03-31-61	100.0
WISCONSIN	MADISON	UNIVERSITY OF WISCONSIN	TRIGA	50-156	R-74	11-23-60	1000.0

* EXPERIMENTAL AND TEST REACTORS *							

CALIFORNIA	SAN JOSE	GENERAL ELECTRIC COMPANY	GETR	50-070	TR-1	01-07-59	50,000.0
DIST OF COLUMBIA	WASHINGTON	NATIONAL BUREAU OF STANDARDS	TEST	50-184	TR-5	06-30-70	10,000.0

* CRITICAL EXPERIMENT FACILITIES *							

NEW YORK	TROY	RENSSELAER POLYTECHNIC INSTITUTE		50-225	CX-22	07-03-64	0.0
VIRGINIA	LYNCHBURG	BABCOCK & WILCOX COMPANY		50-013	CX-10	10-22-58	0.0
WASHINGTON	RICHLAND	BATTELLE MEMORIAL INSTITUTE		50-360	CX-26	11-29-71	0.0

BIBLIOGRAPHIC DATA SHEET

NUREG-0020 Volume 8 Number 8

2. Leave blank

3. TITLE AND SUBTITLE

Licensed Operating Reactors
Status Summary Report

4. RECIPIENT'S ACCESSION NUMBER

5. DATE REPORT COMPLETED

MONTH: SEPTEMBER YEAR: 1984

6. AUTHOR(S)

7. DATE REPORT ISSUED

MONTH: SEPTEMBER YEAR: 1984

8. PERFORMING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)

Division of Budget and Analysis
Office of Resource Management
U. S. Nuclear Regulatory Commission
Washington, DC 20555

9. PROJECT/TASK/WORK UNIT NUMBER

10. FIN NUMBER

11. SPONSORING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)

Division of Budget and Analysis
Office of Resource Management
U. S. Nuclear Regulatory Commission
Washington, DC 20555

12a. TYPE OF REPORT

12b. PERIOD COVERED (Inclusive dates)

JULY 1984

13. SUPPLEMENTARY NOTES

Status Summary Report

14. ABSTRACT (200 words or less)

The OPERATING UNITS STATUS REPORT - LICENSED OPERATING REACTORS provides data on the operation of nuclear units as timely and accurately as possible. This information is collected by the Office of Resource Management from the Headquarters staff of NRC's Office of Inspection and Enforcement, from NRC's Regional Offices, and from utilities. The three sections of the report are: monthly highlights and statistics for commercial operating units, and errata from previously reported data; a compilation of detailed information on each unit, provided by NRC's Regional Offices, IE Headquarters and the utilities; and an appendix for miscellaneous information such as spent fuel storage capability, reactor-years of experience and non-power reactors in the U.S. It is hoped the report is helpful to all agencies and individuals interested in maintaining an awareness of the U.S. energy situation as a whole.

15a. KEY WORDS AND DOCUMENT ANALYSIS

15b. DESCRIPTORS

16. AVAILABILITY STATEMENT

Unlimited

17. SECURITY CLASSIFICATION

(This report)
Unclassified

18. NUMBER OF PAGES

19. SECURITY CLASSIFICATION

(This page)
Unclassified

20. PRICE

\$

DISTRIBUTION LIST - NRC

INTERNAL DISTRIBUTION

Office of the Commissioners	5
Atomic Safety and Licensing Appeal Panel	3
Advisory Committee on Reactor Safeguards	6
Office of Inspector and Auditor	1
Office of Policy Evaluation	1
Office of the General Counsel	1
Office of Public Affairs	21
Office of Congressional Affairs	3
Office of the Executive Director for Operations	7
Office of Administration	2
Office of the Executive Legal Director	2
Office of Analysis and Evaluation of Operational Data	2
Office of International Programs	3
Office of State Programs	1
Office of Resource Management	19
Office of Nuclear Material Safety and Safeguards	2
- Division of Fuel Cycle and Material Safety	3
- Division of Safeguards	2
Office of Nuclear Reactor Regulation	138
- Division of Engineering	
- Division of Safety Technology	
- Division of Licensing	
- Division of Systems Integration	
- Division of Human Factors Safety	
Office of Nuclear Regulatory Research	4
Office of Inspection and Enforcement	7
- Region I	11
- Region II	10
- Region III	10
- Region IV	10
- Region V	7
	<u>281</u>

EXTERNAL DISTRIBUTION

SPECIAL REQUESTS

Air Force	1
Congress	10
Department of Energy	32
Government Accounting Office	1
Environmental Protection Agency	1
Electric Power Research Institute	1
Argonne National Laboratory	3
Bureau of Mines	1
Department of Agriculture	1
Department of the Commerce	1
Department of the Interior	1
	<u>53</u>

OTHER

GPO Depository	440
GPO Stores	75
National Technical Information Service	25
Subscriptions (NTIS)	250
Colleges and Libraries (including Public Document Rooms)	128
Utilities and Other Requests	227
	<u>1145</u>

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300

FIRST CLASS MAIL
POSTAGE & FEES PAID
USNRC
WASH D C
PERMIT No. 667

120555078877 1 LANINU
US NRC
ADM-DIV OF TDC
POLICY & PUB MGT BR-PDR NUREG
W-501
WASHINGTON DC 20555