

October 1, 1984

Docket No. 50-302

Distribution:
Docket File
Memo File
RIngram

MEMORANDUM FOR: Frank Miraglia, Deputy Director
Division of Licensing
Office of Nuclear Reactor Regulation

THRU: Gus C. Lainas, Assistant Director
for Operating Reactors
Division of Licensing

FROM: John F. Stolz, Chief
Operating Reactors Branch No. 4
Division of Licensing

SUBJECT: JUSTIFICATION FOR INDIVIDUAL FEDERAL REGISTER SHOLLY NOTICE
CRYSTAL RIVER UNIT 3


Florida Power Corporation submitted TSCR 121 requesting TS changes to permit auxiliary building ventilation system inoperability for up to 12 hours for maintenance purposes, as well as for surveillance testing as presently allowed. This request had been treated in a routine manner until the PM was informed recently that evaluation by the licensee indicates that the condition of certain system dampers (which initially prompted the request) is deteriorating. It is feared that failure of the dampers might cause fan damage and require more extended plant shutdown. Availability of parts and completion of engineering will permit repair/replacement of the dampers in October 1984. The system design is such that the necessary repairs cannot be performed while any ventilation fans are operating. The present TS, as interpreted by Region II, requires reactor shutdown if more than one pair of exhaust fans is inoperable. Since waiting for the October monthly notice would not permit issuance of the amendment before late November, issuance of an individual notice is requested to minimize the period of potential plant shutdown.


"ORIGINAL SIGNED BY:"


John F. Stolz, Chief
Operating Reactors Branch No. 4
Division of Licensing

Approved:

Frank Miraglia, Deputy Director
10/ /84


ORB#4:DL
HSilver;er
09/24/84


ORB#4:DL
JFStolz
09/24/84


AD:GC:DL
GCLainas
09/25/84

8410180175 841001
PDR ADOCK 05000302
P PDR



UNITED STATES
 NUCLEAR REGULATORY COMMISSION
 WASHINGTON, D.C. 20555
 October 3, 1984

DISTRIBUTION:
 Docket File
 ORB#4 Rdg
 RIngram

DOCKET No. 50-302

MEMORANDUM FOR: Docketing and Service Branch
 Office of the Secretary of the Commission

FROM: Office of Nuclear Reactor Regulation

SUBJECT: CRYSTAL RIVER NUCLEAR GENERATING STATION, UNIT NO. 3

One signed original of the *Federal Register* Notice identified below is enclosed for your transmittal to the Office of the Federal Register for publication. Additional conformed copies (6) of the Notice are enclosed for your use.

- Notice of Receipt of Application for Construction Permit(s) and Operating License(s).
- Notice of Receipt of Partial Application for Construction Permit(s) and Facility License(s): Time for Submission of Views on Antitrust Matters.
- Notice of Consideration of Issuance of Amendment to Facility Operating License.
- Notice of Receipt of Application for Facility License(s); Notice of Availability of Applicant's Environmental Report; and Notice of Consideration of Issuance of Facility License(s) and Notice of Opportunity for Hearing.
- Notice of Availability of NRC Draft/Final Environmental Statement.
- Notice of Limited Work Authorization.
- Notice of Availability of Safety Evaluation Report.
- Notice of Issuance of Construction Permit(s).
- Notice of Issuance of Facility Operating License(s) or Amendment(s).
- Order.
- Exemption.
- Notice of Granting of Relief.
- Other: *Please insert date on the 3rd page 1st paragraph of this notice for a 30-day intervention period, and call Caryn on extension 28960 to inform her of the date inserted. Referenced documents have been provided PDR.

Division of Licensing, ORB#4
 Office of Nuclear Reactor Regulation

Enclosure:
 As stated

OFFICE	NOTE: Expedited handling is requested.	Publication in the FEDERAL REGISTER no later than	
SURNAME	10/9/84 is required to provide a 30-day notice period as required by the Commission's	regulations and to avoid adverse impact on plant operations.	ORB#4:DL M
DATE			RIngram;c.f. 10/3/84

OFFICIAL RECORD COPY