

TEXAS UTILITIES SERVICES INC.

2001 BRYAN TOWER · DALLAS, TEXAS 75201

Log # TXX-4057
File # 10010

October 10, 1983
4

Mr. S. B. Burwell
Licensing Project Manager
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 & 50-446
FSAR AMENDMENT 44 DESCRIPTION

Dear Mr. Burwell:

Attached is a table providing the description of Amendment 44, dated
October 10, 1983.

Sincerely,

J. S. Marshall
J. S. Marshall

RWH:grr
Attachment

cc: H. C. Schmidt

3001
1/1

8410180184 831010
PDR ADUCK 05000445
A PDR

CPSES/FSAR

AMENDMENT 44 DESCRIPTION

<u>SECTION</u>	<u>DESCRIPTION OF CHANGE</u>
1A(B)	Updates commitment to Rev. 2 of R.G. 1.101.
3.7B	Provides update to method of pipe analysis.
F3.7B-50A	"
3.11B	"
EQR T4-1	Provides update to EQ status.
EQR T5-1	"
EQR T5-2	"
4.2	Provides update to rod bow analysis description for newly approved WCAP.
4.4	"
T7.3-4	Provides update to equipment actuated by SI.
8.1	Provides clarification of position on wire splices.
8.2	Provides clarification of position on R.G. 1.30 and IEEE 336.

CPSES/FSAR

<u>SECTION</u>	<u>DESCRIPTION OF CHANGE</u>
8.3	Provides clarification of slow transfer of safety buses. Provides minor correction of relay type for diesel generators.
13.1	Provides clarifications to design control responsibilities.
14.2	Provides clarification of the applicable administrative requirements for use of operation procedures.
17.1	Provides organizational update.
F17.1-2	"
F17.1-3	"
F17.1-6	"
17.2	Refer to 13.1.
II.B.3	Provides testing and training commitment. Provides update to the Post Accident Sampling System due to familiarity with its operation.
III.B.3-1	"

CPSSES/FSAR

SECTION

DESCRIPTION OF CHANGE

032

Provides update to title of manual responsible for specifying alternate instrumentation in the event of a loss of power to a particular bus.