EPP 3.2

PECO Energy Company Nuclear Group Headquarters 965 Chesterbrook Boulevard Wayne, PA 19087-5691

October 11, 1995

Docket Nos. 50-352 50-353

License Nos. NPF-39 NPF-85

NPDES Permit No. PA0051926

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555

PECO ENERGY

Subject: Limerick Generating Station, Units 1 and 2 Changes to National Pollutant Discharge Elimination System Permit

Gentlemen:

This letter is being submitted in accordance with the Limerick Generating Station (LGS), Units 1 and 2, Environmental Protection Plan (EPP) Section 3.2, which stipulates that the NRC shall be notified within 30 days following the date of approval of a change to the National Pollutant Discharge Elimination System (NPDES) permit.

By letter dated September 12, 1995, the Pennsylvania Department of Environmental Resources (PA DER) approved PECO Energy Company's request to revise LGS NPDES Permit No. PA0051926 to allow the use of chemical additives PEC16, PEC17, Copper Trol CU-1, and Powerline 3461 in the cooling towers and spray pond servicing LGS, Units 1 and 2. These chemical additives are replacements for previously approved agents, and will be used to help control corrosion and prevent scaling and silt deposition in the secondary cooling water systems' heat exchangers at LGS. A copy of the PA DER letter approving this change to the LGS NPDES permit is attached. The NRC was previously notified of our request to revise the NPDES permit to use these chemical additives by letter dated August 2, 1995.

If you have any questions or require additional information, please do not hesitate to contact us.

Very truly yours,

G. A. Hunger, Jr. Director - Licensing

9510250045 951011

ADDCK 05000352

PDR

Attachment

PDR

CC: T. T. Martin, Administrator, Region I, USNRC (w/ attachment)
 N. S. Perry, USNRC Senior Resident Inspector, LGS, (w/ attachment)

1823



COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL RESOURCES

-Please note our new name-DEPARTMENT OF ENVIRONMENTAL PROTECTION D E P Lee Park, Suite 6010

555 North Lane Conshohocken, PA 19428 September 12, 1995

Southeast Regional Office

610-832-6130 Fax 610-832-6259

Mr. Robert M. Matty, Jr. Engineer, Environmental Affairs PECO Energy Company 2301 Market Street P.O. Box 8699 Philadelphia, PA 19101-8699

> Re: IW-NPDES Permit PA0051926 Limeric Generating Station Limerick Township Montgomery County

Dear Mr. Matty:

This is in response to your August 2, 1995 letter requesting approval to use chemical additives PEC16, PEC17, Copper Trol CU-1, and Powerline 3461 in the cooling tower and spray pond at the subject facility. The wastewater containing these products will be discharged at an average flow of 14.27 mgd to the Schuylkill River through Outfall 001.

The company has proposed to use PEC16 and PEC 17 in the cooling tower. These products are intended to replace the existing chemical Betz Powerline PEC 12. Copper Trol CU-1 will be used in the cooling tower intake screens for 5 to 15 minutes, every 3 to 6 weeks and in the heat exchanger every 1 to 3 months to control corrosion. This product is intended to replace existing chemical Betz Powerline PEC-03. Betz Powerline 3461 will be applied at the emergency spray pond pumphouse to prevent scale formation and silt deposition in the heat exchangers.

We have completed our review of the information submitted by you and hereby approve your request subject to the following conditions:

1. The approved chemical additives and usage rates are as follows:

NAME	USAGE RATE (Ibs/day)	
	AVERAGE MONTHLY	MAXIMUM DAILY
Betz Powerline PEC-16	160	320
Betz Powerline PEC-17	1450	2850
Betz CopperTrol CU-1	400	5600
Betz Powerline 3461	800	3850

- The discharge containing chemical additives shall be managed by the permittee to ensure that toxic
 effects in the receiving stream are prevented. Usage rates shall be limited to the minimum amount
 necessary to accomplish the intended purposes of chemical addition.
- Accurate records of usage (name of additive, quantity added, date added) of the approved chemical additive and blowdown discharge volumes must be maintained on the Chemical Additive Reporting Form (copy attached) and be submitted to the Department.

4. The NPDES permit will be revised to include this approval upon permit renewal.

If you have any questions, please contact Sohan Garg of our staff.

Sincerely,

Jam Mallet For

Joseph A. Feola Regional Manager Water Management

Enclosure:

. .

Chemical Additive Reporting Form

cc: Mr. Newbold Mr. O'Neil DRBC EPA Limerick Township Permits & Compliance Re 30 (DF)248