

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

October 16, 1984

TELEPHONE
(704) 373-4531

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Ms. E. G. Adensam, Chief
Licensing Branch No. 4

Re: Catawba Nuclear Station
Docket Nos. 50-413 and 50-414


Dear Mr. Denton:

Mr. T. M. Novak's letter of August 17, 1984 requested additional assurance that the Catawba Unit 1 Technical Specifications did not contain additional errors similar to the requested changes to Specification 4.7.1.2.1 for the Auxiliary Feedwater System.

First of all, Technical Specification 4.7.1.2.1 as issued on July 18, 1984 was not inconsistent with the Catawba FSAR. The values reflected in the specification were consistent with the nominal pump parameters in FSAR Section 10.4.9. Our request to change the acceptance criteria of Specification 4.7.1.2.1 to reflect the less restrictive assumptions of the FSAR Chapter 15 accident analysis did not make the present specification inconsistent with the FSAR as certified in my letters dated July 3 and 17, 1984.

Furthermore, our certification of the Catawba Unit 1 Technical Specifications did not guarantee that the document was error free nor that future changes wouldn't be necessary. Rather, we certified that, to the best of our knowledge, the Catawba Unit 1 Technical Specifications were an accurate reflection of the as-built plant and the FSAR. Further reviews of these Technical Specifications, especially pump surveillance specifications, have not identified any generic problems. The few problems that have been identified and changes requested, were of an editorial nature. Our experience to date has indicated that the extensive review program described in my letter of July 3, 1984 has resulted in Technical Specifications that have required far fewer changes than were typically requested on previously licensed units.

Very truly yours,



Hal B. Tucker

ROS:s1b

8410180224 841016
PDR ADOCK 05000413
P PDR

Bo21
110

Mr. Harold R. Denton, Director
October 16, 1984
Page Two

cc: Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

NRC Resident Inspector
Catawba Nuclear Station

Mr. Robert Guild, Esq.
Attorney-at-Law
P. O. Box 12097
Charleston, South Carolina 29412

Palmetto Alliance
2135½ Devine Street
Columbia, South Carolina 29205

Mr. Jesse L. Riley
Carolina Environmental Study Group
854 Henley Place
Charlotte, North Carolina 28207