

DUKE POWER COMPANY
McGUIRE NUCLEAR STATION - UNIT 1
PUMP INSERVICE TESTING PROGRAM
ASME OM CODE-1987, OM Part 6 (OMa-1988 Addenda)

INTRODUCTION

The inservice testing of ASME Code Class 1, 2 and 3 pumps provided with an emergency power source will be tested as required by ASME Operations and Maintenance Standards Part 6 (OM-6), OMa-1988, of the ASME Code for Operation and Maintenance of Nuclear Power Plants, as referenced in 10CFR50.55a (January 1, 1993 Edition), except where specific written relief has been granted by the Nuclear Regulatory Commission. The effective date of the submittal is March 1, 1994.

Technical Specification 4.0.5 requires inservice testing of ASME Code Class 1, 2 and 3 pumps in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50, Section 50.55a(g)(6)(i). Pumps were selected for inclusion in the IST Program (Section I.2) which fall within this category, as required by this Technical Specification. Pumps within the above ASME categories which are required to mitigate the consequences of an accident, shutdown the reactor or maintain shutdown are included in the program. Testing requirements are identified for each pump which ensure that the pump will perform as designed in response to an accident, in shutting down the reactor, or in maintaining shutdown. Acceptance criteria are specified in accordance with ASME Boiler and Pressure Vessel Code Subsection IWP. The safety functions of the pumps listed in Section I.2 are included in the Design Basis Documents, and fall within the basic categories of accident mitigation, reactor shutdown, and maintaining shutdown. Post modification testing requirements are included in the applicable Nuclear System Directive; a modification test plan is required to be developed to verify proper operation. The Code requires the determination of new reference values after pump repair or replacement, or maintenance which could impact operation. These Code requirements and programmatic controls ensure that the pump inservice test program remains current following modifications performed under 10 CFR 50.59. The documents used in development of this program include the following:

- McGuire Technical Specifications.
- Safety Analysis Report.
- ASME Section XI, IWP (1986).
- ASME Operations and Maintenance Standards Part 6 (OM-6), OMa-1988.
- Generic Letter 89-04.
- Supplement 1 to Generic Letter 89-04.
- NUREG 1482, Guidelines for Inservice Testing at Nuclear Power Plants.
- Safety Evaluation Report for the McGuire IST Program dated October 21, 1994.

10/18/95

SECTION I.1

1 of 2

9510250130 951019
PDR ADOCK 05000369
PDR

McGuire Unit 1

A description of the Inservice Testing Program, Justification for Testing Deferral, as well as Specific Relief Requests from code requirements determined to be impractical, is described in the submittal.

- NOTES:**
- 1) OMa-1988 Part 6, Section 7.3 requires the signature of the person or persons responsible for conducting and analyzing the test. The dated initials of the person or persons responsible for conducting and analyzing the test will be used in place of a signature in the record of tests. Initials shall be construed as signatures to meet the intent of OM-6.
 - 2) A Supplemental Test Program has been established, which includes components which have been determined important to safety and prudent to test, but which are not explicitly under the scope of ASME Codes and Standards.

UNIT 1 - McGUIRE NUCLEAR STATION
Pump Inservice Testing General Data

| Pump ID. Number | Description | Code Class | Flow Diagram | Applicable Relief Requests | Test Frequency | Remarks |
|-----------------|-------------------------------------|------------|--------------|----------------------------|----------------|--|
| 1KCPU0004 | Component Cooling Water Pump 1B2 | 3 | MC-1573-1.0 | RR-I.3.1, RR-I.4.3 | Quarterly | NONE |
| 1NDPU0001 | Residual Heat Removal Pump 1A | 2 | MC-1561-1.0 | RR-I.3.1, RR-I.4.4 | Quarterly | The ND Testing Plan meets other code requirements unless otherwise specified. |
| 1NDPU0002 | Residual Heat Removal Pump 1B | 2 | MC-1561-1.0 | RR-I.3.1, RR-I.4.4 | Quarterly | The ND Testing Plan meets other code requirements unless otherwise specified. |
| 1NIPU0009 | Safety Injection Pump 1A | 2 | MC-1562-3.0 | RR-I.3.1, RR-I.4.5 | Quarterly | The NI Testing Plan meets other code requirements unless otherwise specified. |
| 1NIPU0010 | Safety Injection Pump 1B | 2 | MC-1562-3.0 | RR-I.3.1, RR-I.4.5 | Quarterly | The NI Testing Plan meets other code requirements unless otherwise specified. |
| 1NSPU0001 | Containment Spray Pump 1A | 2 | MC-1563-1.0 | RR-I.3.1 | Quarterly | NONE |

UNIT 1 - McGUIRE NUCLEAR STATION

Pump Inservice Testing Specific Data

| Pump ID. Number | Speed | Inlet Pressure | Discharge Pressure | Differential Pressure | Reference Vibration | Flow Rate | Pump Type | Revision |
|-----------------|--------------|-------------------------|-------------------------|-------------------------|---------------------|-------------------------|---------------------------------|----------|
| 1KCPU0004 | Not Required | RR-I.4.3 | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Centrifugal | |
| 1NDPU0001 | Not Required | RR-I.4.4 | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | RR-I.4.4 | Vertical Line Shaft Centrifugal | 22 |
| 1NDPU0002 | Not Required | RR-I.4.4 | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | RR-I.4.4 | Vertical Line Shaft Centrifugal | 22 |
| 1NIPU0009 | Not Required | RR-I.4.5 | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | RR-I.4.5 | Centrifugal | 22 |
| 1NIPU0010 | Not Required | RR-I.4.5 | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | RR-I.4.5 | Centrifugal | 22 |
| 1NSPU0001 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Vertical Line Shaft Centrifugal | |

UNIT 1 - McGUIRE NUCLEAR STATION
Pump Inservice Testing General Data

| Pump ID. Number | Description | Code Class | Flow Diagram | Applicable Relief Requests | Test Frequency | Remarks |
|-----------------|-------------------------------|------------|--------------|----------------------------|---|---|
| 1NSPU0002 | Containment Spray Pump 1B | 2 | MC-1563-1.0 | RR-I.3.1 | Quarterly | NONE |
| 1NVPU0015 | Centrifugal Charging Pump 1A | 2 | MC-1554-1.0 | RR-I.3.1, RR-I.4.6 | Quarterly- Miniflow; Refueling-Full Flow (RR-I.4.6) | The NV Testing Plan meets other code requirements unless otherwise specified. |
| 1NVPU0016 | Centrifugal Charging Pump 1B | 2 | MC-1554-1.0 | RR-I.3.1, RR-I.4.6 | Quarterly- Miniflow; Refueling-Full Flow (RR-I.4.6) | The NV Testing Plan meets other code requirements unless otherwise specified. |
| 1NVPU0027 | Boric Acid Transfer Pump 1A | 3 | MC-1554-5.0 | RR-I.3.1 | Quarterly | NONE |
| 1NVPU0028 | Boric Acid Transfer Pump 1B | 3 | MC-1554-5.0 | RR-I.3.1 | Quarterly | NONE |
| 1RNPU0003 | Nuclear Service Water Pump 1A | 3 | MC-1574-1.1 | RR-I.3.1 | Quarterly | NONE |

UNIT 1 - McGUIRE NUCLEAR STATION
Pump Inservice Testing Specific Data

| Pump ID. Number | Speed | Inlet Pressure | Discharge Pressure | Differential Pressure | Reference Vibration | Flow Rate | Pump Type | Revision |
|-----------------|--------------|-------------------------|-------------------------|-------------------------|---------------------|-------------------------|---------------------------------|----------|
| 1NSPU0002 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Vertical Line Shaft Centrifugal | |
| 1NVPU0015 | Not Required | RR-I.4.6 | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | RR-I.4.6 | Centrifugal | |
| 1NVPU0016 | Not Required | RR-I.4.6 | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | RR-I.4.6 | Centrifugal | |
| 1NVPU0027 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Centrifugal | |
| 1NVPU0028 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Centrifugal | |
| 1RNPU0003 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Centrifugal | 22 |

UNIT 1 - McGUIRE NUCLEAR STATION
Pump Inservice Testing General Data

| Pump ID. Number | Description | Code Class | Flow Diagram | Applicable Relief Requests | Test Frequency | Remarks |
|-----------------|------------------------------------|------------|--------------|----------------------------|----------------|---|
| 1RNPU0004 | Nuclear Service Water Pump 1B | 3 | MC-1574-1.1 | RR-I.3.1 | Quarterly | NONE |
| 1WNPU0094 | Diesel Generator Sump Pump 1A2 | 3 | MC-1609-7.0 | RR-I.3.1 | Two Year | Two year frequency for dry sump pumps per OMa-1988, Part 6 section 5.5. |
| 1WNPU0096 | Diesel Generator Sump Pump 1A3 | 3 | MC-1609-7.0 | RR-I.3.1 | Two Year | Two year frequency for dry sump pumps per OMa-1988, Part 6 section 5.5. |
| 1WNPU0095 | Diesel Generator Sump Pump 1B2 | 3 | MC-1609-7.0 | RR-I.3.1 | Two Year | Two year frequency for dry sump pumps per OMa-1988, Part 6 section 5.5. |
| 1WNPU0097 | Diesel Generator Sump Pump 1B3 | 3 | MC-1609-7.0 | RR-I.3.1 | Two Year | Two year frequency for dry sump pumps per OMa-1988, Part 6 section 5.5. |
| 1WZPU0001 | Groundwater Drainage Sump A Pump A | 3 | MC-1581-1.0 | RR-I.3.1 | Quarterly | NONE |

UNIT 1 - McGUIRE NUCLEAR STATION
Pump Inservice Testing Specific Data

| Pump ID. Number | Speed | Inlet Pressure | Discharge Pressure | Differential Pressure | Reference Vibration | Flow Rate | Pump Type | Revision |
|-----------------|--------------|-------------------------|-------------------------|-------------------------|---------------------|-------------------------|---------------------------------|----------|
| 1RNPU0004 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Centrifugal | 22 |
| 1WNPU0094 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Vertical Line Shaft Centrifugal | |
| 1WNPU0096 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Vertical Line Shaft Centrifugal | |
| 1WNPU0095 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Vertical Line Shaft Centrifugal | |
| 1WNPU0097 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Vertical Line Shaft Centrifugal | |
| 1WZPU0001 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Vertical Line Shaft Centrifugal | 21 |

General Relief Request

RELIEF REQUEST: I.3.1

PUMPS: All pumps in the Inservice Test Program

TEST REQUIREMENTS: OMA-1988 Part 6 Section 6.1 (Table 3a) specifies the allowable range for acceptable operation of vibration measurements.

BASIS FOR RELIEF: Experience has shown that smooth operating pumps ($V_r \leq 0.075$ in/sec) often fall in the alert range of vibration measurement when compared to the acceptance criteria given in OMA-1988 Part 6, Table 3a. The Code does not include provisions for a fixed band acceptance criteria for these pumps. The Alternative Testing provided below applies to all pumps in the Testing Program by establishing a threshold of vibration of ≤ 0.075 in/sec. In addition to this, OMA-1988 Part 6 does not specifically address different types of positive displacement pumps. Since McGuire has internal gear positive displacement pumps, the Alternate Testing below will be used for these pumps.

ALTERNATE TESTING: In addition to the vibration specified in OMA-1988 Part 6, Table 3a, the following ranges shall be used.

| | Acceptable Range | Alert Range | Required Action Range |
|---|------------------|--|--------------------------------|
| For all pumps when $V_r \leq 0.075$ in/sec | 0 to 0.19 in/sec | $> 0.19 \leq 0.45$ in/sec | > 0.45 in/sec |
| For centrifugal, vertical line shaft and positive displacement pumps except reciprocating when $V_r > 0.075$ in/sec | $\leq 2.5 * V_r$ | $> 2.5 * V_r$ to $6 * V_r$ or > 0.325 to 0.70 in/sec | $> 6 * V_r$ or > 0.70 in/sec |
| For reciprocating pumps, when $V_r > 0.075$ in/sec | $\leq 2.5 * V_r$ | $> 2.5 * V_r$ to $6 * V_r$ | $> 6 * V_r$ |

Revised by revision 22

Specific Relief Request

RELIEF REQUEST: 1.4.4

PUMPS: 1NDPU0001, 1A Residual Heat Removal Pump
1NDPU0002, 1B Residual Heat Removal Pump

TEST REQUIREMENT: OMa-1988 Part 6, Section 4.6.1.2.a specifies the range of each instrument shall be three times the reference value or less.

BASIS FOR RELIEF: Range requirements will be waived for the tests. The purpose of the quarterly test is to verify Tech Spec requirements are met and to obtain vibration data for trending. The instrumentation used for the quarterly Residual Heat Removal Pump test will meet accuracy requirements for assuring Residual Heat Removal Pump operability per Technical Specifications.

ALTERNATE TESTING: The Residual Heat Removal Pumps will be tested according to the following program, which is consistent with Generic Letter 89-04.

These pumps have process instrumentation installed such that there are two suction pressure gauges (0-60 psig and 0-600 psig), and one discharge pressure gauge, (0-1000 psig). Each has a 0.5% accuracy. This is done to provide accurate pressure indication in either the recirculation or the heat removal condition of operation. As such, there are times when the 3 times the reference range requirements cannot be met.

Quarterly

The Residual Heat Removal Pumps will be tested quarterly to verify Technical Specifications are met. The test measures differential pressure and velocity vibration data. The differential pressure and velocity vibration data will be trended. The instrument used to measure vibrations will meet the requirements specified in relief request 1.3.1. The test loop used in the test has a flow measuring orifice installed, however, the system resistance cannot be adjusted with the associated throttling valve without invalidating the Residual Heat Removal system flow balance (a Tech Spec balance of flow to all 4 cold legs.) Therefore, flow through this loop will be recorded for information only.

The instrumentation range requirements of OMa-1988 Part 6, Section 4.6.1.2.a will be waived. Since the instrumentation used to measure suction and discharge pressure is more accurate than code requirements (0.5% vs. 2%) using the process instrument for this test will yield results within the overall accuracy requirements of the code and will meet applicable accuracy requirements for the determination of operability per Technical Specifications. Typical values for ND suction pressure in mini-

Specific Relief Request

RELIEF REQUEST: I.4.4 (Continued)

flow are 48-81 psig, and discharge pressures are in the 230-260 psig range. Therefore, the process range for discharge pressure (0-1000 psig) will not meet the three times criteria; the appropriate suction pressure loop can be used, which is within the three times requirement. The accuracy of these process instruments (0.5%) is well below the requirements specified in Table 1 of OM-6 for instrument accuracy (2%). The actual reading error at test pressure due to the process instrument is 2.2 % ($0.5 * 1000/230$) for discharge pressure at the low end of this range (ND pump procedures specify that instrumentation must meet the three times criteria). If a 0-690 psig gauge was used with 2% accuracy, the reading error would be 6% ($2 * 690/230$). When the requirements of Oma-1988 Part 6, Section 4.6.1.2.a and Table 1 are combined, the actual instrument error introduced into the test is less than the code allowable (2.2 % vs. 6 % at the low (conservative) end). Using the process instruments for suction and discharge pressure data does not degrade the quality of the test and meets the intent of the instrumentation requirements of the code.

Refueling Outage

Full flow vibration measurements will be taken during refueling outages as part of the IST Supplemental Program.

Revised by revision 22

Specific Relief Request

RELIEF REQUEST: I.4.5

PUMPS: 1NIPU0009, 1A Safety Injection Pump
1NIPU0010, 1B Safety Injection Pump

TEST REQUIREMENT: OMa-1988 Part 6, Section 4.6.1.2.a specifies the range of each instrument shall be three times the reference value or less.

BASIS FOR RELIEF: Range requirements will be waived for the tests. The purpose of the quarterly test is to verify Tech Spec requirements are met and to obtain vibration data for trending. The instrumentation used for the quarterly Safety Injection Pump test will meet accuracy requirements for assuring Safety Injection Pump operability per Technical Specifications.

ALTERNATE TESTING: The Safety Injection Pumps will be tested according to the following program, which is consistent with Generic Letter 89-04.

Quarterly

The Safety Injection Pumps will be tested quarterly to verify Technical Specifications are met. The test measures differential pressure and velocity vibration data. The differential pressure and velocity vibration data will be trended. The instrument used to measure vibrations will meet the requirements specified in relief request I.3.1. The test loop has a flow measuring orifice installed, however, there is no means provided to vary the system resistance to set either the flow or differential pressure. Therefore, flow through this loop will be recorded for information only.

The instrumentation range requirements of OMa-1988 Part 6, Section 4.6.1.2.a will be waived. The instrumentation used to measure suction and discharge pressure will meet applicable accuracy requirements for the determination of operability per Technical Specifications. The process instruments meet the three times criteria, however in the event a test instrument is to be used, based on available equipment, it may not meet the three times criteria. In these instances, the accuracy of the test instruments is 0.25%, and this accuracy applied over the range of the instrument will meet the uncertainty allowed by the code assuming an accuracy of 2%.

Typical values for NI suction pressure are in the 25-51 psig range, and discharge pressures are in the 1500-1575 psig range. Test equipment used for suction and discharge pressures may not meet the three times

Specific Relief Request**RELIEF REQUEST:**

I.4.5 (Continued)

criteria, however these instruments will have 0.25% accuracy. The NI pump procedures specify that if a test instrument is needed for suction pressure, a 0-60 psig instrument is preferred, and that the range of the instrument must not exceed 0-100 psig. They also specify that if a discharge pressure test instrument is to be used, 0-2000 psig range is preferred, not to exceed 0-4500 psig. Using the low end suction pressure of 25 psig with the high end allowable gauge, accuracy is 1% ($0.25 * 100/25$); if a 0-75 psig gauge was used with a 2% accuracy, the code allowable would be 6% ($2 * 75/25$), so that use of this gauge would be within the code requirements. Using the low end discharge pressure with the high end allowable gauge, accuracy is 0.75% ($0.25 * 4500/1500$); this is at the three times range, and use of a 2% accuracy gauge would produce a total 6% allowable error. Therefore, using these test instruments for suction and discharge pressure data does not degrade the quality of the test and meets the intent of the instrumentation requirements of the code.

Refueling Outage

Full-flow vibration will be recorded under the IST Supplemental Program.

Revised by revision 22

Specific Relief Request

RELIEF REQUEST: I.4.6

PUMPS: 1NVP0015, 1A Centrifugal Charging Pump
1NVP0016, 1B Centrifugal Charging Pump

TEST REQUIREMENT: OMa-1988 Part 6, Section 4.6.1.2.a specifies the range of each instrument shall be three times the reference value or less.

BASIS FOR RELIEF: Range requirements will be waived for the tests. The purpose of the quarterly test is to verify Tech Spec requirements are met and to obtain vibration data for trending. The suction and discharge pressure gauges (0-60 psig and 0-3000 psig) installed for the pump have an accuracy of 0.5%. These pumps are aligned from the VCT for the quarterly test. Since these pumps are tested with different levels of VCT pressure, the suction pressure may vary over a range of approximately 15 to 50 psig. Since the uncertainty associated with using the process gauge is better than that allowed by code requirements, (2% vs. 6% determined by $0.5 * 60/15$ vs. $2 * 45/15$) the instrumentation used for the quarterly Centrifugal Charging Pump test will meet accuracy requirements for assuring Centrifugal Charging Pump operability per Technical Specifications.

Regarding instrument accuracy during the refueling outage testing (in Relief Request 1.4.6), the range of the highest suction pressure test gauge allowed for the full flow point will be 0-450 psig, and the range of the highest discharge pressure test gauge allowed (for the full flow point) will be 0-4500 psig. Suction pressure is typically 140 to 160 psig, and discharge pressure ranges from approximately 1000 to 2700 psig, so that overall suction and discharge pressure reading accuracy are 0.8 % ($0.25 * 450/140$) and 1.1 % ($0.25 * 4500/1000$), respectively. If a 0-420 psig suction pressure gauge was used with 2% accuracy, allowable accuracy would be 6 % ($2 * 420/140$), and if a 0-3000 psig discharge pressure gauge was used with 2% accuracy, allowable accuracy would be 6 % ($2 * 3000/1000$). Therefore, using these test instruments for suction and discharge pressure data (for the full flow point) does not degrade the quality of the test and meets the intent of the instrumentation requirements of the code. A 1% uncertainty is conservatively added for the flow orifice.

Specific Relief Request

RELIEF REQUEST: I.4.6 (Continued)

ALTERNATE TESTING: The Centrifugal Charging Pumps will be tested according to the following program, which is consistent with Generic Letter 89-04.

Quarterly

The Centrifugal Charging Pumps will be tested quarterly to verify Technical Specifications are met. The test measures differential pressure and velocity vibration data. The differential pressure and velocity vibration data will be trended. The instrumentation range requirements of OMa-1988 Part 6, Section 4.6.1.2.a will be waived. The instrumentation used to measure suction and discharge pressure will meet applicable accuracy requirements for the determination of operability per Technical Specifications. The instrument used to measure vibrations will meet the requirements specified in relief request I.3.1. The flow through the miniflow line to the Volume Control Tank will be assumed to be constant at the orifice design conditions (60 gpm).

Refueling Outage

During each refueling outage, a code pump test - including velocity vibration measurements - will be performed at a full flow test point.

The instrumentation used for the refueling outage tests is test instruments, with accuracy of 0.25%. When applied over the span on the instrument and the various range of outputs, in all cases the uncertainty of the overall loop will meet or exceed the code requirements of 2% over the instrument's range.

Revised by revision 22

10/12/95

Specific Relief Request

RELIEF REQUEST: I.4.7

PUMPS: 1RNPU0003, 1A Nuclear Service Water Pump
1RNPU0004, 1B Nuclear Service Water Pump

Relief Request deleted by Revision 22

**DUKE POWER COMPANY
McGUIRE NUCLEAR STATION - UNIT 1
VALVE INSERVICE TESTING PROGRAM**

INTRODUCTION

The inservice testing of ASME Code Categories A, B, C and D will be performed as required by ASME OM-Code-1987, Part 10 OMa-1988 addenda included, (Inservice Testing of Valves in Light-Water Reactor Power Plants), as incorporated in 10CFR50.55a. These rules for IST were instituted by 1989 edition of ASME Section XI and will be adhered to, except where specific written relief has been granted by the Commission. The effective date for this ten year submittal is March 1, 1994.

Technical Specification 4.0.5 requires inservice testing of ASME Code Class 1, 2 and 3 valves in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50, Section 50.55a(g)(6)(i). Valves were selected for inclusion in the IST Program (Section II.2) which fall within this category, as required by this Technical Specification. Valves within the above ASME categories which are required to mitigate the consequences of an accident, shutdown the reactor or maintain shutdown, or are pressure relief devices which protect systems or portions of systems which provide these functions, are included in the program. Testing requirements are identified for each valve which ensure that the valve will perform as designed in response to an accident, shutting down the reactor, or in providing relief protection. Valves are categorized in accordance with OM-10 Section 1.4, as Category A, B or C (there are no Category D valves in the program). Valves with remote position indicators are observed locally at least once every 2 years in accordance with the Code. Acceptance criteria are specified in accordance with ASME Boiler and Pressure Vessel Code Subsection IWV. The safety functions of the valves listed in Section II.2 are included in the Design Basis Documents, and fall within the basic categories of accident mitigation, reactor shutdown or maintaining shutdown, or pressure relief for systems providing such. Post modification testing requirements are included in the applicable Nuclear System Directive; a modification test plan is required to be developed to verify proper operation. OM-10 requires the determination of a new reference value after valve replacement, repair or maintenance that could affect its operation. These Code requirements and programmatic controls ensure that the valve inservice test program is maintained current with modifications performed under 10 CFR 50.59. The documents used in development of this program include the following:

- McGuire Technical Specifications.
- Safety Analysis Report.
- ASME Section XI, IWV (1986).
- ASME OM-Code-1987, Part 10 OMa-1988 addenda included.
- Generic Letter 89-04.
- Supplement 1 to Generic Letter 89-04.
- NUREG 1482, Guidelines for Inservice Testing at Nuclear Power Plants.
- Safety Evaluation Report for the McGuire IST Program dated October 21, 1994.

McGuire Unit 1

- NOTES:**
- 1) The dated initials of the person responsible for the action may be used in place of a signature in the record of tests. Initials shall be construed as signatures to meet the intent of OMa-1988, Section 6.3.
 - 2) Category A and A/C valves include containment isolation valves (CIV) and pressure isolation valves (PIV). CIVs are leak tested in accordance with 10CFR50, Appendix J, and Section 4.2.2.3, unless specific relief is requested.
 - 3) Generic Letter 89-04, provides guidance for sample disassembly of check valves as an alternative to verify operability of check valves. The check valves where sample disassembly will be utilized will be specified in the contents of the program submittal and performed according to the guidelines of Generic Letter 89-04.
 - 4) A Supplemental Test Program has been established, which includes components which have been determined important to safety and prudent to test, but which are not explicitly under the scope of ASME Codes and Standards.

**Unit 1 - McGuire Nuclear Station
Inservice Testing Program**

| VALVE NUMBER | FLOW DIAGRAM | FLOW COOR | ASME CLASS | VALVE CATEGORY | ACT PAS | VALVE TYPE | ACTUATOR TYPE | TEST REQMT #1 | TEST REQMT #2 | RELIEF REQST | JUSTIF OF DEFERRAL | REMARKS | TEST ALTERNATIVES | REV |
|---|--------------|-----------|------------|----------------|---------|------------|---------------|---------------|---------------|--------------|--------------------|------------------------|-------------------|-----|
| CHEMICAL AND VOLUME CONTROL (NV) | | | | | | | | | | | | | | |
| 1NV-0006 | 1554-1.2 | K-09 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 600 PSIG | 22 |
| 1NV-0007B | 1554-1.2 | J-10 | 2 | B | ACT | Globe | EMO | ST-Q | - | - | 1-MC-NV2 | - | - | - |
| 1NV-0020 | 1554-1.2 | E-02 | 2 | C | ACT | Check | - | SP | - | - | - | Spring Loaded Ck Valve | 50 PSIG | - |
| 1NV-0021A | 1554-1.2 | E-03 | 1 | B | ACT | Control | AOV | ST-Q | - | - | 1-MC-NV3 | - | - | - |
| 1NV-0029 | 1554-1.0 | C-01 | 2 | C | ACT | Check | - | MTO-Q | - | - | - | - | - | - |
| 1NV-0031 | 1554-1.0 | D-02 | 1 | C | ACT | Check | - | MTO-Q | - | - | - | - | - | - |
| 1NV-0035A | 1554-1.2 | K-07 | 2 | B | ACT | Gate | AOV | ST-Q | - | - | 1-MC-NV18 | - | - | 22 |
| 1NV-0045 | 1554-1.0 | C-08 | 2 | C | ACT | Check | - | MTO-Q | - | - | - | - | - | - |
| 1NV-0047 | 1554-1.0 | D-08 | 1 | C | ACT | Check | - | MTO-Q | - | - | - | - | - | - |
| 1NV-0061 | 1554-1.1 | C-01 | 2 | C | ACT | Check | - | MTO-Q | - | - | - | - | - | - |
| 1NV-0063 | 1554-1.1 | D-02 | 1 | C | ACT | Check | - | MTO-Q | - | - | - | - | - | - |
| 1NV-0077 | 1554-1.1 | C-08 | 2 | C | ACT | Check | - | MTO-Q | - | - | - | - | - | - |
| 1NV-0079 | 1554-1.1 | D-08 | 1 | C | ACT | Check | - | MTO-Q | - | - | - | - | - | - |
| 1NV-0093 | 1554-1.1 | K-12 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 150 PSIG | - |
| 1NV-0094AC | 1554-1.1 | J-13 | 2 | B | ACT | Gate | EMO | ST-Q | - | - | 1-MC-NV1 | - | - | - |
| 1NV-0095B | 1554-1.1 | H-13 | 2 | B | ACT | Gate | EMO | ST-Q | - | - | 1-MC-NV1 | - | - | - |

**Unit 1 - McGuire Nuclear Station
Inservice Testing Program**

| VALVE NUMBER | FLOW DIAGRAM | FLOW COOR | ASME CLASS | VALVE CATEGORY | ACT PAS | VALVE TYPE | ACTUATOR TYPE | TEST REQMT #1 | TEST REQMT #2 | RELIEF REQST | JUSTIF OF DEFERRAL | REMARKS | TEST ALTERNATIVES | REV |
|--------------|--------------|-----------|------------|----------------|---------|------------|---------------|---------------|---------------|--------------|--------------------|---------|-------------------|-----|
| 1NV-0141A | 1554-2.0 | B-08 | 2 | B | ACT | Gate | EMO | ST-Q | - | - | 1-MC-NV4 | - | - | - |
| 1NV-0142B | 1554-2.0 | B-07 | 2 | B | ACT | Gate | EMO | ST-Q | - | - | 1-MC-NV4 | - | - | - |
| 1NV-0143 | 1554-2.0 | B-07 | 2 | C | ACT | Check | - | MTC-Q | - | - | 1-MC-NV15 | - | - | - |
| 1NV-0150B | 1554-2.0 | F-02 | 2 | B | ACT | Kerotest | EMO | ST-Q | - | - | 1-MC-NV8 | - | - | - |
| 1NV-0151A | 1554-2.0 | G-02 | 2 | B | ACT | Kerotest | EMO | ST-Q | - | - | 1-MC-NV8 | - | - | - |
| 1NV-0155 | 1554-2.0 | I-06 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 150 PSIG | - |
| 1NV-0156 | 1554-2.0 | J-09 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 255 PSIG | - |
| 1NV-0164 | - | - | - | - | - | - | - | DELETED | - | - | - | - | - | 22 |
| 1NV-0170 | 1554-2.0 | C-08 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 75 PSIG | - |
| 1NV-0218 | 1554-3.0 | J-05 | 2 | C | ACT | Check | - | MTC-Q | - | - | - | - | - | - |
| 1NV-0221A | 1554-3.1 | H-01 | 2 | B | ACT | Gate | EMO | ST-Q | - | - | 1-MC-NV6 | - | - | - |
| 1NV-0222B | 1554-3.1 | I-01 | 2 | B | ACT | Gate | EMO | ST-Q | - | - | 1-MC-NV6 | - | - | - |
| 1NV-0223 | 1554-3.1 | I-02 | 2 | C | ACT | Check | - | MTO,C-Q | - | - | 1-MC-NV11 | - | - | - |
| 1NV-0225 | 1554-3.1 | F-05 | 2 | C | ACT | Check | - | MTO,C-Q | - | - | 1-MC-NV10 | - | - | - |
| 1NV-0227 | 1554-3.1 | E-06 | 2 | C | ACT | Check | - | MTO,C-Q | - | - | - | - | - | - |
| 1NV-0229 | 1554-3.1 | I-12 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 220 PSIG | - |

**Unit 1 - McGuire Nuclear Station
Inservice Testing Program**

| VALVE NUMBER | FLOW DIAGRAM | FLOW COOR | ASME CLASS | VALVE CATEGORY | ACT PAS | VALVE TYPE | ACTUATOR TYPE | TEST REQMT #1 | TEST REQMT #2 | RELIEF REQST | JUSTIF OF DEFERRAL | REMARKS | TEST ALTERNATIVES | REV |
|--------------|--------------|-----------|------------|----------------|---------|------------|---------------|---------------|---------------|--------------|--------------------|---------|-------------------|-----|
| 1NV-0231 | 1554-3.1 | F-10 | 2 | C | ACT | Check | - | MTO,C-Q | - | - | 1-MC-NV10 | - | - | - |
| 1NV-0233 | 1554-3.1 | E-10 | 2 | C | ACT | Check | - | MTO,C-Q | - | - | - | - | - | - |
| 1NV-0238 | | | | | | | | DELETED | | | | | | 21 |
| 1NV-0244A | 1554-3.0 | K-08 | 2 | B | ACT | Gate | EMO | ST-Q | - | - | 1-MC-NV5 | - | - | - |
| 1NV-0245B | 1554-3.0 | K-09 | 2 | B | ACT | Gate | EMO | ST-Q | - | - | 1-MC-NV5 | - | - | - |
| 1NV-0261 | 1554-3.1 | J-03 | 2 | C | ACT | Check | - | MTC-Q | - | - | 1-MC-NV13 | - | - | - |
| 1NV-0263 | 1554-3.1 | J-11 | 2 | C | ACT | Check | - | MTC-Q | - | - | 1-MC-NV13 | - | - | - |
| 1NV-0264 | 1554-3.1 | J-10 | 2 | C | ACT | Check | - | MTO,C-Q | - | - | 1-MC-NV7 | - | - | - |
| 1NV-0265B | 1554-3.1 | J-09 | 2 | B | ACT | Globe | EMO | ST-Q | - | - | 1-MC-NV9 | - | - | - |
| 1NV-0383 | 1554-5.0 | E-06 | 3 | C | ACT | Check | - | MTO,C-Q | - | - | - | - | - | - |
| 1NV-0386 | 1554-5.0 | C-06 | 3 | C | ACT | Check | - | MTO,C-Q | - | - | - | - | - | - |
| 1NV-0457A | 1554-1.2 | I-07 | 2 | B | ACT | Control | AOV | ST-Q | - | - | 1-MC-NV18 | - | - | 22 |
| 1NV-0458A | 1554-1.2 | J-07 | 2 | B | ACT | Control | AOV | ST-Q | - | - | 1-MC-NV18 | - | - | 22 |
| 1NV-0482 | 1554-2.0 | D-07 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 150 PSIG | - |
| 1NV-0483 | 1554-2.0 | D-11 | 3 | C | ACT | Relief | - | SP | - | - | - | - | 150 PSIG | - |
| 1NV-0486 | 1554-3.1 | J-09 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 150 PSIG | - |

**Unit 1 - McGuire Nuclear Station
Inservice Testing Program**

| VALVE NUMBER | FLOW DIAGRAM | FLOW COOR | ASME CLASS | VALVE CATEGORY | ACT PAS | VALVE TYPE | ACTUATOR TYPE | TEST REQMT #1 | TEST REQMT #2 | RELIEF REQST | JUSTIF OF DEFERRAL | REMARKS | TEST ALTERNATIVES | REV |
|--------------|--------------|-----------|------------|----------------|---------|------------|---------------|---------------|---------------|--------------|--------------------|---------|-------------------|-----|
| 1RN-0299A | 1574-1.0 | K-02 | 3 | B | ACT | Butterfly | EMO | ST-Q | - | - | - | - | - | - |
| 1RN-0442 | 1574-2.0 | J-11 | 3 | B | ACT | Butterfly | AOV | ST-Q | - | - | - | - | - | - |
| 1RN-0445 | 1574-2.0 | J-11 | 3 | B | ACT | Butterfly | AOV | ST-Q | - | - | - | - | - | - |
| 1RN-0457 | 1574-3.0 | J-11 | 3 | B | ACT | Butterfly | AOV | ST-Q | - | - | - | - | - | - |
| 1RN-0460 | 1574-3.0 | J-11 | 3 | B | ACT | Butterfly | AOV | ST-Q | - | - | - | - | - | - |
| 1RN-0891 | - | - | - | - | - | - | - | DELETED | - | - | - | - | - | 22 |
| 1RN-0892 | - | - | - | - | - | - | - | DELETED | - | - | - | - | - | 22 |
| 1RN-0994 | 1574-3.1 | C-07 | 3 | C | ACT | Check | - | MTC-Q | - | - | - | - | - | 21 |
| 1RN-1006 | 1574-2.1 | E-06 | 3 | C | ACT | Check | - | MTC-Q | - | - | - | - | - | 21 |

Specific Relief Request

Item Number: 1-MC-RR-NS1

Valve: 1NS-13, 1NS-16, 1NS-30, 1NS-33, 1NS-41, 1NS-46

Flow Diagram: MC-1563-1.0

Code Category: C

ASME Class: 2

Function: Open on flow from containment spray pumps.

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Relief: Containment Spray valves 1NS-13, 16, 30, 33, 41, and 46 are Aloyco/Walworth model D-49300 cover hung, swing check valves. They are normally closed providing Category C interior containment isolation for Containment Spray and Auxiliary Containment Spray (valves 1NS-41 and 46). OMA-1988, Part 10, paragraph 4.3.2.1 requires quarterly exercising, deferrable to cold shutdowns or refueling outages. McGuire FSAR Table 6-112 identifies these valves as Leak Class 1A valves not requiring leak rate testing due their inability to release containment atmosphere during a LOCA.

Full stroke operation of the check valves shall be verified by disassembly/inspection of the valves as no operational method exists without actuating containment spray (reference 1MC-NS2, NUREG-1482 Staff Position 2). As a supplement to the full stroke testing, part stroke and closed verification will be conducted upon reassembly and periodically by air test as described for the spray nozzle test in McGuire FSAR 6.5.4 (reference , NUREG-1482 Staff Position 2).

For valve disassembly/inspection, all six valves will be grouped into one group and inspected within a four cycle window (six year interval). All six valves are identical in manufacturer and installation. Operationally, the valves are identical with respect to operational readiness. During system actuation, supply originates from the Containment Spray system for valves 1NS-13, 16, 30, and 33 and Residual Heat Removal system for

Revised by Rev. 22.

10/12/95

SECTION II.6

1 OF 7

Specific Relief Request

Item Number: 1-MC-RR-NS1 (cont.)

1NS-41 and 46. In spray modes both systems have similar hydraulic characteristics. At McGuire's discretion the valves may be disassembled/inspected sequentially, in sub-groups, or as one complete group every fourth outage (six years). Diversion from the sequential disassembly/inspection represents an extension from the Code required frequency.

The relief request does not represent a decrease in quality nor safety. The valve disassembly/inspection will demonstrate ability of the valve to full stroke and fully close. As the valves do not function except during testing and severe plant emergencies, no operating degradation mechanisms exist. Potential degradation mechanisms from the valves being in a static position will be identified by the part stroke test conducted each refueling outage on all valves.

Compliance with the Code requirements is impractical and would impose unnecessary hardship. The valves are located within the containment dome volume and are accessible by a temporary cantilevered scaffold attached to the Polar Crane Scissors Jack. This action, in accordance with the requirements of 29CFR 1910.28, 29CFR 1926.452, ANSI A10.8-1977, and McGuire's Scaffold program places personnel in unsafe positions during the erection/removal of the scaffold and valve testing. No additional assurance of valve function is gained. In fact, although unlikely, frequent intrusion into the valves' internals and the inability to verify exact seat alignment during reassemble may degrade the valves' condition.

Pursuant to NUREG-1482 Staff Position 2, extension of the valve disassembly/inspection interval will be considered in cases of extreme hardship. Response to Question 19 of same implies "extreme hardship" is proportional to the impact on plant safety. The hardship impact is one of undue personnel safety risk and refueling outage extension. Yet the benefit from testing under the current scheme (reference 1MC-NS2) as compared to the proposed scheme is negligible at best. All valves will be disassembled/inspected once per four refueling outages (six years).

Revised by Rev. 22.

10/12/95

SECTION II.6

2 OF 7

Specific Relief Request

Item Number: 1-MC-RR-NS1 (cont.)

A review of McGuire's valves, similar industry valves, and the "EPRI Applications Guidelines for Check Valves in Nuclear Power Plants" was conducted.

A review of the past 6 Unit 1 refueling outages, 7 Unit 2, identified part stroke testing of all valves every outage through 1/2EOC 9. Since 1/2EOC 6 each Containment Spray check valve has been disassembled/inspected once and Auxiliary Containment Spray valves twice (due to the current grouping scheme). A comprehensive review of all valves identified no indication of wear, corrosion, or degradation.

A NPRDS search for Aloyco-Walworth and Walworth check valves provided a list of 34 Containment Spray check valve failures. A detailed review of the 34 failures identified 14 potentially related failures. Subsequent conversation with the respective plants' System Engineers resolved 11 of these potentially related failures as unrelated. Reasons for determining a valve failure was unrelated included the following; valves normally see flow during testing or other plant operation, and recent ISI disassembly/inspection of valves identified no degradation. The 3 remaining potentially related failures included 2 which could not be determined and 1 which was a result of valve disk misalignment. As stated earlier the potential for valve disk misalignment increases, although marginally, with repetitive disassemblies.

A review of the "EPRI Applications Guidelines for Check Valves in Nuclear Power Plants" primarily addressed degradation of check valves regularly in operation service. Design criteria for check valve application was also discussed. Comparison with the subject check valves did not reveal any design misapplication issues. The issue of valve sticking open/closed was discussed in section 6.5.4, identifying improperly assembly as a potential cause. This issue would be addressed by the proposed part flow testing.

This Relief Request evaluation concludes adequate justification without compromise to safety or quality exist to warrant the proposed test methodology.

Revised by Rev. 22.

10/12/95

Specific Relief Request

Item Number: 1-MC-RR-NS1 (cont.)

Test Alternative & Frequency: Containment Spray valves 1NS-13, 16, 30, 33, 41, and 46 will be grouped into a single test group. The valves may be disassembled/inspected sequentially, in sub-groups, or as one complete group every fourth outage (6 years). Each valve will be disassembled/inspected once per four refueling outages (6 years). Each Containment Spray valve will be part stroke tested during each refueling outage.

Revised by Rev. 22.

10/12/95

Justification of Deferral

Item Number: 1-MC-CA1

Valve: 1CA-37, 1CA-41, 1CA-45, 1CA-49, 1CA-53, 1CA-57, 1CA-61,
1CA-65

Flow Diagram: MC-1592-1.0

Code Category: C

ASME Class: 2

Function: Check flow from the steam generators to Auxiliary Feedwater.
Open to allow Auxiliary Feedwater supply to the Steam
Generators.

Test Requirement: Verify proper valve movement once per three months as re-
quired by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Full stroke testing these valves would unnecessarily thermal
shock the steam generators and feedwater piping.

Test Alternative & Frequency: Valves will be full stroke exercised at cold shutdown. Closure
will be verified quarterly.

Justification of Deferral

Item Number: 1-MC-CA2

Valve: 1CA-165, 1CA-166

Flow Diagram: MC-1592-1.1

Code Category: C

ASME Class: 3

Function: Prevents backflow from Auxiliary Feedwater System to Nuclear service Water System until the associated EMOs are closed. EMOs are powered from the same train they serve. Must open to allow assured makeup flow to CA from RN system.

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Deferral: Neither full nor partial flow can be put through these valves without contaminating the Auxiliary Feedwater System with raw water. No means exist for alternate testing techniques using air or any other medium. No means exist to test for proper closure without contaminating the Auxiliary Feedwater System with raw water. These valves will not be tested during cold shutdown because sample disassembly is required.

Test Alternative & Frequency: At least one of these two valves will be disassembled and full stroked during each refueling outage, and both valves will have been disassembled and full stroked after two consecutive refueling outages. Failure of one valve to properly full stroke during a refueling outage will result in the remaining valves being disassembled and full stroked during that outage. Sample disassemble will also be used to verify proper closure of valves.

Justification of Deferral

Item Number: 1-MC-CA3

Valve: 1CA-8, 1CA-10, 1CA-12

Flow Diagram: MC-1592-1.1

Code Category: C

ASME Class: 3

Function: Auxiliary Feedwater Pump Suction Check valves to prevent diversion of assured auxiliary feedwater source.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: These valves cannot be tested to close without contaminating the Auxiliary Feedwater System with raw water. These valves will not be tested during cold shutdown because sample disassembly is required.

Test Alternative & Frequency: Valves will be sample disassembled during refueling outages to verify valve closure capability. 1CA-8 is disassembled every refueling outage, 1CA-10 and 1CA-12 every other refueling outage on a staggered basis.

Justification of Deferral

Item Number: 1-MC-CF1

Valve: 1CF-26AB, 1CF-28AB, 1CF-30AB, 1CF-35AB

Flow Diagram: MC-1591-1.1

Code Category: B

ASME Class: 2

Function: Provide feedwater and containment isolation.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closure of these valves would isolate the Steam Generator feedwater which could result in a severe transient in the Steam Generator, resulting in a Unit trip.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-CF2

Valve: 1CF-17AB, 1CF-20AB, 1CF-23AB, 1CF-32AB

Flow Diagram: MC-1591-1.1

Code Category: B

ASME Class: ANSI B31.1.0 (1967)

Function: Feedwater control.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closure of these valves would isolate the Steam Generator feedwater which could result in a severe transient in the Steam Generator, resulting in a Unit trip.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-CF3

Valve: 1CF-126B, 1CF-127B, 1CF-128B, 1CF-129B

Flow Diagram: MC-1591-1.1

Code Category: B

ASME Class: 2

Function: Opens to provide startup feedwater supply to the steam generators.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Cycling valves during power operation could induce unwanted transients in the steam generators. This would result in an increase in flow to the main feedwater nozzles causing vibrations in the preheater section of the steam generators.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-CF4

Valve: 1CF-104AB, 1CF-105AB, 1CF-106AB, 1CF-107AB

Flow Diagram: MC-1591-1.1

Code Category: B

ASME Class: ANSI B31.1.0 (1967)

Function: Provides tempering flow to the steam generators.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closing these valves during operation would result in a feedwater transient and could result in loss of Steam Generator level control, causing a Unit trip. These valves are normally open at power.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

Justification of Deferral

Item Number: 1-MC-CF5

Valve: 1CF-152, 1CF-154, 1CF-156, 1CF-158

Flow Diagram: MC-1591-1.1

Code Category: C

ASME Class: 2

Function: Opens to allow tempering flow to the Steam Generator auxiliary feedwater nozzles. Closes to form pressure boundary for auxiliary feedwater.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: During normal operation, there is constant flow through these valves to keep the auxiliary feedwater nozzles tempered. Testing these valves would require supplying the Steam Generators with cold water and thus thermally shocking these nozzles.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Justification of Deferral

Item Number: 1-MC-CF6

Valve: 1CF-118, 1CF-119, 1CF-120, 1CF-121

Flow Diagram: MC-1591-1.1

Code Category: C

ASME Class: 2

Function: Opens to allow feedwater flow to the Steam Generators. Closes to form pressure boundary for maintaining Steam Generator inventory. The open function is not within the Scope of OM-10.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: During normal operation, there is constant flow through these valves. The required test is performed while the Steam Generators are in wet-layup, with the main condensate system in service. The piping upstream of the check valve is depressurized, while the downstream side is pressurized. The check valves are verified to prevent gross diversion of flow. These conditions cannot be obtained with the unit operating.

Test Alternative & Frequency: Valves will be full stroke exercised at cold shutdown.

Revised by revision 21

10/16/95

Justification of Deferral

Item Number: 1-MC-FW1

Valve: 1FW-27A

Flow Diagram: MC-1571-1.0

Code Category: B

ASME Class: 2

Function: Isolates low pressure injection from the Refueling Water Storage Tank.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closure of this valve during normal power operation would render all low pressure injection inoperable. This valve is opened and power removed above Mode 4 per Tech Spec 4.5.2.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-FW2

Valve: 1FW-28

Flow Diagram: MC-1571-1.0

Code Category: C

ASME Class: 2

Function: Opens to allow low pressure injection flow. Closes to prevent reverse flow to the Refueling Water Storage Tank, thereby preventing pressurization of the tank.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Valve cannot be full stroked during power operation since the only full flow path is into the RCS by the Residual Heat Removal pumps. These pumps cannot overcome RCS system pressure.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Justification of Deferral

| | |
|-------------------------------|--|
| Item Number: | 1-MC-FW3 |
| Valve: | 1FW-74 |
| Flow Diagram: | MC-1571-1.0 |
| Code Category: | C |
| ASME Class: | 3 |
| Function: | Must close to provide a pressure boundary for the assured makeup (Nuclear service Water) to the Spent Fuel Pool. |
| Test Requirement: | Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1. |
| Basis for Deferral: | The system does not provide a means to verify valve closure. |
| Test Alternative & Frequency: | Valve will be disassembled and inspected to verify closure at refueling outage frequency. |

Revised by revision 21

10/16/95

Justification of Deferral

Item Number: 1-MC-IA1

Valve: 11A-5260, 11A-5270, 11A-5280, 11A-5290, 11A-5300, 11A-5310, 11A-5320, 11A-5330, 11A-5340, 11A-5350, 11A-5360, 11A-5370, 11A-5380, 11A-5390

Flow Diagram: MC-1499-IA1

Code Category: A,C

ASME Class: 2 & 3

Function: 11A-5260, 5270, 5280, 5290, 5300, 5310, 5320 and 5330 prevent loss of air from receiver tank on each personnel airlock door in the event of loss of instrument air supply to door seals. These check valves form a pressure boundary for the inflatable seals. 11A-5340 and 5350 provide the inside containment isolation barrier in the event of a break on the flexible hose connection on the air supply to the door seals. The outside isolation valves are 11A-5080 and 5160. These check valves are on the auxiliary building side of the airlocks. 11A-5360, 5370, 5380 and 5390 provide double isolation on the reactor building side of the airlocks for the pressure relief line.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.
2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.
3) Leak test in accordance with Technical Specification 4.6.1.3.d.

Basis for Deferral: These valves cannot be practically tested during operation due to the design of the system.

Test Alternative & Frequency: Valves will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at a six month frequency per Tech Spec 4.6.1.3.d.

Justification of Deferral

Item Number: 1-MC-KC1

Valve: 1KC-424B, 1KC-425A

Flow Diagram: MC-1573-3.1

Code Category: A

ASME Class: 2

Function: Provide containment isolation for penetration M-320.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Failure of either of these valves in the closed position during testing would inhibit the normal flow path from the reactor coolant pump motor coolers. This action could result in damage to the NC pumps. Within 15 to 30 minutes, the NC Pumps would be tripped on high bearing temperature, and an abnormal shutdown (natural circulation) would be required.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

Justification of Deferral

Item Number: 1-MC-KC2

Valve: 1KC-338B

Flow Diagram: MC-1573-3.1

Code Category: A

ASME Class: 2

Function: Provide containment isolation for penetration M-327.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Failure of this valve in the closed position during testing could result in damage to the NC pumps. Within 15 to 30 minutes, the NC Pumps would be tripped on high bearing temperature, and an abnormal shutdown (natural circulation) would be required.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-KC3

Valve: 1KC-332B, 1KC-333A

Flow Diagram: MC-1573-3.1

Code Category: A

ASME Class: 2

Function: Provide containment isolation for penetration M-355.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Failure of one of these valves in the closed position during testing would inhibit flow through the reactor coolant drain tank heat exchanger. No alternate flowpath for cooling water to the heat exchanger exists. Without flow to the heat exchanger, the drain tank would become over pressurized and steam would be released. Such a test would not be conservative, since Reactor Coolant would be released. This test would challenge the overpressure protection of a Reactor Coolant System component. It is concluded therefore that per NUREG-1482 Section 3.1.1 that these valves should be excluded from quarterly testing.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

| | |
|-------------------------------|---|
| Item Number: | 1-MC-KC4 |
| Valve: | 1KC-320A |
| Flow Diagram: | MC-1573-3.1 |
| Code Category: | A |
| ASME Class: | 2 |
| Function: | Provide containment isolation for penetration M-376. |
| Test Requirement: | Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1. |
| Basis for Deferral: | Failure of this valve in the closed position during testing would inhibit flow through the reactor coolant drain tank heat exchanger. No alternate flowpath for cooling water to the heat exchanger exists. Without flow to the heat exchanger, the drain tank would become over pressurized and steam would be released. Such a release of Reactor Coolant makes this test nonconservative and would challenge the overpressure protection of a Reactor Coolant System component. It is concluded therefore that per NUREG-1482 Section 3.1.1 that this valve should be excluded from quarterly testing. |
| Test Alternative & Frequency: | Valve will be cycled and timed during cold shutdown. |

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-KC5

Valve: 1KC-280

Flow Diagram: MC-1573-3.1

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation and thermal over pressurization protection of line between 1KC-332B and 1KC-333A on penetration M-355.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: This valve cannot be practically tested during operation due to the design of the system. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-KC6

Valve: 1KC-322

Flow Diagram: MC-1573-3.1

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-376.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: This valve cannot be practically tested during operation due to the design of the system. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-KC7

Valve: 1KC-279

Flow Diagram: MC-1573-3.1

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation and thermal over pressurization protection of line between 1KC-424B and 1KC-425A on penetration M-320.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.
2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-KC8

Valve: 1KC-340

Flow Diagram: MC-1573-3.1

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-327.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4 3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-KC9

Valve: 1KC-47

Flow Diagram: MC-1573-4.0

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-322.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Justification of Deferral

Item Number: 1-MC-NB1

Valve: 1NB-262

Flow Diagram: MC-1556-3.0

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-259.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with: CMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-NC1

Valve: 1NC-32B, 1NC-34A, 1NC-36B

Flow Diagram: MC-1553-2.0

Code Category: B

ASME Class: 1

Function: Reactor Coolant System PORV. Opens to relieve pressure for the primary system.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: PORVs do not serve a safety function when unit is at operating temperature and pressure. PORVs protect the Reactor Coolant System from over pressurization during LTOP conditions.

Test Alternative & Frequency: Stroke time testing will be performed at cold shutdown and in all cases prior to entering LTOP conditions in accordance with Generic Letter 90-06. Testing will not be required more often than once per quarter as defined in OMa-1988 Part 10, 4.2.1.1.

Justification of Deferral

Item Number: 1-MC-NC2

Valve: 1NC-272AC, 1NC-273AC, 1NC-274B, 1NC-275B

Flow Diagram: MC-1553-2.1

Code Category: B

ASME Class: 1

Function: Reactor vessel head vent.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Opening these valves at full pressure could cause damage to the valve seating surfaces. A reactor coolant leak could be caused.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-NC3

Valve: 1NC-259, 1NC-261

Flow Diagram: MC-1553-4.0

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation and thermal over pressurization protection of line between 1NC-195B and 1NC-196A on penetration M-361, and line between 1NC-141 and 1NC-142 on penetration M-326 respectively.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-NC4

Valve: 1NC-59

Flow Diagram: MC-1553-2.1

Code Category: C

ASME Class: 2

Function: Must open to allow various relief valves on ECCS systems to relieve to the Pressurizer Relief Tank.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: The system design does not provide a sufficient means of verifying full opening of the check valve.

Test Alternative & Frequency: Valve will be disassembled and inspected to verify full stroke opening at refueling outage frequency.

Justification of Deferral

Item Number: 1-MC-NC5

Valve: 1NC-284

Flow Diagram: MC-1553-2.1

Code Category: C

ASME Class: Duke Class E

Function: Must open to allow various relief valves on ECCS systems to relieve to the Pressurizer Relief Tank.

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Deferral: The system design does not provide a sufficient means of verifying full opening of the check valve.

Test Alternative & Frequency: Valve will be disassembled and inspected to verify full stroke opening at refueling outage frequency.

Justification of Deferral

Item Number: 1-MC-ND1

Valve: 1ND-1B, 1ND-2AC

Flow Diagram: MC-1561-1.0

Code Category: A

ASME Class: 1

Function: Provides suction for Residual Heat Removal pumps during normal cooldown.

Test Requirement: 1) Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.
2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.3.

Basis for Deferral: These valves have an interlock which prevents their opening when the Reactor Coolant System pressure is greater than 385psig.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown. Valve will be leak tested in accordance with Tech Spec 4.4.6.2.2.

Justification of Deferral

Item Number: 1-MC-ND2

Valve: 1ND-58A

Flow Diagram: MC-1561-1.0

Code Category: B

ASME Class: 2

Function: Provides suction to the Centrifugal Charging Pumps and Safety Injection Pumps from the Residual Heat Removal system.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Opening 1ND-58A would seat check valve 1NV-223 (FWST to Charging Pump suction) closed, so that if 1ND-58A failed in the open position, both trains of NV would be inoperable.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: MC-ND3

Valve: 1ND-15B, 1ND-30A

Flow Diagram: MC-1561-1.0

Code Category: B

ASME Class: 2

Function: ND Heat Exchanger Outlet Crossover Block Valves.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: One of the ECCS safety analysis assumptions is that each train of ND can supply flow to all four cold legs. If either of these valves failed closed during testing then only two cold legs could be supplied by each train of ND. This would make both trains of ND inoperable.

Power cannot be removed from these valves, since at least one of them must be closed for cold leg recirc. If power was removed from one valve, a single failure on the opposite train would disable isolation of ND to the cold legs when needed (this isolation is needed for adequate cold leg recirc flow).

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-ND4

Valve: 1ND-70

Flow Diagram: MC-1561-1.0

Code Category: C

ASME Class: 2

Function: Opens to provides suction to the Centrifugal Charging Pumps and Safety Injection Pumps from the Residual Heat Removal system. Closes to provide suction pressure boundary for the Centrifugal Charging Pumps and Safety Injection Pumps

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Deferral: Valve cannot be full stroked during power operation since 1ND-58A would have to be opened, rendering both trains of ND inoperable. Additionally, the flow requirements to full stroke this valve cannot be achieved with the Reactor Coolant System pressurized.

Opening 1ND-58A would seat check valve 1NV-223 (FWST to Charging Pump suction) closed, so that if 1ND-58A failed in the open position, both trains of NV would be inoperable.

Manually closing 1ND-29, a fail-open valve, would be impractical.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown. Valve will be partial stroked quarterly.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-ND5

Valve: 1ND-71

Flow Diagram: MC-1561-1.0

Code Category: C

ASME Class: 2

Function: Opens to provides suction to the Centrifugal Charging Pumps and Safety Injection Pumps from the Residual Heat Removal system. Closes to provide suction pressure boundary for the Centrifugal Charging Pumps and Safety Injection Pumps

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Valve cannot be full stroked during power operation since 1NI-136B would have to be opened, rendering both trains of ND inoperable. Additionally, the flow requirements to full stroke this valve cannot be achieved with the Reactor Coolant System pressurized.

Opening 1ND-136B would seat check valve 1NV-223 (FWST to Charging Pump suction) closed, so that if 1ND-136B failed in the open position, both trains of NV would be inoperable.

Manually closing 1ND-14, a fail-open valve, would be impractical.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-ND6

Valve: 1ND-8, 1ND-23

Flow Diagram: MC-1561-1.0

Code Category: C

ASME Class: 2

Function: Residual Heat Removal pump discharge check valve.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Valves cannot be full stroke exercised during power operation since the only full flow path is into the Reactor Coolant System and the ND pumps cannot overcome RCS pressure.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown. Valves will be partially stroked quarterly. The opposite train valves will be tested closed quarterly except when the opposite train of ND is in service.

Justification of Deferral

Item Number: 1-MC-NF1

Valve: 1NF-229

Flow Diagram: MC-1558-4.0

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-373.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2. 10CFR50 Appendix J requires measurement of local leak rate using air or nitrogen.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: 1) Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

2) Leak Rate testing of the valve will be performed per Tech Spec 4.6.1.2.d.4.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-NI1

Valve: 1NI-9A, 1NI-10B

Flow Diagram: MC-1562-1.0

Code Category: B

ASME Class: 2

Function: Flowpath for Centrifugal Charging Pumps to Reactor Coolant System Cold Legs.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Opening either of these valves during operation would increase the charging flow into the Reactor Coolant System resulting in an increase of pressure and a rapid change in the primary system boron concentration. This could create a transient and possible unit shutdown.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-NI2

Valve: 1NI-100B

Flow Diagram: MC-1562-3.0

Code Category: B

ASME Class: 2

Function: Flowpath from the Refueling Water Storage Tank the Safety Injection Pump suction.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closing this valve during operation would render both trains of Safety Injection inoperable. This valve is opened and power removed above Mode 4 per Tech Spec 4.5.2.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-NI3

Valve: 1NI-147A, 1NI115B

Flow Diagram: MC-1562-3.0

Code Category: B

ASME Class: 2

Function: 1NI-147A provides flowpath for both trains of Safety Injection recirculation line to the Refueling Water Storage Tank. 1NI-115B provides flowpath for A train of Safety Injection recirculation line to the Refueling Water Storage Tank.

Test Requirement: Stroke time test in accordance with OMA-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closing either of these valve during power operation renders both trains of Safety Injection inoperable. 1NI-147A is open with power removed above Mode 4 per Tech Spec 4.5.2.

In the event of a loss of offsite power with the loss of 1B diesel generator as the single failure, 1NI-115B would not open, rendering A Train NI inoperable (due to loss of miniflow path). B Train NI would already be inoperable due to the single failure.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

Justification of Deferral

Item Number: 1-MC-NI4

Valve: 1NI-121A, 1NI-152B

Flow Diagram: MC-1562-3.0

Code Category: B

ASME Class: 2

Function: Isolates Safety Injection flow to the hot legs.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: These valves are closed with power removed above Mode 4 per Tech Spec 4.5.2.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-NI5
Valve: 1NI-162A
Flow Diagram: MC-1562-3.1
Code Category: B
ASME Class: 2
Function: Isolates Safety Injection flow to the cold legs.
Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.
Basis for Deferral: This valve is opened and power removed above Mode 4 per Tech Spec 4.5.2.
Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-NI6

Valve: 1NI-103A

Flow Diagram: MC-1562-3.0

Code Category: B

ASME Class: 2

Function: Provides A Train Safety Injection Pump suction flow from the Refueling Water Storage Tank. Also provides a flowpath for B Train Residual Heat Removal pump discharge to B Train Chemical and Volume Control pump suction.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closing this valve during power operations degrades both trains of Chemical and Volume Control. In the event of a loss of offsite power with the loss of 1A diesel generator as the single failure when the valve was closed, B Train NV would be lost for sump recirc mode. Since that could happen as fast as 30 minutes and would then be inaccessible due to dose rates, credit could not be taken for manually opening 1NI-103A in this event. A Train NV would already be inoperable due to the single failure.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

Justification of Deferral

Item Number: 1-MC-NI7

Valve: 1NI-173A, 1NI-178B

Flow Diagram: MC-1562-3.1

Code Category: B

ASME Class: 2

Function: Provides flowpath for Residual Heat Removal to the cold legs.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: These valves are opened and power removed above Mode 4 per Tech Spec 4.5.2.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-NI8

Valve: 1NI-334B

Flow Diagram: MC-1562-3.0

Code Category: B

ASME Class: 2

Function: Provides flowpath from B Train of Residual Heat Removal to B Train of Chemical and Volume Control, and from A Train of Residual Heat Removal to A Train of Safety Injection.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closing this valve during power operation degrades both trains of Safety Injection. With the single failure of 1B diesel generator, Train A of Safety Injection, which is provided suction from Residual Heat Removal via 1NI-334B or 1NI-136B, would be inoperable (since 1NI-136B is normally closed). Train B of Safety Injection would already be inoperable due to the single failure.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

Justification of Deferral

Item Number: 1-MC-NI9

Valve: 1NI-183B

Flow Diagram: MC-1562-3.0

Code Category: B

ASME Class: 2

Function: Isolates Residual Heat Removal flow to the hot legs.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: This valve is closed and power removed above Mode 4 per Tech Spec 4.5.2.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-NI10

Valve: 1NI-184B, 1NI-185A

Flow Diagram: MC-1562-3.1

Code Category: B

ASME Class: 2

Function: Provides flowpath from the Containment Sump to the Residual Heat Removal Pump and the Containment Spray Pump suction.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Opening these valves during power operation would allow water to enter lower containment. To prevent this, 1FW-27A would have to be closed, rendering both trains of Residual Heat Removal inoperable. Voids in suction piping would be created requiring fill and vent operations to prevent ECCS pump damage.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-NI11

Valve: 1NI-332A, 1NI-333B

Flow Diagram: MC-1562-3.0

Code Category: B

ASME Class: 2

Function: Provides flowpath to Centrifugal Charging Pumps and Safety Injection Pumps from Residual Heat Removal Pumps during recirculation phase.

Test Requirement: Stroke time test in accordance with OMA-1988 Part 10, 4.2.1.1.

Basis for Deferral: Opening these valves during power operations requires 1NI-334B to be closed to prevent aligning FWST to the suction of the Centrifugal Charging Pumps. Injecting FWST boron concentrated water into the Reactor Coolant System would induce a transient. Closing 1NI-334B degrades both trains of Safety Injection (With the single failure of 1B diesel generator, Train A of Safety Injection, which is provided suction from Residual Heat Removal via 1NI-334B or 1NI-136B, would be inoperable (since 1NI-136B is normally closed). Train B of Safety Injection would already be inoperable due to the single failure).

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-NI12

Valve: 1NI-15, 1NI-17, 1NI-19, 1NI-21,
1NI-347, 1NI-348, 1NI-349, 1NI-354

Flow Diagram: MC-1562-1.0

Code Category: C

ASME Class: 1

Function: Opens to allow flow to the cold legs from the Centrifugal Charging Pumps.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Injecting flow through these valves from the Centrifugal Charging Pumps during power operations could result in unnecessary thermal shock to the injection nozzles.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Justification of Deferral

Item Number: 1-MC-NI13

Valve: 1NI-12

Flow Diagram: MC-1562-1.0

Code Category: C

ASME Class: 2

Function: Flowpath for Centrifugal Charging Pumps to Reactor Coolant System cold legs.

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Deferral: Injecting flow through this valve from the Centrifugal Charging Pumps during power operations could result in unnecessary thermal shock to the injection nozzles.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Justification of Deferral

Item Number: 1-MC-NI14

Valve: 1NI-101

Flow Diagram: MC-1562-3.0

Code Category: C

ASME Class: 2

Function: Opens to allow flow from the Refueling Water Storage Tank to the Safety Injection Pumps. Closes to provide suction pressure boundary for these pumps from the Residual Heat Removal Pump discharge.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Valve cannot be full stroke tested during power operation since the Safety Injection Pumps cannot overcome Reactor Coolant System pressure. Closure cannot be verified quarterly since both trains of Residual Heat Removal would be rendered inoperable.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown. Valve will be partial stroked quarterly.

Justification of Deferral

Item Number: 1-MC-NI15

Valve: 1NI-116, 1NI-148

Flow Diagram: MC-1562-3.0

Code Category: C

ASME Class: 2

Function: Pump discharge check valve, opens to allow Safety Injection Flow. Closes to prevent opposite train flow losses.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Valve cannot be full or partial stroke tested during power operation since the Safety Injection Pumps cannot overcome Reactor Coolant System pressure.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown. Valve will be verified closed quarterly.

Justification of Deferral

Item Number: 1-MC-NI16

Vaive: 1NI-124, 1NI-128, 1NI-156, 1NI-157, 1NI-159, 1NI-160

Flow Diagram: MC-1562-3.0

Code Category: AC

ASME Class: 1

Function: 1) Opens on flow from the Safety Injection Pumps to the hot legs.
2) Reactor Coolant System pressure boundary.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.
2) Leak test once per two years in accordance with OMa-1988 Part 10, 4.2.2.3.

Basis for Deferral: Valves cannot be full or partial stroke tested during power operation since the Safety Injection Pumps cannot overcome Reactor Coolant System pressure.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown. Leak test in accordance with Tech Spec 4.4.6.2.2.

Justification of Deferral

Item Number: 1-MC-NI17

Valve: 1NI-165, 1NI-167, 1NI-169, 1NI-171

Flow Diagram: MC-1562-3.1

Code Category: AC

ASME Class: 1

Function: 1) Opens on flow from the Safety Injection Pumps to the cold legs.
2) Reactor Coolant System pressure boundary.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.
2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.3.

Basis for Deferral: Valves cannot be full or partial stroke tested during power operations since the Safety Injection Pumps cannot overcome Reactor Coolant System pressure.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown. Leak test in accordance with Tech Spec 4.4.6.2.2.

Justification of Deferral

Item Number: 1-MC-NI18

Valve: 1NI-175, 1NI-176, 1NI-180, 1NI-181

Flow Diagram: MC-1562-3.1

Code Category: AC

ASME Class: 1

Function: 1) Opens on flow from the Residual Heat Removal Pumps to the cold legs.
2) Reactor Coolant System pressure boundary.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.
2) Leak test once per two years in accordance with OMa-1988 Part 10, 4.2.2.3.

Basis for Deferral: Valves cannot be full or partial stroke tested during power operation since the Residual Heat Removal pumps cannot overcome Reactor Coolant System pressure.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown. Leak test in accordance with Tech Spec 4.4.6.2.2.

Justification of Deferral

Item Number: 1-MC-NI19

Valve: 1NI-125, 1NI-126, 1NI-129, 1NI-134

Flow Diagram: MC-1562-3.0

Code Category: AC

ASME Class: 1

Function: 1) Opens on flow from the Residual Heat Removal Pumps to the hot legs.
2) Reactor Coolant System pressure boundary.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.
2) Leak test once per two years in accordance with OMa-1988 Part 10, 4.2.2.3.

Basis for Deferral: Valves cannot be full or partial stroke tested during power operation since the Residual Heat Removal pumps cannot overcome Reactor Coolant System pressure.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown. Leak test in accordance with Tech Spec 4.4.6.2.2.

Justification of Deferral

Item Number: 1-MC-NI20

Valve: 1NI-136B

Flow Diagram: MC-1562-3.0

Code Category: B

ASME Class: 2

Function: Provides suction to the Centrifugal Charging Pumps and Safety Injection Pumps from the Residual Heat Removal System.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Opening 1NI-136B would seat check valve 1NV-223 (FWST to Charging Pump suction) closed, so that if 1NI-136B failed in the open position, both trains of NV would be inoperable.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

Justification of Deferral

Item Number: 1-MC-NI21

Valve: 1NI-48

Flow Diagram: MC-1562-2.0

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-330.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Justification of Deferral

Item Number: 1-MC-NI22

Valve: 1NI-59, 1NI-70, 1NI-81, 1NI-93

Flow Diagram: MC-1562-2.0, MC-1562-2.1

Code Category: A,C

ASME Class: 1

Function: Opens on flow from the NI cold leg accumulator to the Reactor Coolant System. Reactor Coolant Boundary valve.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMA-1988 Part 10, 4.2.2.3.

3) Leak test in accordance with Tech Spec 4.4.6.2.2.

Basis for Deferral: Valves cannot be full or partial stroked during power operation since the accumulator pressure is ~600 psig and cannot overcome RCS pressure. Valves will not be tested during cold shutdown since disassembly is required. Disassembly would render one train of RHR inoperable for an extended period of time.

Test Alternative & Frequency: Valves will be full stroked at refueling by disassembly on a sample basis. All valves will be partial stroked at refueling. Partial stroke will not be performed at cold shutdown since Tech Spec 4.4.6.2.2 requires leak testing after initiating flow through these valves and does not require leak testing more often than once per nine months. Valves will be verified closed by leak test performed in accordance with Tech Spec 4.4.6.2.2.

Justification of Deferral

Item Number: 1-MC-NI23

Valve: 1NI-436

Flow Diagram: MC-1562-2.1

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation and thermal over pressurization protection for penetration M-321.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22.

10/16/95

Justification of Deferral

| | |
|-------------------------------|--|
| Item Number: | 1-MC-NI24 |
| Valve: | 1NI-60, 1NI-71, 1NI-82, 1NI-94 |
| Flow Diagram: | MC-1562-2.0, MC-1562-2.1 |
| Code Category: | A,C |
| ASME Class: | 1 |
| Function: | Opens on flow from the NI cold leg accumulator to the Reactor Coolant System. Reactor Coolant Boundary valve. |
| Test Requirement: | <p>1) Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.</p> <p>2) Leak test once per 2 years in accordance with OMA-1988 Part 10, 4.2.2.3.</p> <p>3) Leak test in accordance with Tech Spec 4.4.6.2.2.</p> |
| Basis for Deferral: | Valves cannot be full or partial stroked during power operation since a driving head which can overcome RCS pressure does not exist. Instrumentation is not present to measure the flow through the individual valves. Valves will not be tested during cold shutdown since disassembly is required. Disassembly would render one train of RHR inoperable for an extended period of time. |
| Test Alternative & Frequency: | Valves will be full stroked at refueling by disassembly on a sample basis. All valves will be partial stroked at refueling. Partial stroke will not be performed at cold shutdown since Tech Spec 4.4.6.2.2 requires leak testing after initiating flow through these valves and does not require leak testing more often than once per nine months. Valves will be verified closed by leak test performed in accordance with Tech Spec 4.4.6.2.2. |

Justification of Deferral

Item Number: 1-MC-NM1

Valve: 1NM-420, 1NM-421

Flow Diagram: MC-1572-1.0

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation and thermal over pressurization protection for penetrations M-235 and M-309 respectively.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-NS1

Valve: 1NS-38B, 1NS-43A

Flow Diagram: MC-1563-1.0

Code Category: B

ASME Class: 2

Function: Auxiliary Spray Nozzle header isolation.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Opening either of these valves during power operation renders both trains on Residual Heat Removal inoperable. With cross-connected trains of ND, flow would be diverted from both trains through a failed-open NS-38B or 43A. To isolate one train of ND, it would be necessary to manually secure closed either ND-14 or 29, since these valves fail open on loss of air. This would be an impractical measure to perform the quarterly test.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-NS2

Valve: 1NS-13, 1NS-16, 1NS-30, 1NS-33, 1NS-41, 1NS-46

Flow Diagram: MC-1563-1.0

Code Category: C

ASME Class: 2

Function: Open on flow from containment spray pumps.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Full stroke exercising of these check valves is not practical since there is no external indication of disk movement. Full stroke exercising would require for the pumps and spray nozzles to be activated which would require a large scale cleanup effort. Valves will not be tested during cold shutdown since sample disassembly is required.

Test Alternative & Frequency: These valves will be verified to fully cycle by sample disassembly at refueling outage frequencies.

Note: Relief is being requested on these valves. Refer to relief request 1-MC-RR-NS1. When relief is granted, this Justification Of Deferral will be deleted.

Justification of Deferral

Item Number: 1-MC-NS3

Valve: 1NS-4, 1NS-21

Flow Diagram: MC-1563-1.0

Code Category: C

ASME Class: 2

Function: Opens to allow flow from the Refueling Water Storage Tank to the Containment Spray Pump suction. Closes to prevent flow from the Containment Recirculation Sump to the Refueling Water Storage Tank.

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Deferral: Full stroke exercising with flow would require for the pumps and spray nozzles to be activated which would require a large scale cleanup effort. The system design does not provide any indication for verifying closure upon flow reversal.

Test Alternative & Frequency: Full stroke testing will be achieved by sample disassembly. At least one of these valves will be disassembled during each refueling outage, and both valves will have been disassembled and full stroked after two consecutive outages. Sample disassembly will also verify closure. Failure of one of valve to properly full stroke during a refueling outage will result in the remaining valve being disassembled and full stroked during that outage. Valves will be partial stroked quarterly.

Justification of Deferral

Item Number: 1-MC-NS4

Valve: 1NS-140, 1NS-141

Flow Diagram: MC-1563-1.0

Code Category: A,C

ASME Class: 2

Function: Must open to allow Containment Spray to the spray ring headers. Must close to prevent column separation of water in the header after initial building spraydown and pump shutdown. During this time, the column of water in the vertical piping up to the spray rings could separate, creating a void in the system at sub-atmospheric pressure. Upon pump restart, the collapse of this void would damage the piping system.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.3.

Basis for Deferral: Full stroke exercising of these check valves is not practical since there is no external indication of disk movement. Full stroke exercising would require for the pumps and spray nozzles to be activated which would require a large scale cleanup effort. Valves will not be tested during cold shutdown since sample disassembly is required.

Test Alternative & Frequency: Valves will be verified to full stroke open using sample disassembly every other refueling outage on a staggered basis. Valves will be partial stroked quarterly. Valves will be leak tested at refueling outages. Leak testing will also verify closure of these valves.

Justification of Deferral

Item Number: 1-MC-NV1

Valve: 1NV-94AC, 1NV-95B

Flow Diagram: MC-1554-1.1

Code Category: B

ASME Class: 2

Function: 1) Provides flowpath for Reactor Coolant Pump seal water discharge line.
2) Provides containment isolation for penetration M-256

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closure of one of these valves during power operation would inhibit normal seal water flow across the reactor coolant pump number 1 seal. This action could result in damage to the reactor coolant pump seals or the pump itself. Failure of this seal with NC flow out the seal would be a loss of NV system function, and is justification for deferral in accordance with NUREG-1482 Section 3.1.1.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

Justification of Deferral

Item Number: 1-MC-NV2

Valve: 1NV-7B

Flow Diagram: MC-1554-1.2

Code Category: B

ASME Class: 2

Function: 1) Provides flowpath for normal letdown.
2) Provides containment isolation for penetration M-347.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Failure of this valve in a closed position would result in a significant event (letdown isolation), possibly resulting in loss of pressurizer level control, and possible Unit trip (not a normal shutdown).

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-NV3

Valve: 1NV-21A

Flow Diagram: MC-1554-1.2

Code Category: B

ASME Class: 1

Function: Provides isolation for Pressurizer Auxiliary spray.

Test Requirement: Stroke time test in accordance with: OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Opening this valve during power operations could result in a reactor low pressure trip.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-NV4

Valve: 1NV-141A, 1NV-142B

Flow Diagram: MC-1554-2.0

Code Category: B

ASME Class: 2

Function: Provides isolation for Volume Control Tank upon Safety Injection Signal.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closure of one of these valves during power operation would isolate the suction for the Centrifugal Charging Pumps. This action could result in damage to the pumps. Seal water to the Reactor Coolant pumps would be interrupted causing damage to the seals.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-NV5

Valve: 1NV-244A, 1NV-245B

Flow Diagram: MC-1554-3.0

Code Category: B

ASME Class: 2

Function: Isolates charging to the Reactor Coolant System upon Safety Injection.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: If one of these valves were to fail in the closed position while testing during power operation, normal and alternate charging would be lost. Total loss of charging flow would be a significant event, resulting in a possible loss of Pressurizer control, and a likely Unit trip (not a normal shutdown), as well as loss of NC pump seal flow.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-NV6

Valve: 1NV-221A, 1NV-222B

Flow Diagram: MC-1554-3.1

Code Category: B

ASME Class: 2

Function: Flowpath for Refueling Water Storage Tank to the suction of the Centrifugal Charging Pumps.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Opening these valves during power operation allows the Charging Pumps to inject highly borated water into the Reactor coolant System which could result in a unit shutdown.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-NV7

Valve: 1NV-264

Flow Diagram: MC-1554-3.1

Code Category: C

ASME Class: 2

Function: Provides flowpath from the Boric Acid Tank to the Centrifugal Charging Pump suction. Closes to provide pump suction pressure boundary.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: To full stroke exercise this valve during power operations would inject more than 30 gpm of boric acid into the Reactor Coolant System creating a transient. To verify closure, residual boric acid would be injected causing a transient.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Justification of Deferral

Item Number: 1-MC-NV8

Valve: 1NV-150B, 1NV-151A

Flow Diagram: MC-1554-2.0

Code Category: B

ASME Class: 2

Function: Provides isolation for Centrifugal Charging Pump miniflow line to Volume Control Tank.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: If either valve were to fail closed while testing, the Charging Pump miniflow protection line is isolated possibly causing damage to the pump. Closure of either of these valves would render both trains of NV inoperable, since on a spurious safety injection event (in which reactor coolant system pressure is increased above normal), this is a relief path back to the Volume Control Tank.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

Justification of Deferral

Item Number: 1-MC-NV9

Valve: 1NV-265B

Flow Diagram: MC-1554-3.1

Code Category: B

ASME Class: 2

Function: Isolates the Boric Acid Tank from the suction of the Charging Pumps.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: If valve is opened during power operations, boric acid could be injected into the Reactor Coolant System causing a transient.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-NV10

Valve: 1NV-225, 1NV-231

Flow Diagram: MC-1554-3.1

Code Category: C

ASME Class: 2

Function: Pump discharge check valve. Opens to provide flowpath for Centrifugal Charging Pump. Closes to prevent opposite train flow losses.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Valve cannot be full stroke exercised during power operation since this would require an increase in Reactor Coolant System boron concentration which could result in unit shutdown. Normal letdown is not sufficient to verify full stroke, this must be done when aligned to the FWST for suction.

Test Alternative & Frequency: Valve will be full stroke exercised during cold shutdown, partial stroked with normal use.

Justification of Deferral

Item Number: 1-MC-NV11

Valve: 1NV-223

Flow Diagram: MC-1554-3.1

Code Category: C

ASME Class: 2

Function: Provides open flowpath from the FWST. Provides closed pump suction pressure boundary when suction is from the Residual Heat Removal pumps.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Testing this valve during power operations would require opening of either 1NV-221A or 1NV-222B. Opening these valves during power operation could result in a unit trip. See Justification # MC-NV6.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Justification of Deferral

| | |
|-------------------------------|---|
| Item Number: | 1-MC-NV12 |
| Valve: | 1NV-1046 |
| Flow Diagram: | MC-1554-3.0 |
| Code Category: | C |
| ASME Class: | 2 |
| Function: | Closes to provide pump suction pressure boundary for Centrifugal Charging Pumps. Open function is to protect the Positive Displacement Pump from over pressurization. This is not a safety related function. |
| Test Requirement: | Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1. |
| Basis for Deferral: | Testing this valve during power operation would result in the addition of highly borated water into the Reactor Coolant System causing a transient. To place adequate test pressure on this valve, it would be necessary to use ND Pump discharge pressure, which would require opening 1ND-58A. This would inject FWST water into the NC System via the Charging Pumps, which are also on the discharge of the ND Pumps (for cold leg recirc) via 1ND-58A. |
| Test Alternative & Frequency: | Valve will be full stroke exercised at cold shutdown. |

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-NV13

Valve: 1NV-261, 1NV-263

Flow Diagram: MC-1554-3.1

Code Category: C

ASME Class: 2

Function: These valves shall close to provide pump suction pressure isolation for the Centrifugal Charging Pumps by preventing backflow to the Chemical Mixing Tank or the RMWST respectively.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Testing these valves requires 1NI-121A to be opened. This valve is closed with power removed above mode 4 per Tech Spec 4.5.2.

This testing would require opening valve 1ND-58A, which would render both trains of NV inoperable (by seating check valve 1NV-223 (charging pump suction from the FWST in-line check) closed).

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-NV14

Valve: 1NV-1002

Flow Diagram: MC-1554-1.3

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-342.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22.

10/16/95

Justification of Deferral

| | |
|-------------------------------|---|
| Item Number: | 1-MC-NV15 |
| Valve: | 1NV-143 |
| Flow Diagram: | MC-1554-2.0 |
| Code Category: | C |
| ASME Class: | 2 |
| Function: | This valve shall close to provide Centrifugal Charging Pump suction pressure boundary during Recirculation alignment from RHR Pump discharge. |
| Test Requirement: | Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1. |
| Basis for Deferral: | This valve is in the flowpath from the Volume Control Tank to the Charging pumps. During normal system operation, this valve is open. To verify this valve closes properly requires the alignment from the RHR pumps, and would interrupt normal charging activities. |
| Test Alternative & Frequency: | Valve will be full stroke exercised at cold shutdown. |

Justification of Deferral

Item Number: 1-MC-NV16

Valve: 1NV-164

Justification deleted by Revision 22.

Justification of Deferral

Item Number: 1-MC-NV17

Valve: 1NV-1007, 1NV-1008, 1NV-1009, 1NV-1010

Flow Diagram: MC-1554-1.3

Code Category: C

ASME Class: 2

Function: These valves must close to maintain a pressure boundary for normal Reactor Coolant Pump Seal Injection.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: In the event of failure of one of these valves during testing, the seal injection water for that Reactor Coolant Pump would be diverted, thereby creating a loss of seal injection to that pump. This condition would result in destroying a seal for the pump, and possibly creating a small break loss of coolant accident.

Test Alternative & Frequency: These valves will be tested for closure during cold shutdowns.

Revised by revision 21

10/16/95

Justification of Deferral

Item Number: 1-MC-NV18

Valve: 1NV-0035A, 1NV-0457A, 1NV-0458A

Flow Diagram: MCFD-1554-01.02

Code Category: B

ASME Class: 2

Function: These valves must automatically close to isolate containment on a Phase A signal, and to isolate letdown on a Pressurizer Low Level signal. They can be operated from the Auxiliary Shutdown Panel, and cannot be opened unless valves 1NV-1A and 1NV-2A are both open.

Test Requirement: Stroke time test quarterly in accordance with Oma-1988 Part 10, 4.2.1.1.

Basis for Deferral: Letdown header relief valve 1NV-6 has experienced lifting and subsequent seat leakage as a result of pressure transients during orifice swaps for stroke time testing of the above valves. Although the NV operating procedure specifically addresses the potential pressure increase that could occur when swapping from the 45 gpm to the 75 gpm orifice, the increase can occur so quickly that the operator and system controls cannot respond fast enough to prevent the pressure transient. The NV operating procedure currently provides for simultaneous opening/closure of the above orifice isolation valves, and for backpressure reduction using the downstream control valve, to prevent such a pressure transient; however, procedure effectiveness is problematic with respect to repeatability due to the inability to achieve perfect coordination each time.

It is concluded that testing of these valves is impractical and nonconservative during power operation, since it results in pressure transients which have caused relief valve leakage. This leakage is Reactor Coolant (NC) leakage, which is reflected in higher NC leakage values.

Finally, these valves have demonstrated a favorable test history.

Test Alternative & Frequency: Valves will be stroke time tested during cold shutdown.

Added by Rev. 22

10/16/95

Justification of Deferral

Item Number: 1-MC-RF1

Valve: 1RF-823

Flow Diagram: MC-1599-2.2

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-353.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22.

Justification of Deferral

Item Number: 1-MC-RN1

Valve: 1RN-252B, 1RN-253A

Flow Diagram: MC-1574-4.0

Code Category: A

ASME Class: 2

Function: 1) Provides containment isolation for penetration M-307.
2) Provides flowpath for cooling water to the Reactor Coolant Pump Motor Air Cooler

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: If one of these valves were to fail closed during testing, isolation of cooling water to the motor coolers could result in damage to the pumps. Closure of these valves would result in a Unit trip from NC Pump motors being manually shut down due to high stator temperatures (within minutes). An abnormal (natural circulation) shutdown would be required.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

Justification of Deferral

Item Number: 1-MC-RN2

Valve: 1RN-276A, 1RN-277B

Flow Diagram: MC-1574-4.0

Code Category: A

ASME Class: 2

Function: 1) Provides containment isolation for penetration M-315.
2) Provides flowpath for cooling water to the Ractor Coolant Pump Motor Air Cooler.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: If one of these valves were to fail closed during testing, isolation of cooling water to the motor coolers could result in damage to the pumps. Closure of these valves would result in a Unit trip from NC Pump motors being manually shut down due to high stator temperatures (within minutes). An abnormal (natural circulation) shutdown would be required.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

Justification of Deferral

Item Number: 1-MC-RN3

Valve: 1RN-42A

Justification deleted by Revision 21

10/16/95

Justification of Deferral

Item Number: 1-MC-RN4
Valve: 1RN-63B, 1RN-64A

Justification deleted by Revision 21

Justification of Deferral

Item Number: 1-MC-RN5

Valve: 1RN-214

Justification deleted by Revision 21

10/16/95

Justification of Deferral

Item Number: 1-MC-RN6
Valve: 1RN-891, 1RN-892

Justification deleted by Revision 22

Justification of Deferral

Item Number: 1-MC-RV1

Valve: 1RV-32A, 1RV-33B, 1RV-76A, 1RV-77B

Flow Diagram: MC-1604-3.0

Code Category: A

ASME Class: 2

Function: Provide containment isolation for penetration M-240 and M-279 respectively.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Failure of one of these valves in the closed position during testing would isolate cooling flow to the Lower Containment Ventilation Units causing an increase in lower containment temperature which could exceed Tech Spec limits. Although the exact time depends on outside temperature, the Tech Spec limit would be exceeded within minutes if cooling flow was isolated to these ventilation units.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 22.

Justification of Deferral

Item Number: 1-MC-SA1

Valve: 1SA-5, 1SA-6

Flow Diagram: MC-1593-1.2

Code Category: C

ASME Class: 2

Function: Opens to allow steam supply to the turbine driven Auxiliary Feedwater Pump. Closes to prevent cross connecting steam generators 1B and 1C.

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Deferral: System configuration and design do not provide a suitable means to prove the valve prevents reversal of flow. To test the close function of this valve on line would risk personnel safety since high energy steam would be involved.

Test Alternative & Frequency: At least one of these two valves will be disassembled and full stroked during each refueling outage, and both valves will have been disassembled and full stroked after two consecutive outages. Sample disassembly will verify closure. Failure of one of valve to properly full stroke during a refueling outage will result in the remaining valve being disassembled and full stroked during that outage. Valves will be full stroked open quarterly.

Justification of Deferral

Item Number: 1-MC-SM1

Valve: 1SM-1AB, 1SM-3AB, 1SM-5AB, 1SM-7AB

Flow Diagram: MC-1593-1.0, MC-1593-1.3

Code Category: B

ASME Class: 2

Function: Main Steam Isolation Valves

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: These valves cannot be fully cycled closed during power operation since a unit shutdown would result.

Test Alternative & Frequency: These valves will be partially cycled closed while in Modes 1, 2 and 3. These valves will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 1-MC-VB1

Valve: 1VB-50

Flow Diagram: MC-1605-3.1

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-215.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-VG1

Valve: 1VG-17, 1VG-18, 1VG-19, 1VG-20

Flow Diagram: MC-1609-4.0

Code Category: C

ASME Class: 3

Function: Provides flowpath for Diesel Generator control air from individual starting air banks.

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Deferral: Testing these valves requires the Diesel Generator to be started on a single bank of control air which is considered a degraded condition. This is not justified for quarterly starts. This test is required to be done on an 18 month frequency as committed to in our response to SOER 80-1.

Test Alternative & Frequency: Valve will be full stroke exercised with the diesel generator start on a single bank of control air and performed at refueling outage frequency.

Justification of Deferral

Item Number: 1-MC-VI1

Valve: 1VI-368, 1VI-372, 1VI-373, 1VI-374

Flow Diagram: MC-1605-1.3

Code Category: C

ASME Class: ANSI B31.1.0 (1967)

Function: 1VI-368 and 1VI-373 must open to allow nitrogen to the PORV actuator.

1VI-372, 1VI-374 must close to prevent loss of Nitrogen pressure if instrument air is lost.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: All four valves are tested with PORV stroke timing. PORVs are tested on a cold shutdown frequency. Refer to Justification # 1-MC-NC1

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Justification of Deferral

Item Number: 1-MC-VI2

Valve: 1VI-124, 1VI-149

Flow Diagram: MC-1605-1.2

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetrations M-317 and M-386 respectively.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-VI3

Valve: 1VI-40, 1VI-161

Flow Diagram: MC-1605-1.3

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetrations M-220 and M-359 respectively.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-VI4

Valve: 1VI-129B, 1VI-150B, 1VI-160B

Flow Diagram: MC-1605-1.14; MC-1605-1.17

Code Category: A

ASME Class: 2

Function: Provides containment isolation on penetrations M-220, M-317 and M-359 respectively.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: These valves isolate instrument air headers to the reactor building. In the past, to perform stroke timing of these valves, the containment air compressor was started to maintain an uninterrupted air supply to components inside containment. During the past refueling outage, the containment compressor was deleted. Should these valves be closed during power operation, components inside containment would experience a loss of instrument air, resulting in unwanted transients. During cold shutdowns, personnel entry into containment may be made to manually align instrument air headers together, allowing these valves to be tested. Since this is a manual alignment, it is not possible to enter containment to make this alignment for quarterly testing.

Test Alternative & Frequency: Valves will be cycled and timed during cold shutdown. Leak testing will be performed as per the requirements of 10CFR50, Appendix J.

Revised by revision 21

10/16/95

Justification of Deferral

Item Number: 1-MC-VS1

Valve: 1VS-13

Flow Diagram: MC-1605-2.2

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-219.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Justification of Deferral

Item Number: 1-MC-VX1

Valve: 1VX-30

Flow Diagram: MC-1557-1

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-325.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-WL1

Valve: 1WL-24

Flow Diagram: MC-1565-1.1

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation and thermal over pressurization protection of line between 1WL-1B and 1WL-2A on penetration M-375.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.
2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22.

10/16/95

Justification of Deferral

Item Number: 1-MC-WL2

Valve: 1WL-385

Flow Diagram: MC-1565-7.0

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation and thermal over pressurization protection of line between 1WL-322B and 1WL-321A on penetration M-221.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22

10/16/95

Justification of Deferral

Item Number: 1-MC-YM1

Valve: 1YM-116

Flow Diagram: MC-1601-2.4

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-337.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 22.

DUKE POWER COMPANY
McGUIRE NUCLEAR STATION - UNIT 2
PUMP INSERVICE TESTING PROGRAM
ASME OM CODE-1987, OM Part 6 (OMa-1988 Addenda)

INTRODUCTION

The inservice testing of ASME Code Class 1, 2 and 3 pumps provided with an emergency power source will be tested as required by ASME Operations and Maintenance Standards Part 6 (OM-6), OMa-1988, of the ASME Code for Operation and Maintenance of Nuclear Power Plants, as referenced in 10CFR50.55a (January 1, 1993 Edition), except where specific written relief has been granted by the Nuclear Regulatory Commission. The effective date of the submittal is March 1, 1994.

Technical Specification 4.0.5 requires inservice testing of ASME Code Class 1, 2 and 3 pumps in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50, Section 50.55a(g)(6)(i). Pumps were selected for inclusion in the IST Program (Section I.2) which fall within this category, as required by this Technical Specification. Pumps within the above ASME categories which are required to mitigate the consequences of an accident, shutdown the reactor or maintain shutdown are included in the program. Testing requirements are identified for each pump which ensure that the pump will perform as designed in response to an accident, in shutting down the reactor, or in maintaining shutdown. Acceptance criteria are specified in accordance with ASME Boiler and Pressure Vessel Code Subsection IWP. The safety functions of the pumps listed in Section I.2 are included in the Design Basis Documents, and fall within the basic categories of accident mitigation, reactor shutdown, and maintaining shutdown. Post modification testing requirements are included in the applicable Nuclear System Directive; a modification test plan is required to be developed to verify proper operation. The Code requires the determination of new reference values after pump repair or replacement, or maintenance which could impact operation. These Code requirements and programmatic controls ensure that the pump inservice test program remains current following modifications performed under 10 CFR 50.59. The documents used in development of this program include the following:

- McGuire Technical Specifications.
- Safety Analysis Report.
- ASME Section XI, IWP (1986).
- ASME Operations and Maintenance Standards Part 6 (OM-6), OMa-1988.
- Generic Letter 89-04.
- Supplement 1 to Generic Letter 89-04.
- NUREG 1482, Guidelines for Inservice Testing at Nuclear Power Plants.
- Safety Evaluation Report for the McGuire IST Program dated October 21, 1994

McGuire Unit 2

A description of the Inservice Testing Program, Justification for Testing Deferral, as well as Specific Relief Requests from code requirements determined to be impractical, is described in the submittal.

- NOTES:**
- 1) OMa-1988 Part 6, Section 7.3 requires the signature of the person or persons responsible for conducting and analyzing the test. The dated initials of the person or persons responsible for conducting and analyzing the test will be used in place of a signature in the record of tests. Initials shall be construed as signatures to meet the intent of OM-6.
 - 2) A Supplemental Test Program has been established, which includes components which have been determined important to safety and prudent to test, but which are not explicitly under the scope of ASME Codes and Standards.

UNIT 2 - McGUIRE NUCLEAR STATION
Pump Inservice Testing General Data

| Pump ID. Number | Description | Code Class | Flow Diagram | Applicable Relief Requests | Test Frequency | Remarks |
|-----------------|----------------------------------|------------|--------------|----------------------------|----------------|---|
| 2KCPU0004 | Component Cooling Water Pump 2B2 | 3 | MC-2573-1.0 | RR-I.3.1, RR-I.4.3 | Quarterly | NONE |
| 2NDPU0001 | Residual Heat Removal Pump 2A | 2 | MC-2561-1.0 | RR-I.3.1, RR-I.4.4 | Quarterly | The ND Testing Plan meets other code requirements unless otherwise specified. |
| 2NDPU0002 | Residual Heat Removal Pump 2B | 2 | MC-2561-1.0 | RR-I.3.1, RR-I.4.4 | Quarterly | The ND Testing Plan meets other code requirements unless otherwise specified. |
| 2NIPU0009 | Safety Injection Pump 2A | 2 | MC-2562-3.0 | RR-I.3.1, RR-I.4.5 | Quarterly | The NI Testing Plan meets other code requirements unless otherwise specified. |
| 2NIPU0010 | Safety Injection Pump 2B | 2 | MC-2562-3.0 | RR-I.3.1, RR-I.4.5 | Quarterly | The NI Testing Plan meets other code requirements unless otherwise specified. |
| 2NSPU0001 | Containment Spray Pump 2A | 2 | MC-2563-1.0 | RR-I.3.1 | Quarterly | NONE |

UNIT 2 - McGUIRE NUCLEAR STATION
Pump Inservice Testing Specific Data

| Pump ID. Number | Speed | Inlet Pressure | Discharge Pressure | Differential Pressure | Reference Vibration | Flow Rate | Pump Type | Revision |
|-----------------|--------------|-------------------------|-------------------------|-------------------------|---------------------|-------------------------|---------------------------------|----------|
| 2KCPU0004 | Not Required | RR-I.4.3 | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Centrifugal | |
| 2NDPU0001 | Not Required | RR-I.4.4 | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | RR-I.4.4 | Vertical Line Shaft Centrifugal | 22 |
| 2NDPU0002 | Not Required | RR-I.4.4 | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | RR-I.4.4 | Vertical Line Shaft Centrifugal | 22 |
| 2NIPU0009 | Not Required | RR-I.4.5 | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | RR-I.4.5 | Centrifugal | 22 |
| 2NIPU0010 | Not Required | RR-I.4.5 | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | RR-I.4.5 | Centrifugal | 22 |
| 2NSPU0001 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Vertical Line Shaft Centrifugal | |

UNIT 2 - McGUIRE NUCLEAR STATION
Pump Inservice Testing General Data

| Pump ID. Number | Description | Code Class | Flow Diagram | Applicable Relief Requests | Test Frequency | Remarks |
|-----------------|-------------------------------|------------|--------------|----------------------------|---|---|
| 2NSPU0002 | Containment Spray Pump 2B | 2 | MC-2563-1.0 | RR-I.3.1 | Quarterly | NONE |
| 2NVPU0015 | Centrifugal Charging Pump 2A | 2 | MC-2554-1.0 | RR-I.3.1, RR-I.4.6 | Quarterly- Miniflow; Refueling-Full Flow (RR-I.4.6) | The NV Testing Plan meets other code requirements unless otherwise specified. |
| 2NVPU0016 | Centrifugal Charging Pump 2B | 2 | MC-2554-1.0 | RR-I.3.1, RR-I.4.6 | Quarterly- Miniflow; Refueling-Full Flow (RR-I.4.6) | The NV Testing Plan meets other code requirements unless otherwise specified. |
| 2NVPU0027 | Boric Acid Transfer Pump 2A | 3 | MC-2554-5.0 | RR-I.3.1 | Quarterly | NONE |
| 2NVPU0028 | Boric Acid Transfer Pump 2B | 3 | MC-2554-5.0 | RR-I.3.1 | Quarterly | NONE |
| 2RNPU0003 | Nuclear Service Water Pump 2A | 3 | MC-2574-1.1 | RR-I.3.1 | Quarterly | NONE |

UNIT 2 - McGUIRE NUCLEAR STATION
Pump Inservice Testing Specific Data

| Pump ID. Number | Speed | Inlet Pressure | Discharge Pressure | Differential Pressure | Reference Vibration | Flow Rate | Pump Type | Revision |
|-----------------|--------------|-------------------------|-------------------------|-------------------------|---------------------|-------------------------|---------------------------------|----------|
| 2NSPU0002 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Vertical Line Shaft Centrifugal | |
| 2NVPU0015 | Not Required | RR-I.4.6 | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | RR-I.4.6 | Centrifugal | |
| 2NVPU0016 | Not Required | RR-I.4.6 | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | RR-I.4.6 | Centrifugal | |
| 2NVPU0027 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Centrifugal | |
| 2NVPU0028 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Centrifugal | |
| 2RNPU0003 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Centrifugal | 22 |

UNIT 2 - McGUIRE NUCLEAR STATION
Pump Inservice Testing General Data

| Pump ID. Number | Description | Code Class | Flow Diagram | Applicable Relief Requests | Test Frequency | Remarks |
|-----------------|--------------------------------|------------|--------------|----------------------------|----------------|---|
| 2RNPU0004 | Nuclear Service Water Pump 2B | 3 | MC-2574-1.1 | RR-I.3.1 | Quarterly | NONE |
| 2WNPU0094 | Diesel Generator Sump Pump 2A2 | 3 | MC-2609-7.0 | RR-I.3.1 | Two Year | Two year frequency for dry sump pumps per OMa-1988, Part 6 section 5.5. |
| 2WNPU0096 | Diesel Generator Sump Pump 2A3 | 3 | MC-2609-7.0 | RR-I.3.1 | Two Year | Two year frequency for dry sump pumps per OMa-1988, Part 6 section 5.5. |
| 2WNPU0095 | Diesel Generator Sump Pump 2B2 | 3 | MC-2609-7.0 | RR-I.3.1 | Two Year | Two year frequency for dry sump pumps per OMa-1988, Part 6 section 5.5. |
| 2WNPU0097 | Diesel Generator Sump Pump 2B3 | 3 | MC-2609-7.0 | RR-I.3.1 | Two Year | Two year frequency for dry sump pumps per OMa-1988, Part 6 section 5.5. |

UNIT 2 - McGUIRE NUCLEAR STATION
Pump Inservice Testing Specific Data

| Pump ID. Number | Speed | Inlet Pressure | Discharge Pressure | Differential Pressure | Reference Vibration | Flow Rate | Pump Type | Revision |
|-----------------|--------------|-------------------------|-------------------------|-------------------------|---------------------|-------------------------|---------------------------------|----------|
| 2RNPU0004 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Centrifugal | 22 |
| 2WNPU0094 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Vertical Line Shaft Centrifugal | |
| 2WNPU0096 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Vertical Line Shaft Centrifugal | |
| 2WNPU0095 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Vertical Line Shaft Centrifugal | |
| 2WNPU0097 | Not Required | Meets Code Requirements | Meets Code Requirements | Meets Code Requirements | RR-I.3.1 | Meets Code Requirements | Vertical Line Shaft Centrifugal | |

General Relief Request

RELIEF REQUEST: I.3.1

PUMPS: All pumps in the Inservice Test Program

TEST REQUIREMENTS: OMa-1988 Part 6 Section 6.1 (Table 3a) specifies the allowable range for acceptable operation of vibration measurements.

BASIS FOR RELIEF: Experience has shown that smooth operating pumps ($V_r \leq 0.075$ in/sec) often fall in the alert range of vibration measurement when compared to the acceptance criteria given in OMa-1988 Part 6, Table 3a. The Code does not include provisions for a fixed band acceptance criteria for these pumps. The Alternative Testing provided below applies to all pumps in the Testing Program by establishing a threshold of vibration of ≤ 0.075 in/sec. In addition to this, OMa-1988 Part 6 does not specifically address different types of positive displacement pumps. Since McGuire has internal gear positive displacement pumps, the Alternate Testing below will be used for these pumps.

ALTERNATE TESTING: In addition to the vibration specified in OMa-1988 Part 6, Table 3a, the following ranges shall be used.

| | Acceptable Range | Alert Range | Required Action Range |
|---|------------------|--|--------------------------------|
| For all pumps when $V_r \leq 0.075$ in/sec | 0 to 0.19 in/sec | $> 0.19 \leq 0.45$ in/sec | > 0.45 in/sec |
| For centrifugal, vertical line shaft and positive displacement pumps except reciprocating when $V_r > 0.075$ in/sec | $\leq 2.5 * V_r$ | $> 2.5 * V_r$ to $6 * V_r$ or > 0.325 to 0.70 in/sec | $> 6 * V_r$ or > 0.70 in/sec |
| For reciprocating pumps, when $V_r > 0.075$ in/sec | $\leq 2.5 * V_r$ | $> 2.5 * V_r$ to $6 * V_r$ | $> 6 * V_r$ |

Revised by revision 17

Specific Relief Request

RELIEF REQUEST: 1.4.4

PUMPS: 2NDPU0001, 2A Residual Heat Removal Pump
2NDPU0002, 2B Residual Heat Removal Pump

TEST REQUIREMENT: OMa-1988 Part 6, Section 4.6.1.2.a specifies the range of each instrument shall be three times the reference value or less.

BASIS FOR RELIEF: Range requirements will be waived for the tests. The purpose of the quarterly test is to verify Tech Spec requirements are met and to obtain vibration data for trending. The instrumentation used for the quarterly Residual Heat Removal Pump test will meet accuracy requirements for assuring Residual Heat Removal Pump operability per Technical Specifications.

ALTERNATE TESTING: The Residual Heat Removal Pumps will be tested according to the following program, which is consistent with Generic Letter 89-04.

These pumps have process instrumentation installed such that there are two suction pressure gauges (0-60 psig and 0-600 psig), and one discharge pressure gauge, (0-1000 psig). Each has a 0.5% accuracy. This is done to provide accurate pressure indication in either the recirculation or the heat removal condition of operation. As such, there are times when the 3 times the reference range requirements cannot be met.

Quarterly

The Residual Heat Removal Pumps will be tested quarterly to verify Technical Specifications are met. The test measures differential pressure and velocity vibration data. The differential pressure and velocity vibration data will be trended. The instrument used to measure vibrations will meet the requirements specified in relief request 1.3.1. The test loop used in the test has a flow measuring orifice installed, however, the system resistance cannot be adjusted with the associated throttling valve without invalidating the Residual Heat Removal system flow balance (a Tech Spec balance of flow to all 4 cold legs.) Therefore, flow through this loop will be recorded for information only.

The instrumentation range requirements of OMa-1988 Part 6, Section 4.6.1.2.a will be waived. Since the instrumentation used to measure suction and discharge pressure is more accurate than code requirements (0.5% vs. 2%) using the process instrument for this test will yield results within the overall accuracy requirements of the code and will meet applicable accuracy requirements for the determination of operability per Technical Specifications. Typical values for ND suction pressure in mini-

Specific Relief Request

RELIEF REQUEST: 1.4.4 (Continued)

flow are 48-81 psig, and discharge pressures are in the 230-260 psig range. Therefore, the process range for discharge pressure (0-1000 psig) will not meet the three times criteria; the appropriate suction pressure loop can be used, which is within the three times requirement. The accuracy of these process instruments (0.5%) is well below the requirements specified in Table 1 of OM-6 for instrument accuracy (2%). The actual reading error at test pressure due to the process instrument is 2.2 % ($0.5 * 1000/230$) for discharge pressure at the low end of this range (ND pump procedures specify that instrumentation must meet the three times criteria). If a 0-690 psig gauge was used with 2% accuracy, the reading error would be 6% ($2 * 690/230$). When the requirements of Oma-1988 Part 6, Section 4.6.1.2.a and Table 1 are combined, the actual instrument error introduced into the test is less than the code allowable (2.2 % vs. 6 % at the low (conservative) end). Using the process instruments for suction and discharge pressure data does not degrade the quality of the test and meets the intent of the instrumentation requirements of the code.

Refueling Outage

Full flow vibration measurements will be taken during refueling outages as part of the IST Supplemental Program.

Revised by revision 17

Specific Relief Request

RELIEF REQUEST: 1.4.5

PUMPS: 2NIPU0009, 2A Safety Injection Pump
2NIPU0010, 2B Safety Injection Pump

TEST REQUIREMENT: OMa-1988 Part 6, Section 4.6.1.2.a specifies the range of each instrument shall be three times the reference value or less.

BASIS FOR RELIEF: Range requirements will be waived for the tests. The purpose of the quarterly test is to verify Tech Spec requirements are met and to obtain vibration data for trending. The instrumentation used for the quarterly Safety Injection Pump test will meet accuracy requirements for assuring Safety Injection Pump operability per Technical Specifications.

ALTERNATE TESTING: The Safety Injection Pumps will be tested according to the following program, which is consistent with Generic Letter 89-04.

Quarterly

The Safety Injection Pumps will be tested quarterly to verify Technical Specifications are met. The test measures differential pressure and velocity vibration data. The differential pressure and velocity vibration data will be trended. The instrument used to measure vibrations will meet the requirements specified in relief request 1.3.1. The test loop has a flow measuring orifice installed, however, there is no means provided to vary the system resistance to set either the flow or differential pressure. Therefore, flow through this loop will be recorded for information only.

The instrumentation range requirements of OMa-1988 Part 6, Section 4.6.1.2.a will be waived. The instrumentation used to measure suction and discharge pressure will meet applicable accuracy requirements for the determination of operability per Technical Specifications. The process instruments meet the three times criteria, however in the event a test instrument is to be used, based on available equipment, it may not meet the three times criteria. In these instances, the accuracy of the test instruments is 0.25%, and this accuracy applied over the range of the instrument will meet the uncertainty allowed by the code assuming an accuracy of 2%.

Specific Relief Request**RELIEF REQUEST:**

I.4.5 (Continued)

Typical values for NI suction pressure are in the 25-51 psig range, and discharge pressures are in the 1500-1575 psig range. Test equipment used for suction and discharge pressures may not meet the three times criteria, however these instruments will have 0.25% accuracy. The NI pump procedures specify that if a test instrument is needed for suction pressure, a 0-60 psig instrument is preferred, and that the range of the instrument must not exceed 0-100 psig. They also specify that if a discharge pressure test instrument is to be used, 0-2000 psig range is preferred, not to exceed 0-4500 psig. Using the low end suction pressure of 25 psig with the high end allowable gauge, accuracy is 1% ($0.25 * 100/25$); if a 0-75 psig gauge was used with a 2% accuracy, the code allowable would be 6% ($2 * 75/25$), so that use of this gauge would be within the code requirements. Using the low end discharge pressure with the high end allowable gauge, accuracy is 0.75% ($0.25 * 4500/1500$); this is at the three times range, and use of a 2% accuracy gauge would produce a total 6% allowable error. Therefore, using these test instruments for suction and discharge pressure data does not degrade the quality of the test and meets the intent of the instrumentation requirements of the code.

Refueling Outage

Full-flow vibration will be recorded under the IST Supplemental Program.

Revised by revision 17

10/12/95

SECTION I.4
9 OF 12

Specific Relief Request

RELIEF REQUEST: 1.4.6

PUMPS: 2NVPU0015, 2A Centrifugal Charging Pump
2NVPU0016, 2B Centrifugal Charging Pump

TEST REQUIREMENT: OMa-1988 Part 6, Section 4.6.1.2.a specifies the range of each instrument shall be three times the reference value or less.

BASIS FOR RELIEF: Range requirements will be waived for the tests. The purpose of the quarterly test is to verify Tech Spec requirements are met and to obtain vibration data for trending. The suction and discharge pressure gauges (0-60 psig and 0-3000 psig) installed for the pump have an accuracy of 0.5%. These pumps are aligned from the VCT for the quarterly test. Since these pumps are tested with different levels of VCT pressure, the suction pressure may vary over a range of approximately 15 to 50 psig. Since the uncertainty associated with using the process gauge is better than that allowed by code requirements, (2% vs. 6% determined by $0.5 * 60/15$ vs. $2 * 45/15$) the instrumentation used for the quarterly Centrifugal Charging Pump test will meet accuracy requirements for assuring Centrifugal Charging Pump operability per Technical Specifications.

Regarding instrument accuracy during the refueling outage testing (in Relief Request 1.4.6), the range of the highest suction pressure test gauge allowed for the full flow point will be 0-450 psig, and the range of the highest discharge pressure test gauge allowed (for the full flow point) will be 0-4500 psig. Suction pressure is typically 140 to 160 psig, and discharge pressure ranges from approximately 1000 to 2700 psig, so that overall suction and discharge pressure reading accuracy are 0.8 % ($0.25 * 450/140$) and 1.1 % ($0.25 * 4500/1000$), respectively. If a 0-420 psig suction pressure gauge was used with 2% accuracy, allowable accuracy would be 6 % ($2 * 420/140$), and if a 0-3000 psig discharge pressure gauge was used with 2% accuracy, allowable accuracy would be 6 % ($2 * 3000/1000$). Therefore, using these test instruments for suction and discharge pressure data (for the full flow point) does not degrade the quality of the test and meets the intent of the instrumentation requirements of the code. A 1% uncertainty is conservatively added for the flow orifice.

Specific Relief Request

RELIEF REQUEST: I.4.6 (Continued)

ALTERNATE TESTING: The Centrifugal Charging Pumps will be tested according to the following program, which is consistent with Generic Letter 89-04.

Quarterly

The Centrifugal Charging Pumps will be tested quarterly to verify Technical Specifications are met. The test measures differential pressure and velocity vibration data. The differential pressure and velocity vibration data will be trended. The instrumentation range requirements of OMa-1988 Part 6, Section 4.6.1.2.a will be waived. The instrumentation used to measure suction and discharge pressure will meet applicable accuracy requirements for the determination of operability per Technical Specifications. The instrument used to measure vibrations will meet the requirements specified in relief request I.3.1. The flow through the miniflow line to the Volume Control Tank will be assumed to be constant at the orifice design conditions (60 gpm).

Refueling Outage

During each refueling outage, a code pump test - including velocity vibration measurements - will be performed at a full flow test point.

The instrumentation used for the refueling outage tests is test instruments, with accuracy of 0.25%. When applied over the span on the instrument and the various range of outputs, in all cases the uncertainty of the overall loop will meet or exceed the code requirements of 2% over the instrument's range.

Revised by revision 17

Specific Relief Request

RELIEF REQUEST: 1.4.7

PUMPS: 2RNPU0003, 2A Nuclear Service Water Pump
2RNPU0004, 2B Nuclear Service Water Pump

Relief Request deleted by Revision 17

**DUKE POWER COMPANY
McGUIRE NUCLEAR STATION - UNIT 2
VALVE INSERVICE TESTING PROGRAM**

INTRODUCTION

The inservice testing of ASME Code Categories A, B, C and D will be performed as required by ASME OM-Code-1987, Part 10 OMa-1988 addenda included, (Inservice Testing of Valves in Light-Water Reactor Power Plants), as incorporated in 10CFR50.55a. These rules for IST were instituted by 1989 edition of ASME Section XI and will be adhered to, except where specific written relief has been granted by the Commission. The effective date for this ten year submittal is March 1, 1994.

Technical Specification 4.0.5 requires inservice testing of ASME Code Class 1, 2 and 3 valves in accordance with Section XI of the ASME Boiler and Pressure Boiler Code and applicable Addenda as required by 10 CFR 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50, Section 50.55a(g)(6)(i). Valves were selected for inclusion in the IST Program (Section II.2) which fall within this category, as required by this Technical Specification. Valves within the above ASME categories which are required to mitigate the consequences of an accident, shutdown the reactor or maintain shutdown, or are pressure relief devices which protect systems or portions of systems which provide these functions, are included in the program. Testing requirements are identified for each valve which ensure that the valve will perform as designed in response to an accident, shutting down the reactor, or in providing relief protection. Valves are categorized in accordance with OM-10 Section 1.4, as Category A, B or C (there are no Category D valves in the program). Valves with remote position indicators are observed locally at least once every 2 years in accordance with the Code. Acceptance criteria are specified in accordance with ASME Boiler and Pressure Vessel Code Subsection IWV. The safety functions of the valves listed in Section II.2 are included in the Design Basis Documents, and fall within the basic categories of accident mitigation, reactor shutdown or maintaining shutdown, or pressure relief for systems providing such. Post modification testing requirements are included in the applicable Nuclear System Directive; a modification test plan is required to be developed to verify proper operation. OM-10 requires the determination of a new reference value after valve replacement, repair or maintenance that could affect its operation. These Code requirements and programmatic controls ensure that the valve inservice test program is maintained current with modifications performed under 10 CFR 50.59. The documents used in development of this program include the following:

- McGuire Technical Specifications.
- Safety Analysis Report.
- ASME Section XI, IWV (1986).
- ASME OM-Code-1987, Part 10 OMa-1988 addenda included.
- Generic Letter 89-04.
- Supplement 1 to Generic Letter 89-04.
- NUREG 1482, Guidelines for Inservice Testing at Nuclear Power Plants.
- Safety Evaluation Report for the McGuire IST Program dated October 21, 1994.

McGuire Unit 2

- NOTES:**
- 1) The dated initials of the person responsible for the action may be used in place of a signature in the record of tests. Initials shall be construed as signatures to meet the intent of OMa-1988, Section 6.3.
 - 2) Category A and A/C valves include containment isolation valves (CIV) and pressure isolation valves (PIV). CIVs are leak tested in accordance with 10CFR50, Appendix J, and Section 4.2.2.3, unless specific relief is requested.
 - 3) Generic Letter 89-04, provides guidance for sample disassembly of check valves as an alternative to verify operability of check valves. The check valves where sample disassembly will be utilized will be specifically referenced in the contents of the submittal and performed according to the guidelines of Generic Letter 89-04.
 - 4) A Supplemental Test Program has been established, which includes components which have been determined important to safety and prudent to test, but which are not explicitly under the scope of ASME Codes and Standards.

**Unit 2 - McGuire Nuclear Station
Inservice Testing Program**

| VALVE NUMBER | FLOW DIAGRAM | FLOW COOR | ASME CLASS | VALVE CATEGORY | ACT PAS | VALVE TYPE | ACTUATOR TYPE | TEST REQ'MT #1 | TEST REQ'MT #2 | RELIEF REQST | JUSTIF OF DEFERRAL | REMARKS | TEST ALTERNATIVES | REV |
|--|--------------|-----------|------------|----------------|---------|------------|---------------|----------------|----------------|--------------|--------------------|---------|-------------------|-----|
| STEAM GENERATOR BLOWDOWN RECYCLE (BB) | | | | | | | | | | | | | | |
| 2BB-0001B | 2580-1.0 | H-02 | 2 | B | ACT | Gate | AOV | ST-Q | - | - | - | - | - | - |
| 2BB-0002B | 2580-1.0 | H-04 | 2 | B | ACT | Gate | AOV | ST-Q | - | - | - | - | - | 22 |
| 2BB-0003B | 2580-1.0 | H-12 | 2 | B | ACT | Gate | AOV | ST-Q | - | - | - | - | - | 22 |
| 2BB-0004B | 2580-1.0 | H-10 | 2 | B | ACT | Gate | AOV | ST-Q | - | - | - | - | - | - |
| 2BB-0005A | 2580-1.0 | F-02 | 2 | B | ACT | Gate | AOV | ST-Q | - | - | - | - | - | - |
| 2BB-0006A | 2580-1.0 | F-04 | 2 | B | ACT | Gate | AOV | ST-Q | - | - | - | - | - | - |
| 2BB-0007A | 2580-1.0 | F-12 | 2 | B | ACT | Gate | AOV | ST-Q | - | - | - | - | - | - |
| 2BB-0008A | 2580-1.0 | F-10 | 2 | B | ACT | Gate | AOV | ST-Q | - | - | - | - | - | - |

**Unit 2 - McGuire Nuclear Station
Inservice Testing Program**

| VALVE NUMBER | FLOW DIAGRAM | FLOW COOR | ASME CLASS | VALVE CATEGORY | ACT PAS | VALVE TYPE | ACTUATOR TYPE | TEST REQMT #1 | TEST REQMT #2 | RELIEF REQST | JUSTIF OF DEFERRAL | REMARKS | TEST ALTERNATIVES | REV |
|---|--------------|-----------|------------|----------------|---------|------------|---------------|---------------|---------------|--------------|--------------------|------------------------|-------------------|-----|
| CHEMICAL AND VOLUME CONTROL (NV) | | | | | | | | | | | | | | |
| 2NV-0006 | 2554-1.2 | K-08 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 600 PSIG | - |
| 2NV-0007B | 2554-1.2 | J-11 | 2 | B | ACT | Globe | EMO | ST-Q | - | - | 2-MC-NV2 | - | - | - |
| 2NV-0020 | 2554-1.2 | E-02 | 2 | C | ACT | Check | - | SP | - | - | - | Spring Loaded Ck Valve | 200 PSIG | - |
| 2NV-0021A | 2554-1.2 | E-03 | 1 | B | ACT | Control | AOV | ST-Q | - | - | 2-MC-NV3 | - | - | - |
| 2NV-0029 | 2554-1.0 | C-02 | 2 | C | ACT | Check | - | MTO-Q | - | - | - | - | - | - |
| 2NV-0031 | 2554-1.0 | D-02 | 1 | C | ACT | Check | - | MTO-Q | - | - | - | - | - | - |
| 2NV-0035A | 2554-1.2 | K-07 | 2 | B | ACT | Gate | AOV | ST-Q | - | - | 2-MC-NV19 | - | - | 17 |
| 2NV-0045 | 2554-1.0 | C-08 | 2 | C | ACT | Check | - | MTO-Q | - | - | - | - | - | - |
| 2NV-0047 | 2554-1.0 | D-08 | 1 | C | ACT | Check | - | MTO-Q | - | - | - | - | - | - |
| 2NV-0061 | 2554-1.1 | C-02 | 2 | C | ACT | Check | - | MTO-Q | - | - | - | - | - | - |
| 2NV-0063 | 2554-1.1 | D-02 | 1 | C | ACT | Check | - | MTO-Q | - | - | - | - | - | - |
| 2NV-0077 | 2554-1.1 | C-08 | 2 | C | ACT | Check | - | MTO-Q | - | - | - | - | - | - |
| 2NV-0079 | 2554-1.1 | D-08 | 1 | C | ACT | Check | - | MTO-Q | - | - | - | - | - | - |
| 2NV-0093 | 2554-1.1 | K-12 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 150 PSIG | - |
| 2NV-0094AC | 2554-1.1 | J-13 | 2 | B | ACT | Gate | EMO | ST-Q | - | - | 2-MC-NV1 | - | - | - |
| 2NV-0095B | 2554-1.1 | H-13 | 2 | B | ACT | Gate | EMO | ST-Q | - | - | 2-MC-NV1 | - | - | - |

**Unit 2 - McGuire Nuclear Station
Inservice Testing Program**

| VALVE NUMBER | FLOW DIAGRAM | FLOW COOR | ASME CLASS | VALVE CATEGORY | ACT PAS | VALVE TYPE | ACTUATOR TYPE | TEST REQMT #1 | TEST REQMT #2 | RELIEF REQST | JUSTIF OF DEFERRAL | REMARKS | TEST ALTERNATIVES | REV |
|--------------|--------------|-----------|------------|----------------|---------|------------|---------------|---------------|---------------|--------------|--------------------|---------|-------------------|-----|
| 2NV-0141A | 2554-2.0 | B-08 | 2 | B | ACT | Gate | EMO | ST-Q | - | - | 2-MC-NV4 | - | - | - |
| 2NV-0142B | 2554-2.0 | B-07 | 2 | B | ACT | Gate | EMO | ST-Q | - | - | 2-MC-NV4 | - | - | - |
| 2NV-0143 | 2554-2.0 | B-06 | 2 | C | ACT | Check | - | MTC-Q | - | - | 2-MC-NV15 | - | - | - |
| 2NV-0150B | 2554-2.0 | F-02 | 2 | B | ACT | Kerotest | EMO | ST-Q | - | - | 2-MC-NV8 | - | - | - |
| 2NV-0151A | 2554-2.0 | G-02 | 2 | B | ACT | Kerotest | EMO | ST-Q | - | - | 2-MC-NV8 | - | - | - |
| 2NV-0155 | 2554-2.0 | I-06 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 150 PSIG | - |
| 2NV-0156 | 2554-2.0 | J-09 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 255 PSIG | - |
| 2NV-0164 | - | - | - | - | - | - | - | DELETED | - | - | - | - | - | 17 |
| 2NV-0170 | 2554-2.0 | C-08 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 75 PSIG | - |
| 2NV-0218 | 2554-3.0 | J-05 | 2 | C | ACT | Check | - | MTC-Q | - | - | - | - | - | - |
| 2NV-0221A | 2554-3.1 | H-01 | 2 | B | ACT | Gate | EMO | ST-Q | - | - | 2-MC-NV6 | - | - | - |
| 2NV-0222B | 2554-3.1 | I-01 | 2 | B | ACT | Gate | EMO | ST-Q | - | - | 2-MC-NV6 | - | - | - |
| 2NV-0223 | 2554-3.1 | I-02 | 2 | C | ACT | Check | - | MTO,C-Q | - | - | 2-MC-NV11 | - | - | - |
| 2NV-0225 | 2554-3.1 | F-05 | 2 | C | ACT | Check | - | MTO,C-Q | - | - | 2-MC-NV10 | - | - | - |
| 2NV-0227 | 2554-3.1 | E-06 | 2 | C | ACT | Check | - | MTO,C-Q | - | - | - | - | - | - |
| 2NV-0229 | 2554-3.1 | I-12 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 220 PSIG | - |

**Unit 2 - McGuire Nuclear Station
Inservice Testing Program**

| VALVE NUMBER | FLOW DIAGRAM | FLOW COOR | ASME CLASS | VALVE CATEGORY | ACT PAS | VALVE TYPE | ACTUATOR TYPE | TEST REQMT #1 | TEST REQMT #2 | RELIEF REQST | JUSTIF OF DEFERRAL | REMARKS | TEST ALTERNATIVES | REV |
|--------------|--------------|-----------|------------|----------------|---------|------------|---------------|---------------|---------------|--------------|--------------------|---------|-------------------|-----|
| 2NV-0231 | 2554-3.1 | F-10 | 2 | C | ACT | Check | - | MTO,C-Q | - | - | 2-MC-NV10 | - | - | - |
| 2NV-0233 | 2554-3.1 | E-10 | 2 | C | ACT | Check | - | MTO,C-Q | - | - | - | - | - | - |
| 2NV-0238 | | | | | | | | DELETED | | | | | | 16 |
| 2NV-0244A | 2554-3.0 | K-08 | 2 | B | ACT | Gate | EMO | ST-Q | - | - | 2-MC-NV5 | - | - | - |
| 2NV-0245B | 2554-3.0 | K-09 | 2 | B | ACT | Gate | EMO | ST-Q | - | - | 2-MC-NV5 | - | - | - |
| 2NV-0261 | 2554-3.1 | J-03 | 2 | C | ACT | Check | - | MTC-Q | - | - | 2-MC-NV13 | - | - | - |
| 2NV-0263 | 2554-3.1 | J-11 | 2 | C | ACT | Check | - | MTC-Q | - | - | 2-MC-NV13 | - | - | - |
| 2NV-0264 | 2554-3.1 | J-10 | 2 | C | ACT | Check | - | MTO,C-Q | - | - | 2-MC-NV7 | - | - | - |
| 2NV-0265B | 2554-3.1 | J-09 | 2 | B | ACT | Globe | EMO | ST-Q | - | - | 2-MC-NV9 | - | - | - |
| 2NV-0383 | 2554-5.0 | F-06 | 3 | C | ACT | Check | - | MTO,C-Q | - | - | - | - | - | - |
| 2NV-0386 | 2554-5.0 | D-06 | 3 | C | ACT | Check | - | MTO,C-Q | - | - | - | - | - | - |
| 2NV-0457A | 2554-1.2 | I-07 | 2 | B | ACT | Control | AOV | ST-Q | - | - | 2-MC-NV19 | - | - | 17 |
| 2NV-0458A | 2554-1.2 | J-07 | 2 | B | ACT | Control | AOV | ST-Q | - | - | 2-MC-NV19 | - | - | 17 |
| 2NV-0482 | 2554-2.0 | D-07 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 150 PSIG | - |
| 2NV-0483 | 2554-2.0 | D-11 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 150 PSIG | - |
| 2NV-0486 | 2554-3.1 | J-09 | 2 | C | ACT | Relief | - | SP | - | - | - | - | 150 PSIG | - |

**Unit 2 - McGuire Nuclear Station
Inservice Testing Program**

| VALVE NUMBER | FLOW DIAGRAM | FLOW COOR | ASME CLASS | VALVE CATEGORY | ACT PAS | VALVE TYPE | ACTUATOR TYPE | TEST REQMT #1 | TEST REQMT #2 | RELIEF REQST | JUSTIF OF DEFERRAL | REMARKS | TEST ALTERNATIVES | REV |
|--------------|--------------|-----------|------------|----------------|---------|------------|---------------|---------------|---------------|--------------|--------------------|---------|-------------------|-----|
| 2RN-0238B | 2574-3.1 | I-07 | 3 | B | ACT | Butterfly | EMO | ST-Q | - | - | - | - | - | - |
| 2RN-0240B | 2574-3.0 | F-13 | 3 | B | ACT | Globe | AOV | ST-Q | - | - | - | - | - | - |
| 2RN-0252B | 2574-4.0 | E-02 | 2 | A | ACT | Diaphragm | AOV | ST-Q | LT-RF | - | 2-MC-RN1 | - | - | - |
| 2RN-0253A | 2574-4.0 | C-02 | 2 | A | ACT | Diaphragm | EMO | ST-Q | LT-RF | - | 2-MC-RN1 | - | - | - |
| 2RN-0276A | 2574-4.0 | J-02 | 2 | A | ACT | Diaphragm | EMO | ST-Q | LT-RF | - | 2-MC-RN2 | - | - | - |
| 2RN-0277B | 2592-4.0 | H-02 | 2 | A | ACT | Diaphragm | AOV | ST-Q | LT-RF | - | 2-MC-RN2 | - | - | - |
| 2RN-0279B | 1574-1.0 | C-02 | 3 | B | ACT | Butterfly | EMO | ST-Q | - | - | - | - | - | - |
| 2RN-0293 | 2574-3.1 | I-05 | 3 | C | ACT | Relief | - | SP | - | - | - | - | 135 PSIG | - |
| 2RN-0294 | 2574-3.0 | F-12 | 3 | C | ACT | Relief | - | SP | - | - | - | - | 135 PSIG | - |
| 2RN-0295 | 2574-2.0 | H-11 | 3 | C | ACT | Relief | - | SP | - | - | - | - | 135 PSIG | - |
| 2RN-0296A | 2574-1.1 | L-13 | 3 | B | ACT | Butterfly | EMO | ST-Q | - | - | - | - | - | - |
| 2RN-0297B | 2574-3.0 | L-05 | 3 | B | ACT | Butterfly | EMO | ST-Q | - | - | - | - | - | - |
| 2RN-0299A | 1574-1.0 | C-02 | 3 | B | ACT | Butterfly | EMO | ST-Q | - | - | - | - | - | - |
| 2RN-0891 | - | - | - | - | - | - | - | DELETED | - | - | - | - | - | 17 |
| 2RN-0892 | - | - | - | - | - | - | - | DELETED | - | - | - | - | - | 17 |
| 2RN-0994 | 2574-3.1 | C-07 | 3 | C | ACT | Check | - | MTC-Q | - | - | - | - | - | 16 |

Specific Relief Request

Item Number: 2-MC-RR-NS1
Valve: 2NS-13, 2NS-16, 2NS-30, 2NS-33, 2NS-41, 2NS-46
Flow Diagram: MC-2563-1.0
Code Category: C
ASME Class: 2
Function: Open on flow from containment spray pumps.
Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Relief: Containment Spray valves 2NS-13, 16, 30, 33, 41, and 46 are Aloyco/Walworth model D-49300 cover hung, swing check valves. They are normally closed providing Category C interior containment isolation for Containment Spray and Auxiliary Containment Spray (valves 2NS-41 and 46). OMa-1988, Part 10, paragraph 4.3.2.1 requires quarterly exercising, deferrable to cold shutdowns or refueling outages. McGuire FSAR Table 6-112 identifies these valves as Leak Class 1A valves not requiring leak rate testing due their inability to release containment atmosphere during a LOCA.

Full stroke operation of the check valves shall be verified by disassembly/inspection of the valves as no operational method exists without actuating containment spray (reference 2MC-NS2, NUREG-1482 Staff Position 2). As a supplement to the full stroke testing, part stroke and closed verification will be conducted upon reassembly and periodically by air test as described for the spray nozzle test in McGuire FSAR 6.5.4 (reference , NUREG-1482 Staff Position 2).

For valve disassembly/inspection, all six valves will be grouped into one group and inspected within a four cycle window (six year interval). All six valves are identical in manufacturer and installation. Operationally, the valves are identical with respect to operational readiness. During system actuation, supply originates from the Containment Spray system for valves 2NS-13, 16, 30, and 33 and Residual Heat Removal system for

Revised by Rev. 17.

Specific Relief Request

Item Number:

2-MC-RR-NS1 (cont.)

2NS-41 and 46. In spray modes both systems have similar hydraulic characteristics. At McGuire's discretion the valves may be disassembled/inspected sequentially, in sub-groups, or as one complete group every fourth outage (six years). Diversion from the sequential disassembly/inspection represents an extension from the Code required frequency.

The relief request does not represent a decrease in quality nor safety. The valve disassembly/inspection will demonstrate ability of the valve to full stroke and fully close. As the valves do not function except during testing and severe plant emergencies, no operating degradation mechanisms exist. Potential degradation mechanisms from the valves being in a static position will be identified by the part stroke test conducted each refueling outage on all valves.

Compliance with the Code requirements is impractical and would impose unnecessary hardship. The valves are located within the containment dome volume and are accessible by a temporary cantilevered scaffold attached to the Polar Crane Scissors Jack. This action, in accordance with the requirements of 29CFR 1910.28, 29CFR 1926.452, ANSI A10.8-1977, and McGuire's Scaffold program places personnel in unsafe positions during the erection/removal of the scaffold and valve testing. No additional assurance of valve function is gained. In fact, although unlikely, frequent intrusion into the valves' internals and the inability to verify exact seat alignment during reassemble may degrade the valves' condition.

Pursuant to NUREG-1482 Staff Position 2, extension of the valve disassembly/inspection interval will be considered in cases of extreme hardship. Response to Question 19 of same implies "extreme hardship" is proportional to the impact on plant safety. The hardship impact is one of undue personnel safety risk and refueling outage extension. Yet the benefit from testing under the current scheme (reference 2MC-NS2) as compared to the proposed scheme is negligible at best. All valves will be disassembled/inspected once per four refueling outages (six years).

Revised by Rev. 17.

10/12/95

Specific Relief Request

Item Number:

2-MC-RR-NS1 (cont.)

A review of McGuire's valves, similar industry valves, and the "EPRI Applications Guidelines for Check Valves in Nuclear Power Plants" was conducted.

A review of the past 6 Unit 1 refueling outages, 7 Unit 2, identified part stroke testing of all valves every outage through 1/2EOC 9. Since 1/2EOC 6 each Containment Spray check valve has been disassembled/inspected once and Auxiliary Containment Spray valves twice (due to the current grouping scheme). A comprehensive review of all valves identified no indication of wear, corrosion, or degradation.

A NPRDS search for Aloyco-Walworth and Walworth check valves provided a list of 34 Containment Spray check valve failures. A detailed review of the 34 failures identified 14 potentially related failures. Subsequent conversation with the respective plants' System Engineers resolved 11 of these potentially related failures as unrelated. Reasons for determining a valve failure was unrelated included the following; valves normally see flow during testing or other plant operation, and recent ISI disassembly/inspection of valves identified no degradation. The 3 remaining potentially related failures included 2 which could not be determined and 1 which was a result of valve disk misalignment. As stated earlier the potential for valve disk misalignment increases, although marginally, with repetitive disassembles.

A review of the "EPRI Applications Guidelines for Check Valves in Nuclear Power Plants" primarily addressed degradation of check valves regularly in operation service. Design criteria for check valve application was also discussed. Comparison with the subject check valves did not reveal any design misapplication issues. The issue of valve sticking open/closed was discussed in section 6.5.4, identifying improperly assembly as a potential cause. This issue would be addressed by the proposed part flow testing.

This Relief Request evaluation concludes adequate justification without compromise to safety or quality exist to warrant the proposed test methodology.

Revised by Rev. 17.

10/12/95

Specific Relief Request

Item Number: 2-MC-RR-NS1 (cont.)

Test Alternative & Frequency: Containment Spray valves 2NS-13, 16, 30, 33, 41, and 46 will be grouped into a single test group. The valves may be disassembled/inspected sequentially, in sub-groups, or as one complete group every fourth outage (6 years). Each valve will be disassembled/inspected once per four refueling outages (6 years). Each Containment Spray valve will be part stroke tested during each refueling outage.

Justification of Deferral

Item Number: 2-MC-CA1

Valve: 2CA-37, 2CA-41, 2CA-45, 2CA-49, 2CA-53, 2CA-57, 2CA-61, 2CA-65

Flow Diagram: MC-2592-1.0

Code Category: C

ASME Class: 2

Function: Check flow from the steam generators to Auxiliary Feedwater. Open to allow Auxiliary Feedwater supply to the Steam Generators.

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Deferral: Full stroke testing these valves during power operations would unnecessarily thermal shock the steam generators and feedwater piping.

Test Alternative & Frequency: Valves will be full stroke exercised at cold shutdown. Closure will be verified quarterly.

Justification of Deferral

Item Number: 2-MC-CA2

Valve: 2CA-165, 2CA-166

Flow Diagram: MC-2592-1.1

Code Category: C

ASME Class: 3

Function: Prevents backflow from Auxiliary Feedwater System to Nuclear service Water System until the associated EMOs are closed. EMOs are powered from the same train they serve. Must open to allow assured makeup flow to CA from RN system.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Neither full nor partial flow can be put through these valves without contaminating the Auxiliary Feedwater System with raw water. No means exist for alternate testing techniques using air or any other medium. No means exist to test for proper closure without contaminating the Auxiliary Feedwater System with raw water. These valves will not be tested during cold shutdown because sample disassembly is required.

Test Alternative & Frequency: At least one of these two valves will be disassembled and full stroked during each refueling outage, and both valves will have been disassembled and full stroked after two consecutive refueling outages. Failure of one valve to properly full stroke during a refueling outage will result in the remaining valves being disassembled and full stroked during that outage. Sample disassemble will also be used to verify proper closure of valves.

Justification of Deferral

Item Number: 2-MC-CA3

Valve: 2CA-8, 2CA-10, 2CA-12

Flow Diagram: MC-2592-1.1

Code Category: C

ASME Class: 3

Function: Auxiliary Feedwater Pump Suction Check valves to prevent diversion of assured auxiliary feedwater source.

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Deferral: These valves cannot be tested to close without contaminating the Auxiliary Feedwater System with raw water. These valves will not be tested during cold shutdown because sample disassembly is required.

Test Alternative & Frequency: Valves will be sample disassembled during refueling outages to verify valve closure capability. 2CA-8 is disassembled every refueling outage, 2CA-10 and 2CA-12 every other refueling outage on a staggered basis.

Justification of Deferral

Item Number: 2-MC-CF1

Valve: 2CF-26AB, 2CF-28AB, 2CF-30AB, 2CF-35AB

Flow Diagram: MC-2591-1.1

Code Category: B

ASME Class: 2

Function: Provide feedwater and containment isolation.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closure of these valves would isolate the Steam Generator feedwater which could result in a severe transient in the Steam Generator, resulting in a Unit trip.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 2-MC-CF2

Valve: 2CF-17AB, 2CF-20AB, 2CF-23AB, 2CF-32AB

Flow Diagram: MC-2591-1.1

Code Category: B

ASME Class: ANSI B31.1.0 (1967)

Function: Feedwater control.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closure of these valves would isolate the Steam Generator feedwater which could result in a severe transient in the Steam Generator, resulting in a Unit trip.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 2-MC-CF3

Valve: 2CF-126B, 2CF-127B, 2CF-128B, 2CF-129B

Flow Diagram: MC-2591-1.1

Code Category: B

ASME Class: 2

Function: Opens to provide startup feedwater supply to the steam generators.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Cycling valves during power operation could induce unwanted transients in the steam generators. This would result in an increase in flow to the main feedwater nozzles causing vibrations in the preheater section of the steam generators.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 2-MC-CF4

Valve: 2CF-104AB, 2CF-105AB, 2CF-106AB, 2CF-107AB

Flow Diagram: MC-2591-1.1

Code Category: B

ASME Class: ANSI B31.1.0 (1967)

Function: Provides tempering flow to the steam generators.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closing these valves during operation would result in a feedwater transient and could result in loss of Steam Generator level control, causing a Unit trip. These valves are normally open at power.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

Justification of Deferral

Item Number: 2-MC-CF5

Valve: 2CF-152, 2CF-154, 2CF-156, 2CF-158

Flow Diagram: MC-2591-1.1

Code Category: C

ASME Class: 2

Function: Opens to allow tempering flow to the Steam Generator auxiliary feedwater nozzles. Closes to form pressure boundary for auxiliary feedwater.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: During normal operation, there is constant flow through these valves to keep the auxiliary feedwater nozzles tempered. Testing these valves would require supplying the Steam Generators with cold water and thus thermally shocking these nozzles.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Justification of Deferral

Item Number: 2-MC-CF6

Valve: 2CF-118, 2CF-119, 2CF-120, 2CF-121

Flow Diagram: MC-2591-1.1

Code Category: C

ASME Class: 2

Function: Opens to allow feedwater flow to the Steam Generators. Closes to form pressure boundary for maintaining Steam Generator inventory. The open function is not within the Scope of OM-10.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: During normal operation, there is constant flow through these valves. The required test is performed while the Steam Generators are in wet-layup, with the main condensate system in service. The piping upstream of the check valve is depressurized, while the downstream side is pressurized. The check valves are verified to prevent gross diversion of flow. These conditions cannot be obtained with the unit operating.

Test Alternative & Frequency: Valves will be full stroke exercised at cold shutdown.

Revised by revision 16

10/16/95

Justification of Deferral

Item Number: 2-MC-FW1

Valve: 2FW-27A

Flow Diagram: MC-2571-1.0

Code Category: B

ASME Class: 2

Function: Isolates low pressure injection from the Refueling Water Storage Tank.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closure of this valve during normal power operation would render all low pressure injection inoperable. This valve is opened and power removed above Mode 4 per Tech Spec 4.5.2.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 2-MC-FW2

Valve: 2FW-28

Flow Diagram: MC-2571-1.0

Code Category: C

ASME Class: 2

Function: Opens to allow low pressure injection flow. Closes to prevent reverse flow to the Refueling Water Storage Tank, thereby preventing pressurization of the tank.

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Deferral: Valve cannot be full stroked during power operation since the only full flow path is into the RCS by the Residual Heat Removal pumps. These pumps cannot overcome RCS system pressure.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Justification of Deferral

| | |
|-------------------------------|--|
| Item Number: | 2-MC-FW3 |
| Valve: | 2FW-74 |
| Flow Diagram: | MC-2571-1.0 |
| Code Category: | C |
| ASME Class: | 3 |
| Function: | Must close to provide a pressure boundary for the assured makeup (Nuclear service Water) to the Spent Fuel Pool. |
| Test Requirement: | Verify proper valve movement once per three months as required by OMa 1988 Part 10, 4.3.2.1. |
| Basis for Deferral: | The system does not provide a means to verify valve closure. |
| Test Alternative & Frequency: | Valve will be disassembled and inspected to verify closure at refueling outage frequency. |

Revised by revision 16

10/16/95

Justification of Deferral

Item Number: 2-MC-IA1

Valve: 2IA-5260, 2IA-5270, 2IA-5280, 2IA-5290, 2IA-5300, 2IA-5310, 2IA-5320, 2IA-5330, 2IA-5340, 2IA-5350, 2IA-5360, 2IA-5370, 2IA-5380, 2IA-5390

Flow Diagram: MC-2499-IA1

Code Category: A,C

ASME Class: 2 & 3

Function: 2IA-5260, 5270, 5280, 5290, 5300, 5310, 5320 and 5330 prevent loss of air from receiver tank on each personnel airlock door in the event of loss of instrument air supply to door seals. These check valves form a pressure boundary for the inflatable seals.
2IA-5340 and 5350 provide the inside containment isolation barrier in the event of a break on the flexible hose connection on the air supply to the door seals. The outside isolation valves are 2IA-5080 and 5160. These check valves are on the auxiliary building side of the airlocks.
2IA-5360, 5370, 5380 and 5390 provide double isolation on the reactor building side of the airlocks for the pressure relief line.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.
2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.
3) Leak test in accordance with Technical Specification 4.6.1.3.d.

Basis for Deferral: These valves cannot be practically tested during operation due to the design of the system.

Test Alternative & Frequency: Valves will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at a six month frequency per Tech Spec 4.6.1.3.d.

Justification of Deferral

Item Number: 2-MC-KC1

Valve: 2KC-424B, 2KC-425A

Flow Diagram: MC-2573-3.1

Code Category: A

ASME Class: 2

Function: Provide containment isolation for penetration M-320.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Failure of either of these valves in the closed position during testing would inhibit the normal flow path from the reactor coolant pump motor coolers. This action could result in damage to the NC pumps. Within 15 to 30 minutes, the NC Pumps would be tripped on high bearing temperature, and an abnormal shutdown (natural circulation) would be required.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

Justification of Deferral

Item Number: 2-MC-KC2

Valve: 2KC-338B

Flow Diagram: MC-2573-3.1

Code Category: A

ASME Class: 2

Function: Provide containment isolation for penetration M-327.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Failure of this valve in the closed position could result in damage to the NC pumps. Within 15 to 30 minutes, the NC Pumps would be tripped on high bearing temperature, and an abnormal shutdown (natural circulation) would be required.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

Justification of Deferral

Item Number: 2-MC-KC3

Valve: 2KC-332B, 2KC-333A

Flow Diagram: MC-2573-3.1

Code Category: A

ASME Class: 2

Function: Provide containment isolation for penetration M-355.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Failure of one of these valves in the closed position during testing would inhibit flow through the reactor coolant drain tank heat exchanger. No alternate flowpath for cooling water to the heat exchanger exists. Without flow to the heat exchanger, the drain tank would become over pressurized and steam would be released. Such a test would not be conservative, since Reactor Coolant would be released. This test would challenge the overpressure protection of a Reactor Coolant System component. It is concluded therefore that per NUREG-1482 Section 3.1.1 that these valves should be excluded from quarterly testing.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

10/18/95

Justification of Deferral

Item Number: 2-MC-KC4

Valve: 2KC-320A

Flow Diagram: MC-2573-3.1

Code Category: A

ASME Class: 2

Function: Provide containment isolation for penetration M-376.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Failure of this valve in the closed position during testing would inhibit flow through the reactor coolant drain tank heat exchanger. No alternate flowpath for cooling water to the heat exchanger exists. Without flow to the heat exchanger, the drain tank would become over pressurized and steam would be released. Such a release of Reactor Coolant makes this test nonconservative and would challenge the overpressure protection of a Reactor Coolant System component. It is concluded therefore that per NUREG-1482 Section 3.1.1 that this valve should be excluded from quarterly testing.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-KC5

Valve: 2KC-280

Flow Diagram: MC-2573-3.1

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation and thermal over pressurization protection of line between 2KC-332B and 2KC-333A on penetration M-355.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: This valve cannot be practically tested during operation due to the design of the system. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-KC6

Valve: 2KC-322

Flow Diagram: MC-2573-3.1

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-376.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: This valve cannot be practically tested during operation due to the design of the system. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-KC7

Valve: 2KC-279

Flow Diagram: MC-2573-3.1

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation and thermal over pressurization protection of line between 2KC-424B and 2KC-425A on penetration M-320.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-KC8

Valve: 2KC-340

Flow Diagram: MC-2573-3.1

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-327.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-KC9

Valve: 2KC-47

Flow Diagram: MC-2573-4.0

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-322.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Justification of Deferral

Item Number: 2-MC-NB1

Valve: 2NB-262

Flow Diagram: MC-2556-3.0

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-259.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-NB2

Valve: 2NB-438

Flow Diagram: MC-2556-3.0

Code Category: C

ASME Class: 3

Function: Must close to provide a pressure boundary to prevent possible radiological releases caused by backflow from the pressurized sources downstream to the Unit 2 Reactor Makeup Water Storage Tank upstream.

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal.

Test Alternative & Frequency: Valve will be disassembled and inspected to verify closure at refueling outage frequency.

Revised by revision 15

10/16/95

Justification of Deferral

Item Number: 2-MC-NC1

Valve: 2NC-32B, 2NC-34A, 2NC-36B

Flow Diagram: MC-2553-2.0

Code Category: B

ASME Class: 1

Function: Reactor Coolant System PORV. Opens to relieve pressure for the primary system.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: PORVs do not serve a safety function when unit is at operating temperature and pressure. PORVs protect the Reactor Coolant System from over pressurization during LTOP conditions.

Test Alternative & Frequency: Stroke time testing will be performed at cold shutdown and in all cases prior to entering LTOP conditions in accordance with Generic Letter 90-06. Testing will not be required more often than once per quarter as defined in OMa-1988 Part 10, 4.2.1.1.

Justification of Deferral

Item Number: 2-MC-NC2

Valve: 2NC-272AC, 2NC-273AC, 2NC-274B, 2NC-275B

Flow Diagram: MC-2553-2.1

Code Category: B

ASME Class: 1

Function: Reactor vessel head vent.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Opening these valves at full pressure could cause damage to the valve seating surfaces. A reactor coolant leak could be caused.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 2-MC-NC3

Valve: 2NC-259, 2NC-261

Flow Diagram: MC-2553-4.0

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation and thermal over pressurization protection of line between 2NC-195B and 2NC-196A on penetration M-361, and line between 2NC-141 and 2NC-142 on penetration M-326 respectively.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

10/16/95

Justification of Deferral

| | |
|-------------------------------|---|
| Item Number: | 2-MC-NC4 |
| Valve: | 2NC-59 |
| Flow Diagram: | MC-2553-2.1 |
| Code Category: | C |
| ASME Class: | 2 |
| Function: | Must open to allow various relief valves on ECCS systems to relieve to the Pressurizer Relief Tank. |
| Test Requirement: | Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1. |
| Basis for Deferral: | The system design does not provide a sufficient means of verifying full opening of the check valve. |
| Test Alternative & Frequency: | Valve will be disassembled and inspected to verify full stroke opening at refueling outage frequency. |

Revised by revision 16

10/16/95

Justification of Deferral

Item Number: 2-MC-ND1

Valve: 2ND-1B, 2ND-2AC

Flow Diagram: MC-2561-1.0

Code Category: A

ASME Class: 1

Function: Provides suction for Residual Heat Removal pumps during normal cool down.

Test Requirement: 1) Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.3.

Basis for Deferral: These valves have an interlock which prevents their opening when the Reactor Coolant System pressure is greater than 385psig.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown. Valve will be leak tested in accordance with Tech Spec 4.4.6.2.2.

Justification of Deferral

| | |
|-------------------------------|---|
| Item Number: | 2-MC-ND2 |
| Valve: | 2ND-58A |
| Flow Diagram: | MC-2561-1.0 |
| Code Category: | B |
| ASME Class: | 2 |
| Function: | Provides suction to the Centrifugal Charging Pumps and Safety Injection Pumps from the Residual Heat Removal system. |
| Test Requirement: | Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1. |
| Basis for Deferral: | Opening 2ND-58A would seat check valve 2NV-223 (FWST to Charging Pump suction) closed, so that if 2ND-58A failed in the open position, both trains of NV would be inoperable. |
| Test Alternative & Frequency: | Valve will be cycled and timed during cold shutdown. |

Revised by Rev. 17.

Justification of Deferral

Item Number: 2-MC-ND3

Valve: 2ND-15B, 2ND-30A

Flow Diagram: MC-2561-1.0

Code Category: B

ASME Class: 2

Function: ND Heat Exchanger Outlet Crossover Block Valves.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: One of the ECCS safety analysis assumptions is that each train of ND can supply flow to all four cold legs. If either of these valves failed closed during testing then only two cold legs could be supplied by each train of ND. This would make both trains of ND inoperable.

Power cannot be removed from these valves, since at least one of them must be closed for cold leg recirc. If power was removed from one valve, a single failure on the opposite train would disable isolation of ND to the cold legs when needed (this isolation is needed for adequate cold leg recirc flow).

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-ND4

Valve: 2ND-70

Flow Diagram: MC-2561-1.0

Code Category: C

ASME Class: 2

Function: Opens to provides suction to the Centrifugal Charging Pumps and Safety Injection Pumps from the Residual Heat Removal system. Closes to provide suction pressure boundary for the Centrifugal Charging Pumps and Safety Injection Pumps

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Deferral: Valve cannot be full stroked during power operation since 2ND-58A would have to be opened, rendering both trains of ND inoperable. Additionally, the flow requirements to full stroke this valve cannot be achieved with the Reactor Coolant System pressurized.

Opening 2ND-58A would seat check valve 2NV-223 (FWST to Charging Pump suction) closed, so that if 2ND-58A failed in the open position, both trains of NV would be inoperable.

Manually closing 2ND-29, a fail-open valve, would be impractical.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-ND5

Valve: 2ND-71

Flow Diagram: MC-2561-1.0

Code Category: C

ASME Class: 2

Function: Opens to provides suction to the Centrifugal Charging Pumps and Safety Injection Pumps from the Residual Heat Removal system. Closes to provide suction pressure boundary for the Centrifugal Charging Pumps and Safety Injection Pumps

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Valve cannot be full stroked during power operation since 2NI-136B would have to be opened, rendering both trains of ND inoperable. Additionally, the flow requirements to full stroke this valve cannot be achieved with the Reactor Coolant System pressurized.

Opening 2ND-136B would seat check valve 2NV-223 (FWST to Charging Pump suction) closed, so that if 2ND-136B failed in the open position, both trains of NV would be inoperable.

Manually closing 2ND-14, a fail-open valve, would be impractical.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-ND6

Valve: 2ND-8, 2ND-23

Flow Diagram: MC-2561-1.0

Code Category: C

ASME Class: 2

Function: Residual Heat Removal pump discharge check valve.

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Deferral: Valves cannot be full stroke exercised during power operation since the only full flow path is into the Reactor Coolant System and the ND pumps cannot overcome RCS pressure.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown. Valves will be partially stroked quarterly. The opposite train valves will be tested closed quarterly except when the opposite train of ND is in service.

Justification of Deferral

Item Number: 2-MC-NF1

Valve: 2NF-229

Flow Diagram: MC-2558-4.0

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-373.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2. 10CFR50 Appendix J requires measurement of local leak rate using air or nitrogen.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: 1) Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

2) Leak Rate testing of the valve will be performed per Tech Spec 4.6.1.2.d.4).

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-NI1

Valve: 2NI-9A, 2NI-10B

Flow Diagram: MC-2562-1.0

Code Category: B

ASME Class: 2

Function: Flowpath for Centrifugal Charging Pumps to Reactor Coolant System Cold Legs.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Opening either of these valves during operation would increase the charging flow into the Reactor Coolant System resulting in an increase of pressure and a rapid change in the primary system boron concentration. This could create a transient and possible unit shutdown.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 2-MC-NI2

Valve: 2NI-100B

Flow Diagram: MC-2562-3.0

Code Category: B

ASME Class: 2

Function: Flowpath from: the Refueling Water Storage Tank the Safety Injection Pump suction.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closing this valve during operation would render both trains of Safety Injection inoperable. This valve is opened and power removed above Mode 4 per Tech Spec 4.5.2.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 2-MC-NI3

Valve: 2NI-147A, 2NI115B

Flow Diagram: MC-2562-3.0

Code Category: B

ASME Class: 2

Function: 2NI-147A provides flowpath for both trains of Safety Injection recirculation line to the Refueling Water Storage Tank. 2NI-115B provides flowpath for A train of Safety Injection recirculation line to the Refueling Water Storage Tank.

Test Requirement: Stroke time test in accordance with OIva-1923 Part 10, 4.2.1.1.

Basis for Deferral: Closing either of these valve during power operation renders both trains of Safety Injection inoperable. 2NI-147A is open with power removed above Mode 4 per Tech Spec 4.5.2.

In the event of a loss of offsite power with the loss of 2B diesel generator as the single failure, 2NI-115B would not open, rendering A Train NI inoperable (due to loss of miniflow path). B Train NI would already be inoperable due to the single failure.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-NI4

Valve: 2NI-121A, 2NI-152B

Flow Diagram: MC-2562-3.0

Code Category: B

ASME Class: 2

Function: Isolates Safety Injection flow to the hot legs.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: These valves are closed with power removed above Mode 4 per Tech Spec 4.5.2.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 2-MC-NI5
Valve: 2NI-162A
Flow Diagram: MC-2562-3.1
Code Category: B
ASME Class: 2
Function: Isolates Safety Injection flow to the cold legs.
Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.
Basis for Deferral: This valve is opened and power removed above Mode 4 per Tech Spec 4.5.2.
Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 2-MC-NI6

Valve: 2NI-103A

Flow Diagram: MC-2562-3.0

Code Category: B

ASME Class: 2

Function: Provides A Train Safety Injection Pump suction flow from the Refueling Water Storage Tank. Also provides a flowpath for B Train Residual Heat Removal pump discharge to B Train Chemical and Volume Control pump suction.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closing this valve during power operations degrades both trains of Chemical and Volume Control. In the event of a loss of offsite power with the loss of 2A diesel generator as the single failure when the valve was closed, B Train NV would be lost or sumprecirc mode. Since that could happen as fast as 30 minutes and would then be inaccessible due to dose rates, credit could not be taken for manually opening 2NI-103A in this event. A Train NV would already be inoperable due to the single failure.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 2-MC-NI7

Valve: 2NI-173A, 2NI-178B

Flow Diagram: MC-2562-3.1

Code Category: B

ASME Class: 2

Function: Provides flowpath for Residual Heat Removal to the cold legs.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: These valves are opened and power removed above Mode 4 per Tech Spec 4.5.2.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 2-MC-NI8

Valve: 2NI-334B

Flow Diagram: MC-2562-3.0

Code Category: B

ASME Class: 2

Function: Provides flowpath from B Train of Residual Heat Removal to B Train of Chemical and Volume Control, and from A Train of Residual Heat Removal to A Train of Safety Injection.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closing this valve during power operation degrades both trains of Safety Injection. With the single failure of 2B diesel generator, Train A of Safety Injection, which is provided suction from Residual Heat Removal via 2NI-334B or 2NI-136B, would be inoperable (since 2NI-136B is normally closed). Train B of Safety Injection would already be inoperable due to the single failure.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

Justification of Deferral

| | |
|-------------------------------|--|
| Item Number: | 2-MC-NI9 |
| Valve: | 2NI-183B |
| Flow Diagram: | MC-2562-3.1 |
| Code Category: | B |
| ASME Class: | 2 |
| Function: | Isolates Residual Heat Removal flow to the hot legs. |
| Test Requirement: | Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1. |
| Basis for Deferral: | This valve is closed and power removed above Mode 4 per Tech Spec 4.5.2. |
| Test Alternative & Frequency: | Valve will be cycled and timed during cold shutdown. |

Justification of Deferral

Item Number: 2-MC-NI10

Valve: 2NI-184B, 2NI-185A

Flow Diagram: MC-2562-3.0

Code Category: B

ASME Class: 2

Function: Provides flowpath from the Containment Sump to the Residual Heat Removal Pump and the Containment Spray Pump suction.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Opening these valves during power operation would allow water to enter lower containment. To prevent this, 1FW-27A would have to be closed, rendering both trains of Residual Heat Removal inoperable. Voids in suction piping would be created requiring fill and vent operations to prevent ECCS pump damage.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 2-MC-NI11

Valve: 2NI-332A, 2NI-333B

Flow Diagram: MC-2562-3.0

Code Category: B

ASME Class: 2

Function: Provides flowpath to Centrifugal Charging Pumps and Safety Injection Pumps from Residual Heat Removal Pumps during recirculation phase.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Opening these valves during power operations requires 2NI-334B to be closed to prevent aligning FWST to the suction of the Centrifugal Charging Pumps. Injecting FWST boron concentrated water into the Reactor Coolant System would induce a transient. Closing 2NI-334B degrades both trains of Safety Injection (With the single failure of 2B diesel generator, Train A of Safety Injection, which is provided suction from Residual Heat Removal via 2NI-334B or 2NI-136B, would be inoperable (since 2NI-136B is normally closed). Train B of Safety Injection would already be inoperable due to the single failure).

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-NI12

Valve: 2NI-15, 2NI-17, 2NI-19, 2NI-21,
2NI-347, 2NI-348, 2NI-349, 2NI-354

Flow Diagram: MC-2562-1.0

Code Category: C

ASME Class: 1

Function: Opens to allow flow to the cold legs from the Centrifugal Charging Pumps.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Injecting flow through these valves from the Centrifugal Charging Pumps during power operations could result in unnecessary thermal shock to the injection nozzles.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Justification of Deferral

| | |
|-------------------------------|---|
| Item Number: | 2-MC-NI13 |
| Valve: | 2NI-12 |
| Flow Diagram: | MC-2562-1.0 |
| Code Category: | C |
| ASME Class: | 2 |
| Function: | Flowpath for Centrifugal Charging Pumps to Reactor Coolant System cold legs. |
| Test Requirement: | Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1. |
| Basis for Deferral: | Injecting flow through this valve from the Centrifugal Charging Pumps during power operations could result in unnecessary thermal shock to the injection nozzles. |
| Test Alternative & Frequency: | Valve will be full stroke exercised at cold shutdown. |

Justification of Deferral

| | |
|-------------------------------|---|
| Item Number: | 2-MC-NI14 |
| Valve: | 2NI-101 |
| Flow Diagram: | MC-2562-3.0 |
| Code Category: | C |
| ASME Class: | 2 |
| Function: | Opens to allow flow from the Refueling Water Storage Tank to the Safety Injection Pumps. Closes to provide suction pressure boundary for these pumps from the Residual Heat Removal Pump discharge. |
| Test Requirement: | Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1. |
| Basis for Deferral: | Valve cannot be full stroke tested during power operation since the Safety Injection Pumps cannot overcome Reactor Coolant System pressure. Closure cannot be verified quarterly since both trains of Residual Heat Removal would be rendered inoperable. |
| Test Alternative & Frequency: | Valve will be full stroke exercised at cold shutdown. Valve will be partial stroked quarterly. |

Justification of Deferral

Item Number: 2-MC-NI15

Valve: 2NI-116, 2NI-148

Flow Diagram: MC-2562-3.0

Code Category: C

ASME Class: 1

Function: Pump discharge check valve, opens to allow Safety Injection Flow. Closes to prevent opposite train flow losses.

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Deferral: Valve cannot be full or partial stroke tested during power operation since the Safety Injection Pumps cannot overcome Reactor Coolant System pressure.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown. Valve will be verified closed quarterly.

Justification of Deferral

Item Number: 2-MC-NI16

Valve: 2NI-124, 2NI-128, 2NI-156, 2NI-157, 2NI-159, 2NI-160

Flow Diagram: MC-2562-3.0

Code Category: AC

ASME Class: 2

Function: 1) Opens on flow from the Safety Injection Pumps to the hot legs.
2) Reactor Coolant System pressure boundary.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.
2) Leak test once per two years in accordance with OMa-1988 Part 10, 4.2.2.3.

Basis for Deferral: Valves cannot be full or partial stroke tested during power operation since the Safety Injection Pumps cannot overcome Reactor Coolant System pressure.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown. Leak test in accordance with Tech Spec 4.4.6.2.2.

Justification of Deferral

Item Number: 2-MC-NI17

Valve: 2NI-165, 2NI-167, 2NI-169, 2NI-171

Flow Diagram: MC-2562-3.1

Code Category: AC

ASME Class: 1

Function: 1) Opens on flow from the Safety Injection Pumps to the cold legs.
2) Reactor Coolant System pressure boundary.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.
2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.3.

Basis for Deferral: Valves cannot be full or partial stroke tested during power operations since the Safety Injection Pumps cannot overcome Reactor Coolant System pressure.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown. Leak test in accordance with Tech Spec 4.4.6.2.2.

Justification of Deferral

Item Number: 2-MC-NI18

Valve: 2NI-175, 2NI-176, 2NI-180, 2NI-181

Flow Diagram: MC-2562-3.1

Code Category: AC

ASME Class: 1

Function: 1) Opens on flow from the Residual Heat Removal Pumps to the cold legs.
2) Reactor Coolant System pressure boundary.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.
2) Leak test once per two years in accordance with OMA-1988 Part 10, 4.2.2.3.

Basis for Deferral: Valves cannot be full or partial stroke tested during power operation since the Residual Heat Removal pumps cannot overcome Reactor Coolant System pressure.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown. Leak test in accordance with Tech Spec 4.4.6.2.2.

Justification of Deferral

Item Number: 2-MC-NI19

Valve: 2NI-125, 2NI-126, 2NI-129, 2NI-134

Flow Diagram: MC-2562-3.0

Code Category: AC

ASME Class: 1

Function: 1) Opens on flow from the Residual Heat Removal Pumps to the hot legs.
2) Reactor Coolant System pressure boundary.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.
2) Leak test once per two years in accordance with OMA-1988 Part 10, 4.2.2.3.

Basis for Deferral: Valves cannot be full or partial stroke tested during power operation since the Residual Heat Removal pumps cannot overcome Reactor Coolant System pressure.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown. Leak test in accordance with Tech Spec 4.4.6.2.2.

Justification of Deferral

Item Number: 2-MC-NI20

Valve: 2NI-136B

Flow Diagram: MC-2562-3.0

Code Category: B

ASME Class: 2

Function: Provides suction to the Centrifugal Charging Pumps and Safety Injection Pumps from the Residual Heat Removal System.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Opening 2NI-136B would seat check valve 2NV-223 (FWST to Charging Pump suction) closed, so that if 2NI-136B failed in the open position, both trains of NV would be inoperable.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

Justification of Deferral

Item Number: 2-MC-NI21

Valve: 2NI-48

Flow Diagram: MC-2562-2.0

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-330.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Justification of Deferral

Item Number: 2-MC-NI22

Valve: 2NI-59, 2NI-70, 2NI-81, 2NI-93

Flow Diagram: MC-2562-2.0, MC-2562-2.1

Code Category: A,C

ASME Class: 1

Function: Opens on flow from the NI cold leg accumulator to the Reactor Coolant System. Reactor Coolant Boundary valve.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.3.

3) Leak test in accordance with Tech Spec 4.4.6.2.2.

Basis for Deferral: Valves cannot be full or partial stroked during power operation since the accumulator pressure is ~600 psig and cannot overcome RCS pressure. Valves will not be tested during cold shutdown since disassembly is required. Disassembly would render one train of RHR inoperable for an extended period of time.

Test Alternative & Frequency: Valves will be full stroked at refueling by disassembly on a sample basis. All valves will be partial stroked at refueling. Partial stroke will not be performed at cold shutdown since Tech Spec 4.4.6.2.2 requires leak testing after initiating flow through these valves and does not require leak testing more often than once per nine months. Valves will be verified closed by leak test performed in accordance with Tech Spec 4.4.6.2.2.

Justification of Deferral

Item Number: 2-MC-NI23

Valve: 2NI-436

Flow Diagram: MC-2562-2.1

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation and thermal over pressurization protection for penetration M-321.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-NI24

Valve: 2NI-60, 2NI-71, 2NI-82, 2NI-94

Flow Diagram: MC-2562-2.0, MC-2562-2.1

Code Category: A,C

ASME Class: 1

Function: Opens on flow from the NI cold leg accumulator to the Reactor Coolant System. Reactor Coolant Boundary valve.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.3.

3) Leak test in accordance with Tech Spec 4.4.6.2.2.

Basis for Deferral: Valves cannot be full or partial stroked during power operation since a driving head which can overcome RCS pressure does not exist. Instrumentation is not present to measure the flow through the individual valves. Valves will not be tested during cold shutdown since disassembly is required. Disassembly would render one train of RHR inoperable for an extended period of time.

Test Alternative & Frequency: Valves will be full stroked at refueling by disassembly on a sample basis. All valves will be partial stroked at refueling. Partial stroke will not be performed at cold shutdown since Tech Spec 4.4.6.2.2 requires leak testing after initiating flow through these valves and does not require leak testing more often than once per nine months. Valves will be verified closed by leak test performed in accordance with Tech Spec 4.4.6.2.2.

Justification of Deferral

Item Number: 2-MC-NM1

Valve: 2NM-420, 2NM-421

Flow Diagram: MC-2572-1.0

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation and thermal over pressurization protection for penetrations M-235 and M-309 respectively.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-NS1

Valve: 2NS-38B, 2NS-43A

Flow Diagram: MC-2563-1.0

Code Category: B

ASME Class: 2

Function: Auxiliary Spray Nozzle header isolation.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Opening either of these valves during power operation renders both trains on Residual Heat Removal inoperable. With cross-connected trains of ND, flow would be diverted from both trains through a failed-open NS-38B or 43A. To isolate one train of ND, it would be necessary to manually secure closed either ND-14 or 25, since these valves fail open on loss of air. This would be an impractical measure to perform the quarterly test.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

Justification of Deferral

Item Number: 2-MC-NS2

Valve: 2NS-13, 2NS-16, 2NS-30, 2NS-33, 2NS-41, 2NS-46

Flow Diagram: MC-2563-1.0

Code Category: C

ASME Class: 2

Function: Open on flow from containment spray pumps.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Full stroke exercising of these check valves is not practical since there is no external indication of disk movement. Full stroke exercising would require for the pumps and spray nozzles to be activated which would require a large scale cleanup effort. Valves will not be tested during cold shutdown since sample disassembly is required.

Test Alternative & Frequency: These valves will be verified to fully cycle by sample disassembly at refueling outage frequencies.

Note: Relief is being requested on these valves. Refer to relief request 2-MC-RR-NS1. When relief is granted, this Justification Of Deferral will be deleted.

Justification of Deferral

| | |
|-------------------------------|---|
| Item Number: | 2-MC-NS3 |
| Valve: | 2NS-4, 2NS-21 |
| Flow Diagram: | MC-2563-1.0 |
| Code Category: | C |
| ASME Class: | 2 |
| Function: | Opens to allow flow from the Refueling Water Storage Tank to the Containment Spray Pump suction. Closes to prevent flow from the Containment Recirculation Sump to the Refueling Water Storage Tank. |
| Test Requirement: | Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1. |
| Basis for Deferral: | Full stroke exercising with flow would require for the pumps and spray nozzles to be activated which would require a large scale cleanup effort. The system design does not provide any indication for verifying closure upon flow reversal. |
| Test Alternative & Frequency: | Full stroke testing will be achieved by sample disassembly. At least one of these valves will be disassembled during each refueling outage, and both valves will have been disassembled and full stroked after two consecutive outages. Sample disassembly will also verify closure. Failure of one of valve to properly full stroke during a refueling outage will result in the remaining valve being disassembled and full stroked during that outage. Valves will be partial stroked quarterly. |

Justification of Deferral

Item Number: 2-MC-NS4

Valve: 2NS-140, 2NS-141

Flow Diagram: MC-2563-1.0

Code Category: A,C

ASME Class: 2

Function: Must open to allow Containment Spray to the spray ring headers. Must close to prevent column separation of water in the header after initial building spraydown and pump shutdown. During this time, the column of water in the vertical piping up to the spray rings could separate, creating a void in the system at sub-atmospheric pressure. Upon pump restart, the collapse of this void would damage the piping system.

Test Requirement: 1) Verify proper valve movement once per three months as required by CMA-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMA-1988 Part 10, 4.2.2.3.

Basis for Deferral: Full stroke exercising of these check valves is not practical since there is no external indication of disk movement. Full stroke exercising would require for the pumps and spray nozzles to be activated which would require a large scale cleanup effort. Valves will not be tested during cold shutdown since sample disassembly is required.

Test Alternative & Frequency: Valves will be verified to full stroke open using sample disassembly every other refueling outage on a staggered basis. Valves will be partial stroked quarterly. Valves will be leak tested at refueling outages. Leak testing will also verify closure of these valves.

Justification of Deferral

Item Number: 2-MC-NV1

Valve: 2NV-94AC, 2NV-95B

Flow Diagram: MC-2554-1.1

Code Category: B

ASME Class: 2

Function: 1) Provides flowpath for Reactor Coolant Pump seal water discharge line.
2) Provides containment isolation for penetration M-256

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closure of one of these valves during power operation would inhibit normal seal water flow across the reactor coolant pump number 1 seal. This action could result in damage to the reactor coolant pump seals or the pump itself. Failure of this seal with NC flow out the seal would be a loss of NV system function, and is justification for deferral in accordance with NUREG-1482 Section 3.1.1.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

Justification of Deferral

Item Number: 2-MC-NV2

Valve: 2NV-7B

Flow Diagram: MC-2554-1.2

Code Category: B

ASME Class: 2

Function: 1) Provides flowpath for normal letdown.
2) Provides containment isolation for penetration M-347.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Failure of this valve in a closed position would result in a significant event (letdown isolation), possibly resulting in loss of pressurizer level control, and possible Unit trip (not a normal shutdown).

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

10/16/95

Justification of Deferral

| | |
|-------------------------------|---|
| Item Number: | 2-MC-NV3 |
| Valve: | 2NV-21A |
| Flow Diagram: | MC-2554-1.2 |
| Code Category: | B |
| ASME Class: | 1 |
| Function: | Provides isolation for Pressurizer Auxiliary spray. |
| Test Requirement: | Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1. |
| Basis for Deferral: | Opening this valve during power operations could result in a reactor low pressure trip. |
| Test Alternative & Frequency: | Valve will be cycled and timed during cold shutdown. |

Justification of Deferral

Item Number: 2-MC-NV4

Valve: 2NV-141A, 2NV-142B

Flow Diagram: MC-2554-2.0

Code Category: B

ASME Class: 2

Function: Provides isolation for Volume Control Tank upon Safety Injection Signal.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Closure of one of these valves during power operation would isolate the suction for the Centrifugal Charging Pumps. This action could result in damage to the pumps. Seal water to the Reactor Coolant pumps would be interrupted causing damage to the seals.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 2-MC-NV5

Valve: 2NV-244A, 2NV-245B

Flow Diagram: MC-2554-3.0

Code Category: B

ASME Class: 2

Function: Isolates charging to the Reactor Coolant System upon Safety Injection.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: If one of these valves were to fail in the closed position while testing during power operation, normal and alternate charging would be lost. Total loss of charging flow would be a significant event, resulting in a possible loss of Pressurizer control, and a likely Unit trip (not a normal shutdown), as well as loss of NC pump seal flow.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

Justification of Deferral

| | |
|-------------------------------|---|
| Item Number: | 2-MC-NV6 |
| Valve: | 2NV-221A, 2NV-222B |
| Flow Diagram: | MC-2554-3.1 |
| Code Category: | B |
| ASME Class: | 2 |
| Function: | Flowpath for Refueling Water Storage Tank to the suction of the Centrifugal Charging Pumps. |
| Test Requirement: | Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1. |
| Basis for Deferral: | Opening these valves during power operation allows the Charging Pumps to inject highly borated water into the Reactor coolant System which could result in a unit shutdown. |
| Test Alternative & Frequency: | Valve will be cycled and timed during cold shutdown. |

Justification of Deferral

Item Number: 2-MC-NV7

Valve: 2NV-264

Flow Diagram: MC-2554-3.1

Code Category: C

ASME Class: 2

Function: Provides flowpath from the Boric Acid Tank to the Centrifugal Charging Pump suction. Closes to provide pump suction pressure boundary.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: To full stroke exercise this valve during power operations would inject more than 30 gpm of boric acid into the Reactor Coolant System creating a transient. To verify closure, residual boric acid would be injected causing a transient.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Justification of Deferral

Item Number: 2-MC-NV8

Valve: 2NV-150B, 2NV-151A

Flow Diagram: MC-2554-2.0

Code Category: B

ASME Class: 2

Function: Provides isolation for Centrifugal Charging Pump miniflow line to Volume Control Tank.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: If either valve were to fail closed while testing, the Charging Pump miniflow protection line is isolated possibly causing damage to the pump. Closure of either of these valves would render both trains of NV inoperable, since on a spurious safety injection event (in which reactor coolant system pressure is increased above normal), this is a relief path back to the Volume Control Tank.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

Justification of Deferral

Item Number: 2-MC-NV9

Valve: 2NV-265B

Flow Diagram: MC-2554-3.1

Code Category: B

ASME Class: 2

Function: Isolates the Boric Acid Tank from the suction of the Charging Pumps.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: If valve is opened during power operations, boric acid could be injected into the Reactor Coolant System causing a transient.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Justification of Deferral

| | |
|-------------------------------|--|
| Item Number: | 2-MC-NV10 |
| Valve: | 2NV-225, 2NV-231 |
| Flow Diagram: | MC-2554-3.1 |
| Code Category: | C |
| ASME Class: | 3 |
| Function: | Pump discharge check valve. Opens to provide flowpath for Centrifugal Charging Pump. Closes to prevent opposite train flow losses. |
| Test Requirement: | Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1. |
| Basis for Deferral: | Valve cannot be full stroke exercised during power operation since this would require an increase in Reactor Coolant System boron concentration which could result in unit shutdown. Normal letdown is not sufficient to verify full stroke, this must be done when aligned to the FWST for suction. |
| Test Alternative & Frequency: | Valve will be full stroke exercised during cold shutdown, partial stroked with normal use. |

Justification of Deferral

Item Number: 2-MC-NV11

Valve: 2NV-223

Flow Diagram: MC-2554-3.1

Code Category: C

ASME Class: 2

Function: Provides open flowpath from the FWST. Provides closed pump suction pressure boundary when suction is from the Residual Heat Removal pumps.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Testing this valve during power operations would require opening of either 2NV-221A or 2NV-222B. Opening these valves during power operation could result in a unit trip. See Justification # MC-NV6.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Justification of Deferral

Item Number: 2-MC-NV12

Valve: 2NV-1046

Flow Diagram: MC-2554-3.0

Code Category: C

ASME Class: 2

Function: Closes to provide pump suction pressure boundary for Centrifugal Charging Pumps. Open function is to protect the Positive Displacement Pump from over pressurization. This is not a safety related function.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Testing this valve during power operation would result in the addition of highly borated water into the Reactor Coolant System causing a transient. To place adequate test pressure on this valve, it would be necessary to use ND Pump discharge pressure, which would require opening 1ND-58A. This would inject FWST water into the NC System via the Charging Pumps, which are also on the discharge of the ND Pumps (for cold leg recirc) via 1ND-58A.

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-NV13

Valve: 2NV-261, 2NV-263

Flow Diagram: MC-2554-3.1

Code Category: C

ASME Class: 2

Function: These valves shall close to provide pump suction pressure isolation for the Centrifugal Charging Pumps by preventing backflow to the Chemical Mixing Tank or the RMWST respectively.

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Deferral: Testing these valves requires 2NI-121A to be opened. This valve is closed with power removed above mode 4 per Tech Spec 4.5.2.

This testing would require opening valve 1ND-58A, which would render both trains of NV inoperable (by seating check valve 1NV-223 (charging pump suction from the FWST in-line check closed).

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Revised by Rev. 17.

Justification of Deferral

Item Number: 2-MC-NV14

Valve: 2NV-1002

Flow Diagram: MC-2554-1.3

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-342.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMA-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

Justification of Deferral

| | |
|-------------------------------|---|
| Item Number: | 2-MC-NV15 |
| Valve: | 2NV-143 |
| Flow Diagram: | MC-2554-2.0 |
| Code Category: | C |
| ASME Class: | 2 |
| Function: | This valve shall close to provide Centrifugal Charging Pump suction pressure boundary during Recirculation alignment from RHR Pump discharge. |
| Test Requirement: | Verify proper valve movement once per three months as required by OMa- 788 Part 10, 4.3.2.1. |
| Basis for Deferral: | This valve is in the flowpath from the Volume Control Tank to the Charging pumps. During normal system operation, this valve is open. To verify this valve closes properly requires the alignment from the RHR pumps, and would interrupt normal charging activities. |
| Test Alternative & Frequency: | Valve will be full stroke exercised at cold shutdown. |

Justification of Deferral

Item Number: 2-MC-NV16

Valve: 2NV-164

Justification deleted by Revision 17.

Justification of Deferral

Item Number: 2-MC-NV17

Valve: 2NV-1007, 2NV-1008, 2NV-1009, 2NV-1010

Flow Diagram: MC-2554-1.3

Code Category: C

ASME Class: 2

Function: These valves must close to maintain a pressure boundary for normal Reactor Coolant Pump Seal Injection.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: In the event of failure of one of these valves during testing, the seal injection water for that Reactor Coolant Pump would be diverted, thereby creating a loss of seal injection to that pump. This condition would result in destroying a seal for the pump, and possibly creating a small break loss of coolant accident.

Test Alternative & Frequency: These valves will be tested for closure during cold shutdowns.

Revised by revision 16

10/16/95

Justification of Deferral

| | |
|-------------------------------|--|
| Item Number: | 2-MC-NV18 |
| Valve: | 2NV-1034 |
| Flow Diagram: | MC-2554-2.0 |
| Code Category: | C |
| ASME Class: | 3 |
| Function: | Must close to provide a pressure boundary to prevent possible radiological releases caused by backflow from the pressurized sources downstream to the Unit 1 Reactor Makeup Water Storage Tank upstream. |
| Test Requirement: | Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1. |
| Basis for Deferral: | The system design does not provide a means of verifying valve closure upon flow reversal. |
| Test Alternative & Frequency: | Valve will be disassembled and inspected to verify closure at refueling outage frequency. |

Revised by revision 16

10/16/95

Justification of Deferral

Item Number: 2-MC-NV19

Valve: 2NV-0035A, 2NV-0457A, 2NV-0458A

Flow Diagram: MCFD-2554-01.02

Code Category: B

ASME Class: 2

Function: These valves must automatically close to isolate containment on a Phase A signal, and to isolate letdown on a Pressurizer Low Level signal. They can be operated from the Auxiliary Shutdown Panel, and cannot be opened unless valves 2NV-1A and 2NV-2A are both open.

Test Requirement: Stroke time test quarterly in accordance with OMA-1988 Part 10, 4.2.1.1.

Basis for Deferral: Letdown header relief valve 2NV-6 has experienced lifting and subsequent seat leakage as a result of pressure transients during orifice swaps for stroke time testing of the above valves. Although the NV operating procedure specifically addresses the potential pressure increase that could occur when swapping from the 45 gpm to the 75 gpm orifice, the increase can occur so quickly that the operator and system controls cannot respond fast enough to prevent the pressure transient. The NV operating procedure currently provides for simultaneous opening/closure of the above orifice isolation valves, and for backpressure reduction using the downstream control valve, to prevent such a pressure transient; however, procedure effectiveness is problematic with respect to repeatability due to the inability to achieve perfect coordination each time.

It is concluded that testing of these valves is impractical and nonconservative during power operation, since it results in pressure transients which have caused relief valve leakage. This leakage is Reactor Coolant (NC) leakage, which is reflected in higher NC leakage values.

Finally, these valves have demonstrated a favorable test history.

Test Alternative & Frequency: Valves will be stroke time tested during cold shutdown.

Added by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-RF1

Valve: 1RF-834

Flow Diagram: MC-1599-2.2

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-353.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-RN1

Valve: 2RN-252B, 2RN-253A

Flow Diagram: MC-2574-4.0

Code Category: A

ASME Class: 2

Function: 1) Provides containment isolation for penetration M-307.
2) Provides flowpath for cooling water to the Reactor Coolant Pump Motor Air Cooler

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: If one of these valves were to fail closed during testing, isolation of cooling water to the motor coolers could result in damage to the pumps. Closure of these valves would result in a Unit trip from NC Pump motors being manually shut down due to high stator temperatures (within minutes). An abnormal (natural circulation) shutdown would be required.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-RN2

Valve: 2RN-276A, 2RN-277B

Flow Diagram: MC-2574-4.0

Code Category: A

ASME Class: 2

Function: 1) Provides containment isolation for penetration M-315.
2) Provides flowpath for cooling water to the Reactor Coolant Pump Motor Air Cooler.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: If one of these valves were to fail closed during testing, isolation of cooling water to the motor coolers could result in damage to the pumps. Closure of these valves would result in a Unit trip from NC Pump motors being manually shut down due to high stator temperatures (within minutes). An abnormal (natural circulation) shutdown would be required.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-RN3

Valve: 2RN-42A

Justification deleted by revision 16

Justification of Deferral

Item Number: 2-MC-RN4

Valve: 2RN-63B, 2RN-64A

Justification deleted by revision 16

10/16/95

Justification of Deferral

Item Number: 2-MC-RN5

Valve: 2RN-113

Justification deleted by revision 16

10/16/95

Justification of Deferral

Item Number: 2-MC-RN6
Valve: 2RN-891, 2RN-892

Justification deleted by Revision 17

Justification of Deferral

Item Number: 2-MC-RV1

Valve: 2RV-32A, 2RV-33B, 2RV-76A, 2RV-77B

Flow Diagram: MC-2604-3.0

Code Category: A

ASME Class: 2

Function: Provide containment isolation for penetration M-240 and M-279 respectively.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: Failure of one of these valves in the closed position during testing would isolate cooling flow to the Lower Containment Ventilation Units causing an increase in lower containment temperature which could exceed Tech Spec limits. Although the exact time depends on outside temperature, the Tech Spec limit would be exceeded within minutes if cooling flow was isolated to these ventilation units.

Test Alternative & Frequency: Valve will be cycled and timed during cold shutdown.

Revised by Rev. 17.

Justification of Deferral

Item Number: 2-MC-SA1

Valve: 2SA-5, 2SA-6

Flow Diagram: MC-2593-1.2

Code Category: C

ASME Class: 2

Function: Opens to allow steam supply to the turbine driven Auxiliary Feedwater Pump. Closes to prevent cross connecting steam generators 1B and 1C.

Test Requirement: Verify proper valve movement once per three months as required by OMA-1988 Part 10, 4.3.2.1.

Basis for Deferral: System configuration and design do not provide a suitable means to prove the valve prevents reversal of flow. To test the close function of this valve on line would risk personnel safety since high energy steam would be involved.

Test Alternative & Frequency: At least one of these two valves will be disassembled and full stroked during each refueling outage, and both valves will have been disassembled and full stroked after two consecutive outages. Sample disassembly will verify closure. Failure of one of valve to properly full stroke during a refueling outage will result in the remaining valve being disassembled and full stroked during that outage. Valves will be full stroked open quarterly.

Justification of Deferral

Item Number: 2-MC-SM1

Valve: 2SM-1AB, 2SM-3AB, 2SM-5AB, 2SM-7AB

Flow Diagram: MC-2593-1.0, MC-2593-1.3

Code Category: B

ASME Class: 2

Function: Main Steam Isolation Valves

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: These valves cannot be fully cycled closed during power operation since a unit shutdown would result.

Test Alternative & Frequency: These valves will be partially cycled closed while in Modes 1, 2 and 3. These valves will be cycled and timed during cold shutdown.

Justification of Deferral

Item Number: 2-MC-VB1

Valve: 2VB-50

Flow Diagram: MC-2605-3.1

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-215.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-VG1

Valve: 2VG-17, 2VG-18, 2VG-19, 2VG-20

Flow Diagram: MC-2609-4.0

Code Category: C

ASME Class: 3

Function: Provides flowpath for Diesel Generator control air from individual starting air banks.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: Testing these valves requires the Diesel Generator to be started on a single bank of control air which is considered a degraded condition. This is not justified for quarterly starts. This test is required to be done on an 18 month frequency as committed to in our response to SOER 80-1.

Test Alternative & Frequency: Valve will be full stroke exercised with the diesel generator start on a single bank of control air and performed at refueling outage frequency.

Note: A separate relief request has been submitted for these valves. This relief request was submitted on August 24, 1993 as Docket No. 50-370, Relief Request 92-01.

Justification of Deferral

Item Number: 2-MC-VI1

Valve: 2VI-368, 2VI-372, 2VI-373, 2VI-374

Flow Diagram: MC-2605-1.3

Code Category: C

ASME Class: ANSI B31.1.0 (1967)

Function: 2VI-368 and 2VI-373 must open to allow nitrogen to the PORV actuator.

2VI-372, 2VI-374 must close to prevent loss of Nitrogen pressure if instrument air is lost.

Test Requirement: Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

Basis for Deferral: All four valves are tested with PORV stroke timing. PORVs are tested on a cold shutdown frequency. Refer to Justification # 2-MC-NC1

Test Alternative & Frequency: Valve will be full stroke exercised at cold shutdown.

Justification of Deferral

Item Number: 2-MC-VI2

Valve: 2VI-124, 2VI-149

Flow Diagram: MC-2605-1.2

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetrations M-317 and M-386 respectively.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-VI3

Valve: 2VI-40, 2VI-161

Flow Diagram: MC-2605-1.3

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetrations M-220 and M-359 respectively.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-VI4

Valve: 2VI-129B, 2VI-150B, 2VI-160B

Flow Diagram: MC-2605-1.2; MC-2605-1.3

Code Category: A

ASME Class: 2

Function: Provides containment isolation on penetrations M-220, M-317 and M-359 respectively.

Test Requirement: Stroke time test in accordance with OMa-1988 Part 10, 4.2.1.1.

Basis for Deferral: These valves isolate instrument air headers to the reactor building. In the past, to perform stroke timing of these valves, the containment air compressor was started to maintain an uninterrupted air supply to components inside containment. During the past refueling outage, the containment compressor was deleted. Should these valves be closed during power operation, components inside containment would experience a loss of instrument air, resulting in unwanted transients. During cold shutdowns, personnel entry into containment may be made to manually align instrument air headers together, allowing these valves to be tested. Since this is a manual alignment, it is not possible to enter containment to make this alignment for quarterly testing.

Test Alternative & Frequency: Valves will be cycled and timed during cold shutdown. Leak testing will be performed as per the requirements of 10CFR50, Appendix J.

Revised by revision 16

11/16/95

Justification of Deferral

| | |
|-------------------------------|--|
| Item Number: | 2-MC-VS1 |
| Valve: | 2VS-13 |
| Flow Diagram: | MC-2605-2.2 |
| Code Category: | A,C |
| ASME Class: | 2 |
| Function: | Provide containment isolation on penetration M-219. |
| Test Requirement: | 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1. 2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2. |
| Basis for Deferral: | The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels. |
| Test Alternative & Frequency: | Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency. |

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-VX1

Valve: 2VX-30

Flow Diagram: MC-2557-1

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-325.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-WL1

Valve: 2WL-24

Flow Diagram: MC-2565-1.1

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation and thermal over pressurization protection of line between 2WL-1B and 2WL-2A on penetration M-375.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-WL2

Valve: 2WL-385

Flow Diagram: MC-2565-7.0

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation and thermal over pressurization protection of line between 2WL-322B and 2WL-321A on penetration M-221.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

10/16/95

Justification of Deferral

Item Number: 2-MC-YM1

Valve: 2YM-116

Flow Diagram: MC-2601-2.4

Code Category: A,C

ASME Class: 2

Function: Provides containment isolation on penetration M-337.

Test Requirement: 1) Verify proper valve movement once per three months as required by OMa-1988 Part 10, 4.3.2.1.

2) Leak test once per 2 years in accordance with OMa-1988 Part 10, 4.2.2.2.

Basis for Deferral: The system design does not provide a means of verifying valve closure upon flow reversal. Testing during power operation is impractical for this valve since it is located inside containment, as well as the test connection needed to test it. During cold shutdowns, this testing would involve work inside containment, possibly with high radiation levels.

Test Alternative & Frequency: Valve will be verified closed by leak test performed in accordance with 10CFR50 Appendix J at refueling outage frequency.

Revised by Rev. 17.

10/16/95

Supplemental Test Program

The 10CFR50, Appendix B Program (Supplemental Test Program) includes components which have been determined to be important to safety and judged to be prudent to test, but which are not explicitly under the scope of ASME Codes and Standards. Changes to test methods, frequency and acceptance criteria, as well as additions to or deletions from the program do not require Justification of Deferrals, Relief Requests, or other forms of NRC notification. However, such changes should be approved by the IST program administrator, and documented in the IST Correspondence File.

The following items are currently being planned for addition to this program:

- 1) Full-flow vibrations will be recorded during each refueling outage for the ND and NI Pumps (Reference Pump Relief Requests 1.4.4 and 1.4.5, Memorandum to IST Correspondence File dated September 18, 1995).
- 2) Leak-rate testing of the Hydrogen Analyzer/Post Accident Gas Sample loops will be performed during each refueling outage (Reference PIP 1-M95-1622).
- 3) During refueling outages 1(2)EOC10, gross leakage will be monitored past the ND to Auxiliary Spray boundary valves (Reference PIP 0-M95-643).
- 4) A gross diversion leak test of 1(2)NV-164 (hydrogen inlet to the VCT) will be performed (frequency to be determined).

Added by Rev. 22 (Unit 1), Rev. 17 (Unit 2).

10/16/95

Section III
1 of 1