

**Florida  
Power**  
CORPORATION

July 25, 1984  
3F0784-18

Mr. H. R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Subject: Crystal River Unit 3  
Docket No. 50-302  
Operating License No. DPR-72  
Technical Specification Change Request No. 121

Dear Sir:

Enclosed are three (3) originals and forty (40) copies of Technical Specification Change Request No. 121 requesting amendment to Appendix A of Operating License No. DPR-72. As part of this request, proposed replacement pages for Appendix A are enclosed.

This submittal requests a revision to the auxiliary building ventilation system specification that moves a footnote allowing total system inoperability for up to 12 hours to the action statements. Specifically, this amendment would allow system inoperability for 12 hours to perform repairs and maintenance in addition to surveillance testing as is currently allowed.

An amendment application fee of one hundred fifty dollars (\$150), as required by 10 CFR 170, has been included with this Change Request.

Sincerely,

G. R. Westafer  
Manager, Nuclear Operations Licensing and Fuel Management

PGH/feb 8407310339 840725  
PDR ADOCK 05000302  
P PDR


Enclosures

cc: Mr. J. P. O'Reilly  
Regional Administrator, Region II  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
101 Marietta Street N.W., Suite 2900  
Atlanta, GA 30323


*Acc 1 w/ check \$150  
# 669663*

STATE OF FLORIDA  
COUNTY OF PINELLAS

G.R. Westafer states that he is the Manager, Nuclear Operations Licensing and Fuel Management for Florida Power Corporation; that he is authorized on the part of said company to sign and file with the Nuclear Regulatory Commission the information attached hereto; and that all such statements made and matters set forth therein are true and correct to the best of his knowledge, information, and belief.

  
\_\_\_\_\_  
G.R. Westafer  
Manager, Nuclear Operations Licensing and Fuel  
Management


Subscribed and sworn to before me, a Notary Public in and for the State and County above named, this 25th day of July, 1984.

  
\_\_\_\_\_  
Notary Public

Notary Public, State of Florida at Large,  
My Commission Expires: November 19, 1986


STATE OF FLORIDA  
COUNTY OF PINELLAS

G.R. Westafer states that he is the Manager, Nuclear Operations Licensing and Fuel Management for Florida Power Corporation; that he is authorized on the part of said company to sign and file with the Nuclear Regulatory Commission the information attached hereto; and that all such statements made and matters set forth therein are true and correct to the best of his knowledge, information, and belief.



\_\_\_\_\_  
G.R. Westafer  
Manager, Nuclear Operations Licensing and Fuel  
Management

Subscribed and sworn to before me, a Notary Public in and for the State and County above named, this 25th day of July, 1984.



\_\_\_\_\_  
Notary Public

Notary Public, State of Florida at Large,  
My Commission Expires: November 19, 1986

## NO SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION

**Docket No.:** 50-302

**Facility:** Crystal River Unit 3

**Licensee:** Florida Power Corporation

**Date of Application:** July 25, 1984

**Request:**

This submittal requests a revision to the auxiliary building ventilation system specification that moves a footnote allowing total system inoperability for up to 12 hours to the action statements.

**Significant Hazards Consideration Determination:**

- Amendment involves no significant hazards considerations.
- Amendment involves significant hazards considerations.

**Basis for Determination:**

This change may result in some increase in the consequences of a previously analyzed accident, but the results are within the acceptance criteria of SRP Section 9.4.3. Additionally, consequences of previously analyzed accidents are well within 10 CFR 100 guidelines.

**Requested Implementation Date:**

Florida Power requests an implementation date of October 1, 1984.