

MPR ASSOCIATES, INC.

OYSTER CREEK
NUCLEAR GENERATING STATION

SEISMIC REANALYSIS OF MAIN STEAM
AND FEEDWATER PIPING SUPPORTS
INSIDE CONTAINMENT

MPR-802, Rev. 1

Prepared for:

GPU Nuclear
Parsippany, New Jersey

September 1984

MPR ASSOCIATES, INC.

TABLE OF CONTENTS

1. INTRODUCTION

1.1 PURPOSE

1.2 SCOPE

2. SUMMARY

3. DETAIL EVALUATIONS

3.1 DESCRIPTION

3.2 REFERENCE DRAWINGS

3.3 APPLICABLE CODE

3.4 MATERIALS

3.5 LOADS

3.6 ACCEPTANCE CRITERIA

3.7 SPECIFIC EVALUATIONS

4. REFERENCES

5. APPENDICES

A. Seismic Support Loads

B. ASME Code, Section III, Division 1, Subsection NF
Allowable Level D Stresses

C. Main Steam Seismic Supports

D. Feedwater Seismic Supports

E. Main Steam and Feedwater Snubber Evaluation

1. INTRODUCTION

1.1 PURPOSE

This report presents the results of a seismic reanalysis of Oyster Creek main steam and feedwater piping supports inside containment. The reanalysis of the piping supports was performed in response to Section 4.11(1) of NUREG-0822 (Integrated Plant Safety Assessment - Systematic Evaluation Program - Oyster Creek Nuclear Generating Station) which requested in part that licensee (GPU Nuclear/JCP&L) verify the design adequacy of piping supports for the two large diameter piping systems analyzed by the NRC (i.e., the main steam and feedwater lines).

In this report, the seismic reanalysis of main steam and feedwater piping supports inside containment was performed in accordance with the requirements of the 1980 Edition (including Winter 1982 Addenda) of the ASME Code, Section III, Division 1, Subsection NF for Component Supports. Showing that the piping supports meet the applicable requirements of the 1980 Edition (including Winter 1982 Addenda) of the ASME Code is considered confirmation of the adequacy of the original piping support design.

1.2 SCOPE

The main steam and feedwater lines were initially analyzed by the NRC through their contractor EG&G Idaho, Inc. The results of these analyses are presented in EG&G Report EGG-EA-5211, "Summary of the Oyster Creek Unit 1 Piping

"Calculations Performed for the Systematic Evaluation Program" (Reference a). The South piping loops of the main steam and feedwater systems were chosen by EG&G for analysis. This report presents the results of analyses of the piping supports on the South piping loops. Loads for these analyses were generated using the EG&G finite element piping models of the main steam and feedwater lines. The EG&G models were modified slightly to explicitly model the drywell penetration support and the snubber supports. The load paths of the piping supports were analyzed to the point where the loads are transmitted to main structural members of the containment or the biological shield. The analyses are applicable to the piping supports on the North loops of each piping system, which are mirror images of the South loops.

2. SUMMARY

The main steam and feedwater piping dynamic supports inside containment were evaluated for the safe shutdown earthquake (SSE) seismic loads. Allowable stresses were based on Level D Service Limits in accordance with Subsection NF of Section III of the ASME Code.

Dynamic loads on the main steam and feedwater piping seismic supports are tabulated in Tables 2-1 and 2-2, respectively, along with the Level D allowable load for the snubbers. As shown in Tables 2-1 and 2-2, all dynamic loads are below the Level D allowable load for the snubbers. Results of detail evaluations of the structural components of the main steam and feedwater piping supports are summarized in Tables 2-3 and 2-4, respectively. As shown in Tables 2-3 and 2-4, all main steam and feedwater piping supports are judged to be acceptable for seismic loading conditions, (i.e., calculated stresses are below ASME Code allowables for Level D Service Limits).

TABLE 2-1

SUMMARY OF SNUBBER LOADS
MAIN STEAM PIPING SUPPORTS

SUPPORT MARK NO.	FINITE ELEMENT MODEL NODE NO.	SNUBBER LOAD (kips) (Note 1)	ALLOWABLE LEVEL D SNUBBER LOAD (kips) (Note 2)
X-2A-SS-1	620 (Note 3)	3.44	24.2
	625 (Note 4)	1.20	22.9
MS-R1A	50	5.17	24.1
MS-R2A	195	12.33	21.7
MS-R3A	70	7.71	24.1
MS-R4A	285	9.95	23.6
MS-R5A	510	8.33	24.1

NOTES:

1. Loads taken from Appendix E.
2. Allowable Level D snubber load is the minimum of the buckling load of the extension pipe or turnbuckle. See Appendix E.
3. Vertical Snubber.
4. Inclined Snubber.

TABLE 2-2
SUMMARY OF SNUBBER LOADS
FEEDWATER PIPING SUPPORTS

SUPPORT MARK NO.	FINITE ELEMENT MODEL NODE NO.	SNUBBER LOAD (kips) (Note 1)	ALLOWABLE LEVEL D SNUBBER LOAD (kips) (Note 2)
X-4B-SS-1	345 (Note 3)	1.34	14.0
	350 (Note 4)	2.34	23.6
RF-R1A	160	1.30	24.2
RF-R2A	180	1.60	24.1
RF-R3A	180	2.20	24.5
RF-R4A	140	4.19	24.3
RF-R5A	115	4.72	23.3
RF-R6A	115	2.84	24.5

NOTES:

1. Loads taken from Appendix E.
2. Allowable Level D snubber load is the minimum of the buckling load of the extension pipe or turnbuckle. See Appendix E.
3. Inclined Snubber.
4. Vertical Snubber.

TABLE 2-3
SUMMARY OF EVALUATIONS
MAIN STEAM PIPING SUPPORTS

SUPPORT MARK NO.	BERGEN-PATERSON DRAWING NO.	ASME CODE SUBSECTION NF RESULTS
X-2A-SS-1	111	Acceptable
MS-R1A	716A	Acceptable
MS-R2A	717A	Acceptable
MS-R3A	718A	Acceptable
MS-R4A	719A	Acceptable
MS-R5A	720A	Acceptable

TABLE 2-4
SUMMARY OF EVALUATIONS
FEEDWATER PIPING SUPPORTS

SUPPORT MARK NO.	BERGEN-PATERSON DRAWING NO.	ASME CODE SUBSECTION NF RESULTS
X-4B-SS-1	116	Acceptable
RF-R1A	1849	Acceptable
RF-R2A	1850	Acceptable
RF-R3A	1851	Acceptable
RF-R4A	1852	Acceptable
RF-R5A	1853	Acceptable
RF-R6A	1854	Acceptable

3. DETAIL EVALUATIONS

3.1 DESCRIPTION

The piping supports analyzed in this report are shown in Figures 3-1 and 3-2 for the main steam and feedwater pipes, respectively. The main steam piping supports consist of six support locations utilizing seven snubbers. The feedwater piping supports consist of seven support locations utilizing eight snubbers. Analyses were performed for the piping supports on the South loop of each piping system. The analyses are applicable to the piping supports on the North loop of each piping system, which are a mirror image of the South loop.

3.2 REFERENCE DRAWINGS

The main steam and feedwater piping supports are shown on the following drawings.

<u>Company</u>	<u>Drawing No.</u>	<u>Rev.</u>	<u>Description</u>
General Physics	19442 Sh. 2	2	Main Steam Piping
	19443 Sh. 2	2	Feedwater Piping
Bergen-Paterson	716A	2	Support MS-R1A
	717A	1	Support MS-R2A
	718A	3	Support MS-R3A
	719A	3	Support MS-R4A
	720A	2	Support MS-R5A
	111	1	Support X-2A-SS-1
	1849	2	Support RF-R1A
	1850	2	Support RF-R2A
	1851	1	Support RF-R3A
	1852	2	Support RF-R4A
	1853	4	Support RF-R5A
	1854	1	Support RF-R6A
	116	1	Support X-4B-SS-1

<u>Company</u>	<u>Drawing No.</u>	<u>Rev.</u>	<u>Description</u>
Bergen-Paterson	64101	5	EA1 - Attachment
	64108	6	EA2 - Attachment
	E602	0	Supplementary Hanger Supporting Steel
Burns & Roe	4069	4	Reactor Building Radial Beam Framing

3.3 APPLICABLE CODE

The main steam and feedwater piping supports were evaluated in accordance with the 1980 Edition (including Winter 1982 Addenda) of the ASME Code, Section III, Division 1, Sub-section NF for Component Supports.

3.4 MATERIALS

All structural steel was assumed to have the material properties of SA-36 carbon steel:

Yield strength - 36 ksi (min.)
 Ultimate strength - 58 ksi (min.)

3.5 LOADS

The loads used in the analyses of the main steam and feedwater piping supports were generated using the finite element models in EG&G Report EGG-EA-5211, "Summary of the Oyster Creek Unit 1 Piping Calculations Performed for the Systematic Evaluation Program," dated July 1980 (Reference a). A review of the original EG&G analysis indicated the following:

- The drywell penetrations were not modeled as support locations, and
- Main steam support X-2A-SS-1 and feedwater support X-4B-SS-1 were not modeled explicitly.

The finite element models were reconstructed and modified to account for the support at the drywell penetrations and explicitly model the main steam and feedwater supports. The drywell penetrations were modeled as vertical and horizontal (transverse) supports. No horizontal (axial) support for the pipe is provided by the drywell penetration design. Main steam support X-2A-SS-1 and feedwater support X-4B-SS-1 are truss supports. These supports were modeled explicitly by using additional piping elements to represent the truss arrangement. New loads were then generated. Results of these analyses are contained in Appendix A. The loads consist of safe shutdown earthquake (SSE) seismic loads for both the main steam and feedwater systems with additional relief and safety valve discharge (RV and SV) loads for the main steam system. No deadweight or thermal loads are considered in the seismic analysis of the piping supports.

The piping analyses documented in Reference a were performed using seismic response spectra generated by Lawrence Livermore Laboratories in revised Appendix B of NUREG/CR-1981, "Seismic Review of the Oyster Creek Nuclear Power Plant as Part of the Systematic Evaluation Program," dated April, 1981 (Reference b). A damping value of 3% was used. Piping models were developed for the main steam and feedwater South loop piping inside containment. The North loop piping inside containment are mirror images of the South loop piping and therefore were not analyzed. The same analysis methods were used in the generation of the new loads mentioned above.

The piping support loads calculated using the finite element models of Reference a were then multiplied by $0.165/0.220 = 0.75$ to adjust for the site specific zero period acceleration (ZPA) of 0.165 g's for the Oyster Creek site versus the ZPA

at the ground of 0.22 g's used in References a and b. Calculations of the revised piping support loads are also given in Appendix A.

3.6 ACCEPTANCE CRITERIA

The stresses in the piping supports due to SSE seismic loading conditions were evaluated to the requirements of Level D Service Limits of the ASME Code, Section III, Division 1, Subsection NF. The allowable Level D stress limits are calculated in Appendix B and summarized below.

3.6.1 Tension (Net Area)

$$f_t \leq F_t \\ \text{where } F_t = 40.6 \text{ ksi}$$

3.6.2 Tension (Net Area at Pin Holes)

$$f_t \leq F_t \\ \text{where } F_t = 32.4 \text{ ksi}$$

3.6.3 Shear

$$f_v \leq F_v \\ \text{where } F_v = 24.4 \text{ ksi}$$

3.6.4 Shear (Coped Beam)

$$f_v \leq F_v \\ \text{where } F_v = 21.6 \text{ ksi}$$

3.6.5 Bending

$$f_b \leq F_b \\ \text{where } F_b = 40.6 \text{ ksi}$$

3.6.6 Compression

Limited to 2/3 Critical Buckling

$$f_a \leq F_a$$

where:

$$\text{For } Kl/r \leq C_c, F_a = 2/3 \left(1 - \left(\frac{Kl}{r}\right)^2 / 2 C_c^2\right) S_y$$

$$\text{For } Kl/r > C_c, F_a = 2/3 (\pi^2 E / (Kl/r)^2)$$

3.6.7 Axial Compression and Bending

$$\frac{f_a}{F_a} + \frac{f_b}{F_b} \leq 1.0$$

Note: Due to the geometry of the supports, equation (20) of Article NF-3322.1(e) is not used, and equations (21) and (22) reduce to the above interaction equation for Level D Service Limits.

3.6.8 Axial Tension and Bending

$$\frac{f_t}{F_t} + \frac{f_b}{F_b} \leq 1.0$$

Note: Because the reaction loads can act in both directions, the compressive interaction equation will always be controlling in this analysis.

3.6.9 Weld Shear

$$f_v \leq F_v$$

where $F_v = 24.4 \text{ ksi}$

3.6.10 Nomenclature

c_c = slenderness ratio of compression elements

$$= \frac{\sqrt{}}{2\pi^2 E/S_y}$$

E = modulus of elasticity

= 29.2×10^3 ksi @ 135°F.

f_a = allowable stress in axial compression, ksi.

f_b = allowable stress in bending, ksi.

f_t = allowable stress in tension, ksi.

f_v = allowable stress in shear, ksi.

K = effective length factor.

f_y = yield strength, ksi.

f_a = calculated axial compression stress, ksi.

f_b = calculated bending stress, ksi.

f_t = calculated tensile stress, ksi.

f_v = calculated shear stress, ksi.

l = actual unbraced length of member, in.

r = governing radius of gyration, in.

3.7 SPECIFIC EVALUATIONS

The detail calculations for the main steam and feedwater piping supports are given in Appendices C, D, and E of this report. A summary of the calculations is given in Tables 2-1 through 2-4 and discussed below.

3.7.1 Main Steam Piping Supports

Based on the calculations given in Appendices C and E, all structural components of the main steam system piping seismic supports are considered acceptable.

3.7.2 Feedwater Seismic Supports

Based on the calculations given in Appendices D and E, all structural components of the feedwater system piping seismic supports are considered acceptable.





FIGURE 3-1



LOCATION OF FEEDWATER SEISMIC SUPPORTS

FIGURE 3-2

4. REFERENCES

- a. M. E. Nitzel, "Summary of the Oyster Creek Unit 1 Piping Calculations Performed for the Systematic Evaluation Program," EGG-EA-5211, EG&G Idaho, Inc., July 1980.
- b. NUREG/CR-1981, "Seismic Review of the Oyster Creek Nuclear Power Plant as Part of the Systematic Evaluation Program," April 1981.

MPR ASSOCIATES, INC.

5. APPENDICES

- A. Seismic Support Loads
- B. ASME Code, Section III, Division 1, Subsection NF
Allowable Level D Stresses
- C. Main Steam Seismic Supports
- D. Feedwater Seismic Supports
- E. Main Steam and Feedwater Snubber Evaluation

APPENDIX A

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Seismic Support Loads. Calculated by: M. Kennedy Date: 8/1/84
Checked by: B. J. Infeld Date: 8/9/84
Reviewed by: J. H. Miller Date: 8-22-84

Project: SEP Piping Supports
83-03

Page 1 of 23

Purpose The purpose of the following calculation is to determine the seismic support loads for the main steam and feedwater piping at Oyster Creek.

Background This piping was originally analyzed by EG & G Idaho in "Summary of the Oyster Creek Unit 1 Piping Calculations performed for the Systematic Evaluation Program," EGG-EA-5211, dated July, 1980. A review of this report indicates that:

- a) the drywell penetration was not considered a seismic support location,
- b) certain snubber supports were not explicitly modeled, and
- c) the response spectra was not Oyster Creek specific.

As a result, new seismic support loads were generated using the EG & G piping models, loads, and spectra with minor modifications to correct for the above items.

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Seismic Support Loads Calculated by: m Kennedy Date: 8/1/84
Checked by: B. J. Pfeifer Date: 8/9/84
Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 2 of 23

References

- (1) "Summary of the Oyster Creek Unit 1
Piping Calculations performed for the
Systematic Evaluation Program," EGG-FA-5211,
July 1980.
- (2) General Physics Corporation Dwg.
TCP-19442, Sheet 2, TCP-19443, Sheet 2.
- (3) NUREG / CR-1981, "Seismic Review of the
Oyster Creek Nuclear Power Plant as Part
of the Systematic Evaluation Program,
Revised Appendix B, (Revised Appendix B
forwarded to MPR (W. Schmidt) by LLNL
(T. Nelson) in letter dated June 23, 1981.
- (4) USNRC Letter LS05-81-06-068 dated 6/17/81

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Seismic Support Loads Calculated by: M Kennedy Date: 8/1/84
Checked by: S Hagedorn Date: 8/9/84
Reviewed by: J P Date: 8/22/84

Project: 83-83Page 3 of 23

Description A summary of changes made to EG&G finite element piping models are given in Table 1. Plots of the EG &G Main Steam model are given in figures 1-6. Plots of the MPR modifications are given in figures 7-8. Plots of the EG &G Feedwater model are given in figures 9-11. Plots of the MPR modifications are given in figures 12-13. Tables 2 AND 3 summarize the Dynamic Support Loads calculated for main steam AND feedwater piping using the finite element code.

The analyses which developed the loads in Ref (1) AND in Tables 2 AND 3 used a seismic response spectra (Ref. 3) with a ZPA of .22g's.

The currently accepted ZPA is 0.165 g's. The resulting SSE LOADS are reduced by $\frac{0.165}{0.22}$ or

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Seismic Support Loads Calculated by: mJ Kennedy Date: 8/1/84
 Checked by: B.L. Ferguson Date: 8/9/84
 Reviewed by: JF Date: 8/22/84

Project: 83-03

Page 4 of 23

0.75 Ref (4). Tables 4 and 5 show the calculated
main steam and feedwater support loads revised
using the 0.75 reductions. These loads are
the loads used in the analyses in Appendices
C, D and E.

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Seismic Support Loads Calculated by: Jeffrey Date: 8/1/84
 Checked by: B.L. Pugh Date: 8/9/84
 Reviewed by: JJ Date: 8-22-84

Project: 83-63

Page 5 of 23

TABLE I E&G Finite Element Models
Main Steam AND feedwater Piping

Summary of MPR Review & Changes

TYPE of Review	Conclusion	Modification to Model for New Seismic LOAD Generation
Geometry	Geometry used in model is Acceptable	No changes
Hanger Supports	Locations of supports acceptable. Preloads not checked by MPR. (Assured Acceptable - not within scope of this analysis)	No changes
seismic supports (snubbers)	Locations AND directions of seismic supports checked. All found Acceptable except MAIN STEAM support X-2A-SS-1 AND feedwater support X-4B-SS-1.	Supports X-2A-SS-1 AND X-4B-SS-1 were explicitly modeled in order to obtain correct snubber loads. ¹

Notes:

1. See attachments 1 + 2 for the detailed documentation of this modification.

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Seismic Support Loads Calculated by: M Kennedy Date: 8/1/84
 Checked by: B Gipfert Date: 8/9/84
 Reviewed by: JL Date: 8-22-84

Project: 83-03

Page 6 of 23

Table 1 (cont.)

TYPE of Review	Conclusion	modification to Model for New Seismic LOAD generation
Anchors AND Penetrations	Locations of Anchors Acceptable. No modeling of the drywell penetrations as supports.	The drywell penetration does not support the pipe along its longitudinal axis but provides support in the vertical AND horizontal (transverse) direction. This support was included in the models. ²
Response Spectra Loading AND SV & RV LOADS	Response spectra checked Not site specific to Oyster Creek SV & RV LOADS not checked. (Assumed acceptable - NOT within scope of this analysis)	Ratio Seismic LOADS By 0.65/0.22 for reduction to oyster creek specific loading (Note 3)

Notes:

- 2. See Attachment 3 for the detailed documentation of this modification.
- 3. See Reference 4.

O.C. SEP - MAIN STEM 3, HEADER - NEW
NUPIPE MATHEMATICAL MODEL (V 1.6)

Figure 1. ECG & G Piping Model
of Main Stem Piping

LEGENDA

- ' - MOVE LOCATION
- - HIPOINT LOCATION
- SPRING NUMBER
- SPANNER
- KELCO SUPPORT
- FLOOR
- X - ELASTIC JOINT
- FLEXIBLE ANCHOR
- VALVE

Z Kennedy 8/1/84
B Jefferet 8/9/84

P.T of 23

ROTATION ABOUT Y-AXIS = -60 DEG.
X-Z PLANE TILT = 45 DEG.





FIGURE 1. FRAME NO. 1.00 8V/07/18.

Figure 2 EG&G Piping Model
of Main Steam Piping
(See P. A-1 of Reference (1))

LEGEND

- NODE LOCATION
- - MASSPOINT LOCATION
- SPRUNG MEMBER
- SHAKER
- ELASTIC SUPPORT
- ANCHOR
- ELASTIC JOINT
- FLEXIBLE MEMBER
- VALVE



O.C. SEP - HULL STEAM 3, HEADER - NEW
PIPE MATHEMATICAL MODEL (V 1.6)

PIPE LEGEND

- / - PIPE LOCATION
- o - PUMP/VALVE LOCATION
- ~~~~ - SPRING HANGER
- - SUPPORT
- ↔ - RIGID SUPPORT
- - ANCHOR
- x - CLASSIC JOINT
- - FLEXIBLE JOINT
- - VALVE

mckenna 8/1/84
B Joppon 8/9/84 P. 9 of 23





Figure 3. Detail of
CC & C Piping
Model (See P.A.2
of Reference (1))



O.C. SEP - HUIN STEEN S, HEADER - NEW
NUPIPE MATHEMATICAL MODEL (V 1.6)

NOVEMBER


- | | |
|-----------------|-------------------------|
| - INDE LOCATION | - INDEPARTMENT LOCATION |
| ① | - SPANNING MEMBER |
| →VVV | - MEMBER |
| — | - FLOOR SUPPORT |
| — | - ANCHOR |
| — | - GLASS JOINT |
| — | - FLEXIBLE FIXER |
| — | - VALVE |

McKenney 8/1/84
B. T. F. 8/9/84

P. 10 of 23

Detailed description of the EGR piping model (see p. A-3 of Reference (1))

Figure 4. Detail of



X-2 P-1936 III
FORTRESS BOMB Y-405

卷二 1.00

LEGEND

- / - NODE LOCATION
- o - HIGHLIGHT LOCATION
- - SPRING MEMBER
- - SNUBBER
- - RIGID SUPPORT
- - ROD
- X - PLATE JOINT
- - FLUIDIC MEMBER
- - VALVE


Figure 5 Detail of Snubber Location
Main Steam - E/G & G model

mfKennedy
B Jipner 8/1/84
8/9/84

P. 11 of 23

ROTATION ABOUT Y-AXIS = 0 DEG.
X-Z PLANE TILT = 0 DEG.

Snubbers



D.C. SEP - MAIN STEM 3, HENDER - NEW
NUPIPE MATHEMATICAL MODEL (V 1.6)

LEGEND


- / - Hinge Location
- - Restraint Location
- ~~~~ - Spring Member
- - Sparger
- - Axial Support
- - Flange
- - Ductile Joint
- - Flexible Anchor
- - Valve

Figure 6 Detail of Snubber Locations
Main Steam - EG & G Model

mf Kennedy 8/1/84
B Jaffray 8/9/84

P. 12 of 23

ROTATION ABOUT Y-AXIS = 90 DEG.
X-Z PLANE TILT = 0 DEG.



..... FRAME NO. 1.00 84/07/16.

O.C. SEP - MAIN STEAM SIDE, REAR
TYPE MATHEMATICAL MODEL (V 1.6)

THE LEGEND


- | | |
|---|------------------|
| - | HOME LOCATION |
| ④ | NEAREST LOCATION |
| → | SPLINE MARCH |
| ↔ | JACOBI |
| ↔ | KILO SUPPORT |
| — | ANCHOR |
| — | GLASS JOINT |
| — | FLASHING |
| — | VALVE |

Kennedy 81.184
C. Lipofsky 8/8/34

P. 3 27 23

RETRIEVE RETRIEVE RETRIEVE RETRIEVE
X-T-PIPERETRIEVE X-T-PIPERETRIEVE X-T-PIPERETRIEVE X-T-PIPERETRIEVE
= 0.059. = 0.059. = 0.059. = 0.059.


Figure 7. Detail of Subber
Location - Main Stream
-MLR model



O.C. SEP - MAIN STREAM SOUTH SIDE, REANAL
NUPIPE MATHEMATICAL MODEL (V 1.6)



Figure 8 Detail of Snubber
Location - Main Stream
- MPR Model



Submitted 8/1/84 P.14 of 23
B. Jaffee 8/7/84

111111 FRAME no. 1-00 04/07/18.

O.C. STEP - FEEDWATER 5, SIDE - NEW
NUPIPE MATHEMATICAL MODEL (IV 1.6)

Figure 9. EG&G Piping Model
of Feedwater Piping

LEGEND:

- NODE LOCATION
- - HINGEPOINT LOCATION
- SPRING MANGER
- SNUBBER
- RIGID SUPPORT
- ANCHOR
- × - DRASTIC JOINT
- FLEXIBLE ANCHOR
- VALVE




FIGURE: FRAME NO. 1.00 BY 07/19.


O.C. SEP - FEEDWATER S. SIDE - NEW
NUPIPE MATHEMATICAL MODEL (V 1.6)

LEGEND

- HOLE LOCATION
- - MASSPOINT LOCATION
- STRUT MBRACE
- - MEMBER
- RIGID SUPPORT
- JOINT
- ELASTIC JOINT
- FLEXIBLE MEMBER
- VALVE


Figure 10. Detail of Scrubber
Location - Feedwater
EG&G model

McKenney 8/1/94
S. Jippard 8/9/94 P. 16 OF 23



ROTATION ABOUT Y-AXIS = 0 DEG.
X-Z PLANE = 0 DEG.

*****: FRAME NO. 1.00 BY 07/19.




McCarthy 8/1/84
B. Jaffray 8/7/84

Page 17 of 23

REAL ESTATE INVESTMENT

- | | |
|--------------------|--------------------|
| - HIGHEST LOCATION | - HIGHEST LOCATION |
| 0 - | 0 - |
| W - | W - |
| W - | W - |
| H - | H - |
| → - | → - |
| ↔ - | ↔ - |
| ↔ - | ↔ - |
| * | * |
| ↔ - | ↔ - |
| - | - |

Detail of Snubber
Location - Feedwater
EG&G model



O.C. SEP - FEEDWATER SOUTH SIDE, REANALY
NUPIPE MATHEMATICAL MODEL (V 1.6)


MAGAZINE

McKenney 8/1/84
B. Joplin 8/9/84

P. 18 of 23

KAPPE P&P 1.60 04/07/19.

Figure 12. Detail of Swabber Location - Feedwater MPR Model




O.C. SEP - FEEDWATER SOUTH SIDE, REANALY
NUPIPE MATHEMATICAL MODEL (V 1.6)

LEGENDA

- / - PIPE LOCATION
- ◎ - PASSING LOCATION
- - SPANNING MEMBER
- - RIGID SUPPORT
- - NUMBER
- - ANCHOR
- X - PLANT JOINT
- - FLEXIBLE MEMBER
- - VALVE

Figure 13. Detail of Scrubber
Location - feedwater
MPR model



MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Seismic Support Loads Calculated by: J. J. Kennedy Date: 8/1/84
 Checked by: B. L. Pfeifer Date: 8/7/84
 Reviewed by: TJ Date: 8-22-84

Project: 83-03

Page 20 of 23

TABLE 2 Support LOAD Summary - MAIN STREAM
Piping Model - Dynamic LOADS Only
MPR Model ¹

NODE	DIRECTION	SSE (KIPS)	RV & SU (KIPS)	SSE plus RV&SV* (KIPS)
50	Z	4.69	-1.65	6.34
70	X	9.56	-0.54	10.10
195	Y	4.33	-9.08	13.41
285	INCL	12.73	-0.40	13.13
510	INCL	8.06	-2.28	10.34
620	Y	201	-1.93	3.94
625	INCL	1.46	0.10	1.56
570	Y	6.89	-5.76	12.65
570	X	3.29	1.04	4.33

* Absolute Sum

1. Taken from computer run BAC4TUT, pgs. 33, 282, 302,
 (see Attachment 4).

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Seismic Support Loads Calculated by: M. Koenig Date: 8/1/84
 Checked by: P. Lippert Date: 8/9/84
 Reviewed by: JJ Date: 8-22-84

Project: 83-03Page 21 of 23

TABLE 3

Support Load Summary - feedwater
Piping Model - Dynamic Loads Only
MPR Model¹

NODE	DIRECTION	SSE (K.PS)
55	Y	3.68
55	X	3.85
350	Y	3.12
345	INCL	1.78
115	Y	3.78
115	INCL	6.26
140	INCL	5.54
160	Z	2.96
180	X	2.13
180	Y	1.73

¹ Taken from Computer Run BBCYTVF, p. 189,
 (See Attachment 4).

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Seismic Support Loads Calculated by: jkf Date: 7/1/84
 Checked by: C. J. Murphy Date: 9/7/84
 Reviewed by: JK Date: 2/2/84

Project: 83-03

Page 22 of 23

Table 4 Main Stem Support Loads for
use in Analyses

HANGER / SUPPORT DWLR / # / NODE	Support LOAD SSE (KIPS)	Support LOAD RV & SV (KIPS)	Revised Support LOAD SSE + RV & SV (Note 1)	Notes
MS-R1A/50	4.69	1.65	5.17	
MS-R2A/195	4.33	9.08	12.33	
MS-R3A/70	9.56	0.54	7.71	
MS-R4A/285	12.73	0.40	9.95	
MS-R5A/510	8.06	2.28	8.33	
X-2A-SS-1/570 P _I	2.01	1.93	3.44	y direction
P _{II}	1.46	0.10	1.20	Inclined

Notes:

$$1. \text{ Revised } [SSE + RV \& SV]_{LOAD} = .75 * [SSE]_{LOAD} + [RV \& SV]_{LOAD}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Sesmic Support Loads Calculated by: M. Lengyel Date: 2/1/84
 Checked by: B. Sipperly Date: 3/9/84
 Reviewed by: JJ Date: 3-22-84

Project: 83-03

Page 23 of 23

Table 5 Feedwater Support Loads For Use in Analyses

HANGER/ SUPPORT DWG # / NODE	Support LOAD SSE (KIPS)	Revised Support LOAD SSE (KIPS) (Note 1)	Notes
RF-R1A/160	2.96	2.22	
RF-R2A/180	2.13	1.60	X
RF-R3A/160	1.73	1.30	Y
RF-R4A/140	5.54	4.16	
RF-R5A/115	6.26	4.70	L4+
RF-R6A/115	3.78	2.84	Y
X-4B-SS-1	3.12	2.34	Y Direction
	1.78	1.34	Inclined

Notes:

$$1. \text{ Revised } [SSE]_{LOAD} = .75 * [SSE]_{LOAD}$$

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM Support
MODIFICATION

Calculated by: M Kennedy
Checked by: B Jardine
Reviewed by: J Johnson


Date: 7/11/84
Date: 7-18-84
Date: 8-22-84

Project: SEP Piping Supports
Z3-03

Page 1 of 5

Purpose The purpose of the following calculation is to determine the geometry and element constants used in the explicit modeling of support MKN No X-2A-SS-1.

EG&G Model In the EG&G pipe finite element model contained in EG&G report EGG-EA-5211, the pipe was constrained at the location of support X-2A-SS-1 in the following manner:

EG&G PIPE CONSTRAINT

In actuality, the snubbers are mounted to an eccentric pipe which transmits the load.

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Stem Support
Modification

Calculated by: M. Kennedy
Checked by: 187
Reviewed by: JJ

Date: 7/17/84
Date: 7-18-84
Date: 8-22-84


Project: 83-03

Page 2 of 5

Revised Model

Actual Geometry

Ref Bergen-Paterson Dwg 111



MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: Main Steam Support
modification

Calculated by: M. Lavery
Checked by: BJ
Reviewed by: SL

Date: 7/17/84
Date: 7/19/84
Date: 8-22-84

Project: 83-03

Page 3 of 5



MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Steam Support Modification


Calculated by: m Kennedy
Checked by: bj
Reviewed by: JJ

Date: 7-17-84
Date: 7-19-84
Date: 8-22-84

Project: 83-03

Page 4 of 5

Revised pipe constraint




$$a = 4.0"$$

$$b = 7.75"$$

$$c = 12.0"$$

$\left. \begin{array}{l} \\ \\ \end{array} \right\}$ Dimensions Ref: MPR calculation

The elements which run from NODES 550 to 620 AND 620 to 625 have the following pipe properties:



6"Ø sch 40

weight = 19.0 lb/ft
modulus of elasticity = 27.9×10^6 psi *
design pressure = 0.0 psi

Ref: Crane tech. paper No. 410

* USED IN THE ORIGINAL S6&G ANALYSES.

MPR ASSOCIATES, INC.
 1050 Connecticut Ave., NW - Washington, DC 20036

Title: <u>Main Steam Support Modification</u>	Calculated by: <u>M.J. Kennedy</u>	Date: <u>7/17/84</u>
	Checked by: <u>BJ</u>	Date: <u>7-19-84</u>
	Reviewed by: <u>JP</u>	Date: <u>8-22-84</u>

Project: 83-03

Page 5 of 5

Element coordinates

	<u>x (+)</u>	<u>y (+)</u>	<u>z (+)</u>
545	4.814	-58.748	-23.018
550	4.814	-60.784	-23.018
620	3.168	-60.784	-23.018
625	2.835	-60.784	-23.018

Snubber I

using coordinate offsets from node 625

$$\Delta x = \cos 33.6 = -0.833$$

$$\Delta y = \sin 33.6 = -0.553$$

$$\Delta z = 0.0$$

$$K = 2.5 \times 10^3 \text{ lb/in}$$

Snubber II

at node 620 , y direction $K = 2.5 \times 10^5 \text{ lb/in}$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Support
MODIFICATION

Calculated by: M. Kennedy
Checked by: B. Hoffman
Reviewed by: J. Thompson

Date: 7/17/84
Date: 7-19-84
Date: 8-22-84


Project: SEP Piping Supports
83-03

Page 1 of 6

Purpose The purpose of the following calculation is to determine the geometry and element constants used in the explicit modeling of support MARK No. X-4B-55-1

EG & G Model In the EG&G pipe finite element model contained in EG&G report EGG-EA-5211, the pipe was constrained at the location of support X-4B-55-1 in the following manner:

EG & G pipe constraint



In actuality, the snubbers are mounted to an eccentric pipe which transmits the load. There are only two snubbers.

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater support
modification

Calculated by: m Kennedy
Checked by: BG
Reviewed by: JL

Date: 7/17/84
Date: 7-18-84
Date: 8-22-84


Project: 83-03

Page 2 of 6

Revised Model

ACTUAL Geometry

Ref: Bryan-Paterson Dwg 116



MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: Feedwater Support
Modification

Calculated by: Inkennedy
Checked by: BJ
Reviewed by: JJ

Date: 7/17/84
Date: 7-18-84
Date: 8-22-84

Project: 83-03

Page 3 of 6




MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Terminator Support Modification Calculated by: M Kennedy Date: 7/17/84
 Checked by: B.J. Date: 7-19-84
 Reviewed by: JJ Date: 8-22-84

Project: 83-03

Page 4 of 6




$$\alpha = \tan^{-1} \frac{90.09375}{324.125} = 15.53^\circ$$

$$\beta = 28^\circ - \alpha = 28 - 15.53 = 12.47^\circ$$

$$x = \sqrt{(90.09375)^2 + (324.125)^2} = 336.413$$

$$y = x \sin \beta = 336.413 \sin 12.47^\circ = 72.64''$$



MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Seawater Support
Modification


Calculated by: [Signature]
Checked by: [Signature]
Reviewed by: [Signature]

Date: 7/17/84
Date: 7-18-84
Date: 7-22-84

Project: 83-03



Page 5 of 6

Revises pipe constraint



in the plane of the
snubbers

y-z plane




MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Seawater support
mon. friction Calculated by: M. Kennedy Date: 7-17-84
Checked by: B.Y. Date: 7-19-84
Reviewed by: J.J. Date: 8-22-84

Project: 83-03

Page 6 of 6

The elements which run from nodes 65 to 345 and
 345 to 350 have the following pipe properties:



$$\text{OD} = 4.5"$$

$$t = .237"$$

4" SCH 40

$$\text{weight} = 10.79 \text{ lb/ft}$$

$$\text{modulus of elasticity} = 27.9 \times 10^6 \text{ psi}^*$$

$$\text{design pressure} = 0.0 \text{ psi}$$

Ref: Crane Tech Paper No. 410
 * used in the original EGDG Analyses

Element coordinates

	<u>x (+)</u>	<u>y (+)</u>	<u>z (+)</u>
60	0.0	0.0	30.25
65	0.0	2.25	32.5
345	0.0	0.167	32.5
350	0.0	-1.021	32.5

Snubber I

using coordinate offsets from node 345

$$\Delta x = -\cos 53^\circ \cos 28^\circ = -0.531$$

$$\Delta y = -\sin 53^\circ = -0.799$$

$$\Delta z = \cos 53^\circ \sin 28^\circ = 0.283$$

$$K = 2.5 \times 10^5 \text{ lb/in}$$

Snubber II

at node 350, y-direction $K = 2.5 \times 10^5 \text{ lb/in}$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Drywell Penetrations

Calculated by: mj Kennedy

Date: 8/1/84

Checked by: B. J. Johnson

Date: 8/7/84

Reviewed by: H. L. Morrison

Date: 8/22/84

Project: SeP Piping Supports
87-03

Page 1 of 2

Purpose The purpose of the following calculation
is to document the drywell penetration support

Drywell Penetrations In the initial analyses
by EG&G, the drywell penetrations of the
main steam and feedwater piping at Oyster Creek were
not considered to act as supports. The original
models were rerun using NuPIPE II M Version 1.6.1
with radial pipe restraints at the location of
the drywell penetration. These restraints are:

MAIN STEAM

NODE	TRANSLATION (lb/in)			ROTATION (in-lb/rad)		
	X	Y	Z	X	Y	Z
570	1×10^8	1×10^8	0	0	0	0

feedwater

NODE	TRANSLATION (lb/in)			ROTATION (in-lb/rad)		
	X	Y	Z	X	Y	Z
55	1×10^8	1×10^8	0	0	0	0

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Drywell Penetrations

Calculated by: mgk

Date: 8/1/84

Checked by: R. T. J. F.

Date: 8/9/84


Reviewed by: JJ

Date: 8-22-84

Project: 83-03

Page 2 of 3

The following figure illustrates the main steam
and feedwater penetration configurations:



Ref: GE Dwg: 112d2866
Oyster Creek FDSAR Figure V-1-1.

The penetration was assumed to be a rigid support $K = 1 \times 10^8$ lb/in

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: COMPUTER PROGRAM DOCUMENTATION SHEET	Calculated by: _____	Date: _____
	Checked by: _____	Date: _____
	Reviewed by: _____	Date: _____

Project: 83-03	Page 1 of 1
----------------	-------------

PROGRAM: Nupipe IIM	REVISION: 1.6.1
---------------------	-----------------

RUN BANNER: BBCYIUT	DATE: 7/18/84
---------------------	---------------

INPUT PREPARED BY: M. Kennedy	DATE: 7/18/84
-------------------------------	---------------

INPUT CHECKED BY: B. Jifford	DATE: 7/19/84
------------------------------	---------------

OUTPUT REVIEWED BY: T. Johnson	DATE: 7/19/84
--------------------------------	---------------

PROGRAM: Nupipe IIM	REVISION: 1.6.1
---------------------	-----------------

RUN BANNER: BBCYTVF	DATE: 7/18/84
---------------------	---------------

INPUT PREPARED BY: M. Kennedy	DATE: 7/18/84
-------------------------------	---------------

INPUT CHECKED BY: B. Jifford	DATE: 7/19/84
------------------------------	---------------

OUTPUT REVIEWED BY: T. Johnson	DATE: 7/19/84
--------------------------------	---------------

PROGRAM: _____	REVISION: _____
----------------	-----------------

RUN BANNER: _____	DATE: _____
-------------------	-------------

INPUT PREPARED BY: _____	DATE: _____
--------------------------	-------------

INPUT CHECKED BY: _____	DATE: _____
-------------------------	-------------

OUTPUT REVIEWED BY: _____	DATE: _____
---------------------------	-------------

Appendix B

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Section III, Div 1,
Subsection NF Allowable
Level D stresses Calculated by: M Kennedy Date: 12/5/83
Checked by: E Clark Date: 12/27/83
Reviewed by: J Johnson Date: 1-3-84

Project: Piping Supports
83-03

Page 1 of 8

Purpose The purpose of the following calculation
is to document the Allowable Level D stresses for
the main steam and feedwater supports.

Reference

- (1) ASME Boiler AND Pressure Vessel Code, Section III,
Subsection NF - Component Supports, 1980 Edition.
- (2) ASME Boiler AND Pressure Vessel Code, Section III
Appendices, 1980 Edition.
- (3) AISC Steel Construction Manual, 6th Ed.

Approach All structural steel is assumed to
have the material properties of SA-36 carbon
steel

$$\begin{aligned}S_y &= 36.0 \text{ KSI} && \text{yield strength} \\S_u &= 58.0 \text{ KSI} && \text{ultimate strength} \\E &= 29.2 \times 10^3 \text{ KSI} @ 135^\circ\text{F} && \text{modulus of elasticity}\end{aligned}$$

Ref.(2) Table I-7.1
Table I-6.0

Level A Allowables are calculated first to determine
the proper Level D allowable.

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Section III, Div. I,
Subsection NF ALLOWABLE
Level D. Stresses

Calculated by: mgk
Checked by: BDC
Reviewed by: JJ

Date: 12/5/83
Date: 2/27/83
Date: 1-9-84

Project: 83-03

Page 2 of 8

Nomenclature

C_c = slenderness ratio of compression elements
as defined in NF-3322.2

f_a = allowable compressive stress, KSI.

f_b = allowable bending stress, KSI.

f_t = allowable tensile stress, KSI.

f_s = allowable shear stress, KSI.

f_e = Euler stress divided by factor of safety.

K = effective length factor.

s_y = material yield strength

s_u = ultimate strength, KSI.

F_a = computed axial stress, KSI.

F_b = computed bending stress, KSI.

F_t = computed shear stress, KSI.

l = actual unbraced length of member, in.

r = governing radius of gyration, in.

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Section III, D.I. 1 Calculated by: mjk Date: 12/5/83
SubSection NF Allowable Checked by: EJC Date: 12-29-83
Level A stresses Reviewed by: JJ Date: 1-2-84

Project: 83-03Page 3 of 8Level A Allowable StressesTension (Net Area) NF-3322.1 (a) (1)

$$f_t < \frac{0.60 S_y}{0.5 S_u} = 21.6 \text{ KSI}$$

$$0.5 S_u = 29.0 \text{ KSI}$$

$$f_t = 21.6 \text{ KSI}$$

Tension (Net Area w/ Pin Holes) NF-3322.1(a)(2)

$$f_t = 0.45 S_y = 16.2 \text{ KSI}$$

Shear NF-3322.1 (b) (1)

$$f_s = 0.40 S_y = 14.4 \text{ KSI}$$

Shear (coped Beam) NF-3322.1 (b) (2)

$$f_s = 0.30 S_y = 10.8 \text{ KSI}$$

Compression NF-3322.1 (c) (1), (2)

$$C_c = \sqrt{2\pi^2 E / S_y} = 126.5$$

$$\text{IF } \frac{Kl}{r} < C_c \quad f_a = \frac{[1 - (Kl/r)^2 / 2C_c^2] S_y}{5/3 + [3(Kl/r)/8C_c] - [(Kl/r)^3/8C_c^3]}$$

$$\text{IF } \frac{Kl}{r} > C_c \quad f_a = \frac{12\pi^2 E}{23(Kl/r)^2}$$

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Section III Div. I, Calculated by: mjk Date: 12/15/83
Subsection NF, Allowable Checked by: EDC Date: 12/22/83
Level D Stresses Reviewed by: JJ Date: 12/22/83

Project: 83-03Page 4 of 8BENDING NF-3322.1 (d)

$$F_b = 0.60 S_y = 24.0 \text{ KSI}$$

Combined Stresses NF-3322.1 (e)(1) Axial Compression AND Bending

$$(20) \frac{f_a}{F_a} + \frac{c_{mx} f_{bx}}{(1 - \frac{f_a}{F_{ax}}) F_{bx}} + \frac{c_{my} f_{by}}{(1 - \frac{f_a}{F'_{ey}}) F_{by}} \leq 1.0$$

$$(21) \frac{f_a}{0.60 S_y} + \frac{f_{bx}}{F_{bx}} + \frac{f_{by}}{F_{by}} \leq 1.0$$

when $\frac{f_a}{F_a} \leq 0.15$

$$(22) \frac{f_a}{F_a} + \frac{f_{by}}{f_{bx}} \rightarrow \frac{f_{by}}{f_{by}} \leq 1.0$$

$$\text{where } F'_e = \frac{12 \pi^2 E}{23(K l_b / r_b)}$$

(2) Axial Tension AND Bending

Eq (21) Above Applies

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Section III, D.I. 1 Calculated by: mk Date: 12/5/83
Subsentrar NF Checked by: EDC Date: 12-27-83
Alluvial Reviewed by: JL Date: 1-3-84
Level D Stresses

Project: 83-03Page 5 of 8

Linear Support TYPE welds Table - 3324.5(a)-1

allowable shear stress = 21.0 KSI

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Section III Div 1 Calculated by: MJK Date: 12/5/83
Subsection NF Allowable Checked by: EIC Date: 12/27/83
level D stresses Reviewed by: JJ Date: 1-9-84

Project: 83-03

Page 6 of 8

Level D Allowable stresses

Tension (net Area)

$$f_t' = \min \left\{ K_s f_t = 2.0 (21.6) = 43.2 \text{ KSI} \atop 0.7 S_u = 0.7 (58.0) = 40.6 \text{ KSI} \right\} \rightarrow 40.6 \text{ KSI}$$

Tension (net area w/ Pintoles)

$$f_t' = K_s f_t = 2.0 (16.2) = 32.4 \text{ KSI}$$

Shear

$$f_v' = \min \left\{ K_J F_J = 2.0 (14.4) = 28.8 \text{ KSI} \atop 0.42 S_u = 0.42 (58.0) = 24.4 \text{ KSI} \right\} \rightarrow 24.4 \text{ KSI}$$

Shear (caged beam)

$$F_v' = K_J f_J = 2.0 (10.8) = 21.6 \text{ KSI}$$

Compression

2/3 critical Buckling

$$C_c > K_e/r \quad F_a' = \frac{2}{3} \left(1 - \left(\frac{K_e}{r} \right)^2 / 2 C_c^2 \right) S_y$$

$$C_c < K_e/r \quad F_a' = \frac{2}{3} \frac{\pi^2 E}{\left(\frac{K_e}{r} \right)^2}$$

Bending

$$F_b' = \min \left\{ K_s f_b = 2.0 (24.0) = 48.0 \text{ KSI} \atop 0.7 S_u = 0.7 (58.0) = 40.6 \text{ KSI} \right\} \rightarrow 40.6 \text{ KSI}$$

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Section III, Div I
Subsection NF' Allowable
Level D Stressas Calculated by: M/K Date: 12/5/83
Checked by: FAC Date: 12/27/83
Reviewed by: JJ Date: 1-3-84

Project: 83-03

Page 7 of 8

AXIAL COMPRESSION AND BENDING

USE LEVEL D allowables in the denominator of equations (20) (21) and (22). The compression allowable is limited to $2/3$ of the critical buckling stress.

AXIAL TENSION AND BENDING

USE Eq. (21) w/ Level D allowables

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Section III Div. I
 Subsection NF Allowable
 Level D stresses

Calculated by: MJK
 Checked by: EDC
 Reviewed by: JJ

Date: 12/5/83
 Date: 12/27/83
 Date: 1-3-84

Project: 83-03

Page 8 of 8

Linear Support Type weld TABLE NF-3623.2-1

$$\text{allowable shear stress} = \min \left\{ \begin{array}{l} 2.0 (21.0) = 42.0 \text{ KSI} \\ 0.42(S_u) = 0.42(58.0) = 24.4 \text{ KSI} \end{array} \right\}$$

→ 24.4 KSI

Appendix C

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM Seismic Supports

Calculated by: M Kennedy

Date: 8/1/84

Checked by: R Patterson

Date: 8/19/84

Reviewed by: J Johnson

Date: 8-22-84

Project: SEP PIPING SUPPORTS

83-03

Page 1 of 103

PURPOSE: The purpose of the following calculation is to analyze the main steam seismic supports for Level D service conditions.¹ Loads used are from revised EG & G piping model loads documents in Appendix A.

References:

- (1) MPR calculation by M. Kennedy dated 8/2/84
"Seismic Support Loads" - Appendix A.
- (2) Bergen-Patterson Pipe Support Catalog #66
p.46.
- (3) Crane Technical Paper # 10; 1981
- (4) AISC Steel Const. MANUAL, 6th Ed.
- (5) Roark and Young, Formulas for Stress and Strain,
5th Ed.
- (6) Griffen, Handbook of Formulas for Stress and Strain, 2nd Ed.
- (7) AISC Steel Const. MANUAL, 8th Ed

¹ The snubber is analyzed separately in Appendix E. This calculation analyzes clevises, welds and structural members supplied with the snubber.

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS Calculated by: m Kennedy Date: 8/1/84
Checked by: RC Treneth Date: 8/9/84
Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 2 of 103

Reference Drawings

Bergen - Paterson

<u>Support</u>	<u>Dwg #</u>
MS - R1A	716A
MS - R2A	717A
MS - R3A	718A
MS - R4A	719A
MS - R5A	720A
X - 2A-55-1	111

STANDARD Drawings 64101
 64108
 602

Burns & Roe Dwg 4069

General Physics Dwg 19442 Sht. 2 of 4

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Steam Seismic Supports

Calculated by: m/kenny

Date: 8/1/84

Checked by: R.C.Henry

Date: 5/9/84

Reviewed by: J.J.

Date: 6-22-84

Project: 83-03

Page 3 of 103

Summary

Based on the following calculations, all main steam supports meet the stress requirements of the 1980 ASME Code, Section III, Subsection NF. A summary table follows each support calculation.

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Steam Seismic Support


Calculated by: myKenne Date: 8/1/84
Checked by: R.Thomas Date: 8/9/84
Reviewed by: J.T. Date: 8-22-84

Project: _____
_____ 83-03

Page 4 of 103

Support MARK No x-2A-55-1

DESCRIPTION




MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: max Steam Seismic Supports Calculated by: m Kennedy Date: 8/1/84
 Checked by: R Thrush Date: 8/9/84
 Reviewed by: JT Date: 8-22-84

Project: 83-03

Page 5 of 103



$$P_I = 1200 \text{ lb}$$

$$P_{II} = 3440 \text{ lb}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN Steam Seismic Supports Calculated by: M Kennedy Date: 8/1/84
 _____ Checked by: K French Date: 8/9/84
 _____ Reviewed by: JJ Date: 8-22-84

Project: 8303

Page 6 of 103

Item 5 & 6 Clavis Pipe Assembly

C" Sch 40 Pipe

$$I = \frac{\pi}{64} (d_o^4 - d_i^4) = \frac{\pi}{64} (6.625^4 - 6.065^4) = 28.142 \text{ in}^4$$

$$L = 6.625/2 = 3.313 \text{ in}$$

$$A = \frac{\pi}{4} (d_o^2 - d_i^2) = \frac{\pi}{4} (6.625^2 - 6.065^2) = 5.581 \text{ in}^2$$

$$\text{AXIAL LOAD} = 1,298 \text{ lb.}$$

$$\text{TRANSVERSE LOAD} = 4,258 \text{ lb}$$

$$\text{MOMENT LOAD} = 86403 \text{ in-lb.}$$

} Ref. Computer Run BBC4TUT
P. 310 member 550/620

Tension / compression

$$\delta = AL/A = \frac{1298}{5.581} = \underline{233 \text{ PSI}} < 40,600 \text{ PSI}$$

(tension)

$$l \approx 7.75" C_c = 126.5$$

$$r = \sqrt{\frac{d_o^2 + d_i^2}{4}} = \sqrt{\frac{6.625^2 + 6.065^2}{4}} = 2.25"$$

$$K = 2.0; S_y = 36.0 \text{ KSI}$$

} See Section 2
of this
Appendix

$$\sigma_a' = \frac{1}{3} \left(1 - \frac{(Kl)^2}{2C_c^2} \right) S_y$$

$$= \frac{1}{3} \left(1 - \left(\frac{(2.0)(7.75)}{2.25} \right)^2 \right) \frac{1}{2(126.5)^2} 36.0 = 24.0 \text{ KSI}$$

233 PSI < 24000 PSI

MPR ASSOCIATES, INC.
 1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Stem Seismic Supports

Calculated by: mckenna
 Checked by: RCheney
 Reviewed by: JJ

Date: 8/1/84
 Date: 5/9/84
 Date: 8-22-84

Project: 83-03

Page 7 of 103

SHEAR

$$\gamma = T/L_A = 4258 / 5.581 = \underline{763 \text{ PSI}} < 24400 \text{ PSI}$$

BENDING

$$\delta = \frac{MC}{EI} = \frac{86403 (3.313)}{28.142} = 10,172 \text{ psi}$$

$$763 + 10,172 = \underline{10,935 \text{ psi}} < 40,600 \text{ psi}$$

AXIAL COMPRESSION AND BENDING

$$\frac{F_a}{F_a'} + \frac{F_b}{F_b'} \leq 1.0$$

$$\frac{233}{24000} + \frac{10,172}{40600} = 0.26 < 1.0$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS


Calculated by: M.Kangro Date: 8/1/84
Checked by: R.Tripathi Date: 5/9/84
Reviewed by: J.J. Date: 2-22-84

Project: 83-03

Page 8 of 103

Item 5 weld to Main Steam Pipe

Treat weld as line



$$A = \pi d \frac{5}{2} \text{ leg length}$$

$$= \pi (6.625) \frac{5}{2} (.375)$$

$$= 5.519 \text{ in}^2$$

$$Z = \frac{\pi d^2}{4} \frac{5}{2} \text{ leg length}$$

$$= \pi \left(\frac{6.625}{4} \right)^2 \frac{5}{2} (.375)$$

$$= 9.141 \text{ in}^3$$

Tension/compression

$$\gamma_1 = \frac{A\gamma}{A} = 1298 / 5.519 = 235 \text{ PSI}$$

BEND. INC.

$$\gamma_2 = \frac{M/Z}{E} = 86,403 / 9,141 = 9,452 \text{ PSI}$$

SHEAR

$$\gamma_3 = \frac{T_L}{A} = 4,258 / 5.519 = 772 \text{ PSI}$$

$$\gamma_{net} = \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(235 + 9452)^2 + (772)^2}$$

$$= \underline{\underline{9718 \text{ PSI}}} < \underline{\underline{24,400 \text{ PSI}}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: M Kennedy Date: 8/1/84
 Checked by: R Trenth Date: 8/9/84
 Reviewed by: JJ Date: 8-22-84

Project: 83-03

Page 9 of 103

Inclined snubber clevis assemblies (Snubber I)




Assume EA 1-A clevis At end of P.P.E

$$P_I = 1200 \text{ lb}$$

$$\text{AXIAL LOAD} = 1200 \cos 33.6^\circ = 1,000 \text{ lb}$$

$$\text{TRANSVERSE LOAD} = 1200 \sin 33.6^\circ = 664 \text{ lb}$$

6"Ø Sch 40 Pipe Weld to 7.5" x 7.5" x 0.5" Plate



Weld treated as line

$$\begin{aligned} \text{Area} &= \pi d^2 \frac{\sqrt{2}}{2} \text{ leg length} \\ &= \pi (6.625)^2 \frac{\sqrt{2}}{2} (.25) \\ &= 3.679 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} Z &= \frac{\pi d^2}{4} \frac{\sqrt{2}}{2} \text{ leg length} \\ &= \frac{\pi (6.625)^2}{4} \frac{\sqrt{2}}{2} (.25) \\ &= 6.094 \text{ in}^3 \end{aligned}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 3/1/84
 Checked by: R C Tschudi Date: 3/9/84
 Reviewed by: J.T. Date: 1-22-84

Project: 83-03

Page 10 of 103

Tension/compression

$$\gamma_1 = AL/A = 1000 / 3.679 = 272 \text{ psi}$$

BENDING

$$\gamma_2 = M/z = TL \cdot l / z = \frac{664 (3.75)}{6.094} = 409 \text{ psi}$$


SHEAR

$$\gamma_3 = TL/4 = 664 / 3.679 = 180 \text{ psi.}$$

$$\gamma_{\text{net}} = \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(272 + 409)^2 + (180)^2} = 704 \text{ psi}$$

< 24480 psi

Clevis base plate welded to 7.5" x 7.5" x 0.5" Plate



weld treated as line

$$\text{Area} = 4 \times \frac{\sqrt{2}}{2} \text{ leg length} \\ = 4(5.0) \frac{\sqrt{2}}{2} (.25) = 3.536 \text{ in}^2$$

$$z = \left(s^2 + \frac{s^2}{3}\right)^{\frac{\sqrt{2}}{2}} \text{ leg length} \\ = \left(5.0^2 + \frac{5.0^2}{3}\right)^{\frac{\sqrt{2}}{2}} (.25) \\ = 5.893 \text{ in}^2$$

Tension/compression

$$\gamma_1 = AL/A = 1000 / 3.536 = 283 \text{ psi}$$

BENDING

$$\gamma_2 = M/z = TL \cdot l / z = \frac{664 \cdot (3.25)}{5.893} = 366 \text{ psi}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM SEISMIC SUPPORTS

Calculated by: M Kennedy
Checked by: R Chisholm
Reviewed by: J.J.

Date: 8/1/84
Date: 8/9/84
Date: 8/20/84

Project: 83-03

Page 11 of 103


SHEAR

$$\tau_3 = \frac{\tau}{A} = \frac{664}{3.536} = 188 \text{ psi}$$

$$\begin{aligned}\tau_{\text{net}} &= \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(283 + 366)^2 + (188)^2} \\ &= 676 \text{ psi} < 24,400 \text{ psi}\end{aligned}$$

Clevis Plate

BENDING AT BASE



$$I = 2 \frac{bh^3}{12} = 2 \frac{(0.5)(4.0)^3}{12} = 5.333 \text{ in}^4$$

$$c = 2.0 \text{ in}$$

$$A = 2(lw) = 2(0.5 \cdot 4.0) = 4.0 \text{ in}^2$$

$$\delta = \frac{Mc}{I} = \frac{Tl}{I} \frac{l}{c} c = \frac{664 (2.50) 2.0}{5.333} = \underline{\underline{623 \text{ psi}}} \\ < \underline{\underline{40,600 \text{ psi}}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 8/1/84
 Checked by: R Treado Date: 8/1/84
 Reviewed by: JJ Date: 8-22-84

Project: 83-03

Page 12 of 103

Pullout shear

$$\text{Area} = \pi(2rt) = \pi(2(2.0)(0.5)) = 4.0 \text{ in}^2$$

$$P_i = 1200 \text{ lb}$$

$$\sigma = P_i/A = 1200 / 4.0 = \underline{\underline{300 \text{ psi}}} < 24,400 \text{ psi}$$

Bolt hole tension

$$\text{Area} = \pi t (\pi r - \text{hole dia}) = \pi(0.5)(\pi(2.0) - (1 + 1/8)) = 2.938 \text{ in}^2$$

$$\sigma = P_i/A = 1200 / 2.938 = \underline{\underline{408 \text{ psi}}} < 32,400 \text{ psi}$$

Axial compression

$$\text{Area} = \text{min Area} = \pi t (2r) = \pi(0.5)(2(2.0)) = 4.0 \text{ in}^2$$

$$\sigma = A_y/A = 1000 / 4 = 250 \text{ psi}$$

$$l = 2.5", C_c = 126.5$$

$$r = \frac{t}{f_{y2}} = 0.144"$$

$$K = 2.0, S_y = 36 \text{ ksi}$$

see section 2 of
this Appendix

$$F_a = \frac{2}{3} \left(1 - \left(\frac{K}{r} \right)^2 / 2 C_c^2 \right) S_y$$

$$= \frac{2}{3} \left(1 - \left(\frac{2(2.5)}{0.144} \right)^2 / 2 (126.5)^2 \right) 36.0 = 23.1 \text{ ksi}$$

$$\underline{\underline{250 \text{ psi}}} < 23100 \text{ psi}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS Calculated by: n/kennedy Date: 8/1/84
Checked by: R.Churchill Date: 5/9/84
Reviewed by: TT Date: 8-22-8

Project: 83-03


Page 13 of 103

Axial compression + bending

$$\frac{f_a}{f_{a'}} + \frac{f_b}{f_{b'}} \leq 1.0$$

$$\frac{250}{23100} + \frac{623}{40600} = 0.03 < 1.0$$

clevis plate weld to base plate



$$\begin{aligned} \text{Area} &= 2(2L + 2W)^{5/2} \text{ leg length} \\ &= 2(2(4.0) + 2(1.5))^{5/2} (.25) \\ &= 3.182 \text{ in}^2 \end{aligned}$$

$$Z = 2 \left(bd + \frac{d^2}{3} \right)^{5/2} \text{ leg length}$$

$$= 2 (.5(4) + \frac{4^2}{3})^{5/2} (.25)$$

$$= 2.593 \text{ in}^3$$

Tension / compression

$$x_i = \frac{A_L}{A} = \frac{1000}{3,182} = 314 \quad \text{PSI}$$

BENIGN

$$\gamma_r = \frac{T_L \cdot \alpha}{z} = \frac{664 \cdot (2.5)}{2.593} = 640 \text{ PSC}$$

SHEAR

$$\gamma_3 = \frac{TL}{A} = \frac{664}{3.142} = 209 \text{ PSI}$$

$$N_{\text{net}} = \sqrt{(N_1 + N_2)^2 + N_3^2} = \sqrt{(314 + 640)^2 + (209)^2} = 977 \text{ psI}$$

<24,400 psi

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 8/1/84
 Checked by: RCTruncato Date: 2/9/84
 Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 14 of 103


Bolt Shear

$$A_{MA} = 2\pi \frac{d^2}{4} = 2\pi \frac{(1)^2}{4} = 1.571 \text{ in}^2$$

$$\gamma = P_e/A = 1200 / 1.571 = \underline{\underline{764 \text{ PSI}}} < 24,400 \text{ PSI}$$

Item 4 Clevis AND Bolt STANDARD PART EA 1-A
(snubber I)

Bolt stress same as above



$$AL = 664 \text{ lb}$$

$$TL = 1000 \text{ lb}$$

Clevis Plate

BENDING AT BASE

$$I = 5.333 \text{ in}^4, c = 2.0 \text{ in}, A = 4.0 \text{ in}^2$$

(see p. 16 of this calculation)

$$\delta = \frac{mc}{I} = \frac{TL \cdot l \cdot c}{I} = \frac{1000 \cdot (2.5) \cdot (2.0)}{5.333}$$

$$= \underline{\underline{938 \text{ PSI}}} < 40,600 \text{ PSI}$$

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS Calculated by: McKenna Date: 8/1/84
 Checked by: R.C.Jurich J Date: 8/4/84
 Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 15 of 103

Pullout shear & Bolt hole tension are same as
that calculated for snubber I clevis (item 6)

$$\gamma = \frac{300 \text{ PSI}}{24,400 \text{ PSI}} < 1$$

$$\delta = \frac{408 \text{ PSI}}{32,400 \text{ PSI}} < 1$$

AXIAL COMPRESSION

$$A = 4 \text{ in}^2$$

$$\delta = \frac{\Delta \gamma / A}{4} = \frac{664}{4} = \frac{166 \text{ PSI}}{23,100 \text{ PSI}} < 1$$

AXIAL COMPRESSION + BENDING

$$\frac{F_a}{F_a'} + \frac{F_b}{F_b'} \leq 1.0$$

$$\frac{166}{23,100} + \frac{938}{40,600} = \frac{0.03}{0.03} < 1.0$$

CLEVIS PLATE TO BASE PLATE WELD

$$A = 3.182 \text{ in}^2, Z = 2.593 \text{ in}^3$$

TENSION / COMPRESSION

$$\gamma_1 = \Delta \gamma / A = 664 / 3.182 = 209 \text{ PSI}$$

BENDING

$$\gamma_2 = \frac{T_L \cdot L}{Z} = \frac{1000 (2.5)}{2.593} = 964 \text{ PSI}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 8/1/84
 _____ Checked by: R Trujillo Date: 7/9/84
 _____ Reviewed by: JL Date: 8-22-84

Project: 83-03

Page 16 of 103

SHEAR

$$\gamma_3 = T/A = 1000 / 3.182 = 314 \text{ PSI}$$

$$\begin{aligned} \gamma_{\text{net}} &= \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(209 + 964)^2 + (314)^2} \\ &= \underline{\underline{1,214 \text{ PSI} < 24,400 \text{ PSI}}} \end{aligned}$$

BASE PLATE Weld to existing 21 WF I-BEAM

$$A = 3.536 \text{ in}^2 \quad Z = 5.893 \text{ in}^3$$

Tension/compression

$$\gamma_1 = AY_A = 664 / 3.536 = 188 \text{ PSI}$$

BENDING

$$\gamma_2 = M/Z = TL \cdot \delta / Z = \frac{1000 \cdot (3.25)}{5.893} = 552 \text{ psi}$$

SHEAR

$$\gamma_3 = TY_A = \frac{1000}{3.536} = 283 \text{ PSI}$$

$$\begin{aligned} \gamma_{\text{net}} &= \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(188 + 552)^2 + (283)^2} \\ &= \underline{\underline{792 \text{ PSI} < 24,400 \text{ PSI}}} \end{aligned}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS


Calculated by: M. Kennedy
Checked by: P.C. Threlkeld
Reviewed by: JJ

Date: 8/1/84
Date: 3/9/84
Date: 8-22-84

Project: 83-03


Page 17 of 103

Vertical snubber clevis assemblies (Snubber II)



Assume STANDARD
EA 2-A clevis attachment

6"φ S/40 PIPE TO clevis Plate weld



$$\begin{aligned} \text{Area} &= 2(2L + 2W)^{\sqrt{2}/2} \text{ leg length} \\ &= 2(2(6.0) + 2(0.5))^{\sqrt{2}/2} (.25) \\ &= 4.596 \text{ in}^2 \end{aligned}$$

Tension / compression

$$T_{net} = T_c = P_{II}/A = 3440/4.596 = \underline{\underline{748 \text{ PSI}}} < \underline{\underline{24400 \text{ PSI}}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM SEISMIC SUPPORTS

Calculated by: M Kennedy
Checked by: R French
Reviewed by: JJ

Date: 8/1/84
Date: 8/7/84
Date: 8-22-84

Project: 83-03

Page 18 of 103

Clevis Plate

Pullout shear

$$Area = 2(2\pi t) = 2(2(2.0)(1.5)) = 4.8\text{ in}^2$$

$$P_{II} = 3440 \text{ lb.}$$

$$\delta = P_{II}/A = 3440/4 = \underline{860 \text{ PSI} < 24,400 \text{ PSI}}$$

Bolt hole tension

$$Area = 2t(2r - \text{hole dia}) = 2(1.5)(2(2.0) - (1 + 1/4)) = 2.938 \text{ in}^2$$

$$\delta = P_{II}/A = 3440/2.938 = \underline{1176 \text{ psi} < 32,400 \text{ PSI}}$$

Axial compression or tension

$$Area = min Area = 2t(2r) = 2(1.5)(2(2.0)) = 4.8\text{ in}^2$$

$$\delta = P_{II}/A = 3440/4 = \underline{\frac{860 \text{ PSI}}{(Tension)}} < 40,600 \text{ PSI}$$

$$\left. \begin{array}{l} l = 6.25", C_c = 126.5 \\ r = \frac{l}{2\pi} = 0.144" \\ K = 2.0, S_y = 30 \text{ KSI} \end{array} \right\}$$

See Appendix B

$$F_a = 2/3 \left(1 - \left(\frac{K \delta}{2} \right)^2 / 2 C_c^2 \right) S_y$$

$$= 2/3 \left(1 - \left(\frac{2(6.25)}{0.144} \right)^2 / 2 (126.5)^2 \right) 30 = 18.4 \text{ KSI}$$

$$\underline{860 \text{ PSI} < 18,400 \text{ PSI}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS Calculated by: JKennedy Date: 8/1/84
 Checked by: R.Toronto Date: 3/9/84
 Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 19 of 103

Bolt shear

$$A = 2 \frac{\pi d^2}{4} = \frac{\pi (1)^2}{2} = 1.571 \text{ in}^2$$

$$\gamma = PII/A = 3440 / 1.571 = \underline{2,190 \text{ PSI} < 24,400 \text{ PSI}}$$

Item 4 Clevis and Bolt STANDARD PART EA1-A

(snubber II)

Bolt shear, pullout shear, and bolthole tension are same as above for the EA2-A part.

Axial compression

$$\text{Area} = 4.0 \text{ in}^2 \quad \delta = PII/A = 3440 / 4 = 860 \text{ PSI}$$

$$\underline{860 \text{ PSI} < 23,100 \text{ PSI}}$$

Clevis plate to base plate weld

$$A = 3.182 \text{ in}^2$$

Tension / compression

$$\gamma_{Net} = \gamma_t = PII/A = 3440 / 3.182 = \underline{1,081 \text{ PSI} < 24,400 \text{ PSI}}$$

base plate weld to 6 WF 15.5 I-BEAM

$$A = 3.536 \text{ in}^2$$

Tension / compression

$$\gamma_{Net} = \gamma_t = PII/A = 3440 / 3.536 = \underline{973 \text{ PSI} < 24,400 \text{ PSI}}$$


MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM Seismic Supports Calculated by: M Kennedy Date: 8/1/84
 Checked by: RCTrinch Date: 8/9/84
 Reviewed by: JL Date: 8/22/84

Project: 83-03

Page 20 of 103

Item 1 6WF 15.5 I-BEAM



$$P_{II} = 3,440 \text{ lb}$$

$$a = 33.2 \text{ "}$$

$$b = 41.8 \text{ "}$$

$$c = 26.75 \text{ "}$$

$$a+b = 75.0 \text{ "}$$

$$b+c = 68.55 \text{ "}$$

Moment

Location A

$$M_A = 0$$

Location D

$$M_D = 0$$

Location B

$$M_B = \frac{P_{II} a(b+c)}{l} + \frac{F_{PSL} c(l-(b+c))}{l}$$

$$= \frac{3440(33.2)(68.55)}{101.75} + \frac{2340(26.75)(33.2)}{101.75}$$

$$= 97,367 \text{ in. lb.}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM Seismic Supports Calculated by: m Kennedy Date: 3/1/84
 Checked by: R C Gennari Date: 3/9/84
 Reviewed by: ✓ Date: 3/22/84

Project: 83-03

Page 21 of 103

Location C

$$M_C = \frac{F_{PSL} c(b+a)}{l} + \frac{P_{II} a(l-(b+a))}{l}$$

$$= \frac{2340(26.75)}{101.75}(75.0) + \frac{3440(33.2)}{101.75}(26.75)$$

$$= 76,164 \text{ in.lb.}$$

$$R_A = \frac{P_{II}(l-a)}{l} + \frac{F_{PSL} c}{l} =$$

$$= \frac{3440(68.55)}{101.75} + \frac{2340(26.75)}{101.75} = 2,933 \text{ lb}$$

$$R_D = \frac{P_{II} - a}{l} + \frac{F_{PSL}(l-c)}{l} =$$

$$\frac{3440(33.2)}{101.75} + \frac{2340(75.0)}{101.75} = 12,847 \text{ lb}$$

BEAM STRESS

$$I = 30.3 \text{ in}^4, \quad c = 3.0 \text{ in}$$

$$A = 4.62 \text{ in}^2$$

$$\text{Shear Area} = 6.0 (.25) = 1.5 \text{ in}^2$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Steam Seismic Supports Calculated by: M Kennedy Date: 8/1/84
Checked by: R French Date: 8/9/84
Reviewed by: JL Date: 8/22/84

Project: 83-03

Page 22 of 103

BENDING

$$\sigma = \frac{Mc}{I} = \frac{97,367 (3.0)}{30.3}$$
$$= 9,640 \text{ PSI} < 40,600 \text{ PSI}$$

SHEAR

$$\tau = \frac{V}{A} = \frac{2,933}{1.5} = 1,955 \text{ PSI} < 21,600 \text{ PSI}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: M Kennedy Date: 8/1/94
Checked by: RCTrenor Date: 5/9/84
Reviewed by: JJ Date: 2-22-84

Project: 83-03

Page 23 of 103

Item 1 weld to Existing 12C



TREAT WE10 AS A LINE

$$\begin{aligned}
 \text{AREA} &= \text{Perimeter } \frac{5}{8} \text{ Reg Length} \\
 &= \{4(6.0) + 2(5.75)\} \frac{5}{8} (.25) \\
 &= 6.276 \text{ in}^2
 \end{aligned}$$

SHEAR

$$\Sigma_3 = \frac{R_D}{A} = \frac{2847}{6.276} = \underline{\underline{454 \text{ psi}}} \leq 24,400 \text{ psi}$$

MPR ASSOCIATES, INC.


1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN Steam Seismic Supports Calculated by: M Kennedy Date: 8/1/84
 Checked by: R Schenk Date: 8/7/84
 Reviewed by: D Date: 8/22/84


Project: 83-03

Page 24 of 107

Item 1 weld to Existing 10WF



'A' weld



TREAT weld AS LINE

for TOP & Bottom welds

$$A = \frac{1}{2} t \sqrt{2} / 2 \\ = 3.5 (3/16) \sqrt{2} / 2 = 0.928 \text{ in}^2$$

for S.O.E weld

$$A = \frac{1}{2} t \sqrt{2} / 2 \\ = 4 (3/16) \sqrt{2} / 2 = 0.53 \text{ in}^2$$

$$\Sigma A = 2(0.53 + 0.928) = 2.916 \text{ in}^2$$

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM Seismic Supports Calculated by: m Kennedy Date: 3/1/84
Checked by: R Thrush Date: 5/9/84
Reviewed by: JT Date: 8-22-84

Project: 83-03


Page 25 of 103

SHANE

$$\gamma_{\text{net}} = \gamma_3 = R_A / A = 2933 / 2.916 = 1,005 \text{ PSI}$$

< 24400 PSI

'B' weld



$$A = 2 \ell \frac{r_2}{2} e \\ = 2(4.0) \frac{5^2}{2} \frac{\pi}{16} \\ = 1.768 \text{ m}^2$$

SHEAR

$$\gamma_{\text{ref}} = \gamma_3 = R_A / A = 2933 / 1.768 = 1659 \text{ psE}$$

≤ 24,400 psf

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN steam seismic supports

Calculated by: M Kenney

Date: 8/1/84

Checked by: R French

Date: 8/9/84

Reviewed by: JJ

Date: 8/22/84

Project: _____

Page 26 of 103

Support X-2A-55-1 Summary Table

Item	Type of Stress	Calculated Stress (PSI)	Allowable Stress (PSI)
Item 5 1/2 C	AXIAL COMPRESSION	233	24,000
	SHEAR	763	24,400
	BENDING	10,935	40,600
	AXIAL COMP. + BENDING	0.26. (Note 1)	1.0 (Note 1)
Item 5 weld to MS Pipe	SHEAR	9,718	24,400
PIPE weld to P.PE Plate	SHEAR	704	24,400
BASE PLATE weld to P.PE plate	SHEAR	676	24,400
Snubber I clevis	BENDING	623	40,600
	Pullout SHEAR	300	24,400
	Bolt Hole TENSION	408	32,400
	AXIAL compression	250	23,100
	AXIAL comp. + BENDING	0.03 (Note 1)	1.0 (Note 1)
Clevis Plate weld to BASE Plate	SHEAR	977	24,400

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 8/1/84
 Checked by: R Chretien Date: 8/4/84
 Reviewed by: JJ Date: 8-25-84

Project: _____
83-03

Page 27 of 103

Summary Table (Cont.)

Item	Type of Stress	Calculated Stress (PSI)	Allowable Stress (PSI)
Snubber I Bolts	SHEAR	764	24,400
Item 4 for Snubber II	BENDING	938	40,600
	AXIAL compression	766	23,100
	AXIAL comp & BENDING	0.03 (NOTE 1)	1.0 (NOTE 1)
Clevis Plate weld to BASE PLATE	SHEAR	1,214	24,400
BASE PLATE weld to J-BEAM	SHEAR	792	24,400
Pipe to clevis Plate weld	SHEAR	748	24,400
Bolt	SHEAR	2,190	24,400
Clevis Plate	Pullout SHEAR	860	24,400
	Bolt Hole Tension	1,711	32,400
	AXIAL compression	860	18,400

MPR ASSOCIATES, INC.
 1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 3/1/84
 Checked by: FC French Date: 5/3/84
 Reviewed by: JJ Date: 2/22/84

Project: 83-03

Page 28 of 103

Summary Table (cont.)

Item	Type of Stress	Calculated Stress (PSI)	Allowable Stress (PSI)
Item 4 for Shutter II	AXIAL COMPRESSION	860	23,100
Clevis plate to base plate weld	SHEAR	1,081	24,400
BASE PLATE to GWF I-BEAM weld	SHEAR	973	24,400
Item 1 I-BEAM GWF 15.5	BENDING	9,640	40,600
	SHEAR	1,955	21,600
Item 1 weld to channel	SHEAR	454	24,400
Item 1 weld to I-BEAM (coped end)	SHEAR	1,654	24,400

Notes

- (1) Value is not stress in psi but stress ratio
 (non-dimensional),

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM Seismic Supports

Calculated by: M. Koenig

Date: 8/1/84

Checked by: R.C. French

Date: 8/19/84

Reviewed by: T.


Date: 8/22/84

Project: 83-03



Page 29 of 103

Support MS RIA

DESCRIPTION



Snubber load
 $P = 5,170 \text{ lb.}$
Ref (1)



SECT. B-B

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Stem Seismic Supports Calculated by: M. Kennedy Date: 8/1/84
 _____ Checked by: R.L. French Date: 8/3/84
 _____ Reviewed by: T.J. Date: 8/3/84

Project: S3-03

Page 30 of 103

Item 1 Clevis & Bolt STANDARD Part EA2-A

MAKE 'A' dim = 8.0"

MAKE 'B' dim = 9.0"

Bolt rates to 10,000 lb Ref (2)

Actual Load 5,170 lb Ref (1)

No bending moments on the clevis

Axial compression

let $A_{net} = \text{minimum } A_{ncA} = 2tw = 2(1.5)(4.0) = 4.0 \text{ in}^2$

$$\delta = \frac{P}{A} = \frac{5170}{4} = 1293 \text{ psi}$$

$$l \cong 8.0 \text{ in} ; C_c = 126.5$$

$$r = \frac{l}{\sqrt{I_{12}}} = \frac{8.0}{\sqrt{12}} = 0.144$$

$$K=1.0 ; S_y = 36.0 \text{ ksi}$$

$$F_a = \frac{2}{3} \left(1 - \left(\frac{Kl}{r} \right)^2 / 2C_c^2 \right) S_y$$

$$= \frac{2}{3} \left(1 - \left(\frac{20(8.0)}{0.144} \right)^2 / 2(126.5)^2 \right) 36.0 = 14.7 \text{ ksi}$$

$$\underline{1293 \text{ psi} < 14,700 \text{ psi}}$$

} see Appendix B

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: Main Steam Seismic Supports

Calculated by: n Kennedy Date: 8/1/84
 Checked by: R G French Date: 8/9/84
 Reviewed by: JJ Date: 8/25/84

Project: 83-03

Page 31 of 103

Item 1 weld to Main Steam Pipe



Treat weld as line

$$\begin{aligned} \text{Area} &= 2(2L + 2W) \frac{\sqrt{2}}{2} \text{ leg length} \\ &= 2(2(9.0) + 2(.5)) \frac{\sqrt{2}}{2} (.25) \\ &= 6.718 \text{ in}^2 \end{aligned}$$

SHEAR

$$\tilde{c}_{\text{wet}} = \tilde{c}_3 = \frac{P}{A} = \frac{5170}{6.718} = \underline{\underline{770 \text{ PSI}}}$$

< 24,400 PSI

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Steam Seismic Supports

Calculated by: M Kennedy
Checked by: R Crouch
Reviewed by: JJ

Date: 8/1/84
Date: 8/1/84
Date: 2-22-84

Project: 83-03


Page 32 of 103

Item 3 Clevis & Bolt STANDARD Part EA1-4

Rates to 10,000 lb Ref: (2)

Actual load 5170 lb


Item 3 weld to Item 9



TREAT WE10 AS LINE

$$\begin{aligned} \text{Area} &= 4 \times \frac{\sqrt{2}}{2} \text{ leg length} \\ &= 4(5.0) \frac{\sqrt{2}}{2} (.25) \\ &= 3.535 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} Z &= \left(S^2 + \frac{s^2}{3} \right) \frac{\sqrt{2}}{2} \text{ leg length} \\ &= \left(5^2 + \frac{5^2}{3} \right) \frac{\sqrt{2}}{2} (.25) \\ &= 5.893 \text{ in}^3 \end{aligned}$$



Tension / compression

$$\gamma_1 = \frac{P \cos 41}{A} = \frac{5170 (\cos 41)}{3.535} = 1104 \text{ psi}$$

Bending

$$\begin{aligned} \gamma_2 &= \frac{M P \sin 41}{Z} = \frac{(3.25)(5170) \sin 41}{5.893} \\ &= 1871 \text{ psi} \end{aligned}$$

Shear

$$\gamma_3 = \frac{P \sin 41}{A} = \frac{5170 \sin 41}{3.535} = 959 \text{ psi}$$

$$\gamma_{\text{net}} = \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(1104 + 1871)^2 + (959)^2} = \underline{\underline{3,126 \text{ psi}}} \\ \swarrow \underline{\underline{24,600 \text{ psi}}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEM Seismic Supports


Calculated by: J. Kennedy
Checked by: R.C. Dorch
Reviewed by: J.J.

Date: 2/1/84
Date: 2/9/84
Date: 2/22/84

Project: 73-03

Page 33 of 103

TRIPOD STRUCTURE
BEAM FORCES



BEAMS SEE LOAD IN TENSION/COMPRESSION ONLY

Method of tension coefficients

$$w_x = 3392 \text{ lb}; w_y = 3902 \text{ lb}; w_z = 0.0$$

$$x_1 t_{BD} + x_2 t_{AD} + x_3 t_{CD} + w_x = 0$$

$$y_1 t_{BD} + w_y = 0$$

$$z_3 t_{CD} + w_z = 0 \rightarrow t_{CD} = 0$$

$$x_1 = -33.0 \cos 60 = -16.5 "$$

$$x_2 = -30.0 "$$

$$x_3 = -30.0 "$$

$$y_1 = 33.0 \sin 60 = 28.579 "$$

$$z_3 = 38.0 \sin 45 = 26.820 "$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEM Seismic Supports

Calculated by: m Kennedy
Checked by: E.C. French Jr.
Reviewed by: JJ

Date: 8/1/84
Date: 8/9/84
Date: 8/22/84

Project: 83-03

Page 34 of 103

$$W_2 = 0 \quad \therefore t_{C0} = 0$$

$$t_{B0} = -\frac{W_4}{y_1} = \frac{-3902}{28.579} = -137 \quad lb/in$$

$$y_1 \quad t_{B0} \quad x_2 \quad t_{A0} \quad + W_x = 0$$

$$- 16.5 (-137) + -30.0 \quad t_{A0} + 3892 = 0$$

$$t_{A0} = -188 \quad lb/in$$

$$F_{B0} = \overline{B0} \quad t_{B0} = 33.0 (-137) = -4,521 \quad lb.$$

$$F_{A0} = \overline{A0} \quad t_{A0} = 30.0 (-188) = 5,640 \quad lb$$

BEAM AD - Item 9 6WF 15.5 I-BEAM

$$I = 30.3 \text{ in}^4, c = 3.0", A = 4.62 \text{ in}^2$$

pp. 1-21, ref (4).-

Tension / compression

$$\delta = \frac{F_{A0}}{A} = \frac{5640}{4.62} = \underline{\underline{1,221 \text{ psi}}} < 40,600 \text{ psi}$$

(tension)

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Stern Seismic Supports

Calculated by: m Kennedy
Checked by: R Trujillo
Reviewed by: JJ

Date: 8/1/84
Date: 8/9/84
Date: 8/22/84

Project: 83-03

Page 35 of 103

$$l = 30.0 \text{ in} ; C_c = 126.5$$

$$r = 1.45"$$

Ref (4) p 1-21

$$K = 1.0 , \quad S_y = 36.0 \text{ KSI}$$

$$f_a = \frac{2}{3} \left(1 - \left(\frac{Kl}{r} \right)^2 / 2 C^2 \right) S_y = 23.7 \text{ KSI}$$

See Appendix B

$$\underline{1221 \text{ psi}} < \underline{23,700 \text{ psi}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM Seismic Supports


Calculated by: M. Kanner
Checked by: R.C. Tschudi
Reviewed by: J.J.

Date: 8/1/84
Date: 8/9/84
Date: 8/22/84

Project: 8303

Page 36 of 103

Item 3 weld to existing Col 27 WF 177



TREAT WELD AS LINE

$$\begin{aligned} A_{eq} &= (2d + 2l + 2(l-.25)) \sqrt{\frac{1}{2}} \text{ leg length} \\ &= (2(6.0) + 2(6.0) + 2(5.75)) \sqrt{\frac{1}{2}} (.25) \\ &= 6.276 \text{ in}^2 \end{aligned}$$

Tension / Compression

$$\gamma_{net} = \gamma_i = \frac{A_L}{A} = \frac{5,640}{6,276} = \underline{\underline{899 \text{ psi}}} < 24,400 \text{ psi}$$

Item 4 (BEAM BD) 2-L 2" x 3" x 0.25"

$$\begin{aligned} Area &= 2(l_1 w_1 + l_2 w_2) \\ &= 2((2)(.25) + (3.0-.25)(.25)) = 2.375 \text{ in}^2 \end{aligned}$$

Tension / Compression

$$d = \frac{F_{BD}}{A} = \frac{4,521}{2.375} = \underline{\underline{1,904 \text{ psi}}} < 40,600 \text{ psi}$$

(tension)

$$l = 28.5" \quad C_c = 126.5$$

$$r = 0.43"$$

Ref (4) p 1-33

(Axis 2 z-z)

$$K = 1.0 \quad , \quad S_y = 36.0$$

See Appendix B

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Steam Seismic Supports
 Calculated by: M Kennedy
 Checked by: R C Truchi
 Reviewed by: JJ

Date: 8/1/84
 Date: 7/3/84
 Date: 8/2/84

Project: 83-03


Page 37 of 103

$$f_a = \frac{2}{3} \left(1 - \frac{(K_{cr})^2}{2C_0^2} \right) S_y$$

$$= \frac{2}{3} \left(1 - \frac{(1.0(28.5))^2}{2(126.5)^2} \right) 36.0 = 20.7 \text{ ksi}$$

1,904 psi < 20,700 psi

Item 8 Plate 9" x 7/8" x 5" w/ (2) 3/4" Ø x 2" LG B/N



Item 8 weld to 6 WF 15.5 I-BEAM (assume 1/4" fillet)

Area = Perimeter $\frac{\sqrt{2}}{2}$ leg length

$$= 2(l+w) \frac{\sqrt{2}}{2} (\frac{1}{4}) = 2(9 + \frac{3}{8}) \frac{\sqrt{2}}{2} (\frac{1}{4}) = 3.315 \text{ in}^2$$

$$\gamma_1 = \text{compression / tension} = \frac{F_{BD} S_{N60}}{A} = \frac{4521 S_{N60}}{3.315} = 1181 \text{ psi}$$

$$\gamma_3 = \text{clear} = \frac{F_{BD} \cos 60}{A} = \frac{4521 \cos 60}{3.315} = 682 \text{ psi}$$

$$\gamma_{\text{Net}} = \sqrt{\gamma_1^2 + \gamma_3^2} = \sqrt{(1181)^2 + (682)^2} = 1364 \text{ psi} < 24,400 \text{ psi}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: M4W STEAM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 8/1/84
 Checked by: RCTrauch Date: 8/9/84
 Reviewed by: ✓ Date: 8/22/84

Project: 83-03

Page 38 of 103

Item 8 PLATE STRESSES

$$\text{Net Area} = (l - \text{hole dia}) w = (9 - (3/4 + 1/16)) 3/8 = 3.070 \text{ in}^2$$

Tension/Compression

$$\sigma = \frac{f_{BD} \sin 60}{A} = \frac{4521 \cdot \sin 60}{3.070} = \underline{\underline{1275 \text{ PSI} < 32,400}}$$

Shear

$$\tau = f_{BD} \frac{\cos 60}{A} = \frac{4521 \cdot \cos 60}{3.070} = \underline{\underline{736 \text{ PSI} < 24,400 \text{ PSI}}}$$

Bolts

Double Shear

$$A = \frac{1}{4} \left(\frac{\pi}{4} d^2 \right) = \frac{\pi}{16} (3/4)^2 = 1.767 \text{ in}^2$$

$$\tau = \frac{F_{BD}}{A} = \frac{4521}{1.767} = \underline{\underline{2,559 \text{ PSI} < 24,400 \text{ PSI}}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: mR Date: 7/1/84
 Checked by: R.C.Traub Date: 8/9/84
 Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 39 of 103

Item 5 L 4" x 3" x 3/8" x 8" LG



Item 4 weld to Item 5 PLATE

$$\text{Est. Area} = \text{Perimeter } \frac{5\frac{1}{2}}{2} \text{ leg length}$$

$$= 2(3.0 + 1.0 + 3.6) \frac{5\frac{1}{2}}{2} (.25) = 2.687 \text{ in}^2$$

$$\Sigma_{\text{net}} = \frac{F_{BD}}{A} = \frac{4521}{2.687} = \underline{1683 \text{ PSI}} < 24,400 \text{ PSI}$$

Item 5 PLATE stress

$$\text{Area} = l_w + l'w' = 4 \times 3\frac{1}{8} + (3 - 3\frac{1}{8}) \times \frac{3}{8} = 2.484 \text{ in}^2$$

tension/compression

$$\delta = \frac{F_{BD} \sin 41}{A} = \frac{4521 \sin 41}{2.484} = \underline{1194 \text{ PSI}} < 32,400 \text{ PSI}$$

shear

$$\Sigma = \frac{F_{BD} \cos 41}{A} = \frac{4521 \cos 41}{2.484} = \underline{1314 \text{ PSI}} < 24,400 \text{ PSI}$$

MPR ASSOCIATES, INC.
 1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main stem seismic supports

Calculated by: m Kennedy
 Checked by: R L French
 Reviewed by: JJ

Date: 5/1/84
 Date: 5/9/84
 Date: 8-22-84

Project: 83-03

Page 40 of 103

Item 5 plate weld to existing 21 WF 277 I-BEAM

$$\begin{aligned}
 \text{Area} &= \text{Perimeter } \frac{\sqrt{2}}{2} \text{ leg length} \\
 &= (2 + w + 2t + (l-t) + (w-t)) \frac{\sqrt{2}}{2} \text{ leg length} \\
 &= (4 + 3 + 2(\frac{3}{8}) + (4 - \frac{3}{8}) + (3 - \frac{3}{8})) \frac{\sqrt{2}}{2} (.25) \\
 &= 2.475 \text{ in}^2
 \end{aligned}$$

$$\gamma_1 = \text{tension / compression} = \frac{F_{BD}}{A} \sin 41 = \frac{4521}{2.475} \frac{\sin 41}{\sin 41} = 1198 \text{ psi}$$

$$\gamma_2 = \text{shear} = \frac{F_{BD}}{A} \cos 41 = \frac{4521 \cos 41}{2.475} = 1379 \text{ psi}$$

$$\gamma_{\text{net}} = \sqrt{\gamma_1^2 + \gamma_2^2} = \sqrt{(1198)^2 + (1379)^2} = \underline{\underline{1827 \text{ psi}}} \angle \underline{\underline{24,400 \text{ psi}}}$$

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM SEISMIC SUPPORTS

Calculated by: M Kennedy
Checked by: R French
Reviewed by: JJDate: 8/1/84
Date: 8/9/84
Date: 8/22/84

Project: 8303

Page 41 of 103

Support MSRIA Summary Table

Item	Type of Stress	Calculated stress (PSI)	Allowable stress (PSI)
Item 1 weld to MS PIPE	SHEAR	770	24,400
Item 1 clevis	AXIAL compression	1,293	14,700
Item 3 weld to Item 9	SHEAR	3,126	24,400
Item 9 BEAM	TENSION / compression	1,221	23,700
Item 9 weld to 27WF	SHEAR	899	24,400
Item 4 BEAM	TENSION / compression	1,904	20,700
Item 8 weld to 6 WF	SHEAR	1,364	24,400
Item 8 PLATE	TENSION / compression	1,275	32,400
	SHEAR	736	24,400
Bolts	SHEAR	2,559	24,400
Item 4 weld to Item 5	SHEAR	1,623	24,400
Item 5 PLATE	TENSION / compression	1,194	32,400
	SHEAR	1,314	24,400
Item 5 weld to 21 WF	SHEAR	1,827	24,400

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: M Kennedy Date: 8/1/84
Checked by: R French Date: 8/9/84
Reviewed by: JJ Date: 8/22/84Project: 83-03Page 42 of 103

SUMMARY TABLE (CONT.)

Item	Calculated LOAD (lb)	Allowable LOAD (lb)
1	5,170	10,000
3	5,170	10,000

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: m Kennedy
Checked by: R Trensch
Reviewed by: JJ


Date: 8/1/84
Date: 8/1/84
Date: 8/22/84

Project: 73-03

Page 43 of 103

Support MS-R2A

DESCRIPTION



$$P = 12,330 \text{ lb}$$

Ref (1)

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: MAIN STEAM SEISMIC SUPPORTS
 Calculated by: M. Kennedy
 Checked by: R. Trenhol
 Reviewed by: JJ

Date: 8/1/84
 Date: 7/9/84
 Date: 8/22/84

Project: 83-03

Page 44 of 103

Item 2 Pipe Attachment Clevis & Bolt



Pullout shear

$$A = 2(\pi r t) = 2(\pi(2.0).5) = 4.0 \text{ in}^2$$

$$\gamma = P/A = \frac{12,330}{4} = \underline{\underline{3,083 \text{ PSI}}} < 24,400 \text{ PSI}$$

Bolt Hole tension

$$A = 2\pi(2r - h_{hole}) = 2(5)(2(2.0) - (1.0 + 1/16)) = 2.938 \text{ in}^2$$

$$\gamma = P \sin 45 / A = \frac{12,330 \sin 45}{2.938} = \underline{\underline{2968 \text{ PSI}}} < 32,400 \text{ PSI}$$

SHEAR

$$\gamma = P \sin 45 / A = \frac{12,330 \sin 45}{2.938} = \underline{\underline{2968 \text{ PSI}}} < 24,400 \text{ PSI}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS


Calculated by: m Kennedy
Checked by: R Tranch
Reviewed by: JJ

Date: 8/1/84
Date: 8/9/84
Date: 8/22/84

Project: 83-03

Page 45 of 103

BENDING AT BASE



$$I = 2 \frac{b h^3}{12} = 2 \frac{(5)(9.0)^3}{12} = 60.75 \text{ in}^4$$

$$c = 4.5 "$$

$$\sigma = \frac{M c}{I} = 2 \frac{P_{sin45}}{I} c = 7.0 \frac{(12330) sin45 (4.5)}{60.75}$$

$$= \underline{\underline{4521 \text{ PSI}}}$$

$$\underline{\underline{ < 40,600 \text{ PSI}}}$$

AXIAL COMPRESSION

$$\text{let Area} = \text{minimum Area} = 2t_w = 2(5)(4.0) = 40 \text{ in}^2$$

$$\delta = \frac{P_{sin45}}{A} = \frac{12330 \sin 45}{40} = 2180 \text{ PSI}$$

$$l \approx 7.0 \text{ in} , C_c = 126.5$$

$$r = \frac{l}{\sqrt{12}} = \frac{7}{\sqrt{12}} = .144$$

$$K = 2.0 ; S_y = 36.0 \text{ KSI}$$

$$F_a = \frac{2}{3} \left(1 - \left(\frac{K r}{r} \right)^2 / 2 C_c^2 \right) S_y$$

$$= \frac{2}{3} \left(1 - \left(\frac{2.0(7.0)}{.144} \right)^2 / 2 (126.5)^2 \right) 36.0 = 16.9 \text{ KSI}$$

See Appendix B

$$\underline{\underline{2180 \text{ PSI} < 16,900 \text{ PSI}}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 8/1/84
 _____ Checked by: R C French Date: 9/9/84
 _____ Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 46 of 103

AXIAL COMPRESSION AND BENDING

$$\frac{F_a}{F_a} \leq 0.15$$

$$\therefore \frac{F_a}{F_a} + \frac{F_b}{F_b} \leq 1.0$$

(Note: bending in this plane gives a larger radius of gyration $\therefore F_a = 24.0 \text{ kSI}$)

$$\frac{3180}{16,900} + \frac{4521}{40,600} = 0.24 \leq 1.0$$

Bolt - 1" ϕ x 3 $\frac{3}{4}$ " Lg B $\frac{1}{2}$ N

$$\text{AREA} = 2\frac{\pi d^2}{4} = (2\pi \cdot 1)^2 = 1.570 \text{ in}^2$$

double shear

$$\gamma = \frac{P}{A} = \frac{12,330}{1.570} = 7,854 \text{ psi} \leq 24,400 \text{ psi}$$


MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS Calculated by: n/a Date: 8/1/84
Checked by: RCTrench J Date: 8/9/84
Reviewed by: JJ Date: 8-22-84

Project: 83-03

Page 47 of 103

Item 2 Weld to Main Steam Pipe



TREAT weld AS LINE

$$\begin{aligned} A &= 2(2x + 2w)^{\sqrt{3}/2} \text{ leg length} \\ &= 2(2(9.0) + 2(.5))^{\sqrt{3}/2}(25) \\ &= 6.718 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} Z &= 2 \left(bd + \frac{d^2}{3} \right) \frac{\sqrt{2}}{2} \text{ leg length} \\ &= 2 \left(.5(9.0) + \frac{9.0^2}{3} \right) \frac{\sqrt{2}}{2} (.25) \\ &= 11.137 \text{ in}^3 \end{aligned}$$

tension / compression

$$\gamma_1 = \frac{J_2}{J_2 P/A} = \frac{J_2 (12330)}{6.718} = 1298 \text{ psI}$$

Moment

$$C_2 = \frac{J_{\frac{1}{2}} P L / z}{\frac{J_{\frac{1}{2}}(12370)(7.0)}{11,137}} = 5,480 \text{ psi}$$

Sleay

$$\gamma_3 = \frac{\sqrt{2}}{2} P/A = \frac{\sqrt{2}/2 (12,330)}{6,718} = 1,298 \text{ PSI}$$

$$\gamma_{\text{Net}} = \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(1298 + 5480)^2 + 1298^2}$$

$$= \underline{\underline{6,901 \text{ psi}}} < \underline{\underline{24,400 \text{ psi}}}$$


MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Steam Seismic Supports Calculated by: m/kennedy Date: 8/1/84
 Checked by: R.Cheney Date: 3/9/84
 Reviewed by: JH Date: 2-22-84


Project: 83-03

Page 48 of 103

Item 3 clevis & Bolt STANDARD PART FAI-A



Item 3 weld to Item 4 (I-Beam)




TREAT WELD AS LINE

$$\begin{aligned} A &= 4 \times \frac{5}{2} \text{ leg length} \\ &= 4(5.0) \frac{5}{2} (.25) \\ &= 3.536 \text{ in}^2 \end{aligned}$$

Tension / compression

$$\gamma_{\text{net}} = \gamma_i = P/A = \frac{12,330}{3.536} = \underline{\underline{3457 \text{ PSI}}} < 24,400 \text{ PSI}$$

Clevis Plate Weld to Base Plate



$$\begin{aligned} \text{Area} &= 4(l+w) \frac{5}{2} \text{ leg length} \\ &= 4(.5+4) \frac{5}{2} (.25) = 3.182 \text{ in}^2 \end{aligned}$$

Tension / compression

$$\gamma_{\text{net}} = \gamma_i - P/A = \frac{12,330}{3.182} = \underline{\underline{3875 \text{ PSI}}} < 24,400 \text{ PSI}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM Seismic Supports Calculated by: M. Hanafi Date: 8/1/84
 Checked by: R.C.Threlkeld Date: 3/9/84
 Reviewed by: J.L. Date: 2-22-84

Project: 73-03

Page 49 of 103

clavis plate

Pullout shear

$$A = 2(2Rt) = 2(2(2.0)(.5)) = 4.0 \text{ in}^2$$

$$\gamma = P/A = \frac{12,330}{4.0} = \underline{3083 \text{ PSI}} < \underline{24400 \text{ PSI}}$$

Bolt Hole tension

$$A = 2(2(R-\text{hole dia})t) = 2(4-(1\frac{1}{16})) .5 = 2.938$$

$$\delta = P/A = \frac{12,330}{2.938} = \underline{4197 \text{ PSI}} < \underline{32,400 \text{ PSI}}$$

Axial compression

$$A = \text{min Area} = 2(2t) = 2(2(2.0)(.5)) = 4.0 \text{ in}^2$$

$$\delta = P/A = \frac{12,330}{4.0} = \underline{3083 \text{ PSI}}$$

$$l = 2.75", \quad C_c = 126.5$$

$$r = \frac{l}{\sqrt{12}} = 0.144 \text{ in}$$

$$K = 2.0, \quad S_y = 36.0 \text{ KSI}$$

$$F_a = \frac{2}{3} \left(1 - \frac{(K\delta r)^2}{2C_c^2} \right) S_y = 22.9 \text{ KSI}$$

$$\underline{3,083 \text{ PSI}} < \underline{22,900 \text{ PSI}}$$

see Appendix B

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: JKennedy
Checked by: R.C.Tyndall
Reviewed by: JJ

Date: 8/1/84
Date: 3/9/84
Date: 2/22/84

Project: 83-03


Page 50 of 103

Item 4 I-BEAM

6 WF 15.5 x 6' 6 $\frac{1}{2}$ " LG

$$A = 4.62 \text{ in}^2 \quad \text{Ref. (4) P. 3-24}$$

$$I = 30.3 \text{ in}^4 \quad \text{Ref. (4) P. 1-21}$$



$$l = 78.5"$$

$$b = 48.0"$$

$$a = 30.5"$$

the beam is partially restrained at R₁ and R₂ by the 8" x 10" x 1/2" plate. Reactions & Moment in the plates and beams are calculated as follows:


MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 8/1/84
 _____ Checked by: RCTrench Date: 5/9/84
 _____ Reviewed by: JJ Date: 8-22-84

Project: 83-03

Page 51 of 103


Superposition of Loadings



$$\theta_A = \frac{P a (2l-a) (\alpha_3)}{6EI l} ; \quad \theta_B = -\frac{P a (l^2-a^2)}{6EI l}$$


Ref. 5
case 1c
p 97

clockwise rotation positive




Ref. 6
case 7
p 22

$$\theta_A = -\frac{\gamma_3 M_{p1} L}{EI} \quad \theta_B = \gamma_6 \frac{M_{p1} L}{EI}$$



$$\theta_A = -\frac{\gamma_6 M_{p2} L}{EI} \quad \theta_B = \gamma_3 \frac{M_{p2} L}{EI}$$

PLATE



$$\theta = \frac{M_p L}{E_p I_p}$$

Ref. 6
case 21

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: - Mark Koenig

Date: 8/1/84

Checked by: R. T. Finch

Date: 7/18

Reviewed by: TJ

Date: 7-22-80

Project: _____

83-03

Page 52 of 103

$$\theta_{total A} = \frac{M_{P_1} L}{E_P I_P} = \frac{P_a a (2l-a)(l-a)}{6EI_l}$$

$$\Theta_{\text{tot+NL}} = - \frac{M_{P_2} L}{E_P I_P} = - P_a \frac{a (l^2 - a^2)}{6EI_l}$$

$$E_p = E = 29 \times 10^6 \text{ psi} \quad (\text{modulus of elasticity})$$

$$I_p = 0.083 \text{ in}^4 \quad \text{From p 65 of this calculation}$$

$$I = 30.3 \text{ in}^4$$

卷之六

186

$\lambda = 10^{\circ} 3' 40''$

$$a = 30.5 \text{ in}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: mKennedy Date: 8/1/84
Checked by: R.L.Inglehart Date: 8/9/84
Reviewed by: JJ Date: 8-22-84

Project: 83-03

Page 53 of 103

$$(1) M_{P_1} = \left(\frac{L}{E_P I_P} + \frac{1}{3} \frac{L}{EI} \right)^{-1} \left\{ \frac{P_a ((2L-a)(L-a)a)}{6EI L} - M_{P_2} \left(\frac{L}{6EI} \right) \right\}$$

$$(2) M_{P_2} \left(\frac{\frac{L}{E_P I_P} + \frac{1}{3} \frac{L}{EI}}{\left(\frac{L}{EI G} \right)} \right) = P_a \left(\frac{a(L^2-a^2)}{6EI L} \right) - M_{P_1}$$

$$\frac{P_a \left(\frac{a(L^2-a^2)}{6EI L^2} \right)}{\left(\frac{L}{EI G} \right)} = \left\{ \frac{\frac{P_a ((2L-a)(L-a))}{6EI L} - M_{P_2} \left(\frac{L}{6EI} \right)}{\left(\frac{L}{E_P I_P} + \frac{1}{3} \frac{L}{EI} \right)} \right\}$$

$$+ M_{P_2} \left(\frac{\frac{L}{E_P I_P} + \frac{1}{3} \frac{L}{EI}}{\left(\frac{L}{EI G} \right)} \right)$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Stem Seismic Supports Calculated by: ngkennedy Date: 8/1/84
 _____ Checked by: KLThruols Date: 8/1/84
 _____ Reviewed by: JJ Date: 8-22-84

Project: 83-03 Page 54 of 103

$$P_a \left(\frac{a(l^2 - a^2)}{l^2} \right) - \frac{P_a \left(\frac{(2l-a)(a-l)a}{6I_2} \right)}{\left(\frac{l}{I_p} + \frac{1}{3} \frac{l}{I} \right)} =$$

$$M_{p_2} \left\{ \frac{\frac{l}{I_p} + \frac{1}{3} \frac{l}{I}}{\frac{l}{6I}} - \frac{\frac{l}{6I}}{\frac{l}{I_p} + \frac{1}{3} \frac{l}{I}} \right\}$$

$$12330 \left(\frac{30.5 \left(78.5^2 - 30.5^2 \right)}{(78.5)^2} \right) - 12330 \left(\frac{(2(78.5) - 30.5)(78.5 - 30.5) 30.5}{6(30.3)(78.5)} \right)$$

$$\left(\frac{6}{0.083} + \frac{1}{3} \frac{78.5}{30.3} \right)$$

$$= M_{p_2} \left\{ \frac{\left(\frac{6}{0.083} + \frac{1}{3} \frac{78.5}{30.3} \right)}{\frac{78.5}{6(30.3)}} - \frac{\frac{78.5}{6(30.3)}}{\left(\frac{6}{0.083} + \frac{1}{3} \frac{78.5}{30.3} \right)} \right\}$$

$$M_{p_2} = 1872 \text{ in. lb.}$$

Plugging into Eq (1)

$$M_{p_1} = 2176 \text{ in. lb.}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM Seismic Supports Calculated by: M. Kannan
Checked by: R. Chinnath
Reviewed by: T


Project: 83-03

Calculated by: M Kennedy Date: 8/1/84
Checked by: R Chelach Date: 8/9/84
Reviewed by: JJ Date: 8-22-84

Page 55 of 103

Simply supported beam moment

$$\text{MAY M at P} = \frac{P ab}{l} = \frac{12330 (48.0)(30.5)}{(78.5)} \\ = 229,951 \text{ in-lb}$$



* This is calculated assuming linear drop in end moments.

MPR ASSOCIATES, INC.
 1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM Seismic Supports Calculated by: M.Kennedy Date: 8/1/84
 _____ Checked by: R.Torbeck Date: 3/9/84
 _____ Reviewed by: JJ Date: 7-22-84

Project: 83-03

Page 56 of 103

$$\sum M \text{ at } A = P_a + M_{P_2} - R_B l - M_{P_1}$$

$$0 = 12330 (30.5) + 1872 - R_B (78.5) - 2176$$

$$\therefore R_B = 4,787 \text{ lb}$$

$$\sum M \text{ at } B = P_b + M_{P_1} - M_{P_2} - R_A l$$

$$0 = 12330 (48.0) + 2176 - 1872 - R_A (78.5)$$

$$\therefore R_A = 7,543 \text{ lb.}$$

Shear Stress in I-beam

$$R_A \rightarrow P \quad V = R_A = 7543 \text{ lb} \quad (\text{controlling load})$$

$$T = \frac{R_A}{A} = \frac{7543}{4.62} = \underline{\underline{1633 \text{ psi}}} < 24,400 \text{ psi}$$

Bending in I-beam

$$\delta = \pm \frac{Mc}{I} = \frac{227,893 (3.0)}{30.3} = \underline{\underline{22,564 \text{ psi}}} < 40,600 \text{ psi}$$

Note: $M = M_{M_p} + \frac{M_1 (l-a)}{l} + \frac{M_2 a}{l}$

$$= 229,951 - \frac{2176 (48)}{78.5} - \frac{1872 (30.5)}{78.5} = 227,893 \text{ in. lb.}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM SEISMIC SUPPORTS


Calculated by: McKenney
Checked by: Ettrich
Reviewed by: JJ

Date: 8/1/84
Date: 5/9/84
Date: 8-52-84

Project: 83-03

Page 57 of 103

Item 4 Weld to Item 5 plate.
(Location A)



TREAT WEID AS LING

$$\begin{aligned} \text{Area} &= \text{Perimeter } \frac{\sqrt{2}}{2} \text{ leg length} \\ &= \{4(6.0) + 2(5.75)\} \frac{\sqrt{2}}{2} (.25) \\ &= 6.276 \text{ in}^2 \end{aligned}$$

$$\begin{aligned}
 Z &= \left\{ bd + \frac{d^2}{3} + (b-t)(d-2t) \right\} \\
 &\quad \text{5.2/2 leg length} \\
 &= \left\{ 6.0^2 + 6.0^2 \frac{1}{3} + (6.0 - 25)(6.0 - 2(25)) \right\} \\
 &\quad \text{5.2/2 (.25)} \\
 &= 14.076 \text{ in}^3
 \end{aligned}$$

BENDING

$$Z_2 = \frac{M}{z} = \frac{2176}{14.076} = 155 \text{ PSI}$$

SHEAR

$$U_3 = \frac{R_A}{A} = \frac{7543}{6.276} = 1202 \text{ PSI}$$

$$\Sigma_{\text{net}} = \sqrt{\gamma_2^2 + \gamma_3^2} = \sqrt{(155)^2 + (1202)^2} = \frac{1212 \text{ psI}}{\leq 24,400 \text{ psI}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Steam Seismic Supports


Calculated by: M Kennedy
Checked by: R Trenberth
Reviewed by: JT

Date: 8/1/84
Date: 8/1/84
Date: 8-22-84

Project: 83-03


Page 58 of 103

Mitred end of I-beam (Location B)



ASSUME CLIP ANGLE AND WELDS PER BP STANDARD E 602

weld A + B (simplified)



TREAT weld as line

$$\begin{aligned} A_{WA} &= 2l \cdot \frac{5}{2} \text{ leg length} \\ &= 2(4.0) \cdot \frac{5}{2} (\frac{3}{16}) \\ &= 1.061 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} Z &= \frac{l^2}{3} \cdot \frac{5}{2} \text{ leg length} \\ &= \frac{4^2}{3} \cdot \frac{5}{2} (\frac{3}{16}) = 0.707 \text{ in}^3 \end{aligned}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Stream Seismic Supports Calculated by: M Kennedy Date: 8/1/84
 Checked by: R Trunk Date: 3/9/84
 Reviewed by: JJ Date: 1-22-84

Project: 83-03

Page 59 of 103

BENDING


$$\gamma_2 = \frac{M}{I} = \frac{1872}{0.707} = 2648 \text{ PSI}$$

SHEAR

$$\gamma_3 = \frac{R_s/A}{I} = \frac{4787}{1.061} = 4512 \text{ PSI}$$

$$\gamma_{\text{net}} = \sqrt{\gamma_2^2 + \gamma_3^2} = \sqrt{(2648)^2 + (4512)^2} = \underline{5232 \text{ PSI}} < 24,400 \text{ PSI}$$

4 x 3 x 3/8 L clip Angle



$$\begin{aligned} \text{Area} &= 2(l \times w) \\ &= 2(4.0 \times \frac{3}{8}) = 3.0 \text{ in}^2 \end{aligned}$$

$$Z = \frac{2bh^3}{C12} = \frac{\cancel{2}(\frac{3}{8})(4)^3}{\cancel{2}(12)} = 2.0 \text{ in}^3$$

SHEAR

$$\gamma = \frac{R_s/A}{I} = \frac{4787}{3.0} = \underline{1596 \text{ PSI}} < 21,600 \text{ PSI}$$

BENDING

$$\sigma = \frac{M}{Z} = \frac{1872}{2.0} = \underline{936 \text{ PSI}} < 40,600 \text{ PSI}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM Seismic Supports

Calculated by: M Kennedy
Checked by: R Trelch J
Reviewed by: JJ


Date: 3/1/84
Date: 3/4/84
Date: 8-22-84

Project: 83-03

Page 60 of 103

Item 5 Plate

Location A Plate controlling



$$\text{SHEAR} = 0, \text{ AXIAL LOAD} = R_A = 4282 \text{ lb}$$

$$M = M_{P1} = 2176 \text{ in. lb.}$$

$$I_p = \frac{bh^3}{12} = \frac{8.0(1.0)^3}{12} = 0.083 \text{ in}^4$$

AXIAL tension / compression

$$\delta = R_A/A = \frac{7543}{4} = \frac{1886 \text{ psi}}{\text{(tension)}} < 40,600 \text{ psi}$$

$$\begin{aligned} l &= 6.0 \text{ in}, C_c = 126.5 \\ r &= t/\sqrt{I_2} = 0.5/\sqrt{12} = 0.144 \end{aligned} \quad \left. \right\} \text{ see Appendix B}$$

$$K = 1.0, S_y = 36.0 \text{ ksi}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 3/1/84
 _____ Checked by: R C Turchi Date: 3/5/84
 _____ Reviewed by: LJ Date: 2/22/84

Project: 83-03

Page 61 of 103

$$f_a = \frac{2}{3} \left(1 - \left(\frac{k_e}{r} \right)^2 / 2c_e^2 \right) S_y$$

$$= \frac{2}{3} \left(1 - \left(\frac{(1.07)(4.0)}{144} \right)^2 / 2(126.5)^2 \right) (36.0) = 22.7 \text{ KSI}$$

1886 PSI < 22,700 PSI

BENDING

$$I = 0.083 \text{ in}^4, c = .25 \text{ in}$$

$$\delta = \frac{Mc}{I} = \frac{2176 (.25)}{0.083} = \underline{\underline{6554 \text{ PSI}}} \leq 40,600 \text{ PSI}$$

AXIAL COMPRESSION AND BENDING

$$\frac{f_a}{F_a} \leq 0.15$$

$$\therefore \frac{f_a}{F_a} + \frac{f_b}{F_b} \leq 1.0$$

$$\frac{1886}{22700} + \frac{6554}{40600} = \underline{\underline{0.24 < 1.0}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: MAIN STREAM Seismic Supports

Calculated by: M Kennedy Date: 8/1/84
Checked by: R J French Date: 5/9/84
Reviewed by: JJ Date: 2/22/84

Project: 83-03

Page 62 of 103

Item 5 Plate Weld to Existing 21 wt 96 I-BEAM



TREAT WELD AS LINE

$$\begin{aligned} \text{Area} &= 2(b+d)^{\sqrt{2}/2} \text{ leg length} \\ &= 2(8.0 + .5)^{\sqrt{2}/2} (.25) \\ &= 3.005 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} z &= \left(b d + \frac{d^2}{3} \right)^{\sqrt{2}/2} \text{ leg length} \\ &= \left(8(.5) + \left(\frac{.5^2}{3}\right) \right)^{\sqrt{2}/2} (.25) \\ &= 0.722 \text{ in}^3 \end{aligned}$$

tension / compression

$$\gamma_1 = \frac{R_A}{A} = \frac{7543}{3.005} = 2510 \text{ PSI}$$

bending

$$\gamma_2 = \frac{M_y/2}{I} = \frac{2176}{0.722} = 3014 \text{ PSI}$$

$$\gamma_{\text{net}} = \gamma_1 + \gamma_2 = 2510 + 3014 = \underline{\underline{5524 \text{ PSI}}} < 24,400 \text{ PSI}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN Steam Seismic Supports Calculated by: m/Kenney Date: 8/1/84
 Checked by: R.L.Treado Date: 8/9/84
 Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 63 of 103

Support MS-R2A Summary Table

Item	Type of Stress	Calculated stress (PSI)	Allowable stress (PSI)
Item 2 clevis	Pullout SHEAR	3,083	24,400
	Bolt hole tension	2,968	32,400
	SHEAR	2,968	24,400
	BENDING	4,521	40,600
	Axial compression	2,180	16,900
Item 2 weld to MS Pipe	Axial compression and bending	0.24 (Note 1)	1.0 (Note 1)
	SHEAR	7,854	24,400
Item 2 weld to MS Pipe	SHEAR	6,901	24,400
Item 3 clevis	Pullout SHEAR	3083	24,400
	Bolt hole tension	4,197	32,400
	Axial compression	3,083	22,900
Item 3 clevis to Base plate weld	SHEAR	3,875	24,400

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MNW Seismic Supports Calculated by: J. Kennedy Date: 8/1/84
 _____ Checked by: R. Russell Date: 8/1/84
 _____ Reviewed by: J.J. Date: 8/2/84

Project: 03-03

Page 64 of 103

Summary Table (cont.)

Item	TYPE of STRESS	Calculated Stress (PSI)	Allowable Stress (PSI)
Item 3 weld to Item 4	SHEAR	3,487	24,400
Item 4	SHEAR	1,633	24,400
	BENDING	22,564	40,600
Item 4 weld to Item 5	SHEAR	1,212	24,400
	SHEAR	5,232	24,400
Clip Angle	SHEAR	1,596	21,600
	BENDING	936	40,600
Item 5 PLATE	Axial compression	1,886	22,700
	BENDING	6,554	40,600
	Axial compression AND BENDING	0.24 (Note 1)	1.0 (Note 1)
Item 5 weld to 21 WF	SHEAR	5,524	24,400

Notes

- (1) Value is not stress in psi but stress ratio (non dimensional).

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: Main Steam Seismic Supports Calculated by: M. Kennedy Date: 8/1/84
 Checked by: R.C. Tamm Date: 8/19/84
 Reviewed by: J.J. Date: 8/22/84

Project: 83-03

Page 65 of 103

Support MS-R3A

DESCRIPTION



MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Steam Seismic Supports

Calculated by: M. Kennedy

Date: 8/1/84

Checked by: R. J. Tracy

Date: 8/9/84


Reviewed by: ✓

Date: 8-22-84

Project: 83-03

Page 66 of 103

Item 2 Clevis & Bolt



Clevis Plate

Pullout shear

$$Area = 2(\pi(Rt)) = 2(\pi(2 \times .5)) = 4.0 \text{ in}^2$$

$$\gamma = \frac{P}{A} = \frac{7710}{4} = \underline{\underline{1928 \text{ psi}}} < 24400 \text{ psi}$$

Bolthole tension

$$Area = 2t(2r - \text{hole d})$$

$$= 2(.5)(2(2.0) - (1 + 1.6)) = 2.938 \text{ in}^2$$

$$\delta = \frac{P}{A} = \frac{7710}{2.938} = \underline{\underline{3624 \text{ psi}}} < 32400 \text{ psi}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main stem seismic supports

Calculated by: n Kennedy
Checked by: R Trusk
Reviewed by: JJ

Date: 8/1/84
Date: 9/9/84
Date: 2-22-84

Project: 83-03

Page 67 of 103

Axial compression

$$Area = 2t(2r) = 2(.5)(2(2.0)) = 4.0 \text{ in}^2$$

$$\sigma = P/A = 7710/4.0 = 1928 \text{ PSI}$$

$$l = 10.0, C_c = 126.5$$

$$r = t/\sqrt{12} = 0.144$$

$$K = 2.0, E = 29.2 \times 10^3 \text{ KSI}$$

} see Appendix B

$$f_a = \frac{2}{3} \frac{\pi^2 E}{\left(\frac{C_c}{r}\right)^2} = 10.0 \text{ KSI}$$

$$\underline{1928 \text{ PSI} < 10,000 \text{ PSI}}$$

Bolt shear

$$Area = 2 \cdot \frac{\pi}{4} d^2 = 2 \cdot \frac{\pi}{4} (1)^2 = 1.571 \text{ in}^2$$

$$\sigma = P/A = 7710/1.571 = \underline{4908 \text{ PSI} < 24400 \text{ PSI}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Steam Seismic Supports


Calculated by: mg Kennedy
Checked by: RCTranch
Reviewed by: JJ

Date: 8/1/84
Date: 7-11-89
Date: 2-22-84

Project: 83-03

Page 68 of 107

Clevis Plate weld to Main Steam Pipe



TREAT weld AS LINE

$$\begin{aligned} \text{Area} &= 2 (2l + 2w) \sqrt{\frac{3}{2}} \text{ leg length} \\ &= 2 (2 \sqrt{2}(0.25)) + 2(0.5) \sqrt{\frac{3}{2}} (0.25) \\ &= 6.604 \text{ in}^2 \end{aligned}$$

Tension / compression

$$N_c = \frac{\sqrt{3/2} P}{A} = \frac{\sqrt{3/2} (7710)}{6.604} = 826 \text{ PSI}$$

SHEAR

$$N_s = \frac{\sqrt{3/2} P}{A} = \frac{\sqrt{3/2} (7710)}{6.604} = 826 \text{ PSI}$$

$$T_{net} = \sqrt{N_c^2 + N_s^2} = \sqrt{(826)^2 + (826)^2} = \underline{\underline{1168 \text{ PSI}}} \quad < 24400 \text{ PSI}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: M Kennedy
Checked by: R C French
Reviewed by: JJ


Date: 3/1/84
Date: 7/9/84
Date: 2/22/84

Project: 83-03

Page 69 of 103

Item 3 long clevis w/bolt

bolt stress same as above



$$X = 139.5 + \tan 6^\circ + 16.5 + \tan 6^\circ$$

$$= 16.40"$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: Main Steam Seismic Supports

Calculated by: m Kennedy
Checked by: R C Truett
Reviewed by: JJ


Date: 8/1/84
Date: 3/9/84
Date: 7/22-84

Project: 83-03

Page 70 of 103



BASE PLATE TO I BEAM WELD



TREAT weld as line

$$\text{Area} = 4 \sqrt{\frac{3}{2}} \text{ leg length} \\ = 4(5.0) \sqrt{\frac{3}{2}} (.375) = 5.303 \text{ in}^2$$

$$Z = (\sqrt{s^2 + \frac{3}{2}s^2}) \sqrt{\frac{3}{2}} \text{ leg length} \\ = (\sqrt{5.0^2 + \frac{3}{2}5.0^2}) \sqrt{\frac{3}{2}} (.375) = 8.839 \text{ in}^3$$

Tension/compression

$$\gamma_1 = \frac{P \cos \theta}{A} = \frac{7710 \cos 60^\circ}{5.303} = 1446 \text{ PSI}$$

BENDING

$$\gamma_2 = \frac{P \sin \theta}{Z} = \frac{7710 \sin 60^\circ (13.5)}{8.839} = 1231 \text{ PSI}$$

SHEAR

$$\gamma_3 = \frac{P \sin \theta}{A} = \frac{7710 \sin 60^\circ}{5.303} = 152 \text{ psi}$$

$$\gamma_{\text{net}} = \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(1446 + 1231)^2 + (152)^2} = \underline{\underline{2681 \text{ PSI}}} \\ \leq \underline{\underline{24400 \text{ PSI}}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Steam Seismic Supports


Calculated by: m Kennedy
Checked by: R Granchi
Reviewed by: JJ

Date: 8/1/84
Date: 8/9/84
Date: 8/22/84

Project: 83-03

Page 71 of 103

Clevis to Plate Weld



$$\begin{aligned} A &= 2(2e+2w) \frac{5}{2} \text{ leg length} \\ &= 2(2(4.0) + 2(0.5)) \frac{5}{2} (.25) \\ &= 3.182 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} z &= 2(bd + \frac{d^2}{3}) \frac{5}{2} \text{ leg length} \\ &= 2((0.5)(4.0) + \frac{4.0^2}{3}) \frac{5}{2} (.25) \\ &= 2.593 \text{ in}^3 \end{aligned}$$

Tension/Compression

$$\gamma_1 = \frac{P_{tensile}}{A} = \frac{7710 \cos 6}{3.182} = 2410 \text{ PSI}$$

Bending, N.C.

$$\gamma_2 = \frac{P_{bend, N.C.}}{z} = \frac{7710 \sin 6 (13.5)}{2.593} = 4196 \text{ PSI}$$

Shear

$$\gamma_3 = \frac{P_{shear}}{A} = \frac{7710 S.N.C.}{3.182} = 253 \text{ PSI}$$

$$\begin{aligned} \gamma_{net} &= \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(2410 + 4196)^2 + (253)^2} \\ &= 6611 \text{ PSI} < 24,400 \text{ PSI} \end{aligned}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: Main Stem Seismic Supports Calculated by: M Kennedy Date: 8/1/84
 _____ Checked by: R J French Date: 8/9/84
 _____ Reviewed by: JJ Date: 2-22-84

Project: 83-03

Page 72 of 103

Clevis Plate

Pullout shear & Bolt hole tension are the same as Item 2



$$A = 2lw = 2(4 \times 5) = 40 \text{ in}^2$$

$$I = 2 \frac{wl^3}{12} = \frac{2(5)(4)^3}{12} = 533 \text{ in}^4$$

$$C = 2.0 \text{ in}$$

BENDING

$$\delta = \frac{Mc}{I} = \frac{P \sin 60^\circ C}{5333} = \frac{7710 \sin 60^\circ (13.5)^2}{5333} = 4080 \text{ psi}$$

$$\underline{\underline{< 40,600 \text{ psi}}}$$

Axial compression

$$\delta = \frac{Pcos\theta}{A} = \frac{7710 cos 60^\circ}{4} = 1917 \text{ psi}$$

$$\left. \begin{array}{l} l = 13.5 \text{ "}, C_c = 126.5 \\ r = \frac{l}{2\sqrt{2}} = 0.144 \text{ "} \end{array} \right\}$$

See Appendix B

$$K = 2.0, E = 29.2 \times 10^3 \text{ ksi}$$

$$F_A = \frac{\pi^2 E}{\left(\frac{Kl}{r}\right)^2} = \frac{\pi^2}{3} \frac{(29.2 \times 10^3)}{\left(\frac{2 \times 13.5}{0.144}\right)^2} = 5.5 \text{ ksi}$$

$$\underline{\underline{1917 \text{ psi} < 5,500 \text{ psi}}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: M Kennedy Date: 8/1/84
 Checked by: RJ French Date: 2/9/84
 Reviewed by: JL Date: 2-25-84

Project: 83-03

Page 73 of 103


Axial compression AND BENDING

$$\frac{f_a}{f_a} + \frac{f_b}{f_b} \leq 1.0$$

$$\frac{1917}{5500} + \frac{4080}{40600} = \underline{\underline{0.45 < 1.0}}$$

Item 4 I-BEAM

6 WF 15.5



$$I = 30.3 \text{ in}^4 \quad P 1-21 \quad \text{Ref (4)}$$

$$A = 4.62 \text{ in}^2 \quad P 3-24 \quad \text{Ref (4)}$$

$$\text{Clear Area} = \text{web } \tau \times \text{depth} = .25 (6.0) = 1.5 \text{ in}^2$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: MAIN STREAM Seismic Supports

Calculated by: M Kennedy
Checked by: R French
Reviewed by: JJ

Date: 8/1/94
Date: 8/9/84
Date: 12/2-24

Project: 83-03

Page 74 of 103



TREAT BEAM AS SIMPLY SUPPORTED

$$M_a = P \sin 60^\circ l \quad \text{where } l = 13.5'' \\ = 7710 \sin 60^\circ (13.5) = 10,880 \text{ in-lb}$$

From Moment Load

$$R_A = -R_B = \frac{M_a}{l} = \frac{10,880}{28.35} = 384 \text{ lb}$$

From Point Load

$$a = 11.95 \quad l = 28.35 \quad \text{Ref (5) CASE 1-e p.97}$$

$$R_A = \frac{P \cos 60^\circ (l-a)}{l} = \frac{7710 \cos 60^\circ (28.35 - 11.95)}{28.35} = 4436 \text{ lb}$$

$$R_B = \frac{P \cos 60^\circ a}{l} = \frac{7710 \cos 60^\circ (11.95)}{28.35} = 3232 \text{ lb}$$

$$M_{\max} = P \cos 60^\circ \frac{(l-a)a}{l} = \frac{7710 \cos 60^\circ (28.35 - 11.95) 11.95}{28.35} \\ = 53,007 \text{ in-lb.}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS
Calculated by: Z Kennedy Date: 8/1/84
Checked by: R C Clark Date: 8/7/84
Reviewed by: ✓ Date: 8-22-84

Project: 83-03

Page 75 of 103

Net Loads

$$R_A = 4436 + 384 = 4820 \text{ lb.}$$

$$R_B = 3232 + 384 = 3,616 \text{ lb.}$$

$$M = M_a + M_{max} = 10880 + 53,007 = 63,887 \text{ in. lb.}$$

BEAM STRESSES

SHEAR STRESS

$$\tau = R_A/A_s = \frac{4820}{1.5} = \underline{\underline{3213 \text{ psi}}} < 24,400 \text{ psi}$$

BENDING STRESS

$$\sigma = \pm \frac{Mc}{I} = \frac{63,887 (3.0)}{30.3} = \underline{\underline{6325 \text{ psi}}} < 40,600 \text{ psi}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: M Kennedy Date: 8/1/84
Checked by: R Tinkha Date: 7/9/87
Reviewed by: JJ Date: 7/22-87

Project: 83-03

Page 76 of 103

Item 4 weld to 84⁰ 27WF 177 I-BEAM



TREAT WELD AS LINE

$$\begin{aligned} \text{Area} &= (2d + 2b + 2(b-t)) \sqrt{\frac{3}{2}} \text{ leg length} \\ &= (2(6.0) + 2(6.0) + 2(6.0-0.25)) \sqrt{\frac{3}{2}} (.25) \\ &= 6.276 \text{ in}^2 \end{aligned}$$

tension/compression

$$\gamma_1 = \frac{AL}{A} = \frac{7710 \sin 6}{6.276} = 128 \text{ psi}$$

SHEAR

$$\gamma_3 = \frac{TQ}{A} = \frac{4820}{6.276} = 768 \text{ psi}$$

$$\gamma_{\text{net}} = \sqrt{\gamma_1^2 + \gamma_3^2} = \sqrt{(128)^2 + (768)^2} = \underline{\underline{779 \text{ psi} < 24,400 \text{ psi}}}$$

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036


Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: M Kennedy Date: 8/1/84
 Checked by: R Tranchard Date: 3/9/84
 Reviewed by: JJ Date: 2/22/84


Project: 83-03

Page 77 of 103

Item 4 weld to 90° 27WF 177 I-BEAM



'A' weld



TREAT weld AS LINE

$$I \bar{x} = 2 \times 3.5 \times 1.75 \\ \bar{x} = 1.114"$$

For side weld

$$A = 2t \sqrt{2} \\ = 4(\frac{3}{16}) \sqrt{2} = 0.53 \text{ in}^2$$

For TOP & BOTTOM welds

$$A = 2t \sqrt{2/x} \\ = 3.5 (\frac{3}{16}) \sqrt{2} = 0.928 \text{ in}^2$$

$$\sum A = 0.53 + 0.928 = 1.458 \text{ in}^2$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: M. Kennedy Date: 8/1/84
 Checked by: R. Trinchero Date: 9/9/84
 Reviewed by: JJ Date: 2/22/84

Project: 83-d3

Page 78 of 103

compression / tension

$$\gamma_1 = \frac{AL}{A} = \frac{7710 \sin 6}{1.458} = 553 \text{ PSI}$$

SHEAR

$$\gamma_3 = \frac{T_L}{A} = \frac{3616}{1.458} = 2480 \text{ PSI}$$

$$\gamma_{\text{Net}} = \sqrt{\gamma_1^2 + \gamma_3^2} = \sqrt{(553)^2 + (2480)^2} = \underline{\underline{2541 \text{ PSI}}}$$

$$\angle 24400 \text{ PSI}$$

'B' weld



$$A = 2 \times 5\frac{1}{2} \text{ leg length} \\ = 2(4.0) 5\frac{1}{2} (\frac{5}{16}) \\ = 1.768 \text{ in}^2$$

tension / compression

$$\gamma_1 = \frac{AL}{A} = \frac{7710 \sin 6}{1.768} = 456 \text{ PSI}$$

SHEAR

$$\gamma_3 = \frac{T_L}{A} = 3616 / 1.768 = 2095 \text{ PSI}$$

$$\gamma_{\text{Net}} = \sqrt{\gamma_1^2 + \gamma_3^2} = \sqrt{456^2 + 2095^2}$$

$$= \underline{\underline{2095 \text{ PSI} \angle 24,400 \text{ PSI}}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 8/1/84
 Checked by: PC Tienel Date: 8/4/84
 Reviewed by: JJ Date: 8/5/84

Project: 83-03

Page 79 of 103

Support MS-R3A Summary Table

Item	Type of Stress	Calculated Stress (PSI)	Allowable Stress (PSI)
2	Pullout SHEAR	1,928	24,400
	Bolt hole tension	2624	32,400
	AXIAL compression	1,928	10,000
	Bolt SHEAR	1,908	24,400
clevis PLATE weld to MS. PIPE	SHEAR	1,168	24,400
Item 3 weld to I-BEAM	SHEAR	2,681	24,400
clevis PLATE to BASE PLATE weld	SHEAR	6,611	24,400
3	BENDING	4,080	40,600
	AXIAL compression	1,917	5,500
	AXIAL comp. & BENDING	0.45 (Note 1)	1.0 (Note 1)

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTSCalculated by: my Kennedy
Checked by: R (Tranchy)
Reviewed by: JJDate: 5/1/84
Date: 5/7/84
Date: 5/22/84Project: 83-03Page 80 of 103

Summary Table (cont.)

Item	Type of Stress	Calculated stress (PSI)	Allowable Stress
4	SHEAR	3,213	24,400
	BENDING	6,325	40,600
Item 4 weld to 27WF I-BEAM	SHEAR	779	24,400
Item 4 weld to 27WF I-BEAM	SHEAR	2541	24,400

Notes

- (1) Value is not stress in psi but stress ratio (non-dimensional).

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: m) Kennedy

Date: 8/1/84

Checked by: R. French

Date: 2/9/84

Reviewed by: JJ


Date: 2/22/84

Project: 83-03

Page 81 of 103

Support MS-R4A

DESCRIPTION



$P = 9950 \text{ lb}$
Ref (1).

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: M Kennedy
Checked by: R C Trenary
Reviewed by: JJ

Date: 8/1/84
Date: 7/9/84
Date: 2/22/84

Project: 83-03

Page 82 of 103



SECT. B-B

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Stream Seismic Supports



Calculated by: M Kennedy
Checked by: R French
Reviewed by: JJ

Date: 8/1/84
Date: 8/9/84
Date: 8/22/84


Project: 83-03

Page 93 of 103

Item 9 Clevis



Clevis Plate Weld to M.S. Pipe



$$A = 2(2e + 2w) \frac{5}{2} \text{ leg length}$$

$$= 2(2(9.0) + 2(5)) \frac{5}{2} (.25)$$

$$= 6.718 \text{ in}^2$$

$$Z = 2(lw + \frac{w^2}{3}) \frac{5}{2} \text{ leg length}$$

$$= 2(.5(9.0) + \frac{9.0^2}{3}) \frac{5}{2} (.25)$$

$$= 11.137 \text{ in}^3$$

BENDING

$$\gamma_2 = \frac{M}{Z} = \frac{P \cdot d}{Z} = \frac{9,950 (80)}{11.137} = 7147 \text{ psi}$$

SHEAR

$$\gamma_3 = \frac{V}{A} = \frac{9950}{6.718} = 1481 \text{ psi}$$

$$\gamma_{\text{net}} = \sqrt{\gamma_2^2 + \gamma_3^2} = \sqrt{(7147)^2 + (1481)^2}$$

$$= 7299 \text{ psi} < 24,400 \text{ psi}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: m Kennedy
Checked by: R French
Reviewed by: JJ

Date: 3/1/84
Date: 3/1/84
Date: 3/2/84

Project: P3-03

Page 84 of 103

Euler Stress

$$I = 2 \frac{wL^3}{12} = 2 \frac{(0.5)(9)^3}{12} = 60.75 \text{ in}^4$$

$$C = 2.0 \text{ in}$$

$$A = 2(wl) = 2(0.5 \cdot 9.0) = 9.0 \text{ in}^2$$

BENDING

$$\delta = \frac{Mc}{I} = \frac{P \cdot d \cdot c}{I} = \frac{(9,950)(8.0)(2.0)}{60.75} = \underline{\underline{2,620 \text{ psi}}}$$

40,600 psi

SHEAR

$$\gamma = P/A = \frac{9,950}{9} = \underline{\underline{1,106 \text{ psi} < 24,400 \text{ psi}}}$$

Pullout Shear

$$A = 2(2R_t) = 2(2(2.0)(1.5)) = 4.0 \text{ in}^2$$

$$\gamma = P/A = \frac{9950}{4} = \underline{\underline{2488 \text{ psi} < 24,400 \text{ psi}}}$$

(Bolt hole tension same as for Item 8 Below)

Bolt

$$\text{Area} = 2 \frac{\pi}{4} (1.0)^2 = 1.571 \text{ in}^2$$

$$\gamma = P/A = \frac{9,950}{1.571} = \underline{\underline{6,333 \text{ psi} < 24,400 \text{ psi}}}$$


MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 8/1/84
 Checked by: RCTrewh Date: 8/9/84
 Reviewed by: JJ Date: 8/22/84


Project: 83-03

Page 85 of 103

Item 8 clevis & Bolt STANDARD Part EA1-A



BASE PLATE WELD TO GWF 15.5 I-BEAM




TREAT WELD AS LINE

$$\begin{aligned} A &= 4 \times 5 \frac{1}{2} \text{ leg length} \\ &= 4(5.0) \frac{1}{2} (.25) \\ &= 5.536 \text{ in}^2 \end{aligned}$$

TENSION / compression

$$\gamma_{net} = \frac{P}{A} = \frac{9,950}{3.536} = \underline{2,814 \text{ PSI} < 24,400 \text{ PSI}}$$

Clevis PLATE weld to BASE PLATE



$$\begin{aligned} \text{AREA} &= 4(l+w) \frac{1}{2} \text{ leg length} \\ &= 4(1.5+4) \frac{1}{2} (.25) = 3.182 \text{ in}^2 \end{aligned}$$

TENSION / compression

$$\gamma_{net} = \gamma_i = \frac{P}{A} = \frac{9,950}{3.182} = \underline{3127 \text{ PSI} < 24,400 \text{ PSI}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 8/1/84
 _____ Checked by: R L French Date: 3/9/84
 _____ Reviewed by: JJ Date: 2-22-84

Project: 83-03

Page 86 of 103

Clevis plate

Pullout shear

$$A = 2(2 \pi t) = 2(2(2.0)(.5)) = 4.0 \text{ in}^2$$

$$\sigma_c = P/A = \frac{9950}{4.0} = \underline{\underline{2488 \text{ PSI}}} < 24400 \text{ PSI}$$

Bolthole Tension

$$A = 2(2R - \text{hole dia})t = 2(4 - (1 + \frac{1}{8})) .5 = 2.938 \text{ in}^2$$

$$\sigma_t = P/A = \frac{9950}{2.938} = \underline{\underline{3387 \text{ PSI}}} < 32400 \text{ PSI}$$

Axial compression

$$A = \text{min Area} = 2(2 \pi t) = 2(2(2.0).5) = 4.0 \text{ in}^2$$

$$\sigma_c = P/A = \frac{9950}{4.0} = 2488 \text{ PSI}$$

$$l = 2.75", C_c = 126.5$$

$$r = t/\sqrt{r_2} = 0.144 \text{ in}$$

$$K = 2.0, S_y = 36.0 \text{ KSI}$$

$$f_a = 2/3 \left(1 - \left(\frac{Kl}{r} \right)^2 / 2 C_c^2 \right) S_y = 22.9 \text{ KSI}$$

$$\underline{\underline{2488 \text{ PSI}}} < 22,900 \text{ PSI}$$

see Appendix B


MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 8/1/84
 Checked by: R Jacobs Date: 3/9/87
 Reviewed by: JJ Date: 3/22/87

Project: 83-03

Page 87 of 103

TRIPOD STRUCTURE
BEAM FORCES



BEAMS SEE LOAD IN TENSION/compression ONLY

Method of tension coefficients

$$w_x = 0.0 ; w_y = 9,950 \text{ lb} ; w_z = 0.0$$

$$x_1 t_{AD} + x_2 t_{BD} + x_3 t_{CD} + w_x = 0.0$$

$$y_3 t_{CD} + w_y = 0$$

$$z_2 t_{BD} + w_z = 0 \rightarrow t_{BD} = 0 \quad \text{and } F_{BD} = 0$$

x_N, y_N, z_N are the projected lengths onto the respective axes of beams \overline{AD} ($N=1$) \overline{BD} ($N=2$) and \overline{CD} ($N=3$).

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Stream Seismic Supports

Calculated by: M Kennedy
Checked by: R Tranch
Reviewed by: JJ

Date: 8/1/84
Date: 11/1/84
Date: 12/22/84

Project: 83-83

Page 88 of 103

$$t_{CD} = -\frac{w_y}{y_3} \quad y_3 = -\overline{CD} \sin 47.49^\circ \\ = 86.0 \sin 47.49^\circ = -63.396 \text{ in}$$

$$t_{CD} = \frac{-9950}{-63.396} = +156.9 \text{ lb/in}$$

$$x_1 = -\overline{AD} = -54.0 \text{ in.}$$

$$x_3 = -\overline{CD} \cos 47.49^\circ = -86 \cos 47.49^\circ = -58.112 \text{ in}$$

$$x_1 t_{AD} + x_3 t_{CD} + w_x = 0$$

$$-54.0 t_{AD} + (-58.112) (+156.9) = 0$$

$$t_{AD} = + \frac{58.112 (156.9)}{-54.0} = -166.8 \text{ lb/in}$$

$$F_{CD} = \overline{CD} t_{CD} = 86.0 (+156.9) = +13,493 \text{ lb}$$

$$F_{AD} = \overline{AD} t_{AD} = 54.0 (-166.8) = -9,115 \text{ lb}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Steam Seismic Supports

Calculated by: m Kennedy
Checked by: R French
Reviewed by: JJ

Date: 8/1/84
Date: 8/9/84
Date: 8-22-84

Project: 83-03

Page 89 of 103

Item 7 LWF 15.5 I-BEAM

$$A = 4.62 \text{ in}^2$$

Ref (4) p 1-21

Axial compression

$$\delta = F_{AO}/A = \frac{9115}{4.62} = 1973 \text{ PSI}$$

$$l = 54.0", C_c = 126.5$$

$$r = 1.45"$$

Ref (4) p 1-21

$$K = 1.0 \quad S_y = 36.0 \text{ KSI}$$

see Appendix B

$$f_a = \frac{2}{3} \left(1 - \frac{(K_e)^2}{2 C_c^2} \right) S_y$$

$$= \frac{2}{3} \left(1 - \frac{\left(\frac{(1.0)(54.0)}{1.45}\right)^2}{2 (126.5)^2} \right) 36.0 = 23.0 \text{ KSI}$$

1973 PSI < 23,000 PSI

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: MAIN Steam Seismic Supports

Calculated by: P. Kennedy Date: 8/1/84
Checked by: R. French Date: 8/9/84
Reviewed by: JJ Date: 8-22-84

Project: 83-03

Page 90 of 103

Item 7 weld to existing 27 WF 177 I-BEAM



TREAT weld AS LINE

$$\begin{aligned} \text{Area} &= (2d + 2w + 2(w-t)) \sqrt{\frac{1}{2}} \text{ leg length} \\ &= (2(6.0) + 2(6.0) + 2(5.75)) \sqrt{\frac{1}{2}} (.25) \\ &= 6.276 \text{ in}^2 \end{aligned}$$

tension/compression

$$\sigma_{\text{net}} = \gamma_c = \frac{FAD}{A} = \frac{9115}{6.276} = \underline{1452 \text{ PSI} < 24400 \text{ PSI}}$$

Item 2 - 3" x 2" x 1/4" L (2)

$$\text{Area} = 2(l_1 w_1 + l_2 w_2) = 2(3(.25) + 1.75 (.25)) = 2.375 \text{ in}^2$$

Axial compression

$$\delta = \frac{FCD}{A} = \frac{13493}{2.375} = 5,681 \text{ PSI}$$

$$l^* = 77.0" \quad C_e = 126.5$$

$$r = .43"$$

Ref (4) P 1-33 (Axis z-z)

$$K = 1.0 \quad S_y = 36.0 \text{ KSI}$$

$$F = 29.2 \times 10^3 \text{ KSI}$$

See Appendix B

$$* 86.0 - 9.0 = 77.0" (\text{inner bolt to inner bolt length})$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 8/1/84
 _____ Checked by: R French Date: 8/9/84
 _____ Reviewed by: JJ Date: 8-22-84

Project: 83-03


Page 91 of 103

$$F_a = \frac{2}{3} \frac{\pi^2 E}{\left(\frac{kL}{r}\right)^2}$$

$$= \frac{2}{3} \frac{\pi^2 29.2 \times 10^3}{\left(\frac{(1.0)(77.0)}{14.3}\right)^2} = 6.0 \text{ KSI}$$

5,681 PSI < 6,000 PSI

This Assumes Buckling About the z-z Axis



MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: M Kennedy

Date: 8/1/84

Checked by: R O'Brien

Date: 8/1/84

Reviewed by: JJ

Date: 8-52-84

Project: 83-03

Page 92 of 13

Item 3 PLATE w / (2) 3/4" φ x 2" LG. B.C.N




PLATE STRESS

$$Area = w(l - \text{bolt } d) = (375)(12.0 - (0.75 + 1.6)) = 4,195 \text{ in}^2$$

Tension / compression

$$\delta = \frac{F_{CD} \sin 21.8}{A} = \frac{13,493 \sin 20}{4,195} = \underline{1100 \text{ PSI}} < \underline{32,400 \text{ PSI}}$$

SHEAR

$$\gamma = \frac{F_{CD} \cos 21.8}{A} = \frac{13,493 \cos 20}{4,195} = \underline{3,022} < \underline{24,400 \text{ PSI}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Steam Seismic Supports


Calculated by: JKennel
Checked by: RFrench
Reviewed by: ✓

Date: 8/1/84
Date: 3/9/84
Date: 8/2/84

Project: 83-03

Page 93 of 103

Item 3 Plate weld to 27 WF-177



TREAT weld AS LINE

$$\begin{aligned} A &= 2(l+w) \frac{\sqrt{3}}{2} \text{ leg length} \\ &= 2(12.0 + .375) \frac{\sqrt{3}}{2} (.25) \\ &= 4.375 \text{ in}^2 \end{aligned}$$

Tension / compression

$$\gamma_1 = \frac{f_{c0} \sin 20.0}{A} = \frac{13,493 \sin 20.0}{4.375} = 1055 \text{ PSI}$$

Shear

$$\gamma_3 = \frac{f_{c0} \cos 20.0}{A} = \frac{13,493 \cos 20.0}{4.375} = 2898 \text{ PSI}$$

$$\gamma_{\text{Net}} = \sqrt{\gamma_1^2 + \gamma_3^2} = \sqrt{(1055)^2 + (2898)^2} = 3084 \text{ PSI}$$

< 24400 PSI

Bolts (Items 4 & 3)

$$\text{Area} = 4 \left(\frac{\pi}{4} 0^2 \right) = \pi (.75)^2 = 1.767 \text{ in}^2$$

$$\gamma = \frac{f_{c0}}{A} = \frac{13493}{1.767} = 7636 \text{ PSI} < 24400 \text{ PSI}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM SEISMIC SUPPORTS

Calculated by: M. Kennedy
Checked by: RCTree
Reviewed by: JJ

Date: 8/1/84
Date: 8/4/84
Date: 8-22-84

Project: 83-03

Page 94 of 103

Item 4 Plate w(2) 3/4" ϕ x 2" LG B E N




plate stress

$$\text{Area} = \omega (e - \text{volt } d) = (.375)(9.0 - (.75 + k_0)) = 3.070 \text{ in}^2$$

Tension / compression

$$f = \frac{F_c D \sin 45.0}{A} = \frac{13,493 \sin 45.0}{3,070} = \underline{\underline{3,108 \text{ PSI}}}$$

< 32,000 PSI

SHEAR

$$\gamma = \frac{FCD \cos 45.0}{A} = \frac{13493 \cos 45.0}{3,070} = \underline{\underline{3,108 \text{ PSF}}}$$

L 24,400 PS =

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: M Kennedy
Checked by: R L Francis
Reviewed by: JJ


Date: 8/1/84
Date: 8/9/84
Date: 8/22/84

Project: 83 03

Page 95 of 103

Item 4 PLATE weld to Item 7

$$\begin{aligned} \text{Area} &= 2(\text{leg width})^{\sqrt{3}/2} \text{ leg length} \\ &= 2(9.0 + .375)^{\sqrt{3}/2} (.25) = 3.315 \\ \text{tension / compression} \end{aligned}$$



$$\gamma_1 = \frac{f_{cD} \sin 45}{A} = \frac{13493 \sin 45}{3.315} = 2878 \text{ psi}$$

SHEAR

$$\gamma_3 = \frac{f_{cD} \cos 45}{A} = \frac{13493 \cos 45}{3.315} = 2878 \text{ psi}$$

$$\begin{aligned} \gamma_{\text{net}} &= \sqrt{(\gamma_1)^2 + (\gamma_3)^2} \approx \sqrt{(2878)^2 + (2878)^2} \\ &= 4070 \text{ psi} \angle 24.400^\circ \end{aligned}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: M. Kennedy
Checked by: R.C. French
Reviewed by: J.V.

Page #: 87,184
Date: 8/19/84
Reviewed by: J.V.
Date: 8/22/84

Project: 83-03

Page 96 of 103

Support MS-RUA Summary TABLE

ITEM	TYPE OF STRESS	CALCULATED STRESS (PSI)	ALLOWABLE STRESS (PSI)
Item 9 weld to M.S. Pipe	SHEAR	7,299	24,400
	BENDING	2,620	40,600
	SHEAR	2,488	24,400
Item 8 weld to 6WF	SHEAR	2,814	24,400
Item 8 weld	SHEAR	3,127	24,400
	SHEAR	2,488	24,400
	Bolt/Hole TENSION	3,387	32,400
Item 7	AXIAL compression	2,488	22,900
	AXIAL compression	1,973	23,000
	SHEAR	1,452	24,400
Item 2	AXIAL compression	5,681	6,000
Item 3	TENSION/ compression	1,100	32,400
	SHEAR	3,022	24,400

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTSCalculated by: Ind Kennedy
Checked by: RCTrench
Reviewed by: JJDate: 8/1/84
Date: 7/9/84
Date: 8/22/84Project: P3-d3Page 97 of 103

Summary Table (cont.)

Item	TYPE OF STRESS	CALCULATED Stress (PSI)	Allowable stress PSI
Item 3 weld to 27WF	SHEAR	3,084	24,400
Bolts	SHEAR	7,636	24,400
Item 4	Tension/ compression	3,108	32,400
	SHEAR	3,108	24,400
Item 4 weld to Item 7	SHEAR	4,070	24,400
clevis Bolt	SHEAR	6,333	24,400

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: m)Kane

Date: 8/1/84

Checked by: E)Tench

Date: 8/4/84

Reviewed by: JJ


Date: 8-22-84

Project: 83-03


Page 98 of 103

Support MARK No. MS-R5A

DESCRIPTION



LOCATION PLAN



MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036



Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: McKenney
Checked by: R. French
Reviewed by: JJ

Date: 8/1/84
Date: 8/9/84
Date: 8-22-84

Project: 83-03

Page 99 of 103



MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS

Calculated by: E Kennedy

Date: 8/1/84

Checked by: PC French

Date: 8/4/84

Reviewed by: ✓


Date: 8/22/84

Project: 83-03

Page 100 of 103

Item 3 Pipe Attachment w/ (1) 1" ϕ x 3 $\frac{3}{4}$ " LG B.C.N.

Bolt rated to 10,000 lb
Ref (2)



Pullout shear

$$Area = 2(2r t) = 2(2(2.0).5) = 4.0 \text{ in}^2$$

$$\sigma = P/A = \frac{8330}{4.0} = \underline{\underline{2083 \text{ PSI}}}$$

< 24,400

Clevis Bolt Hole Tension Stress

$$Area = 2(2R - \text{hole dia})t = 2(2(2.0) - (1 + 1/16))(.5) = 2.938 \text{ in}^2$$

$$\sigma = \frac{P}{A} = \frac{8330}{2.938} = \underline{\underline{2835 \text{ PSI}}} < 32,400 \text{ PSI}$$

Axial compression

$$\text{let } Area_t = \text{minimum Area} = 2t w = 2(.5)(4.0) = 4.0 \text{ in}^2$$

$$\sigma = \frac{P}{A} = \frac{8330}{4.0} = 2083 \text{ PSI}$$

$$l \approx 9.0 ; C_c = 126.5$$

$$r = \frac{t}{\sqrt{2}} = \frac{.5}{\sqrt{2}} = .144$$

$$K = 2.0 ; S_y = 36.0 \text{ ksi}$$

See Appendix R

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 3/1/84
Checked by: R L French Date: 8/9/84
Reviewed by: JJ Date: 8/22/84


Project: 83-03 Page 101 of 103

$$f_a = \frac{2}{3} \left(1 - \left(\frac{c_e}{r} \right)^2 / 2c_e^2 \right) S_y$$

$$= \frac{2}{3} \left(1 - \left(\frac{207(1.0)}{144} \right)^2 / 2(125)^2 \right) 36.0 = 12.3 \text{ ksi}$$

2083 psi < 12,300 psi

Item 3 weld to 24"Ø P.PG



TREAT word AS LINE

$$\begin{aligned} \text{Area} &= \pi (2R + 2W) \frac{\sqrt{2}}{2} \text{ leg length} \\ &= \pi (2(9.0) + 2(.5)) \frac{\sqrt{2}}{2} (.25) \\ &= 6.718 \text{ in}^2 \end{aligned}$$

$$\gamma_{jet} = \gamma_3 = \frac{8330}{6.718} = \underline{\underline{1240 \text{ psi}}} < \underline{\underline{24,400 \text{ psi}}}$$

Item 2 Clevis & Bolt STANDARD PART EA1-A

Rates to 10000 16

Actual Load 9330 lb


MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM SEISMIC SUPPORTS Calculated by: M Kennedy Date: 8/14/84
 Checked by: E Crennel Date: 8/17/84
 Reviewed by: JJ Date: 8/22/84

Project: 83-03


Page 102 of 103

Item 2 Weld to existing 27WF177 I-BEAM



TREAT weld as line

$$\begin{aligned} A &= 4 \text{ S } \sqrt{\frac{1}{2}} \text{ leg length} \\ &= 4(5.0) \sqrt{\frac{1}{2}} (.25) \\ &= 3.536 \text{ in}^2 \end{aligned}$$



$$\begin{aligned} Z &= \left(S^2 + \frac{S^2}{3} \right)^{\sqrt{\frac{1}{2}}} \text{ leg length} \\ &= \left(S^2 + \frac{S^2}{3} \right)^{\sqrt{\frac{1}{2}}} (.25) \\ &= 5.893 \text{ in}^2 \end{aligned}$$

tension compression

$$\gamma_1 = \frac{P \sin 45}{A} = \frac{8330 \sin 45}{3.536} = 1666 \text{ PSI}$$

bending

$$\gamma_2 = \frac{P \cos 45}{Z} = \frac{8330 \cos 45 (3.25)}{5.893} = 3248 \text{ PSI}$$

SHEAR

$$\gamma_3 = \frac{P \cos 45}{A} = \frac{8330 \cos 45}{3.536} = 1666 \text{ PSI}$$

$$\gamma_{net} = \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(1666 + 3248)^2 + (1666)^2} = \underline{\underline{5189 \text{ PSI}}}$$

L 24400 PSI

MPR ASSOCIATES, INC.
 1050 Connecticut Ave., NW - Washington, DC 20036

Title: Main Stream Seismic Supports Calculated by: M.Karney Date: 8/1/84
 Checked by: R.L.Trench Date: 8/9/84
 Reviewed by: JJ Date: 8-22-84

Project: 83-03

Page 103 of 103

Support MS-R5A Summary TABLE

Item	TYPE OF STRESS	CALCULATED STRESS (PSI)	ALLOWABLE STRESS (PSI)
Item 3	SHEAR	2,083	24,400
	Bolt Hole tension	2,835	32,400
	Axial compression	2,083	12,300
Item 3 weld to M.S. Pipe	SHEAR	1,240	24,400
Item 2 weld to 27WF	SHEAR	5,189	24,400

Item	Calculated Load (lb)	Allowable Load (lb)
2	8,330	10,000

APPENDIX D

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports

Calculated by: mKennedy
Checked by: RCTribble
Reviewed by: JJohnson

Date: 8/1/84
Date: 8/1/84
Date: 1-22-84

Project: SEP PIPING SUPPORTS
83-03

Page 1 of 69

PURPOSE: The purpose of the following calculation is to analyze the feedwater seismic supports for Level D service conditions¹. LOADS used are from revised EG & G piping model loads documented in Appendix A.

References:

- (1) MPR calculation by M. Kennedy dated 8/2/84
"Seismic Support LOADS", Appendix A.
- (2) BERGEN PATERSON PIPE SUPPORT CATALOG #66
P. 46.
- (3) CRANE Technical Paper #410, 1981.
- (4) AISC Steel Const. MANUAL, 6th Ed.
- (5) ROARK AND YOUNG, Formulas for Stress AND STRAIN,
5th Ed.

(1) The snubber is analyzed separately in Appendix E. This calculation analyzes clevises, welds and structural members supplied with the snubber

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Deepwater Seismic Supports Calculated by: M Kennedy Date: 8/1/84
Checked by: R C Trench Date: 8/1/84
Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 2 of 69

Reference Drawings

Bergen - Paterson.

<u>Support</u>	<u>Dwg #</u>
RF - R1A	1849
RF - R2A	1850
RF - R3A	1851
RF - R4A	1852
RF - R5A	1853
RF - R6A	1854
X-4B-55-1	116

STANDARD DRAWINGS 64101
 64102

BURNS & ROE Dwg 4069.

GENERAL PHYSICS Dwg 19443, Sht. 2 of 3.

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: m Kennedy Date: 8/11/84
Checked by: RCTranch Date: 3/9/84
Reviewed by: JJ Date: 7/22/84

Project: 83-03

Page 3 of 69

Summary

Based on the following calculations, the feedwater seismic supports meet the stress requirements of the 1980 ASME Code, Section III, Subsection NF. The supports are considered Acceptable. A summary table follows each support evaluation.

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: Feedwater Seismic Supports Calculated by: M Kennedy Date: 9/1/84
 Checked by: R C Trends Date: 3/9/84
 Reviewed by: JJ Date: 1/22/84

Project: 83-03

Page 4 of 69

Support X-4B-55-1

Description




MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: mKangdy Date: 8/1/84
 Checked by: R.Chencl Date: 3/9/84
 Reviewed by: JT Date: 1/22/84

Project: 8303

Page 5 of 69



$$P_I = 1340 \text{ lb}$$

$$P_{II} = 2340 \text{ lb}$$


MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Service Supports Calculated by: M Kennedy Date: 8/1/84
 Checked by: R French Date: 3/6/84
 Reviewed by: JJ Date: 2/22/84

Project: 83-03

Page 6 of 69

Item 4 PIPE / CLEVIS ASSEMBLY



Pipe

$$\text{AXIAL LOAD} = AL = 4276 \text{ lb}$$

$$\text{TRANSVERSE LOAD} = \sqrt{(948)^2 + (510)^2} = 1076 \text{ lb}$$

$$\text{MOMENT LOAD} = \sqrt{(12,821)^2 + (23,733)^2}$$

$$= 26,975 \text{ in. lb.}$$

$$I = \frac{\pi}{64} (d_o^4 - d_i^4) = \frac{\pi}{64} (4.5^4 - 4.026^4) = 7.232 \text{ in}^4$$

$$c = \frac{4.5}{2} = 2.25 \text{ in.}$$

$$A = \frac{\pi}{4} (d_o^2 - d_i^2) = \frac{\pi}{4} (4.5^2 - 4.026^2) = 3.174 \text{ in}^2$$

Ref Computer
 Raw BBCYTVF
 P. 190
 member 65/345

SHEAR

$$\gamma = P_t / A = 1076 / 3.174 = \underline{339 \text{ PSI}} < \underline{24,400 \text{ PSI}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: M. Kennedy Date: 8/1/84
 _____ Checked by: R.C.Thorne Date: 8/9/84
 _____ Reviewed by: J.T. Date: 8-22-84

Project: 83-03

Page 7 of 69

Axial tension AND compression

Between location A & B

$$L = \text{Axial load} = 4,276 \text{ lb}$$

$$\delta = L/A = 4,276 / 3,174 = \underline{1,347 \text{ psi}} < 40,600 \text{ psi}$$

$$\left. \begin{array}{l} l = 27.5", C_c = 126.5 \\ r = 1.51" \end{array} \right\} \text{see Appendix B}$$

$$K = 2.0, S_y = 36.0 \text{ ksi}$$

$$\begin{aligned} F_a &= \frac{2}{3} \left(1 - \left(\frac{Kl}{r} \right)^2 / 2C_c^2 \right) S_y \\ &= \frac{2}{3} \left(1 - \left(\frac{(2.0)(27.5)}{1.51} \right)^2 / 2(126.5)^2 \right) 36.0 = 23.0 \text{ ksi} \end{aligned}$$

$$\underline{1347 \text{ psi} < 23,000 \text{ psi}}$$

BENDING AT Feedwater Pipe

$$\delta = \frac{Mc}{I} = \frac{26,975 (2.25)}{7,232} = 8,392 \text{ psi}$$

$$1,347 + 8,392 = \underline{9,739 \text{ psi} < 40,600 \text{ psi}}$$

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports

Calculated by: M. Kenna Date: 8/1/84
Checked by: R.C. Herod Date: 8/19/84
Reviewed by: J.J. Date: 8/22/84

Project: 83-03

Page 8 of 49

Axial Compression and Bending

$$\frac{f_a}{f'_a} + \frac{f_b}{f'_b} \leq 1.0$$

$$\frac{1347}{23,000} + \frac{8,392}{40,600} = .27 < 1.0$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: Feedwater Seismic Supports Calculated by: m Kennedy Date: 8/1/84
 _____ Checked by: R French Date: 8/19/84
 _____ Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 9 of 69

Item 4 Weld to Feedwater pipe

TREAT WELD AS LING



$$A = \pi d^2 \frac{5}{2} \text{ leg length} \\ = \pi (4.5)^2 \frac{5}{2} (.25) = 2.499 \text{ in}^2$$

$$Z = \frac{\pi d^3}{4} \frac{5}{2} \text{ leg length} \\ = \frac{\pi (4.5)^3}{4} \frac{5}{2} (.25) = 2.812 \text{ in}^3$$

TENSION / COMPRESSION

$$\gamma_1 = AL/A = 4,276/2.499 = 1,711 \text{ psi}$$

BENDING

$$\gamma_2 = \frac{M}{Z} = 26,975/2.812 = 9,593 \text{ psi}$$

SHEAR

$$\gamma_3 = TL/A = 1076/2.499 = 431 \text{ psi}$$

$$\gamma_{net} = \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(1711 + 9593)^2 + (431)^2}$$

$$= \underline{71,312 \text{ psi}} < \underline{24,400 \text{ psi}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: Feedwater Seismic Supports Calculated by: M. Kennedy Date: 3/1/84
 Checked by: R.C. Thrush Date: 3/9/84
 Reviewed by: J.J. Date: 2/22/84

Project: 83-03

Page 10 of 69

Snubber I. clevis & Bolt

Assume Bergen Paterson STANDARD Part EA2-4



Pullout shear

$$Area = 2(2rt) = 2(2(2.0)(.5)) = 4.0 \text{ in}^2$$

$$P_x = 1340 \text{ lb.}, \quad TL = 1070 \text{ lb.}, \quad AL = 806 \text{ lb.}$$

$$\gamma = \frac{P_x}{A} = \frac{1340}{4.0} = \underline{335 \text{ PSI} < 24,400 \text{ PSI}}$$

Shear at base

$$Area = 2lw = 2(6.0)(.5) = 6.0 \text{ in}^2$$

$$\gamma = \frac{Th}{A} = \frac{1070}{6.0} = \underline{178 \text{ PSI} < 24,400 \text{ PSI}}$$

Bolt Hole tension

$$Area = 2t(2r - hole d) = 2(.5)(2(2.0) - (1 + 1/16)) = 2.938 \text{ in}^2$$

$$\delta = \frac{P_x}{A} = \frac{1340}{2.938} = \underline{456 \text{ PSI} < 32,400 \text{ PSI}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports

Calculated by: M. Koenig Date: 8/1/84
Checked by: R. Thrush Date: 8/9/84
Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 11 of 69

AXIAL COMPRESSION

$$\text{Area} = \text{min. Area} = \pi t (2r) = \pi(0.5)(2(2.0)) = 4.0 \text{ in}^2$$

$$\delta = \frac{A\Delta}{A} = 806/4.0 = 202 \text{ PSI}$$

$$l = \approx 6.75"; C_c = 126.5$$

$$r = t/\sqrt{2} = 0.144"$$


$$K=2.0; S_y = 36.0 \text{ KSI}$$

} See section 2 of
this Appendix

$$\begin{aligned} F_a &= \frac{2}{3} \left(1 - \left(\frac{Kl}{r} \right)^2 / 2 C_c^2 \right) S_y \\ &= \frac{2}{3} \left(1 - \left(\frac{(2.0)(6.75)}{0.144} \right)^2 / 2(126.5)^2 \right) 36.0 = 17.4 \text{ KSI} \end{aligned}$$

$$\underline{202 \text{ PSF} < 17,400 \text{ PSI}}$$

BENDING AT BASE



$$I = \frac{\pi b h^3}{12} = \frac{\pi (6.0)^3}{12} = 18.0 \text{ in}^4$$

$$C = 3.0 \text{ in}$$

$$\sigma = \frac{M C}{I} = \frac{T L d \cdot c}{I} = \frac{1070 (6.75) (3.0)}{18.0} = 1204 \text{ PSI}$$

$$\underline{1204 + 202 = 1406 \text{ PSI} < 40,600 \text{ PSI}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Pedestrian Seismic Supports Calculated by: M. Kennedy Date: 8/1/84
 _____ Checked by: R. French Date: 8/19/84
 _____ Reviewed by: JJ Date: 8-22-84

Project: 83-03 Page 12 of 69

AXIAL COMPRESSION AND BENDING

$$\frac{f_a}{f'_a} + \frac{f_b}{f'_b} \leq 1.0$$

$$\frac{202}{17400} + \frac{1204}{40,600} = 0.04 < 1.0$$

Bolt Shear

$$Area = 2 \pi \frac{d^2}{4} = 2\pi \frac{(1.4)^2}{4} = 1.571 \text{ in}^2$$

$$\gamma = P/A = 1340 / 1.571 = \underline{\underline{953 \text{ PSI}}} \leq \underline{\underline{24,400 \text{ PSI}}}$$


MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater seismic supports Calculated by: M Kennedy Date: 8/1/84
 Checked by: R Trensch Date: 5/9/84
 Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 13 of 69

Item 4 weld to snubber I clevis



TREAT weld AS LINE

$$A = 2(2L + 2W)^{5/2} \text{ leg length}$$

$$= 2(2(4.0) + 2(0.5))^{5/2} (.25)$$

$$= 3.182 \text{ in}^2$$

$$Z = 2(bd + r^{d/3})^{5/2} \text{ leg length}$$

$$= 2(.5(4.0) + 0.5^{4.0/3})^{5/2} (.25)$$

$$= 2.593 \text{ in}^3$$

Tension / compression

$$\gamma_1 = Aw/A = 806/3.182 = 253 \text{ psi}$$

Bending

$$\gamma_2 = M/Z = \frac{(1070)(6.75)}{2.593} = 2785 \text{ psi}$$

Shear

$$\gamma_3 = TL/A = 1070/3.182 = 336 \text{ psi}$$

$$\gamma_{net} = \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(253 + 2785)^2 + (336)^2}$$

$$= 3057 \text{ psi} < 24,400 \text{ psi}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Freewater Seismic supports Calculated by: M Kennedy Date: 8/1/84

Checked by: R C Tuerck Date: 3/9/84

Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 14 of 69


Snubber II clevis & bolt

Assume Bergen-Paterson STANDARD Part EA1-A

$$P_{II} = 2340 \text{ lb}$$


$$\text{AXIAL LOAD} = 2,339 \text{ lb}$$

$$\text{TRANSVERSE LOAD} = 61 \text{ lb.}$$



4" sch 40 pipe weld to base plate

TREAT weld as line



$$\text{Area} = \pi d \frac{\sqrt{3}}{2} \text{ leg length}$$

$$= \pi (4.5) \frac{\sqrt{3}}{2} (.25) = 2.499 \text{ in}^2$$

$$Z = \frac{\pi d^2}{4} \frac{\sqrt{3}}{2} \text{ leg length}$$

$$= \pi \frac{(4.5)^2}{4} \frac{\sqrt{3}}{2} (.25) = 2.812 \text{ in}^3$$

tension / compression

$$\gamma = \frac{AL}{A} = \frac{2339}{2.499} = 936 \text{ psi}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater seismic supports

Calculated by: JK Date: 8/1/84
Checked by: RCT Date: 8/4/84
Reviewed by: JJ Date: 8/22-84

Project: 83-03

Page 15 of 69

BENDING


$$\gamma_2 = \frac{M}{Z} = \frac{T_L \cdot e}{Z} = \frac{61 (3.25)}{2.812} = 71 \text{ psi}$$

SHEAR

$$\gamma_3 = \frac{T_L}{A} = \frac{61}{2.499} = 24 \text{ psi}$$

$$\gamma_{\text{net}} = \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(93.6 + 71)^2 + (24)^2} = \underline{\underline{100.7 \text{ psi}}} \\ < \underline{\underline{24,400 \text{ psi}}}$$

clevis PLATE to BASE PLATE weld



TREAT Weld As Line

$$\text{Area} = 2 (2L + 2W) \frac{\sqrt{2}}{2} \text{ leg length} \\ = 2(2(4.0) + 2(0.5)) \frac{\sqrt{2}}{2} (.25) = 3.182 \text{ in}^2$$

$$Z = 2(bd + \frac{d^2}{3}) \frac{\sqrt{2}}{2} \text{ leg length} \\ = 2(.5(4.0) + (4.0)^2/3) \frac{\sqrt{2}}{2} (.25) \\ = 2.593 \text{ in}^3$$

tension/compression

$$\gamma_1 = \frac{SL}{A} = 2339 / 3.182 = 735 \text{ psi}$$

$$\gamma_2 = \frac{M}{Z} = \frac{T_L \cdot e}{Z} = \frac{(2.75)(61)}{2.593} = 65 \text{ psi}$$

SHEAR

$$\gamma_3 = \frac{T_L}{A} = 61 / 3.182 = 19 \text{ psi}$$

$$\gamma_{\text{net}} = \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(735 + 65)^2 + (19)^2} = \underline{\underline{800 \text{ psi}}} \\ < \underline{\underline{24,400 \text{ psi}}}$$


MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: T. K. Kanchan Date: 3/1/84
 Checked by: R. T. French Date: 3/9/84
 Reviewed by: J.J. Date: 2/22/84

Project: 83-03

Page 16 of 69

Clevis Plate



$$\text{Area} = 2(2w) = 2(.5)(4.0) \\ = 4.0 \text{ in}^2$$

$$I = \frac{2bh^3}{12} = \frac{2(.5)(4.0)^3}{12} \\ = 5.333 \text{ in}^4$$

$$c = 2.0 \text{ in}$$

SHEAR AT BASE

$$\tau = TL/4 = 61/4 = 15 \text{ PSI} < 24400 \text{ PSI}$$

Axial compression

$$\sigma = Ay_d = 2339/4 = 585 \text{ PSI}$$

$$l = 2.75 \text{ in} ; c_c = 126.5$$

$$r = c/c_c = 0.144 \text{ in}$$

$$K = 2.0 , S_y = 36.0 \text{ ksi}$$

$$f_a = \gamma_3 \left(1 - \left(\frac{2.0(2.75)}{0.144} \right)^2 / 2(126.5)^2 \right) 36.0 = 22.9 \text{ ksi}$$

$$= 585 \text{ PSI} < 23900 \text{ PSI}$$

See Appendix B

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: m/Kennedy Date: 8/1/84
Checked by: R.Creath Date: 5/9/84
Reviewed by: JJ Date: 8-22-84

Project: 83-03 Page 17 of 69

Pullout Shear

$$A = 4.0 \text{ in}^2 \quad P_{\text{J}} = 13875 \text{ lb}$$

$$C = \frac{P/A}{4.0} = \frac{2340}{4.0} = 585 \text{ PSI} < 24400 \text{ PSI}$$

Bolt Hole Tension

$$A = 2.938 \text{ in}^2$$

$$\delta = \rho/A = 2340/2.938 = 796 \text{ ps}^{-1} < 32,400 \text{ ps}^{-1}$$

BENDING AT BASE

$$\delta = \frac{M C}{I} = \frac{T L \cdot I \cdot C}{I^2} = \frac{61 \cdot 2.75 \cdot 2}{5.323} = 63 \text{ PSI}$$

$$63 + 585 = \underline{648 \text{ PSI} < 40,000 \text{ PSI}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Pressure Seismic Supports Calculated by: Tony Karel Date: 5/1/84
 Checked by: R. T. French Date: 2/9/84
 Reviewed by: JJ Date: 2/22/84

Project: 83-03

Page 14 of 69

Axial compression and Bending

$$\frac{F_a}{F_a'} + \frac{F_b}{F_b'} \leq 1.0$$

$$\frac{585}{22900} + \frac{63}{40,400} = 0.03 < 1.0$$

Bolt

$$Area = 2 \frac{\pi d^2}{4} = 2 \frac{\pi (1.0)^2}{4} = 1.571 \text{ in}^2$$

$$\gamma = P_r/A = 2339/1.571 = \underline{1489 \text{ psi}} < \underline{24400 \text{ psi}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: FWater Seismic Supports Calculated by: mKennedy Date: 8/1/84
 Checked by: R.Church Date: 8/9/84
 Reviewed by: TJ Date: 8/22/84


Project: 83-03

Page 19 of 69

Snubber II Item 3 Clevis & Bolt STANDARD Part EA 1-A

The stresses for this part are identical to the stresses for the Snubber II clevis & bolt of the clevis / pipe assembly by symmetry.

Snubber II Item 3 weld to 6WF15.5 I-BEAM



TREAT weld as line

$$\text{Area} = 4 \times 5 \frac{1}{2} \text{ leg length} \\ = 4(5) \frac{1}{2} (.25) = 3.536 \text{ in}^2$$

$$Z = (5^2 + 5^2) \frac{1}{2} \text{ leg length} \\ = (5^2 + 5^2) \frac{1}{2} (.25) = 5.893 \text{ in}^3$$

Tension/Compression

$$\gamma_1 = \frac{W}{A} = \frac{2339}{3.536} = 661 \text{ psi}$$

BENDING

$$\gamma_2 = M/Z = \frac{T_L \cdot l}{Z} = \frac{(2.75)(61)}{5.893} = 28 \text{ psi}$$

SHCER

$$\gamma_3 = T_L/A = (61)/3.536 = 17 \text{ psi}$$

$$\gamma_{\text{net}} = \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(661 + 28)^2 + (17)^2} = 689 \text{ psi}$$

< 24400 psi

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: mtkennedy Date: 8/1/84
 Checked by: RCTrench Date: 7/9/84
 Reviewed by: JL Date: P-52-24


Project: 83-03

Page 20 of 69

Snubber I Item 3 Clevis & Bolt STANDARD Part EA1-A

Clevis PLATE

$$P_I = 1340 \text{ lb}$$



$$\text{Area} = 2(b \cdot w) = 2(.5(4.0)) = 4.0 \text{ in}^2$$

$$I = \frac{2 b h^3}{12} = \frac{2(.5)(4.0)^3}{12} = 5.333 \text{ in}^4$$

$$C = 2.0$$

SHEAR AT BASE

$$\gamma = T_L/A = 806/4 = \underline{\underline{202 \text{ PSI}}} < 24400 \text{ PSI}$$

AXIAL compression

$$\text{Area} = \pi r^2 \text{ Area} = \pi t (2r) = \pi (2.5) (2(2.0)) = 4.0 \text{ in}^2$$

$$\sigma = A_L/A = 1070/4.0 = 268 \text{ PSI}$$

$$\left. \begin{aligned} l &= 2.50'' ; C_c = 126.5 \\ r &= t/\sqrt{2} = 0.5/\sqrt{2} = 0.144'' \end{aligned} \right\} \text{See Appendix B}$$

$$K = 2.0 ; S_y = 36.0 \text{ KSI}$$

$$F_a = \gamma_3 \left(1 - \left(\frac{Kl}{r} \right)^2 / 2 C_c^2 \right) S_y = \gamma_3 \left(1 - \left(\frac{2.0(2.5)}{0.144} \right)^2 \right) 36.0 = 23.1 \text{ KSI}$$

$$\underline{\underline{268 \text{ PSI}}} < 23,100 \text{ PSI}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: M Kennedy Date: 8/1/84
 _____ Checked by: R Church Date: 8/9/84
 _____ Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 21 of 69

Pullout Shear

$$Area = 2(2\pi t) = 2(2(2.0)(.5)) = 4.0 \text{ in}^2$$

$$P = 1340 \text{ lb}$$

$$\gamma = P/A = 1340/4.0 = \underline{\underline{335 \text{ PSI}}} < \underline{\underline{24400 \text{ PSI}}}$$

Bolthole Tension

$$Area = 2t(2r - \text{hole dia}) = 2(.5)(2(2.0) - (1 + k_b)) = 2.938 \text{ in}^2$$

$$\delta = P/A = 1340/2.938 = \underline{\underline{456 \text{ PSI}}} < \underline{\underline{32,400 \text{ PSI}}}$$

BENDING AT BASE

$$\delta = \frac{Mc}{I} = \frac{T_h \cdot l \cdot c}{I} = \frac{806(2.5)(2.0)}{5.333} = 756 \text{ psi}$$

$$268 + 756 = \underline{\underline{1,024 \text{ PSI}}} < \underline{\underline{40,600 \text{ PSI}}}$$

AXIAL COMPRESSION AND BENDING

$$\frac{f_a}{f_a} + \frac{f_b}{f_b} \leq 1.0$$

$$\frac{268}{23,100} + \frac{756}{40,600} = 0.03 < 1.0$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater seismic Supports


Calculated by: M Kennedy
Checked by: D Trenck
Reviewed by: J

Date: 8/1/84
Date: 8/9/84
Date: 8-22-84

Project: 83-03

Page 22 of 69

clevis plate weld to base plate



TREAT weld as line

$$\text{Area} = 2(2d + \frac{d^2}{3})^{\frac{5}{2}} \text{ leg strength}$$

$$= 2(2(4.0) + \frac{2(1.5)^2}{3})^{\frac{5}{2}} (2.25) = 3.182 \text{ in}^2$$

$$Z = 2(bd + \frac{d^2}{3})^{\frac{5}{2}} \text{ leg strength}$$

$$= 2(.5(4.0) + \frac{(4.0)^2}{3})^{\frac{5}{2}} (2.25)$$

$$= 2.593 \text{ in}^3$$

tension / compression

$$\gamma_1 = \frac{A_L}{4} = \frac{1070}{3.182} = 336 \text{ psi}$$

BENDING

$$\gamma_2 = \frac{M_y/2}{Z} = \frac{T_L \cdot R}{Z} = \frac{806(2.5)}{2.593} = 777 \text{ psi}$$

SHEAR

$$\gamma_3 = \frac{T_L/A}{3.182} = \frac{806}{3.182} = 253 \text{ psi}$$

$$\gamma_{\text{net}} = \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(336 + 777)^2 + (253)^2} = \underline{\underline{1141 \text{ psi}}}$$

< 24400 psi


MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Seawater Seismic Supports Calculated by: M Kennedy Date: 8/1/84
 Checked by: R Thorne Date: 8/1/84
 Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 23 of 69

BASE PLATE WELD TO A1W F I-BEAM



TREAT WELD AS LINE

$$\text{Area} = 4 \times \frac{5^2}{2} \text{ leg length}$$

$$= 4(5) \frac{5^2}{2} (.25) = 3.536 \text{ in}^2$$

$$z = (5^2 + \frac{5^2}{3}) \frac{\sqrt{5}}{2} \text{ leg length}$$

$$= (5^2 + \frac{5^2}{3}) \frac{\sqrt{5}}{2} (.25) = 5.493 \text{ in}^3$$

Tension compression

$$\gamma_1 = AC/A = \frac{1070}{3.536} = 303 \text{ PSI}$$

Bending

$$\gamma_2 = M/z = \frac{TL \cdot l}{z} = \frac{806 (3.25)}{5.493} = 445 \text{ PSI}$$

Shear

$$\gamma_3 = TVA = \frac{806}{3.536} = 228 \text{ PSI}$$

$$\gamma_{\text{net}} = \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(303 + 445)^2 - (228)^2}$$

$$= \underline{\underline{782 \text{ PSI} < 24,400 \text{ PSI}}}$$

MPR ASSOCIATES, INC.
 1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: TJ Karrow Date: 8/1/84
 Checked by: R.C. French Date: 8/9/84
 Reviewed by: JJ Date: 8-22-84

Project: 83-03

Page 24 of 59

Support X-4B-SS-1 Summary Table

Item	TYPE OF STRESS	CALCULATED STRESS (PSI)	ALLOWABLE STRESS (PSI)
4	SHEAR	339	24,400
	compression	1347	23,000
	BENDING	9,739	40,600
	AXIAL compression AND BENDING	0.27 (Note 1)	1.0 (Note 1)
Snubber I clevis	Pullout SHEAR	335	24,400
	Bolthole tension	456	32,400
	AXIAL compression	202	17,400
	BENDING	1,406	40,600
	AXIAL compression AND BENDING	0.04 (Note 1)	1.0 (Note 1)
Bolt	SHEAR	853	24,400
Item 4 weld to Feed Pipe	SHEAR	11,312	24,400
Item 4 weld to clevis BASE PLATE	SHEAR	1,307	24,400
Item 4 weld to snubber I clevis	SHEAR	3057	24,400

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: m/Kennedy Date: 8/1/84
 Checked by: RCTynerch Date: 5/9/84
 Reviewed by: TJ Date: 8-22-84

Project: 83-03

Page 25 of 69

Summary Table (cont.)

Item	TYPE OF STRESS	Calculated stress (PSI)	Allowable stress (PSI)
Snubber II clevis plate weld to base plate	SHEAR	800	24,400
	SHEAR	75	24,400
	AXIAL compression	585	24,400
	Pullout SHEAR	585	24,400
	Bolthole TENSION	7.96	32,400
	BENDING	648	40,600
	AXIAL compression AND BENDING	0.03 (Note 1)	1.0 (Note 1)
	SHEAR	1,489	24,400
Item 3 weld to 6 WF 15.5 I-BEAM	SHEAR	689	24,400
Item 3 weld to 21 WF I-BEAM	SHEAR	782	24,400

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Federated Seismic SupportsCalculated by: M. Kennedy
Checked by: R. J. Greer
Reviewed by: J. J. GreerDate: 8/1/84
Date: 8/19/84
Date: 8/22/84Project: 83-03Page 26 of 69

Summary table (cont.)

Item	Type of Stress	Calculated Stress (PSI)	Allowable Stress (PSI)
Snubber I Item 3	SHEAR	202	24,400
	AXIAL compression	268	23,100
	Pullout SHEAR	335	24,400
	Bolt-hole TENSION	1456	32,400
	BENDING	1,024	40,600
	AXIAL compression AND BENDING	0.03 (Note 1)	1.0 (Note 1)
Clevis PLATE weld to BASE plate	SHEAR	1,141	24,400

Notes(1) VALUE IS NOT STRESS IN PSI BUT STRESS RATIO
(NON-DIMENSIONAL)

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports


Calculated by: M. Harvey
Checked by: R.G. French
Reviewed by: JJ

Date: 8/1/84
Date: 8/9/84
Date: 8/22/84

Project: 83-03

Page 27 of 69

Support RF-RIA





LOCATION PLAN

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: Feedwater Seismic Supports Calculated by: M. Kavcic Date: 8/1/84
 Checked by: R. T. French Date: 8/9/84
 Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 28 of 69



snubber tilt to horizontal



MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Pedwater Seismic Supports

Calculated by: M.Karney

Date: 8/1/84

Checked by: R.Cherchi

Date: 8/9/84


Reviewed by: J.J.

Date: 8-22-84

Project: 83-03

Page 29 of 69

Freebody Diagram



$$P = 2220 \text{ lbs} \quad \text{Ref.(1)}$$

$$\text{Snubber load} = \frac{P}{\cos 3.75} = 2225 \text{ lbs}$$

$$\begin{aligned} \text{tension/compression load in clevises} &= \text{snubber load} \sin 3.75 \\ &= 145 \text{ lb.} = R_2 \\ &\text{ignored in analyses -} \\ &\text{minimal effect by} \\ &\text{inspection} \end{aligned}$$

$$R_3 = R_2$$

$$R_1 = P$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Seawater Seismic Supports Calculated by: m/karney Date: 8/1/84
 Checked by: RCTreuerd Date: 8/9/84
 Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 30 of 69

Item 1 Clevis & Bolt STANDARD PART EA2-4

RATED to 10,000 lb Ref.(2)


Actual LOAD 2225 lb

Item 3 Clevis & Bolt STANDARD PART EA1-4

RATED to 10,000 lb Ref.(2)

Actual LOAD 2225 lb

Item 3 Weld to Item 4



TREAT weld as line

$$Z = \frac{\pi d^2}{4} \frac{\sqrt{2}}{2} \text{ leg length}$$

$$\begin{aligned} \text{ID weld} &= 0.045 \text{ in} \\ &\approx 4.5'' \\ &= \pi \frac{(4.5)^2}{4} \frac{\sqrt{2}}{2} (0.25) \\ &= 2.812 \text{ in}^3 \end{aligned}$$

$$\begin{aligned} A &= \pi d \frac{\sqrt{2}}{2} \text{ leg length} \\ &= \pi (4.5) \frac{\sqrt{2}}{2} (0.25) = 2.499 \text{ in}^2 \end{aligned}$$

MOMENT

$$\gamma_2 = \frac{P l}{Z} = \frac{2225 (3.25)}{2.812} = \underline{2572} \text{ psi}$$

SHEAR

$$\gamma_3 = \frac{P}{A} = \frac{2225}{2.499} = 890 \text{ psi}$$

$$\gamma_{\text{ret}} = \sqrt{\gamma_2^2 + \gamma_3^2} = \sqrt{(2572)^2 + (890)^2} = \underline{2772 \text{ psi}} < 24,400 \text{ psi}$$

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: feedwater Seismic Supports Calculated by: McKenna Date: 8/1/84
Checked by: RC French Date: 3/9/89
Reviewed by: JJ Date: 8-22-94

Project: 83-03

Page 31 of 69

Item 4 4" Sch 80 pipe stress

$$OD = 4.5", ID = 3.826" \quad (Ref. 3 p.B-17)$$

$$I = 9.610 \text{ in}^4, A = 4.407 \text{ in}^2$$

SHEAR

$$\gamma = \frac{P/A}{4.407} = \underline{505 \text{ PSI}} < \underline{24,400 \text{ PSI}}$$

BENNING

$$\delta = \frac{M_c}{I} = \frac{2225 (137/8) (2.25)}{9,610} = \underline{\underline{7228 \text{ psi} < 40,600 \text{ psi}}}$$

Item 4 Weld to existing 2I WF I-beam

$$A = 2.499 \text{ in}^2 \quad Z = 2.812 \text{ in}^3$$

(Same as Item 3 weld to Item 4)

moment

$$X_2 = \frac{P \cdot l}{z} = \frac{2225 (1.3^{7/8})}{2.812} = 10,979 \text{ PSI}$$

SPEAR

$$\tau_3 = \frac{P}{A} = \frac{2225}{2.499} = 890 \text{ ps}\text{I}$$

$$\gamma_{net} = \sqrt{\gamma_2^2 + \gamma_3^2} = \sqrt{(10,979)^2 + (891)^2} = \frac{11,015 \text{ psi}}{24,400 \text{ psi}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports


Calculated by: M.Karney
Checked by: R.J.Trench
Reviewed by: JK

Date: 8/1/84
Date: 3/7/84
Date: 8-30-84

Project: 83-03

Page 32 of 69

Item 1 weld to Feedwater pipe



TREAT WELD AS LINE

$$A = 2(2l + 2w)^{5/2} \text{ leg length}$$

$$= 2(2(4.0) + 2(.5))^{5/2} (.25)$$

$$= 3.182 \text{ in}^2$$

$$Z = 2(bd + \frac{d^2}{3})^{5/2} \text{ leg length}$$

$$= 2((4.0)(.5) + \frac{(4.0)^2}{3})^{5/2} (.25)$$

$$= 2.593 \text{ in}^3$$

BENDING

$$\gamma_2 = \frac{M}{Z} = \frac{Tl \cdot R}{Z} = \frac{(2225)(6.75)}{2.593} = 5792 \text{ psi}$$

SHCAGR

$$\gamma_3 = P/A = 2225/3.182 = 699 \text{ psi}$$

$$\gamma_{\text{Net}} = \sqrt{\gamma_2^2 + \gamma_3^2} = \sqrt{(5792)^2 + (699)^2} = 5834 \text{ psi}$$

< 24,400 psi

MPR ASSOCIATES, INC.
 1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: M Kennedy Date: 2/1/84
 _____ Checked by: R Thewald Date: 8/9/84
 _____ Reviewed by: ✓ Date: 8/22/84

Project: 83-03

Page 33 of 69

Support RF - RIA Summary Table

Item	TYPE OF STRESS	CALCULATED STRESS (PSI)	ALLOWABLE STRESS (PSI)
Item 3 weld to Item 4	SHEAR	2,722	24,400
4	SHEAR	505	24,400
	BENDING	7,228	40,600
Item 4 weld to I-Beam	SHEAR	11,015	24,400
Item 1 weld to feed P.P.C	SHEAR	5,834	24,400

Item	CALCULATED LOAD (lb)	ALLOWABLE LOAD (lb)
2	2,225	10,000
3	2,225	10,000

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports



Calculated by: M Kennedy Date: 8/1/84
Checked by: R C Truelock Date: 8/19/84
Reviewed by: JJ Date: 8-52-84

Project: _____

Page 34 of 69

Support RF-R2A

DESCRIPTION



MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports

Calculated by: M.J.Kennedy
Checked by: R.G.Jones
Reviewed by: ✓

Date: 8/1/84
Date: 8/9/84
Date: 8/22/84

Project: 83-03


Page 35 of 69

Item 2 Clevis & Bolt STANDARD Part EA2-A

RATED TO 10,000 lb Ref. (2)

ACTUAL LOAD 1,600 lb

Item 2 Weld to Feedwater P.P.E.



TREAT weld as line

$$\begin{aligned} \text{Area} &= 2(2b + 2d) \frac{\sqrt{2}}{2} \text{ leg length} \\ &= 2(2(1.5) + 2(6.00)) \frac{\sqrt{2}}{2} (.25) \\ &= 4.596 \text{ in}^2 \end{aligned}$$

Tension / compression

$$\gamma_i = P/A = 1600/4.596 = 348 \text{ psi}$$

$$\gamma_{net} = \gamma_i = \underline{348 \text{ psi} < 24,400 \text{ psi}}$$

Item 3 Clevis & Bolt STANDARD Part EA1-A

RATED TO 10,000 lb Ref. (2)

ACTUAL LOAD 1,600 lb


MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Pedwater Seismic Supports Calculated by: M Kennedy Date: 7/1/84
 Checked by: R Gengenbach Date: 7/9/84
 Reviewed by: ✓ Date: 8/22/84

Project: 83-03

Page 36 of 69

Item 3 weld to existing 27 WF 177 col



TREAT weld as line

$$\text{Area} = 4 \cdot 5 \frac{\sqrt{2}}{2} \text{ leg length}$$

$$= 4(5.0) \frac{\sqrt{2}}{2} (.25)$$

$$= 3.536 \text{ in}^2$$

$$z = \left(5^2 + \frac{5^2}{3}\right)^{1/2} \frac{\sqrt{2}}{2} \text{ leg length}$$

$$= \left(5^2 + \frac{5^2}{3}\right)^{1/2} \frac{\sqrt{2}}{2} (.25)$$

$$= 5.893 \text{ in}^3$$

tension/compression

$$\gamma_1 = \frac{P \cos \theta}{A} = \frac{(1,600) \cos 60}{3.536} = 450 \text{ PSI}$$

bending

$$\gamma_2 = \frac{P \sin \theta L}{z} = \frac{(1,600) \sin 60 (3.25)}{5.893} = 92 \text{ PSI}$$

SHEAR

$$\gamma_3 = \frac{P \sin \theta}{A} = \frac{(1,600) \sin 60}{3.536} = 46 \text{ PSI}$$

$$\gamma_{\text{net}} = \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(450 + 92)^2 + (46)^2} = 544 \text{ PSI}$$

< 24,400 PSI

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: M Kennedy Date: 8/1/84
Checked by: R Gilmore Date: 3/9/89
Reviewed by: JJ Date: 8/22/89

Project: 83-07 Page 37 of 69

Support RF-R2A SUMMARY Table

Item	TYPE OF STRESS	CALCULATED STRESS (PSI)	ALLOWABLE STRESS (PSI)
Item 2 weld to feed. P.D.	SHEAR	348	24,400
Item 3 weld to col.	SHEAR	544	24,400

Item	Calculated Load (lb)	allowable load (lb)
2	1,600	10,000
3	1,600	10,000

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Ferrowater Seismic Supports


Calculated by: M. Kamel Date: 2/1/84
 Checked by: R. T. French Date: 3/6/84
 Reviewed by: JL Date: 8-22-84

Project: 83-03


Page 28 of 69

Support RF-R3A

DESCRIPTION



LOCATION PLAN



SP. PART EA2-A
REV ONLY DIMS SHOWN
ALL OTHER DIMS REMAIN
THE SAME.

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: MKarey Date: 8/1/84
 Checked by: RCTeach Date: 3/6/84
 Reviewed by: JJ Date: 2/22/84

Project: 83-03

Page 39 of 69

Item 1 Clevis & Bolt STANDARD Part EA2-A

RATED to 10,000 lb Ref. (2)
 (shortened dimension B on BP Dwg 64102
 makes moment arm shorter so load rating
 not affected)


Actual load 1,300 lb

Item 3 Clevis & Bolt STANDARD Part EA1-A

RATED to 10,000 lb Ref. (2)

Actual load 1,300 lb

Item 1 weld to feedwater Pipe



Treat weld as line

$$\begin{aligned} \text{Area} &= 2(2w + 2L) \frac{\sqrt{2}}{2} \text{ leg length} \\ &= 2(2(0.5) + 2(6.0)) \frac{\sqrt{2}}{2} (0.25) \\ &= 4.596 \text{ in}^2 \end{aligned}$$

tension / compression

$$\sigma_i = P/A = 1300/4.596 = 283 \text{ psi}$$

$$\sigma_{\text{net}} = \sigma_i = \underline{283 \text{ psi} < 24,400 \text{ psi}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: Pearwater Seismic Supports

Calculated by: M Kennedy Date: 5/1/84
Checked by: B C Trivedi Date: 8/9/84
Reviewed by: JJ Date: 8-20-84

Project: 83-03

Page 40 of 69

Item 3 weld to Item 4 I-BEAM



Treat weld as line



$$\begin{aligned} \text{Area} &= 2(l) \frac{\sqrt{2}}{2} \text{ leg lengths} \\ &= 2(4) \frac{\sqrt{2}}{2} (.25) \\ &= 1.768 \text{ in}^2 \end{aligned}$$

tension / compression

$$\gamma_i = P/A = 1300/1.768 = 735 \text{ psi}$$

$$\gamma_{\text{net}} = \gamma_i = \underline{735 \text{ psi}} \leq \underline{24,400 \text{ psi}}$$

Item 4 Beam



$$l^2 = a^2 + b^2 - 2ab \cos \theta = (279.125)^2 + (270.75)^2 - 2(279.125)(270.75) \cos 24$$

$$l = 114.619 \text{ "}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Teardrop Seismic Supports

Calculated by: M. Kennedy
Checked by: R. Threlkeld
Reviewed by: JJ

Date: 8/1/84
Date: 9/7/84
Date: 8-22-84

Project: 83-03

Page 41 of 69

$$R_B = P \frac{x}{e} = 1300 \frac{(22.375)}{114.619} = 254 \text{ lb}$$

$$R_A = P \frac{e-x}{e} = 1300 \frac{(114.619 - 22.375)}{114.619} = 1046 \text{ lb}$$

$$M_{max} \text{ at } P = P \frac{(e-x)}{e} x = \frac{1300 (114.619 - 22.375) 22.375}{114.619} = 23,409 \text{ in/lb}$$

I-BEAM 5 WF 16

$$I = 21.3 \text{ in}^4, C = 2.5 \text{ in}, A = 4.7 \text{ in}^2 \quad \text{Ref.(4), P 1-21}$$


SHEAR

$$\gamma = \frac{R_A}{(\text{Web Rang} \times t_w)} = \frac{1046}{(5 \times .25)} = \underline{\underline{837 \text{ psi}}} < \underline{\underline{24,400 \text{ psi}}}$$

BENDING

$$\sigma = \pm \frac{Mc}{I} = \frac{23,409 (2.5)}{21.3} = \underline{\underline{2748 \text{ psi}}} < \underline{\underline{40,600 \text{ psi}}}$$

Item 4 weld to existing 21 WF 96 I-BEAM



treat weld as line

$$\begin{aligned} \text{Area} &= 2(e) \frac{\sqrt{2}}{2} \text{ leg length} \\ &= 2(9) \frac{\sqrt{2}}{2} (.25) \\ &\approx 3.182 \text{ in}^2 \end{aligned}$$

tension / compression

$$N_i = R_A/A = 1300/3.182 = 409 \text{ psi}$$

$$T_{net} = \gamma_i = \underline{\underline{409 \text{ psi}}} < \underline{\underline{24,400 \text{ psi}}}$$

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: M Kennedy Date: 7/1/84
 Checked by: R T French Date: 7/9/84
 Reviewed by: WT Date: 8-22-84

Project: 83-03

Page 42 of 69

Support RF-R3A SUMMARY TABLE

Item	TYPE OF STRESS	CALCULATED STRESS (PSI)	ALLOWABLE STRESS (PSI)
Item 1 weld to Feed. P.P.E	SHEAR	283	24,400
Item 3 weld to Item 4 I-BEAM	SHEAR	735	24,400
4	SHEAR	1837	24,400
	BENDING	2,748	40,600
Item 4 weld to I-Beam	SHEAR	409	24,400

Item	CALCULATED LOAD (lb)	ALLOWABLE LOAD (lb)
1	1300	10,000
3	1,300	10,000

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports




Calculated by: m Kennedy Date: 8/1/84
Checked by: RCTrendell Date: 3/9/84
Reviewed by: JJ Date: 2-22-84

Project: 8303

Page 43 of 69

Support RF-R4A

DESCRIPTION



MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: Feedwater Seismic Supports
 Calculated by: M Kennedy
 Checked by: R (Trend)
 Reviewed by: JL

Date: 8/1/84
 Date: 8/9/84
 Date: 8/22/84



Project: 83-03

Page 44 of 69

Snubber tilt to horizontal



Freebody Diagram



$$R_3 = R_2$$

$$P = R_1$$

$$P = 4160 \text{ lbs} \quad \text{Ref. (1)}$$

$$\text{Snubber load} = P / \cos 6.98 = 4191 \text{ lb.}$$

$$\begin{aligned} \text{tension/compression load in clevises} &= \text{snubber load} \sin 6.98 \\ &= 4191 \sin 6.98 \\ &= 509 \text{ lb.} = R_2 \end{aligned}$$

ignored in Analyses
 minimal effect by
 inspection.

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: m/kennedy Date: 5/1/84
 Checked by: RCTrenholo Date: 5/1/84
 Reviewed by: JJ Date: 5/22/84

Project: 83-03

Page 45 of 69

Item 1 Clevis & Bolt STANDARD Part EA2-A

Rated to 10,000 lb Ref. (2)

Actual load 4,911 lb


Item 3 Clevis & Bolt STANDARD Part EA1-A

Rated to 10,000 lb Ref (2)

Actual load 4,911 lb

Item 3 Weld to Item 4

TREAT weld as line



$$\begin{aligned} Z &= \frac{\pi d^2}{4} \frac{\sqrt{2}}{2} \text{ leg length} \\ &= \frac{\pi (4.5)^2}{4} \frac{\sqrt{2}}{2} (.25) \\ &= 2.912 \text{ in}^3 \end{aligned}$$

$$\begin{aligned} A &= \pi d \frac{\sqrt{2}}{2} \text{ leg length} \\ &= \pi (4.5) \frac{\sqrt{2}}{2} (.25) \\ &= 2.499 \text{ in}^2 \end{aligned}$$

Moment

$$M_2 = \frac{P l}{2} = \frac{4160 (3.25)}{2.912} = 4808 \text{ psi}$$

SHEAR

$$M_3 = P/A = 4160 / 2.499 = 1665 \text{ psi}$$

$$M_{net} = \sqrt{M_2^2 + M_3^2} = \sqrt{(4808)^2 + (1665)^2} = 5084 \text{ psi} < 24400 \text{ psi}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Seawater Seismic Supports Calculated by: M.Kennedy Date: 8/1/84
 Checked by: R.C.Traenak Date: 8/9/84
 Reviewed by: ✓ Date: 8/22/84

Project: 83-03

Page 46 of 69

Item 4 4" Sch 80 pipe Stress

$$OD = 4.5" \quad ID = 3.825"$$

$$I = 9,610 \text{ in}^4, \quad A = 4.407 \text{ in}^2$$

Ref. (3), p B-17

SHEAR

$$\gamma_1 = \frac{P}{A} = \frac{4160}{4.407} = \underline{\underline{944 \text{ psi}}} < 24,400 \text{ psi}$$

BENDING

$$\delta = \frac{MC}{I} = \frac{4160 (13\frac{7}{8}) (2.25)}{9,610} = \underline{\underline{13,614 \text{ psi}}} < 40,600 \text{ psi}$$

Item 4 Weld to Existing 2I WF I-BEAM

$$A = 2,499 \text{ in}^2 \quad Z = 2,812 \text{ in}^3$$

(same as Item 3 weld to Item 4)

Moment

$$\gamma_2 = \frac{Pl}{Z} = \frac{4160 (13\frac{7}{8})}{2,812} = 20,526 \text{ psi}$$

SHEAR

$$\gamma_3 = \frac{P}{A} = \frac{4160}{2,499} = 1665 \text{ psi}$$

$$\gamma_{net} = \sqrt{\gamma_2^2 + \gamma_3^2} = \sqrt{(20,526)^2 + (1665)^2} = \underline{\underline{20,593 \text{ psi}}}$$

≤ 24,400

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: Feedwater Seismic Supports Calculated by: M Kennedy Date: 8/1/84
 Checked by: RCTrunko Date: 3/9/84
 Reviewed by: JJ Date: 2/2/84

Project: 83-03

Page 47 of 69

Item 1 weld to Feedwater Pipe

TREAT weld AS LIP



$$\text{Area} = 2(2l + 2w)^{5/2} \text{ leg length}$$

$$= 2(2(6.0) + 2(1.5))^{5/2} (.25) = 4.596 \text{ in}^2$$

$$Z = 2(bd + \frac{d^2}{3})^{5/2} \text{ leg length}$$

$$= 2(1.5(6.0) + \frac{6.0^2}{3})^{5/2} (.25)$$

$$= 5.303 \text{ in}^3$$

BENDING

$$\gamma_2 = \frac{M}{Z} = \frac{Pd}{Z} = \frac{4160 (7.5)}{5.303} = 5883 \text{ psi}$$

Assumed

SHEAR

$$\gamma_3 = \frac{P}{A} = \frac{4160}{4.596} = 905 \text{ psi}$$

$$\gamma_{\text{net}} = \sqrt{\gamma_2^2 + \gamma_3^2} = \sqrt{(5883)^2 + (905)^2} = \underline{\underline{5953 \text{ psi}}} < 24,400 \text{ psi}$$

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic SupportsCalculated by: M KennedyDate: 8/1/84Checked by: R J TrenschDate: 2/9/84Reviewed by: JJDate: 2-22-84Project: 83-03Page 48 of 69Support RF-R4A Summary Table

Item	TYPE OF STRESS	CALCULATED STRESS (PSI)	ALLOWABLE STRESS (PSI)
Item 3 weld to Item 4	SHEAR	5088	24,400
Item 1 weld to less R.P.E	SHEAR	5,953	24,400
4	SHEAR	944	24,400
	BENDING	13,514	40,600
Item 4 weld to I-Beam	SHEAR	20,593	24,400

Item	Calculated LOAD (lb)	Allowable LOAD (lb)
1	4,191	10,000
3	4,191	10,000

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports




Calculated by: M. Kennedy Date: 8/1/84
Checked by: R. Ireland Date: 3/9/84
Reviewed by: JJ Date: 8-22-84

Project: 83-03

Page 49 of 69

Support RF - RSA

DESCRIPTION



DETAIL "B"

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: Feedwater Seismic Supports

Calculated by: m Kennedy
Checked by: P Chimento
Reviewed by: JJ

Date: 4/1/84
Date: 3/2/84
Date: 2/22-84

Project: 83-03

Page 50 of 69



MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: Feedwater Seismic Supports

Calculated by: m Kennedy Date: 8/1/84
 Checked by: R Toliver Date: 8/9/84
 Reviewed by: JJ Date: 8-22-84


Project: 83-03

Page 51 of 69

Snubber tilt to horizontal



Freebody Diagram



$$P = 4700 \text{ lb} \quad \text{Ref (1)}$$

$$\text{Snubber load} = P / \cos 5.30 = 4720 \text{ lbf}$$

$$\begin{aligned} \text{tension/compression load in pipe clevis} &= \text{snubber load} \sin 5.30 \\ &= 436 \text{ lb} = R_2 \\ &\text{ignored in analyses} \\ &\text{minimal effect} \\ &\text{by inspection} \end{aligned}$$

$$R_2 = R_3 ; P = R_1$$


MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Ferronwater Seismic Supports Calculated by: M Kennedy Date: 7/11/84
 Checked by: R Tolovich Date: 3/9/84
 Reviewed by: JJ Date: 8-32-84

Project: 83-03

Page 52 of 69

Item 3 PIPE ATT'MT CLAVIS w/(1) 1"Ø x 3 3/4" LG
HEX HEAD CAP SCR & NUT.



PULLOUT SHEAR

$$\text{Area} = 2(2\pi t) = 2(2(2.0).5) = 4.0 \text{ in}^2$$


$$\Sigma = \frac{P}{A} = \frac{4720}{4.0} = \underline{\underline{1180 \text{ PSI}}} < 24,400 \text{ PSI}$$

SHEAR AT BASE

$$\text{Area} = 2lw = 2(6.0)(.5) = 6 \text{ in}^2$$

$$\Sigma = \frac{P}{A} = \frac{4700}{6.0} = \underline{\underline{783 \text{ PSI}}} < 24,400 \text{ PSI}$$

BENDING AT BASE



$$I = \frac{bh^3}{12} = \frac{.5(6.0)^3}{12} = 18.0 \text{ in}^4$$

$$C = 3.0 \text{ in.}$$

$$\delta = \frac{Mc}{I} = \frac{P \cdot d \cdot c}{I} = \frac{4700 (7.5) (3)}{18} = \underline{\underline{5875 \text{ PSI}}} \\ < 40,600 \text{ PSI}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036


Title: Feedwater Seismic Supports

Calculated by: M Kennedy Date: 8/1/84
 Checked by: R French Date: 2/5/79
 Reviewed by: JJ Date: 2/22/84

Project: 83-03

Page 53 of 69

Item 3 Weld to Feedwater Pipe



TREAT weld AS LINE

$$\begin{aligned} \text{Area} &= 2(2L + 2W) \frac{\sqrt{2}}{2} \text{ leg length} \\ &= 2(2(6.0) + 2(.5)) \frac{\sqrt{2}}{2} (.25) \\ &= 4.596 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} Z &= 2(bd + \frac{d^2}{3}) \frac{\sqrt{2}}{2} \text{ leg length} \\ &= 2(.5(6.0) + \frac{6.0^2}{3}) \frac{\sqrt{2}}{2} (.25) \\ &= 5.303 \text{ in}^3 \end{aligned}$$

BENDING

$$\gamma_2 = \frac{M}{Z} = \frac{P \cdot d}{Z} = \frac{4100 (7.5)}{5.303} = 6,647 \text{ psi}$$

SHEAR

$$\gamma_3 = \frac{P}{A} = \frac{4100}{4.596} = 1023 \text{ psi}$$

$$\gamma_{\text{Net}} = \sqrt{\gamma_2^2 + \gamma_3^2} = \sqrt{(6647)^2 + (1023)^2} = \underline{\underline{6725 \text{ psi}}} < 24,400 \text{ psi}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports

Calculated by: M.Kenney Date: 8/1/84
Checked by: R.Trench Date: 8/9/84
Reviewed by: T.J. Date: 8/22/84

Project: 83-03


Page 54 of 69

Item 2 Clevis & Bolt STANDARDS Part EA 1-A

Bolt rated to 10,000 lb Ref.(2)

Actual load 4700 lb

The clevis plate length is longer than the standard length so this clevis is ANALYZED



Pullout shear & clevis bolthole tension are the same as for the standard clevis which is rated to 10,000 lb, so they are not calculated.

AXIAL compression

$$\text{let } \text{Area} = \text{minimum Area} = 2t w = 2(0.5)(4.0) = 4.0 \text{ in}^2$$

$$\delta = \frac{f}{A} = \frac{4700}{4.0} = 1175 \text{ PSI}$$

$$J \approx 7.25 \text{ in} ; C_c = 126.5$$

$$r = \sqrt{\frac{J}{C_c}} = \sqrt{\frac{7.25}{126.5}} = .144$$

$$K = 2.0 ; S_y = 36.0 \text{ KSI}$$

} see Appendix B

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: C. M. Kennedy Date: 8/1/84
 Checked by: R.C. French Date: 3/9/84
 Reviewed by: J.J. Date: 8-22-84

Project: 83-03Page 55 of 69

$$F_a = \frac{2}{3} \left(1 - \left(\frac{k_e}{r} \right)^2 / 2C_c^2 \right) S_y$$

$$= \frac{2}{3} \left(1 - \left(\frac{2.0 (7.25)}{1.144} \right)^2 / 2(126.5)^2 \right) 36.0 = 16.4 \text{ KSI}$$

$$\underline{1175 \text{ PSI}} < \underline{16,400 \text{ PSI}}$$

BENDING (AT BASE)

$$I = 2 \frac{bh^3}{12} = 2 \frac{(5)(4)^3}{12} = 5.333 \text{ in}^4$$

$$c = 2.0"$$

$$M = R_2 l = 426(7.25) = 3161 \text{ in-lb}$$

$$J = \pm \frac{Mc}{I} = \frac{3161 (2.0)}{5.333} = \underline{1185 \text{ PSI}} < \underline{+0,600 \text{ PSI}}$$

AXIAL COMPRESSION AND BENDING

$$\frac{f_a}{F_a} \leq 0.15$$


$$\therefore \frac{f_a}{F_a} + \frac{f_b}{F_b} \leq 1.0$$

$$\frac{1175}{16,400} + \frac{1185}{40,600} = \underline{0.10 < 1.0}$$

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Support Calculated by: M Kennedy Date: 8/1/84
 Checked by: R French Date: 8/9/84
 Reviewed by: ✓✓ Date: 8-22-84

Project: 83-03Page 56 of 69clevis plate to base plate weld

TREAT weld as hinge

$$\text{Area} = 2(dL + 2w) \frac{\sqrt{2}}{2} \text{ leg length}$$

$$= 2(2(4.0) + 2(.5)) \frac{\sqrt{2}}{2} (.25)$$

$$= 3.182 \text{ in}^2$$

$$Z = 2(bd + \frac{d^2}{3}) \frac{\sqrt{2}}{2} \text{ leg length}$$

$$= 2(.5(4.0) + \frac{4^2}{3}) \frac{\sqrt{2}}{2} (.25) = 2.593 \text{ in}^3$$

tension / compression

$$\gamma_1 = \frac{P}{A} = \frac{4700}{3.182} = 1477 \text{ PSI}$$

BENDING

$$\gamma_2 = \frac{M}{Z} = \frac{R_2 L}{Z} = \frac{436(7.25)}{2.593} = 1219 \text{ PSI}$$

SHEAR

$$\gamma_3 = \frac{R}{A} = 436/3.182 = 137 \text{ PSI}$$

$$\gamma_{\text{net}} = \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(1477 + 1219)^2 + (137)^2} = 2699 \text{ PSI}$$

 $\leq 24,400 \text{ PSI}$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Floodwater Seismic Supports Calculated by: M/Kennedy Date: 8/1/84
 Checked by: R/Trensch Date: 8/9/84
 Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 57 of 69

Item 2 Weld to Existing 21WF177 Column

TREAT WELD AS LINE



$$\begin{aligned} \text{AREA} &= 2 d \frac{\sqrt{2}}{2} \text{ leg length} \\ &= 2(5) \frac{\sqrt{2}}{2} (.25) \\ &= 1.768 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} z &= \frac{d^2}{3} \frac{\sqrt{2}}{2} \text{ leg length} \\ &= \frac{5^2}{3} \frac{\sqrt{2}}{2} (.25) \\ &= 1.473 \text{ in}^3 \end{aligned}$$

tension/compression

$$\gamma_1 = P/A = \frac{4700}{1.768} = 2658 \text{ psi}$$

BENDING

$$\gamma_2 = \frac{M}{Z} = \frac{R_2 l}{Z} = \frac{436 (8.0)}{1.473} = 2368 \text{ psi}$$

SHEAR

$$\gamma_3 = R_2/A = \frac{436}{1.768} = 247 \text{ psi}$$

$$\begin{aligned} \gamma_{\text{Net}} &= \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(2658 + 2368)^2 + (247)^2} = 5032 \text{ psi} \\ &\quad \underline{< 34,400 \text{ psi}} \end{aligned}$$

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: mKeown Date: 8/1/84
 Checked by: RCTenbrink Date: 8/9/84
 Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 58 of 69

Support RF-R5A SUMMARY TABLE

Item	Type of Stress	Calculated Stress (PSI)	Allowable Stress (PSI)
3	Pullout SHEAR	1,180	24,400
	SHEAR	783	24,400
	BENDING	5,875	40,600
Item 3 weld to feed. P.P.E	SHEAR	6,725	24,400
2	Compression	1,175	16,400
	BENDING	1,185	40,600
	compression & BENDING	0.10 (Note 1)	1.0
	weld SHEAR	2,699	24,400
Item 2 weld to col.	SHEAR	5,032	24,400

Notes

- (1) This is a stress ratio (non-dimensional) not a stress in PSI.

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Seawater Seismic Supports

Calculated by: M Kennedy Date: 8/1/84

Checked by: P French Date: 8/9/84



Reviewed by: JJ Date: 8-22-84

Project: 83-03

Page 59 of 69

Support RF-R6A

DESCRIPTION



DETAIL "C"


MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Seawater Seismic Supports Calculated by: M Kennedy Date: 8/1/84
Checked by: RCTranch Date: 3/9/87
Reviewed by: JJ Date: 6/22/84

Project: 83-03

Page 60 of 69



MPR ASSOCIATES, INC.


1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: M Kennedy Date: 8/1/94
 Checked by: R L French Date: 7/9/94
 Reviewed by: JJ Date: 8-23-94

Project: 83-03

Page 61 of 69

Item 2 P.PE ATTACHMENT w/(1) 1"φ x 3 $\frac{1}{4}$ " LG
HEX HEAD CAP. SCREW & NUT



$$P = 2840 \text{ lb} \quad \text{Ref (1)}$$

$$\text{Axial Load} = \frac{\sqrt{2}}{2} P = \frac{\sqrt{2}}{2} 2840 = 2008 \text{ lb}$$

$$\begin{aligned} \text{Moment Load} &= \frac{\sqrt{2}}{2} P L = \\ &= \frac{\sqrt{2}}{2} 2840 (7.75) = 15,563 \text{ in. lb} \end{aligned}$$

$$\text{Shear Load} = \text{Axial Load} = 2008 \text{ lb.}$$

Pullout shear

$$\text{Area} = 2(2r t) = 2(2(2.0) 0.5) = 4.0 \text{ in}^2$$

$$\gamma = \frac{P}{A} = \frac{2840}{4} = \underline{710 \text{ psi}} < \underline{24,400 \text{ psi}}$$

Clevis Bolt Hole tension stress

$$\text{Area} = 2t(2r - \text{hole } d) = 2(0.5)(2(2.0) - (1.0 + 0.1)) = 2.938 \text{ in}^2$$

$$\delta = \frac{\text{Axial Load}}{A} = \frac{2008}{2.938} = \underline{683 \text{ psi}} < \underline{32,400 \text{ psi}}$$

Shear at Base

$$\text{Area} = 2lw = 2(6.0)(\pi) = 6.0 \text{ in}^2$$

$$\gamma = \frac{\text{Shear load}}{A} = \frac{2008}{6} = \underline{335 \text{ psi}} < \underline{24,400 \text{ psi}}$$

MPR ASSOCIATES, INC.

1050 Connectic t Ave., NW - Washington, DC 20036

Title: SeaWATER Seismic Supports

Calculated by: M. Kennedy Date: 8/1/84
 Checked by: R. French Date: 8/9/84
 Reviewed by: JJ Date: 8/25/84

Project: 73-03

Page 62 of 69

AXIAL COMPRESSION

$$\text{let Area} = \text{minimum Area} = 2t w = 2(5)(4.0) = 40 \text{ in}^2$$

$$\delta = \frac{\text{Axial Load}}{A} = \frac{2000}{4} = 502 \text{ psi}$$

$$l \approx 7.75 \text{ in} ; C_c = 126.5$$

$$r = \frac{t}{\sqrt{12}} = \frac{5}{\sqrt{12}} = .144 \text{ in}$$

$$K = 2.0 ; S_y = 36.0 \text{ ksi}$$


} See Appendix B

$$F_a = \frac{2}{3} \left(1 - \left(\frac{Kl}{r} \right)^2 / 2C_c^2 \right) S_y$$

$$= \frac{2}{3} \left(1 - \left(\frac{(2.0)(7.75)}{.144} \right)^2 / 2(126.5)^2 \right) 36.0 = 15.3 \text{ ksi}$$

$$\underline{502 \text{ psi} < 15,300 \text{ psi}}$$

BENDING AT BASE



$$I = \frac{2bh^3}{12} = \frac{2(5)(6.0)^3}{12} \\ = 18.0 \text{ in}^4$$

$$c = 3.0 \text{ in}$$

$$\delta = \frac{Mc}{I} = \frac{15,563(3.0)}{18.0} = 2594 \text{ psi}$$

$$2594 + 502 = \underline{3096 \text{ psi} < 40,600 \text{ psi}}$$

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports

Calculated by: M Kennedy Date: 5/1/84

Checked by: R L Tyner Date: 8/9/84

Reviewed by: JJ Date: 8-22-84

Project: 83-03

Page 63 of 69

AXIAL COMPRESSION AND BENDING

$$\frac{F_a}{F_a} \leq 0.15$$

Eq (2a) controls

$$\therefore \frac{F_a}{F_a} + \frac{F_b}{F_b} \leq 1.0$$

$$\frac{502}{15,300} + \frac{2,594}{40,600} = 0.10 < 1.0$$


MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: mK Date: 8/1/84
 Checked by: RIT Date: 8/9/84
 Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page 64 of 69

Item 2 Weld to Feedwater P.P.P



TREAT weld as Line

$$\begin{aligned} A &= 4(l+w) \frac{\sqrt{3}}{2} \text{ leg length} \\ &= 4(.5 + 6.0) \frac{\sqrt{3}}{2} (.25) \\ &= 4.596 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} z &= 2(bd + \frac{d^2}{3}) \frac{\sqrt{3}}{2} \text{ leg length} \\ &= 2(.5(6.0) + \frac{6.0^2}{3}) \frac{\sqrt{3}}{2} (.25) \\ &= 5.303 \text{ in}^3 \end{aligned}$$

Tension / compression

$$\gamma_1 = \frac{P \frac{\sqrt{3}}{2}}{A} = \frac{2840 \frac{\sqrt{3}}{2}}{4.596} = 437 \text{ PSI}$$

Bending

$$\gamma_2 = \frac{P \frac{\sqrt{3}}{2} l}{z} = \frac{2840 \frac{\sqrt{3}}{2} (7.75)}{5.303} = 2935 \text{ PSI}$$

Shear

$$\gamma_3 = \frac{P \frac{\sqrt{3}}{2}}{A} = \frac{2840 \frac{\sqrt{3}}{2}}{4.596} = 437 \text{ PSI}$$

$$\gamma_{\text{net}} = \sqrt{(\gamma_1 + \gamma_2)^2 + \gamma_3^2} = \sqrt{(437 + 2935)^2 + 437^2} = \underline{\underline{3400 \text{ PSI}}} \\ \angle \underline{\underline{24,400 \text{ PSI}}}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Feedwater Seismic Supports Calculated by: mKenne Date: 8/1/84
 Checked by: RCTrench Date: 8/9/84
 Reviewed by: JJ Date: 8-22-84

Project: 83-03


Page 65 of 109

Item 3 Clevis & Bolt STANDARD PART EA1-A

Rates to 10,000 lb Ref. (2)

Actual LOAD 2840 lb.

Item 3 Weld to Item 4




TREAT weld as line

$$\begin{aligned} \text{Area} &= 4s \frac{\sqrt{2}}{2} \text{ leg length} \\ &= 4(5) \frac{\sqrt{2}}{2} (.25) \\ &= 3.536 \text{ in}^2 \end{aligned}$$

tension/compression

$$\gamma_{\text{net}} = \gamma_i = P/A = 2840/3.536 = 803 \text{ PSI} < 24,400 \text{ PSI}$$

Item 4 6WF 15.5 I-BEAM




$$\begin{aligned} x^2 &= a^2 + b^2 - 2ac \cos \theta = 320.0^2 + 304.1875^2 - 2(320.0)(304.1875) \cos 18^\circ \\ x &= 98.89 \text{ in} \end{aligned}$$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: Fairwater Seismic Supports Calculated by: NikKempf Date: 8/1/84
 Checked by: RCTrevor Date: 8/9/84
 Reviewed by: JJ Date: 8-22-84

Project: F3-03

Page 66 of 69



$$R_A = \frac{P(l-a)}{l} = \frac{2840(98.89-21.0)}{98.89} = 2237 \text{ lb.}$$

$$R_B = \frac{Pa}{l} = \frac{2840(21.0)}{98.89} = 603 \text{ lb.}$$

$$M = \frac{Pa(l-a)}{l} = \frac{2840(21.0)(98.89-21.0)}{98.89} = 46,975 \text{ in. lb}$$

6 WF 15.5 I-BEAM

$$I = 30.3 \text{ in}^4; c = 3.0 \text{ in}$$

$$A = 4.62 \text{ in}^2$$

Ref(4) p. 1-21

BENDING

$$\delta = \pm \frac{Mc}{I} = \pm \frac{46,975(3.0)}{30.3} = \underline{\pm 4651 \text{ psi}} < 40,600 \text{ psi}$$

SHEAR

$$\gamma = \frac{R_A}{\text{Web, long } t_w} = \frac{2237}{6(.24)} = \underline{1553 \text{ psi}} < 24,400 \text{ psi}$$

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Floodwater Seismic Supports Calculated by: MilKernish Date: 8/1/84
 Checked by: RCTaylor Date: 8/9/84
 Reviewed by: JJ Date: 8/22/84

Project: 83-03Page 67 of 69Item 4 weld to existing 21 wt 9G beam

LOCATION 'A' controlling

TREAT weld AS LINE

$$\begin{aligned} \text{AREA} &= 2l \frac{5}{2} \text{ leg length} \\ &= 2(9) \frac{5}{2} (.25) \\ &= 3.182 \text{ in}^2 \end{aligned}$$

Ref P 1-8

Tension / compression

$$\gamma_{\text{net}} = \gamma_i = R_A/A = \frac{2237}{3.182} = \underline{\underline{703 \text{ psi}}} < 24,400 \text{ psi}$$

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Fesswater Seismic Supports Calculated by: M Kennedy Date: 8/1/84
 Checked by: RITranch Date: 3/9/87
 Reviewed by: JT Date: 8/22/84

Project: F3-03

Page 68 of 69

Support RF-RGA SUMMARY TABLE

Item	Type of Stress	Calculated Stress (PSI)	Allowable Stress (PSI)
2	Pullout SHEAR	710	24,400
	TENSION	683	32,400
	SHEAR	335	24,400
	BENDING	3,096	40,600
	COMPRESSION	502	15,300
	Compression & BENDING (Note 1)	0.10	1.0 (Note 1)
Item 2 weld to Fess Pipe	SHEAR	3400	24,400
Item 3 Weld to Item 4	SHEAR	803	24,400
4	BENDING	4,651	40,600
	SHEAR	1,553	24,400
Item 4 weld to I-BEAM	SHEAR	703	24,400

(1) This is a stress ratio not a stress in PSI

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: Fearwater Seismic Supports Calculated by: MOKawashy Date: 8/1/84
Checked by: R.L.Trenholz Date: 8/9/84
Reviewed by: JJ Date: 8/22/84

Project: 83-03

Page C9 of 69

Item	Calculated Load (lb)	Allowable Load (lb)
3	2840	10,000

Appendix E

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM & Secondary
Snubber Evaluation

Calculated by: jkennedy
Checked by: R. T. Ward
Reviewed by: J. Johnson

Date: 9/24/84
Date: 9/27/84
Date: 9-22-84

Project: SEP PIPING SUPPORTS
83-03

Page 1 of 13

Purpose The purpose of the following calculation is to evaluate the installed Oyster Creek Snubbers for loads and resulting from loads reported in EGG-EA-5211, "Summary of the Oyster Creek piping calculations performed for the systematic evaluation program."

References

- (1) EGG-EA-5211, "Summary of the Oyster Creek Unit 1 Piping Calculations performed for the Systematic Evaluation Program," M. E. Nitzel, July, 1980.
- (2) Nutech PAC-03-001, "ASME Section III Class I Stress Analysis of 10,000 Pound Mechanical Shock Arrestor 1801103-01," R. F. PetroKAS, August, 1975.
- (3) Pacific Scientific Test Report 802 Qualification tests Mechanical Shock Arrestors P/N 1801107-01, -03, -05 and 1801117-01.
- (4) Rank & Young, Formulas for Stress and Strain, McGraw-Hill, 5th Ed.

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM & FEEDWATER
Snubber Evaluation


Calculated by: mf Tammey
Checked by: R Chenev
Reviewed by: JJ

Date: 9/24/84
Date: 9/27/84
Date: 9-27-84

Project: 87-03

Page 2 of 13

DESCRIPTION



MAIN STREAM

SNUBBER	OVERALL length (in.)	L (in.)	D (in.)	Tor C (in.)	B (in.)	A (in.)
X-2A-5S-1	I 81.5	16.0	7.25	3.75	42.0	12.5
	II 39.25	13.5	7.25	3.75	2.75*	12.00
MS-R1A	43.25	16.0	7.25	4.625	2.875	12.50
MS-R2A	51.625	16.0	7.25	3.5625	4.6875	20.125
MS-R3A	44.5	16.0	7.25	3.25	5.5	12.5
MS-R4A	72.0	16.0	7.25	4.25	30.0	14.5
MS-R5A	111.5	16.0	7.25	3.75	72.0	12.5

* min

Ref: Bergan-Paterson catalog 66 AND pipe support drawings

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM & FEEDWATER
Snubber EVALUATION

Calculated by: M Kennedy
Checked by: E C Ireland
Reviewed by: JL

Date: 9/24/84
Date: 9/27/84
Date: 9-27-84

Project: 83-03

Page 3 of 13

FEEDWATER

Snubber	Overall Length (in)	L (in)	D (in)	TorC (in)	B (in)	A (in)
X-4B-SS-1	109.25	16.0	7.25	3.75	69.75	12.5
	79.0	16.0	7.25	3.75	39.5	12.5
RF-R1A	132.0	16.0	7.25	3.9375	92.6875	12.125
RF-R2A	96.125	16.0	7.25	3.3125	57.0625	12.5
RF-R3A	42.375	16.0	7.25	3.1875	4.8125	11.125
RF-R4A	72.0	16.0	7.25	3.5625	33.375	11.8125
RF-R5A	130.0	16.0	7.25	3.5	87.5	15.75
RF-R6A	40.875	16.0	7.25	3.25	3.25	11.125

Ref: Bergen - Paterson catalog 66 and pipe support drawings

Note: In the mid seventies, the hydraulic snubbers originally provided by Bergen - Paterson were replaced by mechanical snubbers provided by Pacific - Scientific. The replacements were designed to replace the parts shown in the figure which span dimension L AND (TorC). The end clevises, turnbuckle and extension pipe provided by Bergen - Paterson were retained. (see drawings)

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM & FEEDWATER
SNUBBER EVALUATION

Calculated by: m/Brady
Checked by: KC Gruch
Reviewed by: JL

Date: 9/24/84
Date: 9/27/84
Date: 9-27-84

Project: 83-03

Page 4 of 13

EVALUATION

Snubber extension pipe

The main steam AND feedwater snubbers have extension pipes which vary in length AND axial stress area. They are evaluated in the following calculation for tension / compression loads in accordance with the requirements of the 1980 ASME Code, Division I, Subsection NF, and are found acceptable.

Snubber turnbuckle

The main steam AND feedwater snubbers have turnbuckle adjustment mechanisms which vary in length. They are evaluated in the following calculation for tension / compression loads in accordance with the requirements of the 1980 ASME Code, Division I, Subsection NF, and are found acceptable.

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM & Feedwater
Snubber EvaluationCalculated by: M Kennedy
Checked by: R L French
Reviewed by: JJDate: 9/24/84
Date: 9/27/84
Date: 7-27-84

Project: 83-03

Page 5 of 13

Snubber

The maximum snubber load is 12,330 lbs AND occurs in MAIN steam support MS-R2A . The snubber is rated for 11,000 lb AND has been tested for an ultimate structural load of 22,000 lb with no yielding of parts (Ref. 3). An ASME Code analysis of the snubber was completed in Reference 2. In this analysis, the limiting component (bases on manufacturer's rates load - not failure) is the BALL NUT AND BALLS in the screw assembly which are rated at 22,000 lb. Because the mechanism is functional at loads of 22,000 lb, the level 0 failure load for this component is much higher. The next most limiting component is the ball screw shaft which has a load rating of 26,000 lb for Level 0 service conditions.

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM & Feedwater
Snubber Evaluation

Calculated by: M Kennedy
Checked by: PC French
Reviewed by: JJ

Date: 9/24/84
Date: 9/27/84
Date: 9/27/84

Project: 83-03

Page 6 of 13

Allowable Calculation

From Appendix B

Level O Compression Allowable

γ_3 critical Buckling

$$C_c = 126.5, \quad S_y = 36.0 \text{ KSI}, \quad E = 29.2 \times 10^3 \text{ KSI}$$

$$C_c > K_{fr} \quad f_a' = \gamma_3 \left(1 - \left(\frac{K_f l}{r} \right)^2 / 2 C_c^2 \right) S_y$$

$$C_c < K_{fr} \quad f_a' = \gamma_3 \frac{\pi^2 E}{\left(\frac{K_f l}{r} \right)^2}$$

Level D Tension Allowable

$$F_t' = 40,600 \text{ PSI}$$

SUPPORT EXTENSION PIPES

MAIN STEAM & Feedwater support extension pipes are evaluated for buckling in tables 1-4. In tables 1 & 2, the allowable stress is calculated. In tables 3 & 4, the actual stress is calculated.

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM & REFWATER
Snubber evaluation

Calculated by: 2/Kennedy Date: 9/24/84
 Checked by: R.Trower Date: 9/27/84
 Reviewed by: TT Date: 9-27-84

Project: 83-03

Page 7 of 13

TABLE I MAIN STEAM SUPPORT EXTENSION PIPES

SNUBBER	OVERALL SNUBBER length (in.)	l (in)	r (in)	$\frac{KL}{r}^{**}$	F_a^1 (KSI)
X-2A-SS-1 (I)	81.5	81.5	0.767	106.3	15.5
	39.25	39.25	0.767	51.2	22.0
MS-R1A	43.25	43.25	0.767	56.4	21.6
MS-R2A	51.625	51.625	0.767	67.3	20.6
MS-R3A	44.5	44.5	0.767	58.0	21.5
MS-R4A	72.0	72.0	0.767	93.9	17.4
MS-R5A*	111.5	111.5	1.134	98.2	16.8

* uses 3" sch 80 pipe. All other snubbers use 2" sch 80 pipe

** $KL = 1$

MPR ASSOCIATES, INC.
 1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM & FEEDWATER Calculated by: n) Kennedy Date: 1/8/84
SNUBBER EVALUATION Checked by: k (G) Date: 5/9/84
 Reviewed by: LL Date: 9-27-84

Project: 83-03

Page 8 of 13

TABLE 2 FEEDWATER SUPPORT EXTENSION PIPES

SNUBBER	OVERALL SNUBBER LENGTH (in.)	l (in.)	r (in.)	$\frac{K\ell}{r}^{**}$	f_a' (KSI)
RF-R1A*	132.0	132.0	1.136	116.2	13.9
RF-R2A*	96.125	96.125	1.136	84.6	18.6
RF-R3A	42.375	42.375	0.767	55.2	21.7
RF-R4A	72.0	72.0	0.767	93.9	17.4
RF-R5A*	130.0	130.0	1.136	114.4	14.2
RF-R6A	40.875	40.875	0.767	53.3	21.9
XHB-SS-1 (P1)	109.25	109.25	0.767	142.4	9.5
(P2)	79.0	79.0	0.767	103.0	16.0

* uses 3" sch 80 PIPE. All other snubbers use
 2" sch 80 PIPE

** K = 1

MPR ASSOCIATES, INC.
 1050 Connecticut Ave., NW - Washington DC 20036

Title: MAIN STEAM & FEEDWATER
SNUBBER EVALUATION Calculated by: m Kennedy Date: 1/8/84
 Checked by: R French Date: 2/1/84
 Reviewed by: JJ Date: 9-27-84

Project: 83-03

Page 9 of 13

TABLE 3 MAIN STEAM SUPPORT EXTENSION PIPES

Support MARK #	Area (in ²)	REVISED LOAD (lb) ¹	ACTUAL LOAD (lb) ²	calculated stress (PSI)	allowable stress (PSI)
(P _{II}) X-2A-55-1	1.477	3,440	3,440	2,329	22,000
	1.477	1,200	1,200	812	15,500
MS-R1A	1.477	5,170	5,170	3,500	21,600
MS-R2A	1.477	12,330	12,330	8,348	20,600
MS-R3A	1.477	7,710	7,710	5,220	21,500
MS-R4A	1.477	9,950	9,950	6,737	17,400
MS-R5A	3.016	8,330	8,330	2,762	16,800

Notes

(1) TAKEN FROM APPENDIX A , TABLE 2

(2) TAKEN FROM APPENDIX C,

(3) $\delta = F/A = \text{ACTUAL LOAD} / \text{Area}$

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM & FEEDWATER
SNubber evaluation

Calculated by: M.Roughy Date: 1/8/84
 Checked by: R.C.McCormick Date: 3/9/84
 Reviewed by: JJ Date: 7-27-84

Project: 83-03

Page 10 of 13

Table 4 Feedwater Support Extension Pipes

SUPPORT MARK #	AREA (IN ²)	REVISED LOAD (lb) ¹	ACTUAL LOAD (lb) ²	CALCULATED STRESS (PSI) ³	ALLOWABLE STRESS (PSI)
(P _I) X-4B-SS-1	1.477	7,340	7,340	907	9,500
	1.477	2,340	2,340	1584	16,000
RF-R1A	3.016	2,200	2,225	738	13,900
RF-R2A	3.016	1,600	1,600	531	19,600
RF-R3A	1.477	1,300	1,300 ²	1880	21,700
RF-R4A	1.477	4,160	4,191	2,838	17,400
RF-R5A	3.016	4,700	4,720	1,565	14,200
RF-R6A	1.477	2,840	2,840	1,923	21,900

Notes

(1) TAKEN FROM APPENDIX A, TABLE 3

(2) TAKEN FROM APPENDIX D.

(3) $\delta = f/A = \text{Actual Load} / \text{Area}$.

MPR ASSOCIATES, INC.
1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM & Feedwater
Snubber Evaluation

Calculated by: m Kennedy
Checked by: R French
Reviewed by: JJ

Date: 9/24/84
Date: 9/27/84
Date: 9-27-84

Project: 83-03

Page 11 of 13

turnbuckle

Assuming the clevis / turnbuckle / threaded rod member has the properties of the threaded rod in buckling

$$\left. \begin{array}{l} \text{Stress Area} = 1.0721 \text{ in}^2 \\ \text{minor diameter} = 1.1478 \text{ in} \end{array} \right\} \quad \begin{array}{l} 1\frac{1}{4} \text{ in. F.} \\ \text{MARKS} \\ \text{HANDBOOK} \\ 8\text{th Ed.} \end{array}$$

$$I = \frac{\pi}{64} d^4 = \frac{\pi}{64} (1.1478)^4 = 8.52 \times 10^{-2} \text{ in}^4$$

$$r = \sqrt{\frac{I}{A}} = \sqrt{\frac{8.52 \times 10^{-2}}{1.0721}} = 0.282 \text{ in}$$

Because the section modulus of this member is significantly less than that of the extension pipe this section is evaluated for buckling as an isolated member and not as a stepped column.

(see Ref.(4) p 534, Table 34, case 1b.) The "A" dimension listed on pp 2 & 3 is used as the buckling length.

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STEAM & FEEDWATER
Snubber EvaluationCalculated by: M Kennedy
Checked by: R Jellum
Reviewed by: JJDate: 9/24/84
Date: 9/27/84
Date: 9-27-84Project: 83-03Page 12 of 13Table 5 MAIN steam turnbuckles

SNUBBER	"A" (IN)	K _L * r	F _{a'} (KSI)	ALLOWABLE LOAD ** (KIPS)	CALCULATED LOAD (KIPS)	CALCULATED STRESS (PSI)
X-2A-SS-1	I	12.5	44.3	22.5	24.1	1.20
	II	12.0	42.6	22.4	24.2	3.44
MS-R1A	12.5	44.3	22.5	24.1	5.17	4,822
MS-R2A	20.125	71.4	20.2	21.7	12.33	11,501
MS-R3A	12.5	44.3	22.5	24.1	7.71	7,191
MS-R4A	14.5	51.4	22.0	23.6	9.95	9,281
MS-R5A	12.5	44.3	22.5	24.1	8.33	7,770

* K=1 ; r=0.282 in. ; L=A

** Allowable load = F_{a'} * Area ; Area = 1.0721 in²

MPR ASSOCIATES, INC.

1050 Connecticut Ave., NW - Washington, DC 20036

Title: MAIN STREAM & Feedwater
SNUBBER EVALUATIONCalculated by: m Kennedy
Checked by: R Trumbo
Reviewed by: SJDate: 9/24/84
Date: 9/27/84
Date: 9-27-84Project: 83-03Page 13 of 13Table 6 Feedwater turnbuckles

SNUBBER	"A" (IN)	$\frac{Kg}{r} *$	F_a' (KSI)	Allowable LOAD ** (KIPS)	calculated LOAD (KIPS)	calculated stress (P.SI)
X-4B-SS-1	I 12.5	44.3	22.5	24.1	1.34	1,250
	II 12.5	44.3	22.5	24.1	2.34	2,183
RF-R1A	12.125	43.0	22.6	24.2	2.23	2,180
RF-R2A	12.5	44.3	22.5	24.1	1.60	1,492
RF-R3A	11.125	39.5	22.8	24.5	1.30	1,213
RF-R1A	11.8125	41.9	22.7	24.3	4.19	3,908
RF-R5A	15.75	55.9	21.7	23.3	4.72	4,403
RF-R5A	11.125	39.5	22.8	24.5	2.84	3,649

* $K=1$; $r = 0.282$ in.; $l = A$ ** Allowable load = $F_a' * \text{Area}$; Area = 1.0721 in^2