

Docket No. 50-336
B15338

Attachment 1

Millstone Nuclear Power Station, Unit No. 2
Proposed Revision to Technical Specifications
Electrical Power Systems - Shutdown

Marked-up Pages

October 1995

9510260073 951020
PDR ADDCK 05000336
P PDR

August 1, 1975

ELECTRICAL POWER SYSTEMS

SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.B.1.2 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the switchyard, and
- b. One diesel generator with a fuel oil supply tank containing a minimum of 12,000 gallons of fuel.

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above minimum required A.C. electrical power sources OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes ~~until the minimum required A.C. electrical power sources are restored to OPERABLE status.~~

or movement of irradiated fuel assemblies.

SURVEILLANCE REQUIREMENTS

4.B.1.2 The above required A.C. electrical power sources shall be demonstrated OPERABLE per Surveillance Requirements 4.B.1.1.1 and 4.B.1.1.2.

EXCEPT FOR TESTING PURSUANT TO SURVEILLANCE REQUIREMENTS 4.B.1.1.2 c.2, c.5 and c.8.
4.B.1.2.a.3,

August 1, 1975

ELECTRICAL POWER SYSTEMS

A.C. DISTRIBUTION - SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.2.2 As a minimum, the following A.C. electrical busses shall be OPERABLE and energized from sources of power other than a diesel generator but aligned to an OPERABLE diesel generator:

- 1 - 4160 volt Emergency Bus
- 1 - 480 volt Emergency Load Center
- 2 - 120 volt A.C. Vital Busses

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above complement of A.C. busses OPERABLE and energized, establish CONTAINMENT INTEGRITY within 8 hours.

REPLACE WITH
INSERT (A)

SURVEILLANCE REQUIREMENTS

4.8.2.2 The specified A.C. busses shall be determined OPERABLE and energized from normal A.C. sources at least once per 7 days by verifying correct breaker alignment and indicated power availability.

INSERT A

With less than the above complement of A.C. busses OPERABLE and energized, suspend all operations involving CORE ALTERATIONS or positive reactivity changes or movement of irradiated fuel assemblies.

10/14/94

ELECTRICAL POWER SYSTEMS

D.C. DISTRIBUTION - SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.2.4 As a minimum, the following D.C. electrical equipment and bus shall be energized and OPERABLE:

- 1 - 125-volt D.C. bus, and
- 1 - 125-volt battery bank and at least 400 ampere charging capacity supplying the above D.C. bus.

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above complement of D.C. equipment and bus OPERABLE, establish CONTAINMENT INTEGRITY within 8 hours.

REPLACE WITH INSERT (B)

SURVEILLANCE REQUIREMENTS

4.8.2.4.1 The above required 125-volt D.C. bus shall be determined OPERABLE and energized at least once per 7 days by verifying correct breaker alignment and indicated power availability.

4.8.2.4.2 The above required 125-volt battery bank and charger shall be demonstrated OPERABLE per Surveillance Requirement 4.8.2.3.2.

INSERT B

With less than the above complement of D.C. electrical equipment and bus energized and OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes or movement of irradiated fuel assemblies.

Docket No. 50-336
B15338

Attachment 2

Millstone Nuclear Power Station, Unit No. 2
Proposed Revision to Technical Specifications
Electrical Power Systems - Shutdown

Retyped Pages

October 1995

ELECTRICAL POWER SYSTEMS

SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.1.2 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the switchyard, and
- b. One diesel generator with a fuel oil supply tank containing a minimum of 12,000 gallons of fuel.

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above minimum required A.C. electrical power sources OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes or movement of irradiated fuel assemblies. |

SURVEILLANCE REQUIREMENTS

4.8.1.2 The above required A.C. electrical power sources shall be demonstrated OPERABLE per Surveillance Requirements 4.8.1.1.1 and 4.8.1.1.2, except for testing pursuant to Surveillance Requirements 4.8.1.1.2.a.3, 4.8.1.1.2.c.2, 4.8.1.1.2.c.5, and 4.8.1.1.2.c.8. |

ELECTRICAL POWER SYSTEMS

A.C. DISTRIBUTION - SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.2.2 As a minimum, the following A.C. electrical busses shall be OPERABLE and energized from sources of power other than a diesel generator but aligned to an OPERABLE diesel generator:

- 1 - 4160 volt Emergency Bus
- 1 - 480 volt Emergency Load Center
- 2 - 120 volt A.C. Vital Busses

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above complement of A.C. busses OPERABLE and energized, suspend all operations involving CORE ALTERATIONS or positive reactivity changes or movement of irradiated fuel assemblies.

SURVEILLANCE REQUIREMENTS

4.8.2.2 The specified A.C. busses shall be determined OPERABLE and energized from normal A.C. sources at least once per 7 days by verifying correct breaker alignment and indicated power availability.

ELECTRICAL POWER SYSTEMS

D.C. DISTRIBUTION - SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.2.4 As a minimum, the following D.C. electrical equipment and bus shall be energized and OPERABLE:

- 1 - 125-volt D.C. bus, and
- 1 - 125-volt battery bank and at least 400 ampere charging capacity supplying the above D.C. bus.

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above complement of D.C. electrical equipment and bus energized and OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes or movement of irradiated fuel assemblies.

SURVEILLANCE REQUIREMENTS

4.8.2.4.1 The above required 125-volt D.C. bus shall be determined OPERABLE and energized at least once per 7 days by verifying correct breaker alignment and indicated power availability.

4.8.2.4.2 The above required 125-volt battery bank and charger shall be demonstrated OPERABLE per Surveillance Requirement 4.8.2.3.2.