PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-V-84-68 Date: 10/15/84

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by Region V staff on this date.

FACILITY: Southern California Edison Co.

San Onofre Nuclear Generating Station

San Clemente, CA Docket No. 50-362 Licensee Emergency Classification Notification of Unusual Event

Alert

Site Area Emergency General Emergency XX Not Applicable

STEAM GENERATOR TUBE LEAK SUBJECT:

The licensee has detected a tube leak in Unit 3 steam generator E-089. The leak rate was measured at 34 gallons per day (approximately 0.02 gpm), on October 14, 1984. Plant operation continues at 100% power. Based on past experience, the leak rate is expected to trend upward (reference: PNO-RV-84-41, dated 7/17/84). Industry experience has indicated that a leak rate less than 100 gallons per day is difficult to locate.

The licensee is closely monitoring the situation and plans to shut the unit down well before the Technical Specification limit is reached. The resident inspector is also actively involved in following this matter.

A supplement to this PN will be issued when further significant developments (e.g. plant shutdown) occur.

This information is current as of 12:00 noon (PDT) on October 15, 1984.

A. Chaffee (714) 492-2641

DISTRIBUTION

H St. 2:20 MNBB2:24Phillips 8E/W Willste Air Rights Mail:
Chairman Pallidino EDO NRR IE NMSS ADM:DM
Comm. Zech PA OIA RES DOT:Tr OIA Comm. Zech Regions: I-3:20, II - 8:37, III - 3:36, IV - 8:2/ Comm. Bernthal MPA Comm. Roberts ELD Comm. Asselstine INPO 9: SCHSAC 15 SECY Licensee: male ACRS (Reactor Licensees) REGION V: FORM 211 CA PDR Resident Inspector (Revised 3/14/83)

8410190309 841015 PDR I&E PNO-V-84-068 PD

1E-34