



Consumers
Power
Company

David J VandeWalle
Director of
Nuclear Licensing

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-1636

September 27, 1984

James G Keppler, Administrator
Region III
US Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

DOCKET 50-255 - LICENSE DPR-20 -
PALISADES PLANT - REVISED RESPONSE TO NONCOMPLIANCE 50-255/84-09-08

Three items of noncompliance were identified in IE Inspection Report 50-255/84-09 dated June 29, 1984. Consumers Power Company letter of August 10, 1984 provided the response to these items. We have reconsidered the commitment made in response to noncompliance 50-255/84-09-08 because we do not believe there is basis for this noncompliance. Our revised response is as follows.

Noncompliance (50-255/84-09-08)

10 CFR 50, Appendix B, Criterion XV, as implemented by Section 15 of Consumers Power Quality Assurance Program Description for Operation Nuclear Power Plants (CPC-2A) requires measures to be established to control materials, parts or components which do not conform to requirements in order to prevent their inadvertent use or installation. Appendix A of CPC-2A states the Consumers Power Quality Assurance Program complies with Regulatory Guide 1.38, Revision 2, which endorses ANSI N45.2.2-1972, "Quality Assurance Requirements for Packaging, Shipping, Receiving, Storage and Handling of Items for Water Cooled Nuclear Power Plants".

Contrary to the above, Consumers Power Quality Assurance Program and its implementing procedures do not require a technical justification be prepared and documented for the conditional release of a nonconforming item for installation. This documented technical justification prior to installing a nonconforming item is required by ANSI N45.2.2, paragraph 5.3.3.

Corrective Action Taken and Results Achieved:

No corrective action has been taken for the following reason. All items that are deficient in characteristic or documentation which renders the quality of the item unacceptable or indeterminate is identified as nonconforming and any further use is controlled by the issuance of a Nonconforming Material Report (NMR). If the item is installed prior to the closeout of the NMR, it is

OC0984-0016A-NL02

8410220103 841018
PDR ADOCK 05000255
Q PDR

OCT 1 1984

JGKeppler, Administrator
Palisades Plant
REVISED RESPONSE TO IEIR 84-09
September 27, 1984

2

further controlled by the issuance of a Conditional Material Release (CMR). Both the NMR and CMR require the item to be tagged. CMRs are not allowed for consumables. Prior to placing reliance on the item to perform a safety-related function all NMRs and CMRs associated with that NMR for that item are closed out. This includes completion of the technical justification.


As required by ANSI N45.2.2-1972, a technical justification is completed as part of the NMR process which serves as the technical justification for the CMR. We do not interpret paragraph 5.3.3 of N45.2.2 to imply a technical justification be completed prior to the installation of the item. As long as a technical justification which reclassifies the item from unacceptable to acceptable is completed prior to placing reliance on the item, the requirement of paragraph 5.3.3 is met. Our Quality Assurance Program Description (CPC-2A) and implementing procedures are consistent with this interpretation.

Corrective Action to be Taken to Avoid Further Noncompliances:

None

Date When Full Compliance Will be Achieved:

Full compliance has been achieved.



David J Vandewalle
Director, Nuclear Licensing

CC Director, Office of Nuclear Reactor Regulation
Director, Office of Inspection and Enforcement
NRC Resident Inspector - Palisades