

OCT 12 1984

DMBolt

Docket No. 50-313

Mr. John M. Griffin, Senior Vice President
of Energy Supply
Arkansas Power and Light Company
P. O. Box 551
Little Rock, Arkansas 72203

DISTRIBUTION

<u>Docket File</u>	EBlackwood
NRC PDR	Hornstein
L PDR	RIngram
ORB#4 Rdg	GVising
DEisenhut	Gray File
OELD	NLauben
EJordan	RLobel
JNGrace	PKadambi
JPartlow	
ACRS-10	

Dear Mr. Griffin:

We are reviewing your submittal of September 26, 1984 which provides proposed Technical Specifications for Arkansas Nuclear One, Unit No. 1 (ANO-1) Cycle 7 operation. We note that the impact of NUREG 0630, "Cladding Swelling Models for LOCA Analysis", was assessed by bounding calculations with offset credit taken for use of FLECSET heat transfer correlation. We have not completed our review of the FLECSET heat transfer correlation and the corresponding offset credit taken for use of FLECSET. We do not anticipate our review of FLECSET to be complete such that any credit can be given for Cycle 7. We request that you supplement your application of September 26, 1984 with applicable proposed Technical Specification limits which would take no credit for use of FLECSET.

We note that your September 26, 1984 submittal did not provide us 90 days for review before your planned start up of December 15, 1984. With our review period and time to prepare and publish a Federal Register Notice for a 30 day waiting period before issuance of the amendment already cut short, you should provide your proposed supplement no later than October 31, 1984, in order for us to complete all the above to meet your December 15, 1984 start up date. We can not justify an emergency amendment.

The reporting and/or recordkeeping requirements of this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

*ORIGINAL SIGNED BY
JOHN F. STOLZ*

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

cc: See next page

ORB#4:DL
GVising;cf
10/12/84

ORB#4:DL
JStolz
10/17/84

8410220157 841012
PDR ADOCK 05000313
P PDR

cc w/enclosure(s):

Mr. John R. Marshall
Manager, Licensing
Arkansas Power & Light Company
P. O. Box 551
Little Rock, Arkansas 72203

Mr. James M. Levine
General Manager
Arkansas Nuclear One
P. O. Box 608
Russellville, Arkansas 72801

Mr. W. D. Johnson
U.S. Nuclear Regulatory Commission
P. O. Box 2090
Russellville, Arkansas 72801

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Mr. Nicholas S. Reynolds
Bishop, Liberman, Cook, Purcell & Reynolds
1200 17th Street, NW
Washington, DC 20036

Honorable Ermil Grant
Acting County Judge of Pope County
Pope County Courthouse
Russellville, Arkansas 72801

Regional Radiation Representative
EPA Region VI
1201 Elm Street
Dallas, Texas 75270

Mr. John T. Collins, Regional Administrator
U. S. Nuclear Regulatory Commission, Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Mr. Frank Wilson
Director, Division of Environmental
Health Protection
Department of Health
Arkansas Department of Health
4815 West Markham Street
Little Rock, Arkansas 72201



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

October 12, 1984

Docket No. 50-313

Mr. John M. Griffin, Senior Vice President
of Energy Supply
Arkansas Power and Light Company
P. O. Box 551
Little Rock, Arkansas 72203

Dear Mr. Griffin:

We are reviewing your submittal of September 26, 1984 which provides proposed Technical Specifications for Arkansas Nuclear One, Unit No. 1 (ANO-1) Cycle 7 operation. We note that the impact of NUREG 0630, "Cladding Swelling Models for LOCA Analysis", was assessed by bounding calculations with offset credit taken for use of FLECSET heat transfer correlation. We have not completed our review of the FLECSET heat transfer correlation and the corresponding offset credit taken for use of FLECSET. We do not anticipate our review of FLECSET to be complete such that any credit can be given for Cycle 7. We request that you supplement your application of September 26, 1984 with applicable proposed Technical Specification limits which would take no credit for use of FLECSET.

We note that your September 26, 1984 submittal did not provide us 90 days for review before your planned start up of December 15, 1984. With our review period and time to prepare and publish a Federal Register Notice for a 30 day waiting period before issuance of the amendment already cut short, you should provide your proposed supplement no later than October 31, 1984, in order for us to complete all the above to meet your December 15, 1984 start up date. We can not justify an emergency amendment.

The reporting and/or recordkeeping requirements of this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

A handwritten signature in cursive script, appearing to read "John F. Stolz".

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

cc: See next page