



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 06, 1984

84 OCT 10 11:06

NUCLEAR LICENSING & SAFETY DEPARTMENT

U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30323

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File: 0260/L-835.0
Special Report 84-036/0, Diesel
Generator Fuel Oil Leak
AECM-84/0461

On September 8, 1984, during reactor startup, fuel oil was found leaking from the gasket on the fuel oil filter of Diesel Generator 11 while performing a surveillance. In order to minimize the potential fire hazard, the diesel generator was secured, placed in the maintenance mode and declared inoperable. The washer which seals around the nut on the filter gasket was found leaking. The washer was replaced and the diesel generator was returned to service within 8 hours.

This was not a valid failure, therefore, the current test interval of the diesel generator remains at 14 days. This Special Report is submitted pursuant to Technical Specification 4.8.1.1.3.

Yours truly,

[Handwritten signature]

L. F. Dale
Director

[Handwritten initials]

EBS/SHH:rg

cc: Mr. J. B. Richard
Mr. R. B. McGehee

Mr. N. S. Reynolds
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8410220179 841005
PDR ADOCK 05000416
S PDR

OFFICIAL COPY

1/0

1022