

October 9, 1984
(NMP2L 0194)


Mr. R. W. Starostecki, Director
U. S. Nuclear Regulatory Commission
Region I
Division of Project and Resident Programs
631 Park Avenue
King of Prussia, PA 19406

Re: Nine Mile Point - Unit 2
Docket No. 50-410

Dear Mr. Starostecki:

Enclosed is an interim report, in accordance with 10CFR50.55(e), for the problem concerning the check valves. This problem was reported via tel-con to S. Collins of your staff on September 7, 1984.

Very truly yours,



C. V. Mangan
Vice President
Nuclear Engineering and Licensing

CVM/GG/pbd

xc: Director of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

R. A. Gramm, NRC Resident Inspector

Project File (2)

B410230284 B41009
PDR ADOCK 05000410
S PDR

NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT - UNIT 2
DOCKET NO. 50-410

Interim Report for a Problem
Concerning Check Valves (55(e)-84-38)

Description of the Problem

The problem pertains to the check valves supplied by Anchor Darling Valve Company. During a review of the certified material test reports it was discovered that impact test data was not recorded for various components (gasket retaining ring, seat ring, disc) of the subject valves. The valves are located in various safety-related systems (feedwater, residual heat removal, low pressure core spray, high pressure core spray, and reactor core isolation cooling). This condition has been documented on Nonconformance and Disposition Report Nos. Z099 and Z100.

The matter is still under investigation and a final report will be submitted by January 21, 1985.