

October 11, 1995

Mr. D. R. Gipson
Senior Vice President
Nuclear Generation
The Detroit Edison Company
6400 North Dixie Highway
Newport, MI 48166

SUBJECT: NRC INTEGRATED INSPECTION REPORT NO. 50-341/95011

Dear Mr. Gipson:

This refers to the routine safety inspection conducted by Messrs. A. Vogel, C. O'Keefe, and others of this office from August 18 through September 22, 1995. The inspection included a review of activities authorized for your Fermi 2 facility. At the conclusion of the overall inspection effort, the findings from each inspection were discussed with those members of your staff identified in the enclosed report at an integrated inspection exit.

Areas examined during the inspection are identified in the report. Within these areas, the inspections consisted of a selective examination of procedures and representative records, interviews with personnel, and observation of activities in progress. The purpose of the inspection effort was to determine whether activities authorized by the license were conducted safely and in accordance with NRC requirements.

The inspection revealed some improvements and weaknesses in performance. Improvements were noted in inter-organizational coordination and communication, with a particular strength being operations taking charge and setting priorities for other organizations with respect to addressing plant equipment problems. However, the degraded material condition of some balance of plant systems, especially the General Service Water system, and the numerous equipment problems that occurred this inspection period indicate that continued emphasis on the importance of aggressively monitoring and maintaining plant systems appears warranted. You are encouraged to identify potential problems or declining trends in equipment performance and correct them prior to them self disclosing in failures.

200015

9510270111 951011
PDR ADOCK 05000341
Q PDR

TEO/
11

D. R. Gipson

-2-

No violations of NRC requirements were identified during the course of this inspection.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter, and its enclosures, will be placed in the NRC's Public Document Room.

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

/s/M. J. Jordan, Chief
M. J. Jordan, Chief
Reactor Projects Branch 7

Docket No. 50-341
License No. NPF-43

Enclosure: Inspection Report
No. 50-341/95011

cc w/encl: J. Conen, Principal
Compliance Engineer
P. A. Marquardt, Corporate
Legal Department
James R. Padgett, Michigan Public
Service Commission
Michigan Department of
Public Health
Monroe County, Emergency
Management Division

Distribution:

Docket File/w encl
PUBLIC IE-01/w encl
OC/LFDCB/w encl
SRI Fermi/w encl
IPAS (E-Mail)/w encl

Project Manager, NRR/w encl
DRP/w encl
RIII PRR/w encl

To receive a copy of this document, indicate in the box "C" - Copy without attach/encl "E" - Copy with attach/encl "N" - No copy

OFFICE	RIII	C	RIII	E	RIII	E	RIII	N
NAME	Dupont Phillips <i>[Signature]</i>		Creed <i>[Signature]</i> (para 4.2 through 4.2.3)		Lougheed (para 5.0.1) <i>[Signature]</i>		Ring <i>[Signature]</i>	
DATE	10/11/95		10/11/95		10/11/95		10/11/95	

OFFICIAL RECORD COPY