

ML212

May 9, 1980

MEMORANDUM TO: V. Tain
 FROM: *J. C. McKinley*
 SUBJECT: MIDLAND PLANT, UNITS 1 & 2

I have just reviewed the file on the Midland Plant, Units 1 & 2 and have spoken to the NRC Project Manager (D. Hood).

I believe there is an unresolved safety issue in the poor quality of fill material under the containment and other vital structures as evidenced by the settlement observed with the diesel generator building. Please review the information available and, if you concur in my view, send a memo to that effect suggesting a Subcommittee meeting to the Subcommittee Chairman (P. G. Shewmon) with copies to all ACRS members and put a copy in the 242nd ACRS meeting folder under the tab for future agenda.

Other topics for consideration by the Subcommittee should include; overall QA performance and security in the face of several acts of apparent sabotage.

cc: M. W. Libarkin
 G. Young

FILE: MIDLAND 1 & 2

8408010198 840718
 PDR FOIA
 RICEB4- 5 PDR

OFFICE	ACRS				
SURNAME	JCMCKinley/bgs				
DATE	5-9-80				