

CP&L

Carolina Power & Light Company

Shearon Harris Energy & Environmental Center
Route 1, Box 327
New Hill, North Carolina 27562

Serial: ESS-84-290

July 27, 1984

Mr. Charles Wakild
Regional Supervisor
North Carolina Division of Environmental Management
7525 Wrightsville Avenue
Wilmington, North Carolina 28403


RE: BRUNSWICK NUCLEAR PROJECT
NPDES PERMIT NO. NCO007064

Dear Mr. Wakild:

As required by the NPDES permit for this facility, this is to provide you with notification that Unit No. 1 at the Brunswick Nuclear Project was operated with less than two fine mesh screens during July. The 1D cooling water pump bay was without screens from July 4, 1984 at 04:45 to July 11, 1984 at 20:03. This initially was due to scheduled preventive maintenance being performed on the screen. The screen, however, was inadvertently left out longer than the maintenance required due to a problem in miscommunication. Appropriate action has been taken to reduce the probability of similar occurrence in the future.

If you have any questions, please call R. K. Miller at
(919) 836-7185.

Yours very truly,



R. B. Starkey, Jr.
Manager

Environmental Services

RKM/kjr (1753RKM)

cc: Mr. H. R. Denton ✓
Mr. J. P. O'Reilly

8408010295 840724
PDR ADOCK 05000325
S PDR

IE23
1/2