

DMB

JUL 13 1984

Docket No. 50-374

Commonwealth Edison Company
ATTN: Mr. Cordell Reed
Vice President
Post Office Box 767
Chicago, IL 60690

Gentlemen:

This refers to the special safety inspection conducted by Mr. M. J. Jordan of this office on June 6 through 22, 1984, of activities at LaSalle County Station, Unit 2, authorized by NRC Operating License No. NPF-18 and to the enforcement conference conducted on June 22, 1984.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

During this inspection, certain of your activities appeared to be in non-compliance with NRC requirements, as specified in the enclosed Appendix. A written response is required.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosure(s) will be placed in the NRC Public Document Room unless you notify this office, by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 2.790(b)(1). If we do not hear from you in this regard within the specified periods noted above, a copy of this letter, the enclosure(s), and your response to this letter will be placed in the Public Document Room.

During the enforcement conference we discussed our concerns regarding the system for managing surveillance tests. Specifically, the controls over conducting testing on both electrical divisions of one system and on more than one system simultaneously. In your response please describe changes in your system for managing surveillance testing to preclude recurrence of such violations.

8408010312 840713
PDR ADOCK 05000374
G PDR

IE01
11

JUL 13 1984

The responses directed by this letter (and the accompanying Notice) are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

"Original Signed by C. E. Norelius"

C. E. Norelius, Director
Division of Reactor Projects

Enclosures:

- 1. Appendix, Notice of Violation
- 2. Inspection Report No. 50-374/84-23(DPRP)

cc w/encls:

- D. L. Farrar, Director of Nuclear Licensing
- G. J. Diederich, Station Superintendent
- R. H. Holyoak, Project Manager DMB/Document Control Desk (RIDS)
- Resident Inspector, RIII
- Phyllis Dunton, Attorney General's Office, Environmental Control Division

RIII

[Signature]
C. Missotimos/db
07/09/84

RIII

[Signature]
Diederich

RIII

[Signature]
Norelius
7/12/84