

Appendix

NOTICE OF VIOLATION

Commonwealth Edison Company

Docket No. 50-374

As a result of the inspection conducted on June 6 through 22, 1984, and in accordance with the General Policy and Procedures for NRC Enforcement Actions, (10 CFR Part 2, Appendix C), the following violation was identified:

Technical Specification 3.3.2.c states that with the number of operable channels less than required by Table 3.3.2.-2 per trip system for both trip systems, place at least one trip system in the tripped condition within one hour, close the isolation valves within one hour and declare the affected system inoperable.

Contrary to the above, both trip systems for the Reactor Water Cleanup System had the trip functions for high differential flow, high heat exchanger area temperature, high heat exchanger area ventilation differential temperature, high pump area temperature, and high pump area ventilation differential temperature bypassed such that both trip systems did not have the required operable channels for 7.5 hours, and the isolation valves remained open with neither trip system tripped.

This is a Severity Level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

JUL 13 1984

Dated _____

C. E. Norelius

C. E. Norelius, Director
Division of Reactor Projects