

RECEIVED
NRC

Arizona Public Service Company

1984 JUL 19 PM 1:37

July 16, 1984
ANPP-29975-TDS/TRB

REGION VISE

U. S. Nuclear Regulatory Commission
Region V
Creskide Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, CA 94596-5368

Attention: Mr. T. W. Bishop, Director
Division of Resident
Reactor Projects and Engineering Programs

Subject: Time Extension For Report - DER 83-80
A 50.55(e) Potentially Reportable Deficiency Relating To Main
Feedwater Isolation Valves Closed In Twenty (20) Seconds;
Specification Requires A Five (5) Second Closing Time
File: 84-019-026; D.4.33.2

Reference: (A) Telephone conversation between P. Narbut and K. C. Parrish
on November 22, 1983
(B) ANPP-28462, dated December 19, 1983 (Interim Report)
(C) ANPP-28800, dated February 6, 1984 (Time Extension)
(D) ANPP-28980, dated March 2, 1984 (Time Extension)
(E) ANPP-29178, dated March 28, 1984 (Time Extension)
(F) ANPP-29581, dated May 23, 1984 (Interim Report)

Dear Sir:

The NRC was notified of a potentially reportable deficiency in
Reference (A), and an Interim Report was transmitted by Reference (B).
At that time, it was estimated that a Final Report would be available by
July 20, 1984.

A Final Report has been received by APS for review. This review and
submittal of a Final Report to the NRC is scheduled for August 23, 1984

Very truly yours,

E. E. Van Brunt / TRB

E. E. Van Brunt, Jr.
APS Vice President
Nuclear Production
ANPP Project Director

8408010384 840716
PDR ADOCK 05000528
S PDR

EEVB/TRB:db

cc: See Page Two

1/0
IE-27

Mr. T. W. Bishop
DER 83-80
Page Two

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
D. B. Karner
W. E. Ide
D. B. Fasnacht
A. C. Rogers
L. A. Souza
D. E. Fowler
T. D. Shriver
C. N. Russo
J. Vorees
J. R. Bynum
J. M. Allen
J. A. Brand
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
H. D. Foster
D. R. Hawkinson
L. E. Vorderbrueggen
R. P. Zimmerman
S. R. Frost
J. Self
D. Canady
T. J. Bloom

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, GA 30339