

Colt Industries



DMB
Fairbanks Morse
Engine Division
701 Lawton Avenue
Beloit, Wisconsin 53511
608/364-4411

October 26, 1984

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Attention: Mr. James G. Keppler, Director, Region III


Subject: Colt Industries-Fairbanks Morse Engine Division
Emergency Diesel Generators
Part 21 Report Dated May 5, 1983
Jacket Water Check Valve Disassembly
Supplemental Report Number 1

Gentlemen:

The GPE Controls jacket water check valves used on the four D.G. sets at Public Service Electric & Gas Company's Hope Creek Station have been upgraded to eliminate the potential defect described in our May 5, 1983 Part 21 report.

A copy of this report is being sent to the utility involved and to GPE Controls.

Very truly yours,


J. M. Moriarty
MANAGER UTILITY SALES

JMM:jc

cc: Bechtel Power Corp.
P. O. Box 3965
San Francisco, CA 94119
Attention: Hope Creek Project Engineer

U. S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, D.C. 20555

GPE Controls
6511 Oakton Street
Morton Grove, IL 60053
Attention: Mr. Daniel P. Schleiter
Quality Assurance Manager

OCT 29 1984

8411060175 841026
PDR ADOCK 05000354
S PDR

A division of the Colt Industries Operating Corp.

IE1910