



# THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

*Serving The Best Location in the Nation*

MURRAY R. EDELMAN  
VICE PRESIDENT  
NUCLEAR

July 25, 1984  
PY-CEI/NRR-0126 L

Mr. B. J. Youngblood, Chief  
Licensing Branch No. 1  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Perry Nuclear Power Plant  
Docket Nos. 50-440; 50-441  
SQRT and PVORT Form Submittal

Dear Mr. Youngblood:

This submittal forwards copies of the summary forms on each item of equipment selected for the Seismic Qualification Review Team (SQRT) and Pump and Valve Operability Review Team (PVORT) audits by the NRC Equipment Qualification Branch. Also included are the Floor Response Spectra relating to the audit of selected SQRT equipment, and the Valve Qualification Program Description which provides the requirements on seismic inputs for valves qualified by our architect-engineer.

This information is provided at this time to assist the review teams in their preparation for the upcoming audits. If there are additional questions, please feel free to call.

Very truly yours,

Murray R. Edelman  
Vice President  
Nuclear Group

MRE:njc

#### Attachments

cc: J. Silberg, Esq.  
J. Grobe, NRC Resident  
J. Stefano w/attachments  
G. Bagchi, NRC, w/attachments  
J. Singh, E.G. & G. Idaho w/SQRT attachments  
C. Kido, E.G. & G. Idaho w/PVORT attachments

8408030145 840725  
PDR ADOCK 05000440  
A PDR

*g*  
*13001*  
*1/1*  
*Limited*  
*Dist*

Attachment 1

The attached SQRT and PVORT forms address the following equipment:

<u>SEISMIC (SQRT)</u>		<u>OPERABILITY (PVORT)</u>	
<u>NSSS</u>	<u>BOP</u>	<u>NSSS</u>	<u>BOP</u>
1E22F0010	OP47C0001B	1E51C0001	OP47C0001B
1C71S0003G	1N11F0020A	1E21C0001	1P45F0571A
1H22P0072	1R42S0003	1E22F0010	1P50F0140
1C11F0180	1M51F0010B	1B21F0047B	1E12F0006A
1C41F0004B	OH51P0077A		1M51F0110
1E51C0002	1R24S0032		1M16F0020A
1H13P0702	1P45C0002		
1H13P0618	OH51P0177A		
1H13P0870	1M39B0004		
1H13P0680	1M51S0002		
OG41F0085	OC41N0415B		
1E12N0057	1R72S0002		

Limitorque Actuators

Please note that CEI review and approval is documented as follows:

For NSSS qualified items a signature stamp appears on the front page;  
For A/E qualified items approval is shown on the signature block of  
the last page.

TO SQR Audit File

FROM

H. A. Putre

DATE July 25, 1984

SUBJECT

Seismic Requirements for Valves  
Qualified by Gilbert Associates

We are submitting to the NRC the attached "Perry Nuclear Power Plant Valve Qualification Program Description" Sec. 1 and 2. These seismic requirements are specified in lieu of Floor Response Spectra for the valves qualified by Gilbert Associates. These apply to the following Audit Valves:

1N11F0020A

1M51F0010B

0641F0085

1E22F0010

1P45F0571A

1P50F0140

1E12F006A

1M51F0110

1M16F0020A

*H. A. Putre*  
Senior Engineer, EQ

PERRY NUCLEAR POWER PLANT  
VALVE QUALIFICATION PROGRAM DESCRIPTION  
REV. 4

F. C. Rosch  
July 26, 1983

19 Aug. 83  
8-51

## 1. Qualification Specifications

The following specifications include all of the valves qualified under this description.

### SP

301	General Electric (Anchor Darling)	HPCS Valves
521-01	TRW	2 1/2" Check Valves
521-02	Borg Warner	Gates, Globes & Checks 2 1/2"
521-03	Rockwell, Raleigh	Gates, Globes & Checks 2 1/2"
523	Target Rock	Safety & Relief Valves
524	Contromatics	Butterfly & Ball Valves
531-01	Dresser	Gates, Globes & Checks 2"
531-02	Borg Warner	Gates, Globes & Checks 2"
531-03	Dragon	CRD Vent Valves 1" & 1 1/4"
531-04	Kerotest	Gates, Globes & Checks 2"
531-06	Rockwell, Sulphur Springs	Gate, Globe & Check Valves
635	GPE	Containment & Drywell Vacuum Relief Valves
639	Anderson-Greenwood	Vacuum Breaker and Check Valve

## 2. Valve - Actuator Assembly Dynamic Load Capability

The following description outlines the requirements and procedures for qualification for seismic and new loads.

### REQUIREMENTS

#### USNRC Regulatory Guide 1.48

All of the qualification procedures and requirements are in accordance with the requirements of Reg. Guide 1.48.

#### Equipment Qualification Review List (EQRL)

The EQRL lists all of the Seismic Category I active valves for qualification.

#### FSAR

Qualification was performed in accordance with the requirements described in paragraphs 3.9.3.2.

#### Code Requirements

Paragraph NB 3524 W77 Section III of the ASME B&PV Code states: "Where valves are provided with operators having extended structures and these structures are essential to maintaining pressure integrity, an analysis, when required by the Design Specifications may be performed based on static forces resulting from equivalent earthquake accelerations acting at the centers of gravity of the extended masses."

### Seismic Qualification

The specific valve specifications require that all of the valves have a fundamental frequency greater than 33Hz and be capable of withstanding at least a simultaneous 3g load on each orthogonal axis. General test and analysis procedural requirements are included in GAI specifications SP-750-4549-00. The vendor

was allowed to demonstrate compliance by test or analysis.

Analyses were generally provided to demonstrate compliance with the specification. Analyses also were generally based on modal vibration techniques except that equivalent static analyses were allowed when the fundamental frequency was demonstrated to be above the range of application.

Tests were performed to either the appropriate Floor Response Spectrum or to 3g using a 10 cycle sine beat.

The valve seismic response was reviewed to assure that it did not exceed the 3g capability required by the specification.

The valve capability was reviewed for locations where the response exceeded 3g to determine if the valve capability was less than or equal to the response. Failure of the valve to meet the response requirements would require upgrading of the valve to an acceptable level or rearrangement of piping supports to lower the response.

#### Hydrodynamic Loads Qualification ("New Loads")

(Safety/Relief Valve Discharge and LOCA and all associated pressure and hydrodynamic loads such as Chug and Condensate Oscillation)

The valve specifications for New Loads require a "fragility analysis" to determine the valve capability particularly in the area of the fundamental frequency. This analysis assumes all of the input energy at the frequency analyzed and thus generally indicates relatively low capability.

The Piping Analysts were asked to provide the actual valve response where the fragility analysis indicated that loads might be too high. Piping Analysis was able to develop a procedure to determine the valve-actuator assembly response based on analysis of systems with detailed models. The valve response is based on the actual input loads across the whole spectrum for the piping system. The piping analysis calculation defines the appropriate floor (required) response spectra used for the system input loads. These calculations are on file organized by systems.\* The valve response can be compared to the equivalent static load analysis to determine if the valve is capable of withstanding the loads. It was frequently necessary to extrapolate the static analysis to determine the maximum allowable hydrodynamic and seismic loads (these calculations followed formal project procedures and are incorporated into the project documentation).\* It would be necessary to increase the valve capability or rearrange supports to lower the response to the capability for locations where the response initially exceeded the capability.

\*GAI Files, Reading, PA

## SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

MPL# E22 F0010

- I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: \_\_\_\_\_
1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_
2. NSSS: GENERAL ELECTRIC BWR: X
3. A/E: GILBERT/COMMONWEALTH Other \_\_\_\_\_
- II. COMPONENT NAME: TEST BY-PASS<sup>VALVE</sup> CONDENSATE STORAGE
1. Scope:  NSSS  BOP  Other
2. Model Number: NOT ASSIGNED BY VENDOR Quantity: 1 UNIT 1, 1 UNIT 2
3. Size or Range: 10" ANSI CLASS 900
4. Vendor: ANCHOR DARLING
5. If the component is a cabinet or panel, name and model Number of the devices included:  
N/A
6. Physical Description: LIMITORQUE SMB-4-200
- a. Appearance: MOTOR OPERATED GLOBE VALVE
- b. Dimensions: H=93", W=21" L=33"
- c. Weight: 3600 LBS. INCLUDING ACTUATOR
7. Location: Building: AUXILIARY  
Elevation: 574'
8. Field Mounting Conditions  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)  
 Weld (Length CIRCUM)  
 \_\_\_\_\_
9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)  
PIPE MOUNTED WITH STEM VERTICAL
10. a. System in which located: E22-HIGH PRESSURE CORE SPRAY
- b. Functional Description: SYSTEM FLOW SHUT OFF WHEN CLOSED, THROTTLE WHEN OPEN, PRESSURE RETENTION.
- c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other TEST

11. Pertinent Reference Design Specifications for Qualification Requirements:

SPEC. SP-301-4508-00, REV I, 10-11-73: G.E. DOCUMENT NO  
REV. 3, 1-9-78: G.E. DOCUMENT NO. 21A8717 REV. 1, 10-31-73 <sup>21A9457</sup>

- a. Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

- Yes
- No
- Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

- Test
- Analysis
- Combination of Test and Analysis

Qualification Report\*: DESIGN CALCULATION FOR 10" 900 LB GLOBE VALVE

(No., Title and Date): WUH SMB-4-200 MOTOR OPERATOR, 2-15-83

Company that Prepared Report: AUCHINCLOSS DARLING

Company that Reviewed Report: GILBERT/COMMONWEALTH

Where Report is filed or available: PERRY NUCLEAR POWER PLANT

Applicable Codes And/Or Standards: ASME B&PV CODE SECTION III, NB 3200 & NB 3500, 1971 EDITION, ADDENDA TO WINTER 1973. (FOR ACTUATOR - SEE LIMITORQUE VALVE ACTUATOR SPEC)

V. VIBRATION INPUT:

1. Loads considered:
  - a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Vibration from normal operation
  - d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

- Absolute Sum
- SRSS
- N/A  
(other, specify)

3. Required Response Spectra \*\* (attach the graphs): SEE PUPP VALVE QUALIFICATION PROGRAM DESCRIPTION (TAB 6)

NOTE:

\*If more than one report complete Items IV thru VII for each report.  
\*\*If other than RRS is used, describe method.



4. Damping Corresponding to RRS: N/A OBE \_\_\_\_\_ SSE \_\_\_\_\_

5. Required Acceleration in Each Direct:

ZPA  Other PEAK \*  
(specify)

OBBA or OBE S/S = ≤ SSBA F/B = ≤ SSBA V = ≤ SSBA

(SSBA) or SSE S/S = 0.418g F/B = 0.726g V = 0.287g

6. Were fatigue effects considered:

Yes  No

If yes, describe how they were treated in overall

qualification program: SEE PNPP VALVE FATIGUE LOADING

ANALYSIS (TAB 6)

*\* MAXIMUM ACCELERATION FROM PIPING ANALYSIS.*

VI. IF QUALIFICATION BY TEST, THEN COMPLETE:

1.  Single Frequency  Multi-Frequency  random  
 sine beat  \_\_\_\_\_

2.  Single Axis  Multi-Axis  
 Independent Axis  In-phase motions

3. Number of Qualifications Tests:

OBE \_\_\_\_\_ SSE \_\_\_\_\_ Other \_\_\_\_\_  
(specify)

4. Frequency Range: \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies

Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test

Yes (Attach TRS and RRS graphs)

No

8. Maximum Input g Level Test:

OBBA or OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

SSBA or SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

- a.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_ )  
 Weld (Length \_\_\_\_\_ )  \_\_\_\_\_

b. Orientation and Fixturing: \_\_\_\_\_

10. Functional operability verified:

- Yes  No  Not Applicable

11. Test Results including modifications made: \_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including results): \_\_\_\_\_

13. Failure Modes (If appropriate) \_\_\_\_\_

14. Margins Available:  Input Spectrum  Fragility

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. Method of Analysis:

- Static Analysis  Equivalent Static Analysis  
 Dynamic Analysis:  Time-History  Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = 34 HZ F/B = 34 HZ V = \_\_\_\_\_

3. Model Type:

- 3D  2D  1D  
 Finite Element  Beam  
 Closed Form Solution  Other \_\_\_\_\_

4.  Computer Codes: N/A

Frequency Range and No. of Modes N/A

Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads: N/A (see 8.a below)

Absolute Sum       SRSS       Other: \_\_\_\_\_  
(specify)

6. Damping:

OBE N/A SSE N/A Basis for the damping used: N/A

7. Support Considerations in the model: FIXED AT WELD ENDS

8. Critical Structural Elements:

a. Identification-Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
MAXIMUM ACCELERATIONS FROM PIPING ANALYSIS	Asis 0.418g	AF/B 0.726g	Av 0.287g	
ACCELERATIONS USED IN REPORT (FOR STRESSES SEE REPORT PG 130)	4.5g	0	4.0g	
b. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability		
0.0048 in.	ACTUATOR ADAPTER FLANGE	0.020 in.		

9. Failure Modes: PERMANENT DEFORMATION OR FAILURE OF YOKE LEGS

10. Margins Available:       Input Spectrum       Stress or Deflection

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
/	/	/	/	/
/	/	/	/	/
/	/	/	/	/

REVIEWED BY J. A. DAISE / 6-23-83

CHECKED BY J. D. CAHERLY / 6-23-83

APPROVED BY F. A. Petros / 7-23-84  
AS 7-23-84

PERRY NUCLEAR  
POWER STATION  
UNIT 1

CEI  
REVIEWED BY  
*RAS. etc. / 7-21-87*  
APPROVED BY  
*NA Pate / 7-21-87*

SEISMIC QUALIFICATION REEVALUATION  
CLASS 1E EQUIPMENT

COMPONENT NAME: ELECTRICAL PROTECTION ASSEMBLY

PPD. NO.: 21A3120

MPL REFERENCE: C71-S003 A-H, (G)

THE SEISMIC QUALIFICATION REPORT(S) IDENTIFIED HEREIN HAVE BEEN EVALUATED AND REQUALIFIED WHERE NECESSARY TO SHOW THAT THE ABOVE-MENTIONED COMPONENT IS CAPABLE OF MEETING THE NUCLEAR REGULATORY COMMISSION SEISMIC QUALIFICATION REVIEW TEAM (SQRT) REQUIREMENTS.

PREPARED BY: N.H. ANDERSEN *N.A. Andersen* DATE 4-6-84

ORGANIZATION: GENERAL ELECTRIC CO., QUALIFICATION & CONTROL EQUIPMENT DESIGN ENGINEERING

REVIEWED BY: R.W. HARDY *R.W. Hardy* DATE 5/18/84  
SQRT PROGRAM MANAGER

APPROVED BY: N.G. LURIA *N.G. Luria* DATE 4/11/84  
QUALIFICATION ANALYSIS AND DESIGN  
ENGINEERING MANAGER

*See Book MO2 (Tab 6) for Introduction to SQRT.  
6-84 J*

GENERAL  ELECTRIC

1

Seismic and Dynamic Qualification Summary of Equipment

I. Plant Name: Perry Type: \_\_\_\_\_  
 1. Utility: Cleveland Electric Illuminating Co PWR \_\_\_\_\_  
 2. NSSS: General Electric Co. BWR- 6 MK III  
 3. A/E: Gilbert/Commonwealth Other \_\_\_\_\_

II. Component Name Electrical Protection Assembly

1. Scope:  NSSS  BOP  Other
2. Model Number: GE DWG 914E175 Quantity: 8
3. Size or Range: 13.7 KVA 20
4. Vendor: General Electric
5. If the component is a cabinet or panel, name and model number of the devices included: See Parts List of drawing 914E175 (Attachment 1)
6. Physical Description:
  - a. Appearance: Metal Enclosure
  - b. Dimensions: 16" x 20" x 8"
  - c. Weight: 150#(EST)
7. Location: Building: See Attachment 5, CONTROL COMPLEX  
Elevation: See Attachment 5, 620
8. Field Mounting Conditions  Bolt (No. 4, Size 3/8"φ) RA1  
 Weld (Length \_\_\_\_\_)  
 See Attachment 5 \_\_\_\_\_
9. Mounting Orientation [e.g., on floor, cantilevered, suspended, etc.]  
See Attachment 5, WALL MOUNTED
10. a. System in which located: Process Radiation Monitoring System  
 b. Functional Description: Performs 1E Function  
 c. Is the equipment required for  Hot Standby  Cold Shutdown  Both  Neither  Other \_\_\_\_\_

## 11. Pertinent Reference Design Specification for Qualification

Requirements: Gilbert/Commonwealth Letter PY-GAI/GEN-2904

- |   |  |
|---|--|
| a. <input checked="" type="checkbox"/> Seismic Input          | d. <input type="checkbox"/> Service Conditions |
| b. <input type="checkbox"/> Hydrodynamic Load Input           | e. <input type="checkbox"/> Qualified Life     |
| c. <input checked="" type="checkbox"/> Fatigue Considerations |  |

III. Is Equipment Available for Inspection in the Plant:

Yes       No       Partial or limited availability

IV. Equipment Qualification Method:

Test       Analysis       Combination of Test and Analysis

Qualification Report\*: Final Test Report-Electrical Protection Assembly(No., Title and Date): DRF C71-00044Company that Prepared Report: General ElectricCompany that Reviewed Report: General ElectricWhere Report is filed or available: General ElectricApplicable Codes and/or Standards: IEEE 344-1975V. Vibration Input:

1. Loads considered: a.  Seismic only  
 b.  Hydrodynamic only  
 c.  Vibration from normal operation  
 d.  Combination of (a), (b), and (c)

## 2. Method of Combining RRS:

Absolute Sum       SRSS       \_\_\_\_\_  
 (other, specify)

## 3. Required Response Spectra\*\* (attach the graphs): \_\_\_\_\_

See Attachment 2NOTE:

\* If more than one report complete Items IV thru VII for each report.

\*\* If other than RRS is used, describe methods.

3

4. Damping Corresponding to RRS: OBE 2% SSE 4%
5. Required Acceleration in Each Direction:  
 EPA       Other \_\_\_\_\_ (specify).  
 OBE S/S = .213      F/B = .213      V = .36  
 SSE S/S = .33      F/B = .33      V = .58
6. Were fatigue effects considered:  
 Yes       No  
 If yes, describe how they were treated in overall qualification program: SRV and Hydrodynamic loads were considered in RRS sent to test lab per

VI. If Qualification by Test, then Complete:

1.  Single Frequency       Multi-Frequency       random  
 sine beat  
 \_\_\_\_\_
2.  Single Axis       Multi-Axis  
 Independent Axis       In-phase motions
3. Number of Qualifications Tests:  
 OBE 10      SSE 4      Other \_\_\_\_\_  
5 in phase, 5 out of phase      2 in phase, 2 out of phase      (specify)
4. Frequency Range: 3-100 Hz
5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
 S/S = 54.5      F/B = 61      V = 54.5
6. Method of Determining Natural Frequencies:  
 Lab Test       In-Situ Test       Analysis
7. TRS enveloping RRS using Multi-Frequency Test:  
 Yes (Attach TRS & RRS graphs) See Attachment 4  
 No

4

## 8. Maximum Input g Level Test:

OBE S/S = 5.4      F/B = 8.0      V = 7.0  
 SSE S/S = 11.0      F/B = 10.07      V = 8.9

## 9. Laboratory Mounting:

A.  Bolt (No. 4, Size 3/8" φ - 11 <sup>RA1</sup>) and clamped  
 Weld (Length     )      

B. Orientation and Fixturing:     

## 10. Functional operability verified:

Yes       No       Not Applicable

## 11. Test Results including modifications made:

See Qualification Summary

## 12. Other tests performed (such as aging or fragility test, including results):

No Seismic Aging or Fragility Testing Performed

13. Failure Modes (If appropriate See Qualification Summary)

14. Margins Available:  Input Spectrum       Fragility

## VII. If Qualification by Analysis, then complete: N/A

## 1. Method of Analysis:

Static Analysis       Equivalent Static Analysis  
 Dynamic Analysis       Time-History       Response Spectrum

## 2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S =           F/B =           V =     

3. Model Type:  3D       2D       1D

Finite Element       Beam

Closed Form Solution       Other



4.  Computer Codes: \_\_\_\_\_  
 Frequency Range and No. of modes

Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other  
 Dynamic Loads:

Absolute Sum       SRSS       Other: \_\_\_\_\_  
 (specify)

6. Damping:

OBE \_\_\_\_\_ SSE \_\_\_\_\_ Basis for damping used: \_\_\_\_\_

7. Support Considerations in the model: \_\_\_\_\_


8. Critical Structural Elements:

A. <u>Identification Location</u>	<u>Governing Load or Response Combination</u>	<u>Seismic Stress</u>	<u>Total Stress</u>	<u>Stress Allowable</u>

B. <u>Maximum Critical Deflection</u>	<u>Location</u>	<u>Maximum Allowable Deflection to Assure Functional Operability</u>


9. Failure Modes: \_\_\_\_\_

10. Margins Available:  Input Spectrum  
 Stress or Deflection




2 CYCLES X 10 DIVISIONS PER INCH

FERRY MOTOR FOREMOUNT  
UNITS 1 & 2  
CONTROL CENTER  
FLOOR KEYS & STEERING  
MAX. GROUND ACCL. 55% 0.150g  
VERTICAL DISTANCE  
ELEVATION 638'-6"  
FIG. C-2  
NARROW BANDWIDTH  
FLOOR RESPONSE  
ENVIRONMENT



8-15-79 REV.




FERRY NUCLEAR POWER PLANT  
 UNIT 1 & 2  
 CONTROL COMPLEX  
 FLOOR RESPONSE SPECTRA  
 MAX. GRAVIT. ACCEL. CASE = 0.075g  
 WEST-WEST & NORTH-SOUTH  
 CHARACTERISTICS

FIG. 5A-3

NARROW BANDWIDTH  
 FLOOR RESPONSE  
 SPECTRA

EQUIPMENT  
 DAMPING



8-15-79 REV. 0

QUALIFICATION SUMMARY Conditionally

**CEI**  
**REVIEWED BY**  
*RA L.L. / 7.23.84*  
**APPROVED BY**  
*RA Peter / 7.23.84*

- 1. Component Name: Position Multiplexer Cabinet Conditionally
- 2. A. MPL or EDL Item No.: H22-P071/72
- B. GE Drawing No.: 865E133AA

*Subject to GE Resolution of  
PT-GAI/GEN-3113 of 5.7.84  
RA*

3. Qualification Documentation

- A. Qualification Summary of Equipment (SQR Form Attached)
- B. Reference Documents

<u>Reference Number</u>	<u>Document Identification</u>	<u>Date</u>	<u>Title</u>
1	A00-794-8	3-18-80	BWR 6 Rod Control and information system, Index A
2	NEDC 30387 Book No. C27	April 1984	Rod Position Multiplexer Cabinet H22-P071/72

4. Requirements

The Rod Position Multiplexer Cabinet is required to transmit correct rod position information or to fail safely during normal plant operation or after a seismic event. During a seismic event and after a design basis event, the Multiplexer Cabinet must not fail in a way that violates divisional separation.

5. Demonstrated Capability

This equipment has been seismically tested to levels that exceed the requirements of the Perry plant. Test data was analysed to 23 Hz. Test levels reached 20 g and exceed the Perry RRS in the 2-23 Hz range. A failure modes analysis has shown that none of the failure modes identified can prevent the Position Multiplexer from failing safely or can have a detrimental impact on the bus supplying power to this equipment.

6. Rationale for Qualification

The P071/72 cabinets have demonstrated structural integrity when subjected to seismic levels that exceed the Perry requirements in magnitude. Additional test or analysis is not required since it was shown that the identified failure modes will cause the position multiplexer to fail safely and will not jeopardize the bus supplying power to these units.

Seismic and Dynamic Qualification Summary of Equipment

- I. Plant Name: Perry-Unit 1 Type: \_\_\_\_\_
1. Utility: Cleveland Electric Illuminating Co. PWR \_\_\_\_\_
2. NSSS: General Electric Co. BWR 6-Mark III
3. A/E: Gilbert Associates Inc. Other \_\_\_\_\_

II. Component Name ROD POSITION MULTIPLEXER CABINET

1. Scope:  NSSS  BOP  Other
2. Model Number: H22-P071 Quantity: 1 Each
3. Size or Range: N/A
4. Vendor: General Electric Co.
5. If the component is a cabinet or panel, name and model number of the devices included: As shown on attached device list
6. Physical Description:
- a. Appearance: Rack
- b. Dimensions: 72"W x 53"H x 30"D
- c. Weight: 1500 lbs. (approx.)
7. Location: Building: Containment  
Elevation: 620'0"
8. Field Mounting Conditions  Bolt (No. 12, Size 3/16"φ) RA  
 Weld (Length \_\_\_\_\_)  
 ~~Provided by others 12 - 3/16"φ TA~~
9. Mounting Orientation [e.g., on floor, cantilevered, suspended, etc.]  
Floor mounted
10. a. System in which located: POSITION MULTIPLEXER  
b. Functional Description: Instrument Support  
c. Is the equipment required for  Hot Standby  Cold Shutdown  Both  Neither  Other \_\_\_\_\_





MPL: H22-P071/P072

4. Damping Corresponding to RRS: OBE 0.03 SSE 0.03
5. Required Acceleration in Each Direction:

ZPA [ ] Other \_\_\_\_\_ (specify)

OBE S/S = N/A F/B = N/A V = N/A

SSE S/S = \* g F/B = \* g V = \* g

\* see RRS CH

6. Were fatigue effects considered:

[ ] Yes [X] No RA

If yes, describe how they were treated in overall qualification program: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

VI. If Qualification by Test, then Complete:

1. [ ] Single Frequency [X] Multi-Frequency [X] random  
[ ] sine beat  
[ ] \_\_\_\_\_
2. [ ] Single Axis [ ] multi-Axis [X] Dependent biaxial  
[ ] Independent Axis [ ] In-phase motions in and out of phase
3. Number of Qualifications Tests:  
OBE 5 . SSE 1 Other \_\_\_\_\_  
(specify)
4. Frequency Range: 2-22 Hz
5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
S/S = None below 33 F/B = 28.0 Hz V = None below 33 Hz
6. Method of Determining Natural Frequencies:  
[X] Lab Test [ ] In-Situ Test [ ] Analysis
7. TRS enveloping RRS using Multi-Frequency Test:  
[X] Yes (Attach TRS & RRS graphs)  
[ ] No

MPL: H22-P071/P072

## 8. Maximum Input g Level Test:

OBE S/S = 9 g      F/B = 10 g      V = 10 g  
 SSE S/S = 20 g      F/B = 20 g      V = 20 g

## 9. Laboratory Mounting:

- A.  Bolt (No.      Size     )  
 Weld (Length     ) [      ]  
 B. Orientation and Fixturing: Longitudinal & lateral on table

## 10. Functional operability verified:

Yes       No       Not Applicable  Applicable

## 11. Test Results including modifications made:

Demonstrated structural and functional integrity.

## 12. Other tests performed (such as aging or fragility test, including results):

13. Failure Modes (If appropriate) None14. Margins Available:  Input Spectrum       Fragility

## VII. If Qualification by Analysis, then complete: NOT APPLICABLE

## 1. Method of Analysis:

Static Analysis       Equivalent Static Analysis  
 Dynamic Analysis       Time-History       Response Spectrum

## 2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S =           F/B =           V =     

3. Model Type:  3D       2D       1D  
 Finite Element       Beam  
 Closed Form Solution       Other

4.  Computer Codes: \_\_\_\_\_  
Frequency Range and No. of modes \_\_\_\_\_

Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other  
Dynamic Loads:

Absolute Sum       SRSS       Other: \_\_\_\_\_  
(specify)

6. Damping:

OBE \_\_\_\_\_ SSE \_\_\_\_\_ Basis for damping used: \_\_\_\_\_

7. Support Considerations in the model: \_\_\_\_\_

8. Critical Structural Elements:

A. <u>Identification Location</u>	<u>Governing Load or Response Combination</u>	<u>Seismic Stress</u>	<u>Total Stress</u>	<u>Stress Allowable</u>

B. <u>Maximum Critical Deflection</u>	<u>Location</u>	<u>Maximum Allowable Deflection to Assure Functional Operability</u>

9. Failure Modes: \_\_\_\_\_


10. Margins Available:  Input Spectrum  
 Stress or Deflection

POSITION MULTIPLEXER CABINET H22-P071/72 TRS (3% DAMPING) VS.  
 PERRY-CT 3 CONTAINMENT ELEVATION 620'0" (SEE BELOW)

FULL SCALE 100G

46 7403

LOGARITHMIC 3 X 3 CYCLES  
 KUMF, J. & ESSER CO. MADE IN U.S.A.



- SSE + SRV + POOL SWELL + CO + CHUG (HORIZ) 3%
- - - SSE + SRV + POOL SWELL + CO + CHUG (VERT.) 5%
- · - · SSE + SRV + CO + CHUG (VERT.) 3%

# PERRY NUCLEAR POWER PLANT UNITS 1 AND 2

## DYNAMIC QUALIFICATION

<b>CEI</b>
REVIEWED BY <i>DAH li</i> 17-21-84
APPROVED BY <i>DAH Pate</i> 17-21-84

COMPONENT NAME: CONTROL ROD DRIVE VENT VALVE

MPL OR EDL ITEM NO.: C11-F010 (F180) *DAH*

MPL REFERENCE: 283X318CA, REV. 13

EQUIPMENT CLASSIFICATION:  ACTIVE  PASSIVE

THE SEISMIC QUALIFICATION REPORT(S) IDENTIFIED HEREIN HAVE BEEN EVALUATED AND REQUALIFIED WHERE NECESSARY TO SHOW THAT THE ABOVE-MENTIONED COMPONENT IS CAPABLE OF MEETING THE NUCLEAR REGULATORY COMMISSION SEISMIC QUALIFICATION REVIEW TEAM (SQRT) REQUIREMENTS.

PREPARED BY: S.Y. Koh *S.Y. Koh* DATE 7-16-84

ORGANIZATION: GENERAL ELECTRIC CO. -- NEBO

REVIEWED BY: G.I. Samstad *G.I. Samstad* DATE 7/18/84  
SQRT PROGRAM MANAGER

APPROVED BY: *K.C. Yee* *for* DATE 7-17-84  
RESPONSIBLE DESIGN ENGINEER

GENERAL  ELECTRIC

Seismic and Dynamic Qualification Summary of Equipment

I. Plant Name: Perry 1 & 2 Type: \_\_\_\_\_  
 1. Utility: Cleveland Electric PWR \_\_\_\_\_  
 2. NSSS: General Electric BWR 6 - Mark III  
 3. A/E: Gilbert Associates, Inc. Other \_\_\_\_\_

II. Component Name CRD Scram Discharge Volume Vent Valve

1. Scope:  NSSS  BOP  Other  
 2. Model Number: 522FRR62HAZ9 Quantity: 2  
 3. Size or Range: 1 inch  
 4. Vendor: ITT Hammel Dahl  
 5. If the component is a cabinet or panel, name and model number of the devices included: N/A  
 6. Physical Description:  
 a. Appearance: Air Operated Globe Valve  
 b. Dimensions: 34" ± 2" High and 10" Wide  
 c. Weight: 215#  
 7. Location: Building: Inside Containment  
 Elevation: ASPLV 642' R2  
 8. Field Mounting Conditions  Bolt (No. \_\_, Size \_\_ )  
 Weld (Length \_\_)  
 Socket Weld  
 9. Mounting Orientation [e.g., on floor, cantilevered, suspended, etc.]  
Pipe mounted on SDV piping.  
 10. a. System in which located: CRD  
 b. Functional Description: Valve normally open, required to close when scram occurs.  
 c. Is the equipment required for  Hot Standby  Cold Shutdown  Both  Neither  Other \_\_\_\_\_

\*To be determined during field check.





MPL: C11-F010/F180

4. Damping Corresponding to RRS: OBE 2% SSE 5%
5. Required Acceleration in Each Direction:  
 ZPA  Other N/A (specify) SEE NOTE ON PAGE 1  
RA  
 OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_  
 SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Were fatigue effects considered:

Yes  No

If yes, describe how they were treated in overall

qualification program: a) A 90 minute vibration aging in each orthogonal axis was performed with a 0.75g sinusoidal input from 5 Hz to 200 Hz to 5 Hz at a rate of 2 octaves/minute.

b) A biaxial 15 minute SRV cycling fatigue aging was conducted in each of the horizontal axes separately but simultaneously with the vertical axis.

VI. If Qualification by Test, then Complete:

1.  Single Frequency  Multi-Frequency  random  
 sine beat  
 \_\_\_\_\_
2.  Single Axis  Multi-Axis  
 Independent Axis  In-phase motions
3. Number of Qualifications Tests:  
 OBE 5 SSE 1 Other \_\_\_\_\_  
 (specify)
4. Frequency Range: 1.25 to 100 Hz
5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
 S/S = 20 Hz (lateral) F/B = 60 Hz (long) V = greater than 100 Hz
6. Method of Determining Natural Frequencies:  
 Lab Test  In-Situ Test  Analysis
7. TRS enveloping RRS using Multi-Frequency Test:  
 Yes (Attach TRS & RRS graphs)  
 No

## 8. Maximum Input g Level Test: \*

BE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_  
 SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

\* N/A - RRS used during test

## 9. Laboratory Mounting: 8 per

A.  Bolt (No. nozzle size \_\_\_\_\_)

Weld <sup>Socket</sup> (Length \_\_\_\_\_)  \_\_\_\_\_

B. Orientation and Fixturing: TO SIMULATE FIELD CONDITION *RRS*

## 10. Functional operability verified:

Yes  No  Not Applicable

## 11. Test Results including modifications made:

There were no modifications made. Valve stroking times prior, during and after the test were within the specified limits.

## 12. Other tests performed (such as aging or fragility test, including results):

Prior to seismic (upset and faulted) test, the valve was subjected to a 90 minute vibration aging and 15 minute SRV cycling fatigue aging in each of the axes (see answer to Section V, question 6). The tests were successful.

13. Failure Modes (If appropriate) <sup>\*\*</sup> None Identified

14. Margins Available:  Input Spectrum  Fragility

## VII. If Qualification by Analysis, then complete: N/A

## 1. Method of Analysis:

Static Analysis  Equivalent Static Analysis  
 Dynamic Analysis  Time-History  Response Spectrum

## 2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

3. Model Type:  3D  2D  1D  
 Finite Element  Beam  
 Closed Form Solution  Other \_\_\_\_\_

\*\*Thermal aging analyses have also shown that the aging mechanism does not affect the valve performance under dynamic conditions.

4.  Computer Codes: \_\_\_\_\_  
 Frequency Range and No. of modes \_\_\_\_\_  
 Hand Calculations
5. Method of Combining Dynamic Responses from Seismic and Other  
 Dynamic Loads:  
 Absolute Sum       SRSS       Other: \_\_\_\_\_  
 (specify)
6. Damping:  
 OBE \_\_\_\_\_      SSE \_\_\_\_\_      Basis for damping used: \_\_\_\_\_
7. Support Considerations in the model: \_\_\_\_\_
8. Critical Structural Elements:

A. <u>Identification Location</u>	<u>Governing Load or Response Combination</u>	<u>Seismic</u>	<u>Total</u>	<u>Stress</u>
		<u>Stress</u>	<u>Stress</u>	<u>Allowable</u>

B. <u>Maximum Critical Deflection</u>	<u>Location</u>	<u>Maximum Allowable Deflection to Assure Functional Operability</u>
---	-----------------	--

9. Failure Modes: \_\_\_\_\_
10. Margins Available:  Input Spectrum  
 Stress or Deflection

FIGURE 2

OBE (Upset)

Required Response Spectra

Horizontal Direction

C11-F010/F180

RESPONSE SPECTRUM




FIGURE 3

OBE (Upset)

Required Response Spectra

Vertical Direction

C11-F010/F180

RESPONSE SPECTRUM




FIGURE 4


SSE (Faulted)

Required Response Spectra

Horizontal Direction

C11-F010/F130

RESPONSE SPECTRUM



CUSTOMER G.E.

Job No. 58840

Date 6-3-83


Specimen 1" VENT VALVE { 2" DRAIN VALVE, 2500 LBS, C11/12-F180 } F181 Axis of Test Z-Y

Accel. No. 2 Axis VERT. Control (✓) Response ( ) OBE ( ) SSE (✓) DBE ( )

Full Scale 100 Damping 1.3, (5%) Run No. 12

Operator SPETZMAN Engineer C. Lee

\* NEW VALVES, SN 005 { 006 RESPONSE SPECTRUM



# PERRY NUCLEAR POWER PLANT UNITS 1 AND 2

## DYNAMIC QUALIFICATION

<b>CEI</b>
REVIEWED BY <i>E. S. [unclear]</i> / 7-21-84
APPROVED BY <i>[unclear]</i> / 7-21-84

COMPONENT NAME: SLCS (Explosive) Valve A, B *2/24/84*

MPL OR EDL ITEM NO.: C41-F004 A, (B) *12/84*

MPL REFERENCE: 283X224CA Rev. 14

EQUIPMENT CLASSIFICATION:  ACTIVE  PASSIVE

THE SEISMIC QUALIFICATION REPORT(S) IDENTIFIED HEREIN HAVE BEEN EVALUATED AND REQUALIFIED WHERE NECESSARY TO SHOW THAT THE ABOVE-MENTIONED COMPONENT IS CAPABLE OF MEETING THE NUCLEAR REGULATORY COMMISSION SEISMIC QUALIFICATION REVIEW TEAM (SQRT) REQUIREMENTS.

PREPARED BY: W. J. Roit *[Signature]* DATE: 2/24/84

ORGANIZATION: GENERAL ELECTRIC CO. — NEBO

REVIEWED BY: [Signature] DATE: 2/24/84  
SQRT PROGRAM MANAGER

APPROVED BY: G. L. Moore *[Signature]* DATE: 2-24-84  
RESPONSIBLE DESIGN ENGINEER



PY-GEN/CEI-207L



Seismic and Dynamic Qualification Summary of Equipment

I. Plant Name: Perry Type: \_\_\_\_\_  
 1. Utility: Cleveland Electric Illum. Co. PWR \_\_\_\_\_  
 2. NSSS: General Electric Co. BWR 6, Mark III  
 3. A/E: Gilbert Associates Other \_\_\_\_\_

II. Component Name Standby Liquid Control System Explosive Valve

1. Scope:  NSSS  BOP  Other
2. Model Number: 1832-159-01 Quantity: 2
3. Size or Range: 1400 psi, Cy  $\geq$  13
4. Vendor: Conax
5. If the component is a cabinet or panel, name and model number of the devices included: N/A
6. Physical Description:
- a. Appearance: Cylindrical Valve
- b. Dimensions: 4.5 in. Long x 7 in. O.D.
- c. Weight: 40 lbs.
7. Location: Building: Reactor Building, outside drywell  
 Elevation: Approx. 644 ft.
8. Field Mounting Conditions  Bolt (No. 4, Size 1") (Between Flanges)  
 Weld (Length \_\_\_\_\_)  
 \_\_\_\_\_
9. Mounting Orientation [e.g., on floor, cantilevered, suspended, etc.]  
The valve is mounted between 2 flanges attached to 1 1/2" pipe
10. a. System in which located: Standby Liquid Control System (SLC)  
 b. Functional Description: Provide Leaktight shutoff of SLC until fired  
 c. Is the equipment required for  Hot Standby  Cold Shutdown  Both  Neither  Other \_\_\_\_\_



MPL: C41-F0044. Damping Corresponding to RRS: OBE N/A (Note 1) SSE N/A (Note 1)

5. Required Acceleration in Each Direction:

[ X ] ZPA [ ] Other \_\_\_\_\_ (specify)

OBE S/S = .3g F/B = .3g V = .2gSSE S/S = .45g F/B = .45g V = 2g

6. Were fatigue effects considered:

[ X ] Yes [ ] No

If yes, describe how they were treated in overall

qualification program: The valve was aged 90 minutes per axis in a .75g 5 to 200 hz sine sweep, while pressurized to 1400 psi. The valve was also aged 15 minutes each axis at 4.5g peak (min.) acceleration by the sine beat method. At least 8 minutes per axis was performed at the test setup natural frequency.

VI. If Qualification by Test, then Complete:

1. [ X ] Single Frequency [ ] Multi-Frequency [ ] random  
[ X ] sine beat  
[ ] \_\_\_\_\_

2. [ X ] Single Axis [ ] Multi-Axis  
[ ] Independent Axis [ ] In-phase motions

3. Number of Qualifications Tests:

OBE 5 per axis SSE 1 per axis Other \_\_\_\_\_  
(specify)

4. Frequency Range: 5-200 hz during aging; 5-20 hz, 45-60hz, and 90-100 hz for

5. Natural Frequencies in Each Direction (Side/Side, Front/Rear, Vertical): (See Note 1)

S/S = >100 hz F/B = >100 hz V = >100 hz

6. Method of Determining Natural Frequencies:

[ ] Lab Test [ ] In-Situ Test [ X ] Analysis (Attachment C)

7. TRS enveloping RRS using Multi-Frequency Test:

[ ] Yes (Attach TRS & RRS graphs) RRS attached as Attachment A  
[ X ] No --TIM envelopes RIM by single frequency tests (See Note 1)

NOTE 1: The valve is very compact and massive; therefore it has an inherent high natural frequency. The trigger sub-assembly has the lowest natural frequency as identified in Attachment C where its natural frequency is determined to be >100 hz. Due to the high natural frequency, RIM (for ZPA) testing is justified and damping is not pertinent.

## 8. Maximum Input g Level Test:

OBE S/S = 4.5g      F/B = 4.5g      V = 4.5g  
 SSE S/S = 6.75g      F/B = 6.75g      V = 6.75g

## 9. Laboratory Mounting:

A.  Bolt (No. 4, Size 1") Bolted between two mating flanges  
 Weld (Length     )                      

B. Orientation and Fixturing: Attached to 2-11" lengths of 1 1/2" pipe

## 10. Functional operability verified:

Yes       No       Not Applicable

## 11. Test Results including modifications made:

The valve did not sustain any functional or structural damage during or after test. The valve fired successfully during later environmental

12. Other <sup>testing</sup> tests performed (such as aging or fragility test, including results):

The valve was thermally and radiation aged prior to dynamic testing.

The valve was later successfully tested during DBE (LOCA) testing.

13. Failure Modes (If appropriate) None Identified14. Margins Available:  Input Spectrum       Fragility

## VII. If Qualification by Analysis, then complete: N/A

## 1. Method of Analysis:

Static Analysis       Equivalent Static Analysis  
 Dynamic Analysis       Time-History       Response Spectrum

## 2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S =                           F/B =                           V =                     

3. Model Type:  3D       2D       1D  
 Finite Element       Beam  
 Closed Form Solution       Other



J - ACCIDENT - Seismic and Dynamic Loads

Acceleration Response Spectra Data Sheet

I. LOAD COMBINATION: OBBA/SSBA DIRECTION: H-HORIZONTAL  
V-VERTICAL  
COMBINATION METHOD: SRSS X ABS \_\_\_\_\_

II. SPECTRA TO BE ~~DESCRIBED~~ (or provided on sheets attached)

AS NOTED BELOW:

OBBA = OBE + SRV, 2%	EQ-644-1-H,V,REV 0
DE1 = SSE + PS, 3%	EQ-644-2-H,V,REV.
LC3 = SSE + SRV + CO, 3%	EQ-644-3-H,V,REV
LC4 = SSE + SRV + CHUG, 3%	EQ-644-4-H,V,REV.
DE2 = HIGHER OF LC3 OR LC4, 3%	EQ-644-3/4-H,V,REV.
SSBA = HIGHER OF DE1 OR DE2, 3%	EQ-644-2/3/4-H,V,REV

FATIGUE CURVES:

SRV (DURATION BY GE)	EQ-642-3RVH,V,REV 0
CHUGGING (DURATION BY GE)	EQ-642-CH,V,REV. 0

Acceleration

PWA 424933 REV 0  
PAGE 69 OF 300

Frequency (Hz)

PIPE MOUNTING EQUIPMENT SHALL ALSO BE QUALIFIED TO A REQUIRED INPUT MOTION (R.M.) OF 6g FROM 1 TO 100 Hz. FOR EQUIP. THAT IS SUBJECT TO NEW LOADS.

III SPECIAL INSTRUCTION: and derivation details:

FIELD MOUNTING/ORIENTATION IS IN ACCORDANCE WITH MANUFACTURERS AND/OR GE. INTERFACE RECOMMENDATIONS

IV. REFERENCES:

1. FOR DURATION OF SRV AND CHUGGING LOADS SEE GE. LTR, NEDE 24326-P

NOTES:

- (1) EQUIPMENT LOCATION - Define location of equipment within the plant e.g., room #, zone designation, panels, elevation, etc.
- (2) SERVICE CONDITION - Environmental, power, and signal conditions expected as a result of normal operation requirements and expected non-accident transients requirements.

Parameter values should represent environmental conditions in the vicinity of the equipment. Heating sources (pipes, cooling fans, etc.) and area stratification should be included in establishing temperature.

Parameters Margins as defined in NUREG 0588 should not be included. If test margins are included, they shall be identified and described.

- (3) SIGNIFICANT ENVIRONMENTAL VARIATIONS - Those environmental variations resulting from postulated operating events which have impact on the equipment. Events to be considered in variations during normal plant operation, test and non-accident transients.


- (4) CYCLES - Defined as number of occurrences.

PROJECT: PNPP  
EQUIP. LOC: CT-4  
PPD NO.: 21A9370AB

REV 2 W.F.B 8-9-82  
REV. 3 KJM 11-15-82

DIETZEN CORPORATION  
MADE IN U.S.A.

NO 340-L210 DIETZEN GRAPH PAPER  
SEMI-LOGARITHMIC  
3 CYCLES X 10 DIVISIONS PER INCH








DIETZGEN CORPORATION  
MADE IN U.S.A.

NO. 340-L210 DIETZGEN GRAPH PAPER  
SEMI-LOGARITHMIC  
2 CYCLES X 10 DIVISIONS PER INCH




DIETZGEN CORPORATION  
MADE IN U.S.A.

NO. 340-L310 DIETZGEN GRAPH PAPER  
SEMI-LOGARITHMIC  
3 CYCLES X 10 DIVISIONS PER INCH

PWA REV


PAGE 04

A5/17



DIETZEN CORPORATION  
MADE IN U.S.A.


NO. 340 L210 DIETZEN GRAPH PAPER  
SEMI-LOGARITHMIC  
2 CYCLES X 10 DIVISIONS PER INCH



0.01 0.02 0.05 0.1 0.2 0.5 1.0 2.0 5.0 10 20 50 100  
FACE REV

DIXIECORP CORPORATION  
MADE IN U.S.A.

NO. 240-LS10 DIFFERENTIAL GRAPH PAPER  
SEMI-LOGARITHMIC  
5 CYCLES X 10 DIVISIONS PER INCH




PERFECT INDUCTIVE MOTOR PLANT  
LOW NOISE COMBUSTION  
55% EFFICIENCY  
ELECTRICITY CONSUMPTION

FIG. 10 - 5000 RPM

100  
80  
60  
40  
20


FREQUENCY (cps)

ACCELERATION (g)



DIETZEN CORPORATION  
MADE IN U.S.A.

NO. 340-LEID DIETZEN GRAPH PAPER  
SEMI-LOGARITHMIC  
2 CYCLES X 10 DIVISIONS PER INCH




FERRY UNCLEY POWER STATION  
LOAD WITH COMBINATION A  
55% RESONANCE  
RELATION OF VERTICAL  
375 DAMPING

FIG. 100 - 6414 - A-10

DIETZEN CORPORATION  
MADE IN U.S.A.

NO. 340-1210 DIETZEN GRAPH PAPER  
SEMI-LOGARITHMIC  
5 CYCLES X 10 DIVISIONS PER INCH



PERRY MULLER POWER PLANT  
 ENVELOPE DE BE NEVELLA  
 SEBASTYANOV, BOSTON  
 ELEV. 100' HOR. 2000' 100'  
 1/2" DIA.


FIG. EQ. 12/1/50  
 A.E.V. AUG. 4, 1952

PWA 100  
 PWA 100

100

DIETZEN CORPORATION  
MADE IN U.S.A.


NO. 340-L210 DIETZEN GRAPH PAPER  
SEMI-LOGARITHMIC  
2 CYCLES X 10 DIVISIONS PER INCH






DIETZGEN CORPORATION  
MADE IN U.S.A.

FIG. 340-L210 DIETZGEN GRAPH PAPER  
SEMI-LOGARITHMIC  
2 CYCLES X 10 DIVISIONS PER INCH



DIETZMAN CORPORATION  
MADE IN U.S.A.

NO. 340-1210 DIETZMAN GRAPH PAPER  
SEMI-LOGARITHMIC  
2 CYCLES X 10 DIVISIONS PER INCH




PERRY INDUSTRIES, PAPER DIVISION  
 40 WALLACE ST.  
 P.O. BOX 1000, BOSTON, MASS.  
 PERRY INDUSTRIES INTERNATIONAL  
 216 ZUMBEK ST.  
 ATTN: P.O. BOX 1000, BOSTON, MASS.  
 02111-1000

100 / INCHES

MADE IN U.S.A.

141 J-0-L210 OR EQUIV. INSTRUMENTS  
SEMI-LOGARITHMIC  
2 CYCLES X 10 DIVISIONS PER INCH



PARSONS NUCLEAR POWER PLANT  
LOADS SEV  
ELEVATED HORIZONTAL  
DAMPING 2 1/2, 2 1/2

FIG. EQ-642-5R1H  
REV. D OCT. 11, 1962


PAGE 60  
REV OF

NOV 1962

20  
15  
10  
5


DIETZEN CORPORATION  
MADE IN U.S.A.

NO. 340-L21D DIETZEN GRAPH PAPER  
SEMI-LOGARITHMIC  
2 CYCLES X 10 DIVISIONS PER INCH



10

5



PERRY NUCLEAR POWER PLANT  
LOAD: 4110G  
EL. 642' TO 0' HORIZONTAL  
DAMPING: 2% 3%


FIG. EQ. 642 - CH.  
REV. 0  
OCT. 11, 1982

ACCELERATION (G)

ROT. VEL. (rpm)

MADE IN U.S.A.

SEMI-COHERENT MIC  
3 CYCLES X 10 DIVISIONS PER INCH



DEERY NUCLEAR POWER PLANT  
 LOAD LOGS  
 5000 RPM VERTICAL  
 DAMPING: 2/21 5%

FIG. EQ-64421-CV  
 REV. D OCT. 11, 1962

17/1

# PERRY NUCLEAR POWER PLANT UNITS 1 AND 2

## DYNAMIC QUALIFICATION

<p><b>CEI</b>                  REVIEWED BY  <i>Walt</i> / 7-21-83                  APPROVED BY  <i>Walt</i> / 7-21-83</p>
---

COMPONENT NAME: RCIC STEAM TURBINE ASSEMBLY  
 MPL OR EDL ITEM NO.: E51-C002  
 MPL REFERENCE: 283X239CA Rev. 15  
 EQUIPMENT CLASSIFICATION:  ACTIVE  PASSIVE

THE SEISMIC QUALIFICATION REPORT(S) IDENTIFIED HEREIN HAVE BEEN EVALUATED AND REQUALIFIED WHERE NECESSARY TO SHOW THAT THE ABOVE-MENTIONED COMPONENT IS CAPABLE OF MEETING THE NUCLEAR REGULATORY COMMISSION SEISMIC QUALIFICATION REVIEW TEAM (SORT) REQUIREMENTS.

PREPARED BY: J.C. Kelso *JCK* DATE 9-14-83  
 Responsible Design Engineer

ORGANIZATION GENERAL ELECTRIC CO. — NEBO

REVIEWED BY: G.I. Samstad, Jr. *GIS* DATE 9/16/83  
 SORT PROGRAM MANAGER

APPROVED BY: C.W. Dillmann *CWD* DATE 9/16/83  
 RESPONSIBLE DESIGN ENGINEER  
 Manager

GENERAL  ELECTRIC

Seismic and Dynamic Qualification Summary of Equipment

- I. Plant Name: Perry NPP, Unit 1 & 2 Type: \_\_\_\_\_
1. Utility: Cleveland Electric PWR: \_\_\_\_\_
2. NSSS: General Electric BWR: 6, Mark III
3. A/E: Gilbert Assoc., Inc. Other: \_\_\_\_\_
- II. Component Name: Reactor Core Isolator Cooling Steam Turbine Assembly
1. Scope:  NSSS  BOP  Other
2. Model Number: GS-2N Quantity: 1 per unit
3. Size or Range: See item 6, below
4. Vendor: Terry Corporation
5. If the component is a cabinet or panel, name and model number of the devices included: N/A
6. Physical Description:
- a. Appearance: Base mounted, single wheel steam turbine
- b. Dimensions: 7 ft. long X 6 ft. wide X 5 ft. high
- c. Weight: 5000 lbs., approximate
7. Location: Building: Auxiliary Building, AB-3 & AB-6  
Elevation: Between 568' 4" & 599' 0" / used 599' 0" RRS
8. Field Mounting Conditions  Bolt (No. 6, Size 1")  
 Weld (Length     )  
 \_\_\_\_\_
9. Mounting Orientation [e.g., on floor, cantilevered, suspended, etc.]  
Floor mounted
10. a. System in which located: Reactor Core Isolation Cooling  
b. Functional Description: Drives RCIC Pump Assembly  
c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other \_\_\_\_\_



11. Pertinent Reference Design Specifications for Qualification Requirements: Purchase Spec. 21A9526, Rev. 2; Data Sheet 21A9526AE, Rev. 3; Qual Test Spec. E/L 20397, Rev. 4 (VPF 3622-491-1)

- W/L*  a. Seismic Input  d. Service Conditions  
 b. Hydrodynamic Load Input  e. Qualified Life  
 c. Fatigue Considerations

SEE "REQUIREMENTS" ON 2ND PAGE OF SEISMIC SUMMARY. RAS 5.16.87

III. Is Equipment Available for Inspection in the Plant:

Yes  No  Partial or limited availability

IV. Equipment Qualification Method:

Test  Analysis  Combination of Test and Analysis

Qualification Report\*: Environmental Qualification Report

(No., Title and Date): E/L 20458<sup>2</sup>, Rev. 1, dated 4-21-80

Company that Prepared Report: Wyle Laboratory & Terry Corporation

Company that Reviewed Report: General Electric Company

Where Report is filed or available: GE Vendor Print File 3622-527-1

Applicable Codes and/or Standards: IEEE 344-1975

V. Vibration Input:

1. Loads considered: a.  Seismic only  
 b.  Hydrodynamic only  
 c.  Vibration from normal operation  
 d.  Combination of (a), (b), and (c)
2. Method of Combining RRS: Seismic is the only  
 Absolute Sum  SRSS  dynamic load on turbine  
 (other, specify)
3. Required Response Spectra\*\* (attach the graphs): \_\_\_\_\_  
RRS is attached

NOTE:

\*If more than one report complete Items IV thru VII for each report.

\*\*If other than RRS is used, describe method.

4. Damping Corresponding to RRS: OBE 2.0% SSE 2.0%

5. Required Acceleration in Each Direction:  
 ZPA  Other See attached RRS (specify) *FR A2-111-A2-C*  
*RRS*

OBE S/S = RRS F/B = RRS V = RRS

SSE S/S = RRS F/B = RRS V = RRS

6. Were fatigue effects considered:

Yes  No

If yes, describe how they were treated in overall qualification program:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

VI. If Qualification by Test, then Complete:

1.  Single Frequency  Multi-Frequency  random  
 sine beat  
 \_\_\_\_\_

2.  Single Axis  Multi-<sup>Axis</sup> Frequency  
 Independent Axis  In-phase motions

3. Number of Qualifications Tests:

OBE 5 SSE 1 Other None  
(specify)

4. Frequency Range: 1 Hz to 60 Hz input, 1 Hz to 100 Hz analyzed

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = 17 Hz, 24 Hz F/B = 16 Hz, 22 Hz V = 18 Hz, 33 Hz

6. Method of Determining Natural Frequencies:

Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test:

Yes (Attach TRS & RRS graphs)  
 No

8. Maximum Input g Level Test:  
 OBE S/S =   \*   F/B =   \*   V =   \*    
 OBE C/S =   \*   F/B =   \*   V =   \*
9. Laboratory Mounting:  
 A.  Bolt (No.   6  , Size   1"  )  
      Weld (Length       )  \_\_\_\_\_  
 B. Orientation and Fixturing:   Simulated installed equipment
10. Functional operability verified:  
 Yes       No       Not Applicable
11. Test Results including modifications made:   Supports were added to the turbine auxiliary piping. Following these modifications, dynamic qualification was successfully demonstrated.
12. Other tests performed (such as aging or fragility test, including results):   Prior to dynamic test qualification, the turbine components were subjected to radiation aging, and thermal and mechanical aging, in order to simulate their "end of life" condition.
13. Failure Modes (If appropriate)   None evaluated
14. Margins Available:  Input Spectrum       Fragility

## VII. If Qualification by Analysis, then complete:

1. Method of Analysis: (required for nozzle load evaluation only)  
 Static Analysis       Equivalent Static Analysis, using test accel data.  
 Dynamic Analysis       Time-History       Response Spectrum
2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
 S/S =   N/A   F/B =   N/A   V =   N/A
3. Model Type:  3D       2D       1D  
 Finite Element       Beam  
 Closed Form Solution       Other \_\_\_\_\_

\* As required to generate "test response spectra".

4.  Computer Codes: None used  
 Frequency Range and No. of modes  
 Hand Calculations
5. Method of Combining Dynamic Responses from Seismic and Other  
 Dynamic Loads:  
 Absolute Sum  SRSS  Other: Seismic is the only dynamic load on turbine.  
 (specify)
6. Damping:  
 OBE N/A SSE 2.0% \* Basis for damping used: G.E. Specification 385HA603, Table 4.2
7. Support Considerations in the model: Bolted interface to welded pedestals and to concrete pad
8. Critical Structural Elements:

A. <u>Identification Location</u>	<u>Governing Load or Response Combination</u>	<u>Seismic Stress</u>	<u>Total Stress</u>	<u>Stress Allowable</u>
Pedestal Bolts, Coup. End	Tension	4.0gV	24.16	25.00
Taper Pins, Coup. End	Shear	4.0gH	12.14	14.22
Guide Block Weld, Gov. End	Shear	4.0gH	15.49	27.30


  

B. <u>Maximum Critical Deflection</u>	<u>Location</u>	<u>Maximum Allowable Deflection to Assure Functional Operability</u>
0.014 inch	Turbine Shaft	0.125 inch

9. Failure Modes: None evaluated
10. Margins Available:  Input Spectrum  
 Stress or Deflection

\* Specification 385HA603 identifies 3.0% damping. However, 2.0% was used for added conservatism.

PERRY, UNIT 1 & 2, RCIC TURBINE  
 RESPONSE SPECTRA COMPARISON  
 HORIZONTAL SSE @ 2% DAMPING



9-15-83  
 [Signature]

FREQUENCY - Hz

ACCELERATION - g's

RRS 0.599 g's

TBS

15.8 ZPH

0.38 ZPH

PERRY, UNIT 1 & 2, RCIC TURBINE  
RESONANCE SPECTRA COMPARISON  
HORIZONTAL 0.3E @ 2% DAMPING

ACCELERATION - g's

100

50

20

10

5

2

1

0.5

0.25

0.125

0.0625

0.03125

0.015625

0.0078125

0.00390625

0.001953125

0.0009765625

0.00048828125

0.000244140625

0.0001220703125

0.00006103515625

0.000030517578125

0.0000152587890625

0.00000762939453125

0.000003814697265625

0.0000019073486328125

0.00000095367431640625

0.000000476837158203125

0.0000002384185791015625

0.00000011920928955078125

0.000000059604644775390625

0.0000000298023223876953125

0.00000001490116119384765625

0.000000007450580596923828125

0.0000000037252902984619140625

0.00000000186264514923095703125

0.000000000931322574615478515625

0.0000000004656612873077392578125

0.00000000023283064365386962890625

0.000000000116415321826934814453125

0.0000000000582076609134674071875

0.00000000002910383045673370359375

0.000000000014551915228366851796875

0.0000000000072759576141834258984375

0.00000000000363797880709171294921875

0.000000000001818989403545856474609375

0.0000000000009094947017729282373046875

0.00000000000045474735088646411865234375

0.000000000000227373675443232059326171875

0.0000000000001136868377216160296630859375

0.00000000000005684341886080801483154296875

0.000000000000028421709430404007415771484375

0.0000000000000142108547152020037078857421875

0.00000000000000710542735760100185394287109375

0.000000000000003552713678800500926971435546875

0.0000000000000017763568394002504634857177734375

0.0000000000000008881784197001252317428588891875

0.00000000000000044408920985006261587142944459375

0.000000000000000222044604925031307935714722296875

0.0000000000000001110223024625156539678573611484375

0.00000000000000005551115123125782698392868057421875

0.000000000000000027755575615628913491964340287109375

0.0000000000000000138777878078144567459821701435546875

0.00000000000000000693889390390722837299108507177734375

0.00000000000000000346944695195361418649554253588891875

0.00000000000000000173472347597680709324777126794459375

0.000000000000000000867361737988403546623885633972296875

0.0000000000000000004336808689942017733119428169861484375

0.00000000000000000021684043449710088665597140849307421875

0.000000000000000000108420217248550443327985704246537109375

0.0000000000000000000542101086242752216639928521232685546875

0.0000000000000000000271050543121376108319964260616342796875

0.00000000000000000001355252715606880541599821303081713984375

0.00000000000000000000677626357803440270799910651540856984375

0.00000000000000000000338813178901720135399955325770428484375

0.0000000000000000000016940658945086006769997766288521424375

0.00000000000000000000084703294725430033849988831442607121875

0.0000000000000000000004235164736271501692499441572130358891875

0.00000000000000000000021175823681357505962497207860651794459375

0.000000000000000000000105879118406787529812486039303258984375

0.0000000000000000000000529395592033937649062430196516294921875

0.00000000000000000000002646977960169688245312150982581474609375

0.000000000000000000000013234889800848441226560754912907373046875

0.000000000000000000000006617444900424220613280377456453686984375

0.000000000000000000000003308722450212110306640188728226843484375

0.000000000000000000000001654361225106055153320094364113421722296875

0.000000000000000000000000827180612553027576660047182056710861484375

0.0000000000000000000000004135903062765137883300235910283554307421875

0.0000000000000000000000002067951531382568941650117955141777163984375

0.0000000000000000000000001033975765691284470825058977570888581984375

0.0000000000000000000000000516987882845642235412529488785444290984375

0.00000000000000000000000002584939414228211177062647443927221454921875

0.00000000000000000000000001292469707114105588531323721963610724609375

0.000000000000000000000000006462348535570527942656618609815536123046875

0.0000000000000000000000000032311742677852639713283093049077681123046875

0.00000000000000000000000000161558713389263198566415465245388406123046875

0.0000000000000000000000000008077935669463159428320773262269420306123046875

0.000000000000000000000000000403896783473157971416038663113471015306123046875

0.0000000000000000000000000002019483917365789857080193315673550765306123046875

0.000000000000000000000000000100974195868289492854009665783677537765306123046875

0.00000000000000000000000000005048709793414474642700483289183876888265306123046875

0.0000000000000000000000000000252435489670723732135024164459193844413265306123046875

0.00000000000000000000000000001262177448353618660675120822295969222066306123046875

0.0000000000000000000000000000063108872417680933033756041114798461033315306123046875

0.000000000000000000000000000003155443620884046651687802055739923051665765306123046875

0.00000000000000000000000000000157772181044202332584390102786996152583288265306123046875

0.0000000000000000000000000000007888609052210116629219505139349907629164413265306123046875

0.00000000000000000000000000000039443045261050583146097525696749538145822066306123046875

0.0000000000000000000000000000001972152263052529157304876284837476907291103315306123046875

0.000000000000000000000000000000098607613152626457865223814241687345364555165765306123046875

0.00000000000000000000000000000004930380657631322893261190712084367272727778288265306123046875

0.0000000000000000000000000000000246519032881566144653059535604218363638888914413265306123046875

0.00000000000000000000000000000001232595164407830723265297678021091681694444572066306123046875

0.0000000000000000000000000000000061629758220391536163264883901054584084722228603315306123046875

0.000000000000000000000000000000003081487911019576808163244195052729204236111430165765306123046875

0.00000000000000000000000000000000154074395550978840408162209752636460211805571515288265306123046875

0.0000000000000000000000000000000007703719777548942020408110487631821010902778575764413265306123046875

0.00000000000000000000000000000000038518598887744710102040552437815105451389287878822066306123046875

0.0000000000000000000000000000000001925929944387235505102027621890755272569444393941103315306123046875

0.000000000000000000000000000000000096296497219361775255101381094537763628472219697055165765306123046875

0.00000000000000000000000000000000004814824860968088762755069054726888181423610984852778288265306123046875

0.0000000000000000000000000000000000240741243048404438137753452736344409071180549242638914413265306123046875

0.000000000000000000000000000000000012037062152420221906887672636817220453552746213169444572066306123046875

0.00000000000000000000000000000000000601853107621011095344383631840861022677637310658472228603315306123046875

0.00000000000000000000000000000000000300926553810505547672191815704305113888818655272569444393941103315306123046875

0.00000000000000000000000000000000000150463276905252773836095907853715056944423610984852778288265306123046875

0.00000000000000000000000000000000000075231638452626386918047953926857528472219697055165765306123046875

0.00000000000000000000000000000000000037615819226313193459023976963428763638914413265306123046875

0.0000000000000000000000000000000000001880790961315659672951198848171438180571180549242638914413265306123046875

0.0000000000000000000000000000000000000940395480657829836475599424085717190285571180549242638914413265306123046875


0.0000000000000000000000000000000000000470197740328914941737799712042858595142771180549242638914413265306123046875

0.00000000000000000000000000000000000002350988701644574708688998560214292975713888818655272569444393941103315306123046875

0.000000000000000000000000000000000000011754943508222873543444999280107146388914413265306123046875

0.00000000000000000000000000000000000000587747175411143677172249964005357319444236109848527782882653061230468

PERRY, UNIT 1 & 2, RCIC TURBINE  
RESPONSE SPECTRA COMPARISON  
VERTICAL SSE @ 2% DAMPING




9-13-83  
K

PERRY, UNIT 1 & 2, RCIC TURBINE  
RESPONSE SPECTRA COMPARISON  
VERTICAL OBE @ 2% DAMPING

ACCELERATION - g's  
0  
2  
4  
6  
8

FREQUENCY - HZ

9-13-83  
100  
50  
20  
10  
5  
2





PERRY NUCLEAR  
POWER PLANT  
UNIT 1

CEI  
REVIEWED BY  
*R.H. Little* / 7-21-87  
APPROVED BY  
*N. G. Luria* / 7-21-87

SEISMIC QUALIFICATION REEVALUATION  
CLASS 1E EQUIPMENT

COMPONENT NAME: TERMINATION CABINETS

MPL OR EDL ITEM NO.: AS ATTACHED

MPL REFERENCE: H13-P701, P702, P703, P704, P706, P707, P710, P711, P712, P713, P714, P715, P717, P730, P740, P741, P743, P744, P745, P746, P747, P748

THE SEISMIC QUALIFICATION REPORT(S) IDENTIFIED HEREIN HAVE BEEN EVALUATED AND REQUALIFIED WHERE NECESSARY TO SHOW THAT THE ABOVE-MENTIONED COMPONENT IS CAPABLE OF MEETING THE NUCLEAR REGULATORY COMMISSION SEISMIC QUALIFICATION REVIEW TEAM (SQRT) REQUIREMENTS.

PREPARED BY: D.B. SHAMIS *D.B. Shamis* DATE 10-29-82

ORGANIZATION: GENERAL ELECTRIC COMPANY, CONTROL ROOM DESIGN ENGINEERING

REVIEWED BY: R.W. HARDY *R.W. Hardy* DATE 1/6/83  
SQRT PROGRAM MANAGER

APPROVED BY: N.G. LURIA *N.G. Luria* DATE 10/29/82  
RESPONSIBLE DESIGN ENGINEER



Qualification Summary of Equipment

MPL: H13-P701,-P702,-P703,-P704,-P706,-P707,-P710,P711,-P712,-P713,-P714,-P715 -P717-P730,-P740,-P741,-P743, P744-P745,-P746,-P747,-P748

- I. Plant Name: Perry Type:
1. Utility: Cleveland Electric Illuminating Co. PWR
2. NSSS: GE 3. A/E: Gilbert Associates Inc. BWR- 6 MK 3

II. Component Name Control Room Panel

1. Scope:  NSSS  BOP
2. Model Number: See MPL list, above Quantity: 23
3. Vendor: General Electric
4. If the component is a cabinet or panel, name and model No. of the devices included: Termination Modules, Junction Boxes and Cables
5. Physical Description a. Appearance 4 Bay Panels, 2 Sets of Double Doors
- b. Dimensions 96" W x 102" H x 36"D
- c. Weight N/A ~2400# EAs
6. Location: Building: Control Complex
- Elevation: 654'-6"
7. Field Mounting Conditions  Bolt (No. 24, Size 5/8")12" centers  
 Weld (Length \_\_\_\_\_)  
 \_\_\_\_\_
8. a. System in which located: Various Systems
- b. Functional Description: House Termination Modules, Junction Boxes & Cables
- c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither
9. Pertinent Reference Design Specifications: G.E. Assembly Dwg.s 137D7665 through 137D7687

12/80

MPL H13-P701, -P702, -P703,  
-P704, -P706, -P707, -P710, P711,  
-P712, -P713, -P714, -P715 -P717  
-P730, -P740, -P741, -P743, P744  
-P745, -P746, -P747, -P748

-2-

III. Is Equipment Available for Inspection in the Plant:  Yes  No

IV. Equipment Qualification Method:

Test  Analysis  Combination of Test  
and Analysis

Qualification Report\*: GE DRF A00-794-5-1

(No., Title and Date) Seismic Qualification Test Report - Oct. 1, 1980

Company that Prepared Report: David M. Rheuble & Associates

Company that Reviewed Report: General Electric

V. Vibration Input:

1. Loads considered: a.  Seismic only  
b.  Hydrodynamic only  
c.  Combination of (a) and (b)

2. Method of Combining RRS:  Absolute Sum  SRSS  \_\_\_\_\_  
(other, specify)

3. Required Response Spectra (attach the graphs): Figure 4.2

4. Damping Corresponding to RRS: OBE N/A SSE 4%

5. Required Acceleration in Each Direction:  ZPA  Other \_\_\_\_\_  
(specify)

OBE S/S = N/A 0.43g F/B = N/A 0.43g V = N/A 0.40g  
SSE S/S = 0.64g's\*\* F/B = 0.64g's\*\* V = 0.6g's

OBE = 2/3 SSE  
R4

6. Were fatigue effects or other vibration loads considered?

Yes  No

If yes, describe loads considered and how they were treated in overall  
qualification program: N/A

\*NOTE: If more than one report complete items IV thru VII for each report.

\*\*0.64g's is the combined (SRSS) horizontal ZPA.








FIGURE 4-2. COMPARISON OF GE MINIMUM RRS WITH PERRY RRS, CONTROL COMPLEX, 654'-6" ELEVATION

PERRY NUCLEAR  
POWER PLANT  
UNIT 1

CEI  
REVIEWED BY  
R.R. 17.21.82  
APPROVED BY  
J.P. 17.21.82

SEISMIC QUALIFICATION REEVALUATION  
CLASS 1E EQUIPMENT

COMPONENT NAME: CONTROL ROOM PANEL  
MPL OR EDL ITEM NO.: AS ATTACHED  
MPL REFERENCE: H13-F-18

THE SEISMIC QUALIFICATION REPORT(S) IDENTIFIED HEREIN HAVE BEEN EVALUATED AND REQUALIFIED WHERE NECESSARY TO SHOW THAT THE ABOVE-MENTIONED COMPONENT IS CAPABLE OF MEETING THE NUCLEAR REGULATORY COMMISSION SEISMIC QUALIFICATION REVIEW TEAM (SQRT) REQUIREMENTS.

PREPARED BY: D.B. SHAMIS DBShamis DATE 10-29-82

ORGANIZATION: GENERAL ELECTRIC COMPANY, CONTROL ROOM DESIGN ENGINEERING

REVIEWED BY: R.W. HARDY RWHardy DATE 1/6/83  
SQRT PROGRAM MANAGER

APPROVED BY: N.G. LURIA NGLuria DATE 10/29/82  
RESPONSIBLE DESIGN ENGINEER

GENERAL  ELECTRIC

Qualification Summary of Equipment

MPL: H13-P618

I. Plant Name: Ferry

Type:

1. Utility: Cleveland Electric Illuminating Co.

PWR

2. NSSS: GE 3. A/E: Gilbert Associates Inc.

BWR- 6 MK 3

II. Component Name Control Room Panel

1. Scope:  NSSS  BOP

2. Model Number: H13-P618

Quantity: 1 each

3. Vendor: General Electric

4. If the component is a cabinet or panel, name and model No. of the devices included: See attached device list.

5. Physical Description a. Appearance Vertical Board

b. Dimensions 96" W x 36" D x 90" H

c. Weight N/A ~ 2400# RH

6. Location: Building: Control Room

Elevation: 654'-6"

7. Field Mounting Conditions  Bolt (No. 16, Size 1/2")

Weld (Length     )

8. a. System in which located: Low Pressure Core Spray & Residual Heat Removal

b. Functional Description: LPCS & RHR Relay Vertical Board

c. Is the equipment required for  Hot Standby  Cold Shutdown

Both  Neither

9. Pertinent Reference Design Specifications: See reference 4.

12/80



-2-

III. Is Equipment Available for Inspection in the Plant:  Yes  No

IV. Equipment Qualification Method:

Test  Analysis  Combination of Test and Analysis

Qualification Report\*: GE DRF A00-1138

(No., Title and Date) CSA-P001 Seismic Test, Index A

Company that Prepared Report: General Electric

Company that Reviewed Report: General Electric

V. Vibration Input:

1. Loads considered:
  - a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Combination of (a) and (b)
2. Method of Combining RRS:  Absolute Sum  SRSS  (other, specify)

3. Required Response Spectra (attach the graphs): See Figure 4.2

4. Damping Corresponding to RRS: OBE N/A SSE 4%

5. Required Acceleration in Each Direction:  ZPA  Other (specify)

OBE	S/S = <u>N/A 0.43g's</u>	F/B = <u>N/A 0.43g's</u>	V = <u>N/A 0.40g's</u>	OBE = 2/3 SSE RAI
SSE	S/S = <u>0.64g's**</u>	F/B = <u>0.64g's**</u>	V = <u>0.6g's</u>	

6. Were fatigue effects or other vibration loads considered?

Yes  No

If yes, describe loads considered and how they were treated in overall qualification program: N/A

\*NOTE: If more than one report complete items IV thru VII for each report.

\*\*0.64g's is the combined (SRSS) horizontal ZPA.

12/80



VII. If Qualification by Analysis, then complete:

1. Method of Analysis: N/A

Static Analysis  Equivalent Static Analysis

Dynamic Analysis:  Time-History  Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

3. Model Type:  3D  2D  1D

Finite Element  Beam  Closed Form Solution

4.  Computer Codes: \_\_\_\_\_

Frequency Range and No. of modes considered: \_\_\_\_\_

Hand Calculations

5. Method of Combining Dynamic Responses:  Absolute Sum  SRSS

Other: \_\_\_\_\_  
(specify)

6. Damping: OBE \_\_\_\_\_ SSE \_\_\_\_\_ Basis for the damping used: \_\_\_\_\_

7. Support Considerations in the model: \_\_\_\_\_

8. Critical Structural Elements:

<u>A. Identification</u>	<u>Location</u>	<u>Governing Load or Reponse Combination</u>	<u>Seismic Stress</u>	<u>Total Stress</u>	<u>Stress Allowable</u>

B. Max. Critical Deflection

Location

Maximum Allowable Deflection to Assure Functional Operability




FIGURE 4-2. COMPARISON OF GE MINIMUM TRS WITH PERRY RRS ,CONTROL COMPLEX, 654'-6" ELEVATION

4-6

PERRY NUCLEAR  
POWER PLANT  
UNIT 1

CEI  
REVIEWED BY  
*RAG-LL* / 7.21.87  
APPROVED BY  
*W.H. Pitzer* / 7.21.87

SEISMIC QUALIFICATION REEVALUATION  
CLASS 1E EQUIPMENT

COMPONENT NAME: CONTROL ROOM PANEL  
MPL OR EDL ITEM NO.: AS ATTACHED  
MPL REFERENCE: H13-P870

THE SEISMIC QUALIFICATION REPORT(S) IDENTIFIED HEREIN HAVE BEEN EVALUATED AND REQUALIFIED WHERE NECESSARY TO SHOW THAT THE ABOVE-MENTIONED COMPONENT IS CAPABLE OF MEETING THE NUCLEAR REGULATORY COMMISSION SEISMIC QUALIFICATION REVIEW TEAM (SQRT) REQUIREMENTS.

PREPARED BY: D.B. SHAMIS *D.B. Shamis* DATE 10-29-82

ORGANIZATION: GENERAL ELECTRIC COMPANY, CONTROL ROOM DESIGN ENGINEERING

REVIEWED BY: R.W. HARDY *R.W. Hardy* DATE 1/6/83  
SQRT PROGRAM MANAGER

APPROVED BY: N.G. LURIA *N.G. Luria* DATE 10/29/82  
RESPONSIBLE DESIGN ENGINEER



Qualification Summary of Equipment

MPL: H13-P870

- I. Plant Name: Perry Type: \_\_\_\_\_
1. Utility: Cleveland Electric Illuminating Co. PWR \_\_\_\_\_
2. NSSS: GE 3. A/E: Gilbert Associates Inc. BWR- 6 MK 3

II. Component Name Control Room Panel

1. Scope:  NSSS ~~QA~~  BOP
2. Model Number: H13-P870 Quantity: 1 each
3. Vendor: General Electric
4. If the component is a cabinet or panel, name and model No. of the devices included: See attached device list.
5. Physical Description a. Appearance BenchBoard
- b. Dimensions 252" W x 36" D x 90"H
- c. Weight N/A ~7560 #.
6. Location: Building: Control Room
- Elevation: 654'-6"
7. Field Mounting Conditions  Bolt (No. <sup>84</sup>42, Size 1/2") RAJ  
 Weld (Length \_\_\_\_\_)  
 \_\_\_\_\_
8. a. System in which located: Long Response
- b. Functional Description: Long Response BenchBoard
- c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both ~~RAJ~~ RAJ Neither RAJ
9. Pertinent Reference Design Specifications: See reference 4.

12/80

-2-

III. Is Equipment Available for Inspection in the Plant:  Yes  No

IV. Equipment Qualification Method:

Test  Analysis  Combination of Test and Analysis

Qualification Report\*: GE DRF A00-1138

(No., Title and Date) H13-P870 Seismic Test, Index I

Company that Prepared Report: General Electric

Company that Reviewed Report: General Electric

V. Vibration Input:

1. Loads considered: a.  Seismic only  
 b.  Hydrodynamic only  
 c.  Combination of (a) and (b)

2. Method of Combining RRS:  Absolute Sum  SRSS  \_\_\_\_\_  
 (other, specify)

3. Required Response Spectra (attach the graphs): See Figure 4.2

4. Damping Corresponding to RRS: OBE N/A SSE 4%

5. Required Acceleration in Each Direction:  ZPA  Other \_\_\_\_\_  
 (specify)

OBE	S/S =	<u>N/A 0.43g</u>	F/B =	<u>N/A 0.41g</u>	V =	<u>N/A 0.40g</u>	OBE = 2/3 SSE E4
SSE	S/S =	<u>0.64g's**</u>	F/B =	<u>0.64g's**</u>	V =	<u>0.6g's</u>	

6. Were fatigue effects or other vibration loads considered?

Yes  No

If yes, describe loads considered and how they were treated in overall qualification program: N/A

\*NOTE: If more than one report complete items IV thru VII for each report.

\*\*0.64g's is the combined (SRSS) horizontal ZPA.

12/80

VI. If Qualification by Test, then Complete\*:

1.  Single Frequency  Multi-Frequency:  random  
 sine beat  
 In and out of phase
2.  Single Axis  Multi-Axis
3. No. of Qualification Tests: OBE 5 SSE 1 Other \_\_\_\_\_  
(specify)
4. Frequency Range: 1-45 Hz
5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
S/S = 14 Hz F/B = 17.5 Hz V = None below 33 Hz
6. Method of Determining Natural Frequencies  
 Lab Test  In-Situ Test  Analysis
7. TRS enveloping RRS using Multi-Frequency Test  Yes (Attach TRS & RRS graphs)  
See Figure 4.2.  No
8. Input g-level Test: OBE S/S = N/A F/B = N/A V = N/A  
\*\*Dual axis combined SSE S/S = 2.7g's F/B = 2.7g's V = \*\*  
Vertical in-phase
9. Laboratory Mounting: (SUBSECTION TEST MOUNTING) RAH  
> SIMILAR SERVICE CONDITIONS
1.  Bolt (No. 26 Size 5/8")  Weld (Length \_\_\_\_\_)  \_\_\_\_\_
10. Functional operability verified:  Yes  No  Not Applicable
11. Test Results including modifications made: Panel structural  
integrity was maintained & class 1E devices functioned as required.
12. Other test performed (such as aging or fragility test, including results):  
Fragility test results were applied as noted on device sheets to  
establish seismic capability.

\*Note: If qualification by a combination of test and analysis also complete Item VII.

12/80



VII. If Qualification by Analysis, then complete:

- 1. Method of Analysis: N/A  
 Static Analysis       Equivalent Static Analysis  
 Dynamic Analysis:       Time-History       Response Spectrum
- 2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_
- 3. Model Type:  3D       2D       1D  
 Finite Element       Beam       Closed Form Solution
- 4.  Computer Codes: \_\_\_\_\_  
Frequency Range and No. of modes considered: \_\_\_\_\_  
 Hand Calculations
- 5. Method of Combining Dynamic Responses:  Absolute Sum  SRSS  
 Other: \_\_\_\_\_  
(specify)
- 6. Damping: OBE \_\_\_\_\_ SSE \_\_\_\_\_ Basis for the damping used: \_\_\_\_\_
- 7. Support Considerations in the model: \_\_\_\_\_
- 8. Critical Structural Elements:

A. Identification	Location	Governing Load or Reponse Combination	Seismic Stress	Total Stress	Stress Allowable

B. Max. Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Opera- bility




FIGURE 4-2. COMPARISON OF GE MINIMUM TRS WITH PERRY RRS , CONTROL COMPLEX, 654'-6" ELEVATION

4-6

PERRY NUCLEAR  
POWER PLANT  
UNIT 1

CEI  
REVIEWED BY  
*R. Smith* 1/21/84  
APPROVED BY  
*D. Plutic* 1/21/84

SEISMIC QUALIFICATION REEVALUATION  
CLASS 1E EQUIPMENT

COMPONENT NAME: CONTROL ROOM PANEL  
MPL OR EDL ITEM NO.: AS ATTACHED  
MPL REFERENCE: H13-P680

THE SEISMIC QUALIFICATION REPORT(S) IDENTIFIED HEREIN HAVE BEEN EVALUATED AND REQUALIFIED WHERE NECESSARY TO SHOW THAT THE ABOVE-MENTIONED COMPONENT IS CAPABLE OF MEETING THE NUCLEAR REGULATORY COMMISSION SEISMIC QUALIFICATION REVIEW TEAM (SQRT) REQUIREMENTS.

PREPARED BY: D.B. SHAMIS *D. Shamis* DATE 10-27-82

ORGANIZATION: GENERAL ELECTRIC COMPANY, CONTROL ROOM DESIGN ENGINEERING

REVIEWED BY: R.W. HARDY *R. W. Hardy* DATE 1/6/83  
SQRT PROGRAM MANAGER

APPROVED BY: N.G. LURIA *N. G. Luria* DATE 10/29/82  
RESPONSIBLE DESIGN ENGINEER

GENERAL  ELECTRIC

Qualification Summary of Equipment

MPL: H13-P680

- I. Plant Name: Perry Type: \_\_\_\_\_
1. Utility: Cleveland Electric Illuminating Co. PWR \_\_\_\_\_
2. NSSS: GE 3. A/E: Gilbert Associates Inc. BWR- 6 MK 3

II. Component Name Control Room Panel

1. Scope:  NSSS ~~QA~~  BOP
2. Model Number: H13-P680 Quantity: 1 each
3. Vendor: General Electric
4. If the component is a cabinet or panel, name and model No. of the devices included: See attached device list.
5. Physical Description a. Appearance Console
- b. Dimensions 240" W x 33" D x 63.5"H (irregular)
- c. Weight ~~N/A~~ ~1200# RA5
6. Location: Building: Control Room
- Elevation: 654'-6"
7. Field Mounting Conditions  Bolt (No. 4, Size 1/2")
- Weld (Length \_\_\_\_\_)
- WELDED @ EACH SUPPORT BEAM RA5
8. a. System in which located: Principle Plant Control
- b. Functional Description: Principle Plant Control Console
- c. Is the equipment required for  Hot Standby  Cold Shutdown
- Both  Neither
9. Pertinent Reference Design Specifications: See reference 4.

12/80

-2-

III. Is Equipment Available for Inspection in the Plant:  Yes  No

IV. Equipment Qualification Method:

Test  Analysis  Combination of Test and Analysis

Qualification Report\*: GE DRF A00-1138

(No., Title and Date) H13-P680 Seismic Test, Index T

Company that Prepared Report: General Electric

Company that Reviewed Report: General Electric

V. Vibration Input:

1. Loads considered: a.  Seismic only  
 b.  Hydrodynamic only  
 c.  Combination of (a) and (b)

2. Method of Combining RRS:  Absolute Sum  SRSS  \_\_\_\_\_  
 (other, specify)

3. Required Response Spectra (attach the graphs): See Figure 4.2

4. Damping Corresponding to RRS: OBE N/A SSE 4%

5. Required Acceleration in Each Direction:  ZPA  Other \_\_\_\_\_  
 (specify)

OBE	S/S =	<u>N/A 0.43g</u>	F/B =	<u>N/A 0.43g</u>	V =	<u>N/A 0.40g</u>
SSE	S/S =	<u>0.64g's**</u>	F/B =	<u>0.64g's**</u>	V =	<u>0.6g's</u>

OBE =  $\frac{2}{3}$  SSE  
 RH

6. Were fatigue effects or other vibration loads considered?

Yes  No

If yes, describe loads considered and how they were treated in overall qualification program: N/A

\*NOTE: If more than one report complete items IV thru VII for each report.

\*\*0.64g's is the combined (SRSS) horizontal ZPA.

12/80



VII. If Qualification by Analysis, then complete:

- 1. Method of Analysis: N/A
  - Static Analysis       Equivalent Static Analysis
  - Dynamic Analysis:     Time-History     Response Spectrum
- 2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
 

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_
- 3. Model Type:  3D                       2D                       1D
  - Finite Element     Beam                       Closed Form Solution
- 4.  Computer Codes: \_\_\_\_\_  
 Frequency Range and No. of modes considered: \_\_\_\_\_  
 Hand Calculations
- 5. Method of Combining Dynamic Responses:  Absolute Sum  SRSS  
 Other: \_\_\_\_\_  
 (specify)
- 6. Damping: OBE \_\_\_\_\_ SSE \_\_\_\_\_ Basis for the damping used: \_\_\_\_\_
- 7. Support Considerations in the model: \_\_\_\_\_
- 8. Critical Structural Elements:

A. Identification	Location	Governing Load or Reponse Combination	Seismic Stress	Total Stress	Stress Allowable

B. Max. Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Opera- bility




FIGURE 4-2. COMPARISON OF GE MINIMUM TRS WITH PERRY RRS ,CONTROL COMPLEX, 654'-6" ELEVATION

4-6



SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

MPL No. 0641F0085

BM No. RNg7

- I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: \_\_\_\_\_
1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_
2. NSSS: GENERAL ELECTRIC BWR: X
3. A/E: GILBERT/COMMONWEALTH Other \_\_\_\_\_

II. COMPONENT NAME: RETURN LINE TO FUEL POOL, FLOW CONTROL VALVE

1. Scope:  NSSS  BOP  Other
2. Model Number: C-W 2566-CC Quantity: 1
3. Size or Range: 10" - 150 LB CLASS
4. Vendor: CONTROMATICS CORP.
5. If the component is a cabinet or panel, name and model Number of the devices included:  
NOT A CABINET OR PANEL

6. Physical Description:

- a. Appearance: BUTTERFLY VALVE - S.S. W/ LIMITORQUE <sup>ACTUATOR</sup> SMB-002 /  
ITCBC
- b. Dimensions: FACE TO FACE = 2<sup>13/16"</sup>, WD = 28", HT = 41"
- c. Weight: 345 LB W/ ACTUATOR

7. Location: Building: INTERMEDIATE  
Elevation: 599

8. Field Mounting Conditions  Bolt (No. 12, Size 7/8" T 9)  
 Weld (Length \_\_\_\_\_)  
 \_\_\_\_\_

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)  
PIPE MOUNTED BETWEEN FLANGES WITH STEM HORIZONTAL

10. a. System in which located: G41 - FUEL POOL COOLING & CLEANUP
- b. Functional Description: OPEN FOR THROTTLED FLOW, CLOSE TO SHUTOFF FLOW.
- c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other THROTTLING

\* SEE: 1  
SEPERATE SORT FOR LIMITORQUE

REF DWG  
GAI U2  
FILE NO.  
0-10-0221-  
001

REF DWG  
GAI U2  
FILE NO.  
04-4549  
D304-658

II. Pertinent Reference Design Specifications for Qualification Requirements:

SP 524-4549-00

- a. Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

- Yes
- No
- Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

- Test
- Analysis
- Combination of Test and Analysis

Qualification Report\*: 12875-1 SEISMIC VIBRATION TESTING OF ONE 10"

(No., Title and Date): STAINLESS STEEL BUTTERFLY VALVE WITH LIMITORQUE ACTUATOR, 4/27/77

Company that Prepared Report: ACTON ENVIRONMENTAL TESTING CORP.

Company that Reviewed Report: GILBERT/COMMONWEALTH

Where Report is filed or available: PERRY NUCLEAR POWER PLANT

Applicable Codes And/Or Standards: USNRC REGULATORY GUIDE 1.48  
ASME B\*PV CODE SECTION III, CLASS 3

V. VIBRATION INPUT:

1. Loads considered:
- a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Vibration from normal operation
  - d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

- Absolute Sum
- SRSS
- N/A (RRS NOT USED)  
(other, specify)

3. Required Response Spectra \*\* (attach the graphs): N/A (RIM TEST PERFORMED)

NOTE:

\*If more than one report complete Items IV thru VII for each report.

\*\*If other than RRS is used, describe method.

4. Damping Corresponding to RRS: OBE N/A SSE N/A  
SEE  $\checkmark$  3.

5. Required Acceleration in Each Direct:

ZPA  Other RIM (REQUIRED INPUT MOTION)  
(specify)

OBBA or OBE S/S = 1.014 g F/B = 0.522 g V = 0.307 g

SSBA or SSE S/S = 1.014 g F/B = 0.522 g V = 0.307 g  
ACCELERATIONS FROM PIPING ANALYSIS 6.41913A

6. Were fatigue effects considered:

Yes  No

If yes, describe how they were treated in overall qualification program: N/A

VI. IF QUALIFICATION BY TEST, THEN COMPLETE: (ACTION REPORT 12875-1)

1.  Single Frequency  Multi-Frequency  random  sine beat  \_\_\_\_\_

2.  Single Axis  Multi-Axis  In-phase motions  Independent Axis

3. Number of Qualifications Tests: TESTING WAS PERFORMED AT ALL DEFINED NATURAL FREQUENCIES  
 OBE - SSE - Other PLUS 1, 5, 10, 15, 20, 25, 30, & 33 HZ.  
(specify)

4. Frequency Range: 1 ~ 50 HZ

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = 22.8 HZ F/B = NONE V = NONE

6. Method of Determining Natural Frequencies

Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test

Yes (Attach TRS and RRS graphs)  No N/A (RIM TEST PERFORMED)

8. Maximum Input g Level Test: (RIM TEST)  
 OBBA of OBE S/S = 3.0g F/B = 3.0g V = 3.0g  
 SSBA or SSE S/S = 3.0g F/B = 3.0g V = 3.0g

9. Laboratory Mounting:

a.  Bolt (No. 12, Size 7/8"-9)  
 Weld (Length \_\_\_\_\_)  \_\_\_\_\_

b. Orientation and Fixturing: VALVE MOUNTED TO A RIGID TEST FIXTURE WHICH WAS SECURELY ATTACHED TO THE LARGE BIAXIAL TEST TABLE OF THE AETC 45° BIAXIAL SEISMIC TEST FACILITY

10. Functional operability verified:  
 OPERATED AT LEAST ONCE AT EACH FREQUENCY OF THE SINE BEAT TEST  
 Yes  No  Not Applicable  
SEE ALSO \* AT BOTTOM OF PAGE.

11. Test Results including modifications made: ALL SEISMIC TESTING WAS SUCCESSFULLY COMPLETED WITH NO MODIFICATIONS.

12. Other tests performed (such as aging or fragility test, including results):

THE VALVE WAS PRESSURIZED TO 16.5 PSI DURING THE TESTING. NO LEAKS WERE FOUND DURING OR AFTER THE TESTING.

13. Failure Modes (if appropriate) NONE

14. Margins Available:  Input Spectrum  Fragility

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE: (NONE)

1. Method of Analysis:  
 Static Analysis  Equivalent Static Analysis  
 Dynamic Analysis:  Time-History  Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
 S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

3. Model Type:  3D  2D  1D  
 Finite Element  Beam  
 Closed Form Solution  Other \_\_\_\_\_

\* SPECIFICATION 524 REQUIRES AN OPERATING TIME OF 30 SECONDS, WHILE ACTON REPORT 12875-1 DID NOT INCLUDE THIS DATA IN THAT REPORT, ACTON TEST REPORT 12243-3 FOR A 10" STAINLESS STEEL VALVE WITH LIMITORQUE ACTION (NEW-LOADS REPORT) DID SHOW OPEN AND CLOSE TIME IN LESS THAN 30 SECONDS.

4.  Computer Codes: \_\_\_\_\_

Frequency Range and No. of Modes

Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

Absolute Sum       SRSS       Other: \_\_\_\_\_  
(specify)

6. Damping:

OBE \_\_\_\_\_ SSE \_\_\_\_\_ Basis for the damping used: \_\_\_\_\_

7. Support Considerations in the model: \_\_\_\_\_

8. Critical Structural Elements:

a.	Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
----	-------------------------	--	----------------	--------------	------------------

b.	Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
----	-----------------------------	----------	---

9. Failure Modes: \_\_\_\_\_

10. Margins Available:       Input Spectrum       Stress or Deflection

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
/		/	/	/
/		/	/	/
/		/	/	/

REVIEWED BY R. H. Youman 12/10/84  
CHECKED BY J. D. Cahery 12/17/84  
APPROVED BY RHS 7.21.87 HA Puteo 12/24/84

# PERRY NUCLEAR POWER STATION UNIT 1

CEI  
REVIEWED BY  
*R. Allen* / 7-21-84  
APPROVED BY  
*W. Patton* / 7-21-84

## SEISMIC QUALIFICATION REEVALUATION CLASS 1E EQUIPMENT

COMPONENT NAME: TRANSMITTER

PPD. NO.: 163C 1563

MPL REFERENCE: E12 N057

THE SEISMIC QUALIFICATION REPORT(S) IDENTIFIED HEREIN HAVE BEEN EVALUATED AND REQUALIFIED WHERE NECESSARY TO SHOW THAT THE ABOVE-MENTIONED COMPONENT IS CAPABLE OF MEETING THE NUCLEAR REGULATORY COMMISSION SEISMIC QUALIFICATION REVIEW TEAM (SQRT) REQUIREMENTS.

*N. H. Andersen*  
PREPARED BY: N.H. ANDERSEN DATE 2-2-84

ORGANIZATION: GENERAL ELECTRIC CO., QUALIFICATION & CONTROL EQUIPMENT DESIGN ENGINEERING

REVIEWED BY: R.W. HARDY *RW Hardy* DATE 2/15/84  
SQRT PROGRAM MANAGER

APPROVED BY: N.G. LURIA *NGL Luria* DATE 2/8/84  
QUALIFICATION ANALYSIS AND DESIGN  
ENGINEERING MANAGER

GENERAL  ELECTRIC

GE PPD # 163C1563MPL: E12-N057Seismic and Dynamic Qualification Summary of Equipment

- I. Plant Name: Perry Type: \_\_\_\_\_
1. Utility: Cleveland Electric Illuminating Co PWR \_\_\_\_\_
  2. NSSS: General Electric Co BWR- 6 - MKIII
  3. A/E: Gilbert/Commonwealth Other \_\_\_\_\_
- II. Component Name Transmitter, Differential Pressure
1. Scope:  NSSS  BOP  Other
  2. Model Number: 1151 Quantity: 1
  3. Size or Range: 0-120 to 0-1000 psig
  4. Vendor: Rosemount
  5. If the component is a cabinet or panel, name and model number of the devices included: N/A
  6. Physical Description:
    - a. Appearance: See Drawing Attachment 1
    - b. Dimensions: See Drawing Attachment 1
    - c. Weight: 11.9 LB
  7. Location: Building: Auxiliary  
Elevation 568 FT 4 IN
  8. Field Mounting Conditions  Bolt (No. 4, Size 1/4"φ)   
 Weld (Length \_\_\_\_\_)  
 See Attachment 5
  9. Mounting Orientation [e.g., on floor, cantilevered, suspended, etc.]  
See Attachment 5 ON STEEL CHANNEL MOUNTED TO WALL
  10. a. System in which located: Residual Heat Removal (RHR)  
b. Functional Description: Instrument Performs IE Function  
c. Is the equipment required for  Hot Standby  Cold Shutdown  Both  Neither  Other \_\_\_\_\_

GE PPD # 163C1563

MPL: E12-N057

11. Pertinent Reference Design Specification for Qualification

Requirements: \* Gilbert/Commonwealth Letter PY-GAI/CEI-13916

- a.  Seismic Input
- b.  Hydrodynamic Load Input
- c.  Fatigue Considerations
- d.  Service Conditions
- e.  Qualified Life

\* RRS @ THIS LEVEL INCLUDES NO HYDRODYNAMIC EFFECT. IF ANY ARE

III. Is Equipment Available for Inspection in the Plant: PROVIDED IT IS TO BE ASSUMED FOR AS NOT REQUIRED INT LOAD CONSERVATIVE  
 Yes  No  Partial or limited availability Pgs 5-15-84

IV. Equipment Qualification Method:

Test  Analysis  Combination of Test and Analysis

Qualification Report\*: G.E. DRF NO. A00-794-10

(No., Title and Date): H22 Local Panels Qual Report

Company that Prepared Report: General Electric

Company that Reviewed Report: General Electric

Where Report is filed or available: General Electric

Applicable Codes and/or Standards: IEEE 344-1975

V. Vibration Input:

1. Loads considered:
  - a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Vibration from normal operation
  - d.  Combination of (a), (b), and (c) \* NOTE ASSE

2. Method of Combining RRS:

Absolute Sum  SRSS  \_\_\_\_\_  
(other, specify)

3. Required Response Spectra\*\* (attach the graphs): \_\_\_\_\_

See Attachment 2

NOTE:

\* If more than one report complete Items IV thru VII for each report.

\*\* If other than RRS is used, describe methods.



4. Damping Corresponding to RRS: OBE \*4% SSE \*4%

5. Required Acceleration in Each Direction:

ZPA  Other \_\_\_\_\_ (specify)

OBE S/S = .28 F/B = .28 V = .22

SSE S/S = .35 F/B = .35 V = .3

NOTE: SS Represents N-S, FB represent E-W

6. Were fatigue effects considered:

Yes  No

If yes, describe how they were treated in overall

qualification program: SRV and hydrodynamic loads were  
considered in RRS FOR CONSERVATION ONLY. RA

VI. If Qualification by Test, then Complete:

1.  Single Frequency  Multi-Frequency  random  
 sine beat  
 \_\_\_\_\_

2.  Single Axis  Multi-Axis  
 Independent Axis  In-phase motions

3. Number of Qualifications Tests:  
OBE 5 SSE 1 Other \_\_\_\_\_  
(specify)

4. Frequency Range: 1.0 to 250 Hz

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): <sup>\*\*</sup>As noted in Paragraph 6, Rationale for Qualification  
S/S = \*\* F/B = \*\* V = \*\*

6. Method of Determining Natural Frequencies:  
 Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test:  
 Yes (Attach TRS & RRS graphs) SEE ATTACHMENT 4  
 No

\* RRS Damping Coefficient selected to be as similar as possible to TRS (4% / 5%)

8. Maximum Input g Level Test: (ZPA) Floor Response Spectra for Panel  
Mounted Device

OBE S/S = 5.4 F/B = 6.0 V = 5.8

SSE S/S = 7.5 F/B = 6.5 V = 7.5

9. Laboratory Mounting:

A.  Bolt (No.    , Size 3/4-10) 100 ft lb torque.

Weld (Length    )     

B. Orientation and Fixturing: See Attachment 3<sup>rd</sup> set

10. Functional operability verified:

Yes  No  Not Applicable

11. Test Results including modifications made: Before, during and  
after seismic testing instruments were functionally monitored.  
Transmitter output varied with respect to panel size and position.  
Pressure integrity was maintained throughout.

12. Other tests performed (such as aging or fragility test,  
including results):

No seismic aging or fragility tests were performed

13. Failure Modes (If appropriate) N/A

14. Margins Available:  Input Spectrum  Fragility

VII. If Qualification by Analysis, then complete: N/A

1. Method of Analysis:

Static Analysis  Equivalent Static Analysis

Dynamic Analysis  Time-History  Response  
Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back,  
Vertical):

S/S =     F/B =     V =    

3. Model Type:  3D  2D  1D

Finite Element  Beam

Closed Form Solution  Other

4.  Computer Codes: \_\_\_\_\_  
Frequency Range and No. of modes \_\_\_\_\_

Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other  
Dynamic Loads:

Absolute Sum       SRSS       Other: \_\_\_\_\_  
(specify)

6. Damping:

OBE \_\_\_\_\_ SSE \_\_\_\_\_ Basis for damping used: \_\_\_\_\_

7. Support Considerations in the model: \_\_\_\_\_

8. Critical Structural Elements:

	Governing Load or Response	Seismic Stress	Total Stress	Stress Allowable
A. <u>Identification Location</u>	<u>Combination</u>	<u>Stress</u>	<u>Stress</u>	<u>Allowable</u>

B. <u>Maximum Critical Deflection</u>	<u>Location</u>	<u>Maximum Allowable Deflection to Assure Functional Operability</u>


9. Failure Modes: \_\_\_\_\_

10. Margins Available:  Input Spectrum  
 Stress or Deflection

HERRY NUCLEAR POWER PLANT  
 UNIT 1, 52  
 HANFORD BLDG.  
 FIG. R. TEST RESULTS WITH  
 MAXIMUM ALLOWABLE  
 ELEVATION = 100' ±  
 FIG. M-4  
 \* REVISION 1, 500' ±

NARRAGANSETT  
 FIG. R. TEST  
 RESULTS


8-15-79 REV. 0



1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

REVISION 1 (2)



PERRY NUCLEAR POWER PLANT  
 UNIT 1 & 2  
 MIXTURES POLYMER  
 TEST: 1000116, 1000117, 1000118  
 1000119, 1000120, 1000121, 1000122, 1000123, 1000124  
 1000125, 1000126, 1000127, 1000128, 1000129, 1000130  
 1000131, 1000132, 1000133, 1000134, 1000135, 1000136  
 1000137, 1000138, 1000139, 1000140, 1000141, 1000142  
 1000143, 1000144, 1000145, 1000146, 1000147, 1000148  
 1000149, 1000150, 1000151, 1000152, 1000153, 1000154  
 1000155, 1000156, 1000157, 1000158, 1000159, 1000160  
 1000161, 1000162, 1000163, 1000164, 1000165, 1000166  
 1000167, 1000168, 1000169, 1000170, 1000171, 1000172  
 1000173, 1000174, 1000175, 1000176, 1000177, 1000178  
 1000179, 1000180, 1000181, 1000182, 1000183, 1000184  
 1000185, 1000186, 1000187, 1000188, 1000189, 1000190  
 1000191, 1000192, 1000193, 1000194, 1000195, 1000196  
 1000197, 1000198, 1000199, 1000200

MARK 144 - 5/10/78  
 OPERATION 570-1-1000  
 FIG. A1-5  
 REFERRED TO 570-1-1000


MARK 144 - 5/10/78  
 OPERATION 570-1-1000  
 FIG. A1-5

0978

B-15-78 REV. 0

ACCELERATION (g)

EQUILIBRIUM CRACKING



FERRI NUCLEAR POWER PLANT  
 UNITS 5, 2  
 APPROXIMATE BEPG  
 FLOOR RESONANCE OF 1.7 Hz  
 MAXIMUM ACCELERATION  
 VELOCITY IN VIBRATION  
 ELECTRICAL POWER

FIG A1-6

MARK II LAMINATED FLOOR RETAINS ENVELOPE


MARK II LAMINATED FLOOR RETAINS ENVELOPE

ACCELERATION (g)

1 2 3 4 5 6 7 8 9 10 20 30

MARK II LAMINATED FLOOR RETAINS ENVELOPE

B 74




0-15-79 REV 0

27 50

3 4 5 6 7 8 10

7

1




6-15-79 REV 0

PERCENTAGE (%)

ACCELERATION (g)



3 CYCLES X 10 DIVISIONS PER INCH



pg 76

B-1579 REVO

EXHIBIT 10E (Cont)

(5) 11/23/70 70-58

# SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: \_\_\_\_\_

1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_

2. NSSS: GENERAL ELECTRIC BWR: X \_\_\_\_\_

3. A/E: GILBERT/COMMONWEALTH Other: \_\_\_\_\_

II. COMPONENT NAME: CONTROL COMPLEX CHILLED WATER PUMPS OP47-COO1A,B,C | I

1. Scope:  NSSS  BOP  Other

2. Model Number: BX1450 Quantity: 3

3. Size or Range: 1600 GPM @ 1750 RPM | I

4. Vendor: INGERSOLL-RAND COMPANY

5. If the component is a cabinet or panel, name and model Number of the devices included:  
N/A

6. Physical Description:

a. Appearance: HORIZONTAL PUMP

b. Dimensions: 35" x 39.13" x 40.13"

c. Weight: 1,060 lbs

*Ref p 7 of 94Q-211-2  
 Ref p 1-2 of IR INSTRUC-TION MANUAL*

7. Location: Building: CONTROL COMPLEX

*Ref GAZ DIAG D-923-002*

Elevation: 574'-10"

8. Field Mounting Conditions (ANCHOR BOLTS TO FLOOR)  Bolt (No. 6, Size 7/8")  Weld (Length \_\_\_\_\_)  \_\_\_\_\_

*Ref p 7 of 94Q-211-2*

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)

MOUNTED ON 136D PLATE WHICH IS ANCHORED TO CONCRETE FLOOR

10. a. System in which located: CONTROL COMPLEX CHILLED WATER SYSTEM | I

b. Functional Description: SUPPLY COOLING WATER FOR CONTROL ROOM CHILLERS

c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other ALL PLANT MODES

11. Pertinent Reference Design Specifications for Qualification Requirements:

SP-644-4549-00

SP-750-4549-00

- (a) Seismic Input
- (b) Hydrodynamic Load Input
- (c) Fatigue Considerations
- (d) Service Conditions
- (e) Qualified Life

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

- Yes       No       Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

- Test       Analysis       ~~Combination of Test and Analysis~~

Qualification Report\*: STRUCTURAL INTEGRITY AND OPERABILITY ANALYSIS OF BX14SD PUMP

(No., Title and Date): 94Q-211-2      NOVEMBER 23, 1982

Company that Prepared Report: INGERSOLL-RAND COMPANY

Company that Reviewed Report: GILBERT/COMMONWEALTH

Where Report is filed or available: PERRY NUCLEAR POWER PLANT

Applicable Codes And/Or Standards: ASME SECTION III SUBSECTION ND, ASME SECTION IX, ASME SECTION XI, ANSI B10.5 REG GUIDE 1.4B

V. VIBRATION INPUT:

1. Loads considered:
- a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Vibration from normal operation
  - d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

- Absolute Sum       SRSS       \_\_\_\_\_ I  
 (other, specify)

3. Required Response Spectra \*\* (attach the graphs): ATTACHMENT 2

NOTE:

\*If more than one report complete Items IV thru VII for each report.

\*\*If other than RRS is used, describe method.

4. Damping Corresponding to RRS: OBE 2% SSE 3%

5. Required Acceleration in Each Direct:

ZPA  Other \_\_\_\_\_  
(specify)

OBBA or OBE S/S = 0.09 G F/B = 0.09 G V = 0.09 G

SSBA or SSE S/S = 0.18 G F/B = 0.18 G V = 0.18 G

6. Were fatigue effects considered:

Yes  No

If yes, describe how they were treated in overall qualification program: N/A

VI. IF QUALIFICATION BY TEST, THEN COMPLETE:

1.  Single Frequency  Multi-Frequency  random  
 sine beat  \_\_\_\_\_

2.  Single Axis  Multi-Axis  
 Independent Axis  In-phase motions

3. Number of Qualifications Tests:

OBE \_\_\_\_\_ SSE \_\_\_\_\_ Other \_\_\_\_\_  
(specify)

4. Frequency Range: \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies

Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test

Yes (Attach TRS and RRS graphs)  
 No

8. Maximum Input g Level Test:

OBBA or OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

SSBA or SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

a.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)

Weld (Length \_\_\_\_\_)  \_\_\_\_\_

b. Orientation and Fixturing: \_\_\_\_\_

10. Functional operability verified:

Yes

No

Not Applicable

11. Test Results including modifications made: \_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including results):

13. Failure Modes (If appropriate) \_\_\_\_\_

14. Margins Available:

Input Spectrum

Fragility

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. Method of Analysis:

Static Analysis

Equivalent Static Analysis

Dynamic Analysis:

Time-History

Response Spectrum

*Rpt 01 of 1  
94Q-211-2*

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = > 33 Hz

F/B = > 33 Hz

V = > 33 Hz

*Rpt 04 of 6  
94Q-211-2*

3. Model Type:

3D

2D

1D

Finite Element

Beam

*(3-D ELASTIC BEAM)*

*Rpt 05 of 6  
94Q-211-2*

Closed Form Solution

Other \_\_\_\_\_

4.  Computer Codes: ANSYS COMPUTER PROGRAM

Ref. pB-2 of  
94Q-211-2

Frequency Range and No. of Modes

Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

Absolute Sum       SRSS       Other: NA ONLY SEISMIC LOADS INVOLVED  
(specify) Ref p1 of  
94Q-211-2

6. Damping:

OBE        SSE        Basis for the damping used: EQUIVALENT STATIC ANALYSIS USED

7. Support Considerations in the model: BED PLATE AND ANCHOR BOLTS

8. Critical Structural Elements:

a.	Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
	<u>ATTACHMENT 1 GIVES CALCULATED VERSUS ALLOWABLE STRESSES</u>				
	<u>FLEET SHEAR PINS</u>	<u>DN+T+NOBLE</u>		<u>15752 psi</u>	<u>16800 psi</u>


b.	Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
	<u>NONE GIVEN</u>		



9. Failure Modes: FLEET SHEAR PINS HAVE LOWEST MARGIN BETWEEN ALLOWABLE AND CALCULATED STRESSES | 5

10. Margins Available:       Input Spectrum       Stress or Deflection


REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
<u>I</u>	<u>7-27-84</u>	<u>JSS</u>	<u>RAS</u>	<u>JAP</u>
<u>/</u>	<u>/</u>	<u>/</u>	<u>/</u>	<u>/</u>
<u>/</u>	<u>/</u>	<u>/</u>	<u>/</u>	<u>/</u>


REVIEWED BY JSSmith 1-14-83  
 CHECKED BY FJLahovski 1-14-83  
 APPROVED BY KAMatheny 10/7/83











FERRY NUCLEAR POWER PLANT  
UNITS 1 & 2  
CONTROL SAMPLE  
ROOM REVERSE SPECTRA  
MAX. GROUND ACCEL.  $0.0168$   
VERTICAL DIRECTION  
ELEVATION  $57.4$  AN

FIG. C1-4

--- INFRAN BURSTING  
— FLOOR RESPONSE  
— FURNACE

SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

MPL# 0P47-C001B

- I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: \_\_\_\_\_
1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_
2. NSSS: GENERAL ELECTRIC BWR: X
3. A/E: GILBERT/COMMONWEALTH Other \_\_\_\_\_
- II. COMPONENT NAME: MOTORS FOR ① CONTROL COMPLEX CHILLED WATER PUMPS  
② EMERGENCY CLOSED COOLING PUMPS
1. Scope:  NSSS  BOP  Other
2. Model Number: TADP Quantity: 5 UNIT 1 2 UNIT 2
3. Size or Range: 100 HP 1775 RPM pl Report No. AL50037 I.T.A
4. Vendor: WESTINGHOUSE
5. If the component is a cabinet or panel, name and model Number of the devices included:  
N/A
6. Physical Description:
- a. Appearance: SEE ATTACHED p6-7 of REPORT No AL50037 I.T.A (ATTACHMENT 3)
- b. Dimensions: SEE ATTACHED p6-7 of REPORT No AL50037 I.T.A (ATTACHMENT 3)  
~36" x 19" x 19"
- c. Weight: 915 lbs pl Report No. AL50037 I.T.A
7. Location: Building: CONTROL COMPLEX pl GAI Dwg D-923-002 D-304-621  
 Elevation: 5'4" - 10"
8. Field Mounting Conditions  Bolt (No. 4, Size 3/4")  
 Weld (Length \_\_\_\_\_)  
 \_\_\_\_\_
9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)  
MOUNTED ON SKID TO FLOOR
10. a. System in which located: ① CONTROL COMPLEX CHILLED WATER ② EMERGENCY CLOSED COOLING
- b. Functional Description: ① SUPPLY COOLING WATER FOR CONTROL ROOM CHILLERS  
② PROVIDE COOLING WATER FOR SAFETY RELATED COMPONENTS
- c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other ① ALL PLANT MODES  
② HOT STANDBY, NORMAL SHUTDOWN, CONTINUATION OF NORMAL SHUTDOWN AND POST ACCIDENT

II. Pertinent Reference Design Specifications for Qualification Requirements:

SP-644-4549-00      SD-750-4549-00

---

- a. Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

- Yes       No       Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

- Test       Analysis       Combination of Test and Analysis

Qualification Report\*: SEISMIC ANALYSIS

(No., Title and Date): ALS0037 I.T. A 6-16-83

Company that Prepared Report: WESTINGHOUSE

Company that Reviewed Report: GILBERT/COMMONWEALTH

Where Report is filed or available: PERRY NUCLEAR POWER PLANT

Applicable Codes And/Or Standards: IEEE 344-1975

V. VIBRATION INPUT:

1. Loads considered:
- a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Vibration from normal operation
  - d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

- Absolute Sum       SRSS       \_\_\_\_\_  
 (other, specify) PIB Report  
No ALS0037  
I.T. A

3. Required Response Spectra \*\* (attach the graphs): ATTACHMENT 2 (C-1)

NOTE:

\*If more than one report complete Items IV thru VII for each report.  
 \*\*If other than RRS is used, describe method.

4. Damping Corresponding to RRS: OBE 2% SSE 3%

5. Required Acceleration in Each Direct:

ZPA  Other \_\_\_\_\_  
(specify)

OBBA or (OBE) S/S = 0.09G F/B = 0.09G V = 0.09G SEE ATTACHED RRS  
SSBA or (SSE) S/S = 0.18G F/B = 0.18G V = 0.18G SEE ATTACHED RRS

6. Were fatigue effects considered:

Yes  No

If yes, describe how they were treated in overall qualification program: N/A

VI. IF QUALIFICATION BY TEST, THEN COMPLETE:

1.  Single Frequency  Multi-Frequency  random  
 sine beat  \_\_\_\_\_

2.  Single Axis  Multi-Axis  
 Independent Axis  In-phase motions

3. Number of Qualifications Tests:

OBE \_\_\_\_\_ SSE \_\_\_\_\_ Other \_\_\_\_\_  
(specify)

4. Frequency Range: \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies

Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test

Yes (Attach TRS and RRS graphs)  
 No

8. Maximum Input g Level Test:

OBBA or OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

SSBA or SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

- a.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)
- Weld (Length \_\_\_\_\_)  \_\_\_\_\_

b. Orientation and Fixturing: \_\_\_\_\_

10. Functional operability verified:

- Yes
- No
- Not Applicable

11. Test Results including modifications made: \_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including results):

*Equipment qualified w/ IEEE-STD 322-1974 (see MM-9112) RTR 9/21/87*

13. Failure Modes (If appropriate) \_\_\_\_\_

14. Margins Available:  Input Spectrum  Fragility

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. Method of Analysis:

- HE-1-83*
- Static Analysis
- Equivalent Static Analysis
- Dynamic Analysis:
- Time-History
- Response Spectrum

*p2 Report No AL50037 IT.A*

2. \* Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = GREATER THAN 33 Hz F/B = GREATER THAN 33 Hz V = GREATER THAN 33 Hz

*p 39 Report No AL50037 IT.A*

3. Model Type:

- 3D
- 2D
- 1D
- Finite Element
- Beam
- Closed Form Solution
- Other \_\_\_\_\_

*p27 Report No. AL50037 IT.A*

\* PAGE 3 of REPORT No AL50037 IT.A INDICATES THE MOTOR WILL BE MODELED AS A "RIGID" MASS. IT IS REQUIRED THAT THE MOTOR WILL BE RIGIDLY MOUNTED TO THE BASE, IN ORDER TO MEET THE REQUIREMENT OF THE SPECIFICATION.  
 PLEASE REFER TO PAGE 1 OF INGERSOLL-RAND'S REPORT FOR BR1450 PUMPS WHERE IT IS STATED THE FUNDAMENTAL FREQUENCY OF THE PUMP-MOTOR-SUPPORT FRAME IS DEMONSTRATED TO BE ABOVE THE RIGID FREQUENCY.

4.  Computer Codes: N/A  
 Frequency Range and No. of Modes  
 Hand Calculations
5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:  
 Absolute Sum       SRSS       Other: N/A  
 (specify)

6. Damping:  
 OBE \_\_\_\_\_ SSE \_\_\_\_\_ Basis for the damping used: EQUIVALENT STATIC ANALYSIS USED

7. Support Considerations in the model: MOTOR FOOT

8. Critical Structural Elements:

a. Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
<u>ATTACHMENT 1</u> <u>SHAFT</u>			<u>3739 psi</u>	<u>36000 psi</u> <u>AS</u>


b. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
<u>ATTACHMENT 1</u> <u>SHAFT @ 0.0019"</u>		<u>0.0068" AS</u>

9. Failure Modes: SHAFT STRESS

10. Margins Available:       Input Spectrum       Stress or Deflection  
 107 Report No  
 ALS0037 ITR  
 Also Ref attached stress comparisons

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
/		/	/	/
/		/	/	/
/		/	/	/

REVIEWED BY [Signature] 1/7-15-83  
 CHECKED BY James D. Caherty 1/9/01/83  
 APPROVED BY [Signature] 1/7/24/84




SCALE: 1/8" = 1 G  
 2 CIRCLES X 100 L. DIVISIONS PER INCH

(6) 10/11/64



4 CHECK X TO DIVISION FOR THIS




AGILITY AND STABILITY  
 UNITS 1/2  
 CONTROL COMPLEX  
 FLOOR RESPONSE SPECTRA  
 ANTENNA ACCEL - SSE = 0.160 G  
 VERTICAL EXCITATION  
 FLUCTUATION 57% ± 10%


AGILITY AND STABILITY  
 UNITS 1/2

AGILITY AND STABILITY  
 UNITS 1/2

MADE IN U.S.A.

2 CYCLES X 10 DIVISIONS PER INCH





## SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

- I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: \_\_\_\_\_
1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_
2. NSSS: GENERAL ELECTRIC BWR: X
3. A/E: GILBERT/COMMONWEALTH Other \_\_\_\_\_
- II. COMPONENT NAME: MAIN STEAM STOP 3<sup>RD</sup> ISOLATION VALVE NIIFO020A B,C,D
1. Scope:  NSSS  BOP  Other
2. Model Number: 81240 Quantity: 4 UNIT 1, 0 UNIT 2
3. Size or Range: 28" ANSI CLASS 900
4. Vendor: BOG - WARNER
5. If the component is a cabinet or panel, name and model Number of the devices included:  
N/A  
(NOT A CABINET OR PANEL)
6. Physical Description:
- a. Appearance: GATE VALVE WITH SMR-4-200 LIMITORQUE ACTUATOR
- b. Dimensions: H=162" L=90.75" W=48"
- c. Weight: 19,358 LBS. (VALVE), 1905 LBS. ACTUATOR
7. Location: Building: AUXILIARY BUILDING - STEAM TUNNEL  
Elevation: 620'
8. Field Mounting Conditions  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)  
 Weld (Length circum.)  
 \_\_\_\_\_
9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)  
MOUNTED IN HORIZONTAL PIPE RUN WITH STEM VERTICAL
10. a. System in which located: NII - MAIN \* REHEAT STEAM
- b. Functional Description: SYSTEM FLOW SHUTOFF WHEN CLOSED, PASS FLOW WHEN OPEN
- c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other MAIN STEAM SHUTOFF

II. Pertinent Reference Design Specifications for Qualification Requirements:

SPEC. S21-02

- a. Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

- Yes
- No
- Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

- Test
- Analysis
- Combination of Test and Analysis

Qualification Report\*: NSR 81240 REV D, 3-1-84, SEISMIC ANALYSIS OF

(No., Title and Date): 28" 900 LB. CARBON STEEL, MOTOR OPERATED, GATE VALVE

Company that Prepared Report: BERG-WARNER

Company that Reviewed Report: GILBERT/COMMONWEALTH

Where Report is filed or available: PERRY NUCLEAR POWER PLANT

Applicable Codes And/Or Standards: ASME B&PV CODE, SECT III, NB-3200 & NC-3500  
1971 EDITION, ADDENDA TO WINTER 1972

V. VIBRATION INPUT:

1. Loads considered:
- a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Vibration from normal operation
  - d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

- Absolute Sum
- SRSS
- N/A RRS NOT USED  
(other, specify)

3. Required Response Spectra \*\* (attach the graphs): SEE PNPP VALVE QUALIFICATION PROGRAM DESCRIPTION (TAB 6)

NOTE:

\*If more than one report complete Items IV thru VII for each report.  
 \*\*If other than RRS is used, describe method.

4. Damping Corresponding to RRS: OBE N/A SSE N/A  
SEE SECTION IX of THIS SORT

5. Required Acceleration in Each Direct:  
 ZPA  Other PEAK\*  
(specify)

OBBA or OBE S/S = < SSBA F/B = < SSBA V = < SSBA

SSBA or SSE S/S = ≤ 3g F/B = ≤ 3g V = ≤ 3g  
SEE ATTACHMENT A, SECTION 4.

6. Were fatigue effects considered:  
 Yes  No

If yes, describe how they were treated in overall qualification program: SEE PNPP VALVE FATIGUE LOADING ANALYSIS (TABLE)

\* MAXIMUM ACCELERATIONS FROM PIPING ANALYSIS.

VI. IF QUALIFICATION BY TEST, THEN COMPLETE:

1.  Single Frequency  Multi-Frequency  random  sine beat  \_\_\_\_\_

2.  Single Axis  Multi-Axis  
 Independent Axis  In-phase motions

3. Number of Qualifications Tests:  
OBE \_\_\_\_\_ SSE \_\_\_\_\_ Other \_\_\_\_\_  
(specify)

4. Frequency Range: \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies  
 Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test  
 Yes (Attach TRS and RRS graphs)  
 No

- 8. Maximum Input g Level Test:  
 OBBA or OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_  
 SSBA or SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_
- 9. Laboratory Mounting:  
 a.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_ )  
 Weld (Length \_\_\_\_\_ )  \_\_\_\_\_  
 b. Orientation and Fixturing: \_\_\_\_\_
- 10. Functional operability verified:  
 Yes  No  Not Applicable
- 11. Test Results including modifications made: \_\_\_\_\_  
 \_\_\_\_\_
- 12. Other tests performed (such as aging or fragility test, including results):  
 \_\_\_\_\_  
 \_\_\_\_\_
- 13. Failure Modes (If appropriate) \_\_\_\_\_
- 14. Margins Available:  Input Spectrum  Fragility

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

- 1. Method of Analysis:  
 Static Analysis  Equivalent Static Analysis <sup>①</sup>  
 Dynamic Analysis: <sup>②</sup>  Time-History  Response Spectrum
- 2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
 S/S = 47.5 F/B = 47.5 V = \_\_\_\_\_
- 3. Model Type:  3D  2D  1D  
 Finite Element <sup>②</sup>  Beam <sup>①</sup>  
 Closed Form Solution  Other \_\_\_\_\_

① EQUIVALENT STATIC - STRESS CALCULATION  
 ② DYNAMIC ANALYSIS - DETERMINATION OF NATURAL FREQUENCY.

4.  Computer Codes: MSC/NASTRAN

Frequency Range and No. of Modes 0-33Hz, 0 MODES IN FREQUENCY RANGE OF INTEREST

Hand Calculations ABOVE 33Hz ANALYSIS CALCULATED 3 MODES OF 47.5Hz, 69.4Hz, AND 174Hz

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads: N/A

Absolute Sum  SRSS  Other: \_\_\_\_\_ (specify)

6. Damping:

OBE N/A SSE N/A Basis for the damping used: NOT USED IN THE ANALYSIS

7. Support Considerations in the model: FIXED AT WELD ENDS ② SEE BOTTOM PG 4.

8. Critical Structural Elements: SIMPLY SUPPORTED AT WELD ENDS ① SEE BOTTOM PG 4

a. Identification-Location	Governing-Load or-Response Combination-	Seismic Stress-	Total Stress-	Stress-Allowable
<u>FOR PIPING ACCELERATIONS SEE PG. 3</u>				
<u>FOR STRESSES SEE REPORT NSR B1240 - SUMMARY SECTION PG 8</u>				

b. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
<u>0.0098"</u>	<u>CG OF ACTUATOR</u> <u>SEE NSR B1240 PG. 61</u>	<u>X</u>

9. Failure Modes: FAILURE OF BODY NECK

10. Margins Available:  Input Spectrum  Stress or Deflection

\* MAXIMUM ALLOWABLE NOT GIVEN - MAXIMUM DISPLACEMENTS ARE SUFFICIENTLY SMALL AND VALVE MACHINING TOLERANCES ADEQUATELY ACCOMMODATE MOVEMENTS. IN ADDITION, THE DYNAMIC MOVEMENT OF THE VOICE ASSEMBLY ASSOCIATED WITH A SEISMIC EVENT WOULD TEND TO FREE ANY BINDING THAT MIGHT OCCUR.

REV.NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
<u>1</u>	<u>7-27-83</u>	<u>JAD</u>	<u>JDC</u>	<u>KAM</u>
<u>2</u>	<u>4-27-83</u>	<u>SRM</u>	<u>RAS</u>	<u>HAP</u>
<u>3</u>	<u>7-18-84</u>	<u>[Signature]</u>	<u>[Signature]</u>	<u>[Signature]</u>

SP-581-02

REVIEWED BY A. HIRSHBERGER 12-16-82

CHECKED BY F. J. LAHOVSKI 1-19-83

APPROVED BY K. A. MATHENY 4-22-83



# SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: \_\_\_\_\_  
 1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_ MPL# 124250002  
124250003  
 2. NSSS: GENERAL ELECTRIC BWR: X  
 3. A/E: GILBERT/COMMONWEALTH Other: \_\_\_\_\_

II. COMPONENT NAME: Lead Acid Electrical Storage Batteries and Racks

1. Scope:       NSSS                       BOP                       Other
- \* 2. Model Number: 2GN-15                      Quantity: 2
- \* 3. Size or Range: 125VDC, 1200 Ampere-hours (8 hour rating)
4. Vendor: Exide Power Systems Division, ESB Corporation
5. If the component is a cabinet or panel, name and model Number of the devices included:  
N/A
6. Physical Description:
  - \* a. Appearance: Clear plastic battery cells mounted on open steel lattice rack
  - \* b. Dimensions: 108" wide, 38.25" high, 48.75" deep
  - c. Weight: 14550 LB. REF TELECON PY-GAI/CEI 8462T
7. Location: Building: CC  
Elevation: 638' 6"
- \* 8. Field Mounting Conditions                       Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)  
 Weld (Length 2.5", 16 per rack,  
5.0", 8 per rack)  
 \_\_\_\_\_
9. Mounting Orientation (e.g., on floor, cantilever, suspended, etc.):  
on floor
10. a. System in which located: 125Volt DC/Battery system  
 b. Functional Description: Provide 125VDC for DC System  
 c. Is the equipment required for       Hot Standby       Cold Shutdown  
 Both                       Neither                       Other \_\_\_\_\_

\* REF. VENDOR LAYOUT DRAWING  
 EXIDE POWER SYSTEMS DRAWING  
 PH-47339

II. Pertinent Reference Design Specifications for Qualification Requirements:

SP-554-4549-00

a. Seismic Input

d. Service Conditions

b. Hydrodynamic Load Input

e. Qualified Life

c. Fatigue Considerations

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

Yes

No

Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

Test

Analysis

Combination of Test and Analysis

REF. TITLE PAGE | R1

TEST: Nuclear Environmental Qualification Program on Electrical Storage Batteries

Qualification Report\*: Analysis: Comparison Test & Analysis of 2 step 3 bay high voltage Battery Rack

TEST: 45001-1 Jan. 18, 1982

(No., Title and Date): Analysis: A-3-82; Feb. 10, 1982; A-4-82, Feb. 10, 1982 (REF. TITLE PAGE) | R1

TEST: Wyle Laboratories

Company that Prepared Report: ANALYSIS: Flight Dynamics, Inc. REF. TITLE PAGE | R1

Company that Reviewed Report: GILBERT/COMMONWEALTH

Where Report is filed or available: PERRY NUCLEAR POWER PLANT

Applicable Codes And/Or Standards: IEEE 323-1974, IEEE 344-1975

V. VIBRATION INPUT:

1. Loads considered:

a.  Seismic only

b.  Hydrodynamic only

c.  Vibration from normal operation

d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

Absolute Sum

SRSS

\_\_\_\_\_

(other, specify)

3. Required Response Spectra \*\* (attach the graphs):

C4(-1 thru -4)

| R1

NOTE:

\*If more than one report complete Items IV thru VII for each report.

\*\*If other than RRS is used, describe method.

4. Damping Corresponding to RRS: OBE 2% SSE 2%

5. Required Acceleration in Each Direct: REF. RRS CY CURVES | R1

ZPA  Other Peak  
(specify)

OBBA or OBE S/S = 2.53 g F/B = 2.53 g V = 2.53 g  
 SSBA or SSE S/S = 3.2 g F/B = 3.2 g V = 3.2 g

6. Were fatigue effects considered:  
 Yes  No

If yes, describe how they were treated in overall qualification program: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

VI. IF QUALIFICATION BY TEST, THEN COMPLETE: REF. SEC. IV (of 4500-1 Wj6) | R1

1.  Single Frequency  Multi-Frequency REF. PARA. 2.3  random  sine beat  
 \$3.3, 2.2\$

2.  Single Axis  Multi-Axis REF. PARA. 2.3  In-phase motions  
 Independent Axis \$3.3, 2.2\$

3. Number of Qualifications Tests: REF. PARA. 2.3 & 3.3 | R1  
 OBE 10 SSE 2 Other \_\_\_\_\_  
 in two component/direction each, i.e. resulting in 50% of 1st & 2nd Qual. Test (specify)

4. Frequency Range: 1 Hz to 200 Hz REF. PARA. 2.3 & 3.3 | R1

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): REF. APP. IV TO SEC. IV | R1  
 S/S = 11.5 Hz F/B = 15.2 Hz V = 35 Hz

6. Method of Determining Natural Frequencies REF. PARA. 2.2 & 3.2 | R1  
 Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test REF. APP. V TO SEC. IV | R1  
 Yes (Attach TRS and RRS graphs)  
 No

8. Maximum Input g Level Test: REF. FIGS IN APP. V (SEE ATTACH)  
 OBBA or OBE S/S = 6.25 F/B = 6.25 V = 6.95  
 SSBA or SSE S/S = 10.0 F/B = 9.8 V = 17.4

9. Laboratory Mounting: REF. FIG. 3, SEC. VI, SEC. 3.1, SEC. IV  
 a.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_) 749, VI-20 + 23; exp. photo IV-1  
 Weld (Length 2.5" / 5.0")  16 per rack / 8 per rack } welded to test fixture  
 b. Orientation and Fixturing: \_\_\_\_\_ (see FIG 3 of VI-20) 2/2/82

10. Functional operability verified:  
 Yes  No  Not Applicable

11. Test Results including modifications made: No structural failures noted; REF. SEC. 3.3.1  
No voltage or current deviations were noted; REF. SEC. 3.7.1

12. Other tests performed (such as aging or fragility test, including results):  
Aging: Batteries successfully passed tests after thermal and radiation aging procedures REF. SEC. I, II, III

13. Failure Modes (If appropriate) \_\_\_\_\_

14. Margins Available: REF. FIGS. FROM APP. II OF SEC. IV  
 Input Spectrum  Fragility

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE: \*

1. Method of Analysis: REF. A-3-92 4.0, 5.0; A-4-82 5.0  
 Static Analysis  Equivalent Static Analysis  
 Dynamic Analysis:  Time-History  Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): REF. A-3-92 TABLE 4.1  
 S/S = 11.17 Hz \*\* F/B = 15.98 Hz \*\* V = 34.51 Hz \*\*  
 \*\* Calculated From model

3. Model Type:  3D  2D  1D  
 REF. A-3-92  Finite Element  Beam  
4.0, 5.0  Closed Form Solution  Other \_\_\_\_\_

\* Analysis used to prove seismic qualification of 15 battery rack; test was for 12 battery rack

4.  Computer Codes: SAP IV REF. A-3-82 SEC. 5, D |R1

Frequency Range and No. of Modes 1 Hz to 50 Hz Vertical, 1 Hz to 40 Hz Horizontal;  
~~Hand~~ Calculations 3 modes

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads: REF. SEC. 5, D, A-4-82 |R1

Absolute Sum  SRSS <sup>6/24/83</sup> Other: ~~1/A~~ (specify)

6. Damping: REF. A-4-82 FIG. 2.1, 2.2 |R1  
 OBE — SSE 2% Basis for the damping used: Used for test which provided data.

7. Support Considerations in the model: Model is assumed to be welded to test fixture

8. Critical Structural Elements: REF. A-4-82, 6.0 |R1  
fixed at the base - see input  
mds 570-627 RAS 9/20/83

a. Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
Support angle, elem. 416 lower left frame support (p23)	Static weight of batteries plus seismic (dynamic) load		950. 27,795	28,000 31,110


b. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
N/A RAS		

9. Failure Modes: Bending REF. A-4-82 6.0 |R1

10. Margins Available:  Input Spectrum  Stress or Deflection |R1  
 REF. A-4-82 FIG. 2.1, 2.2


REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
1	1/7/24/83	ETB	BSK	1/7/83
1				
1				

REVIEWED BY Edward J. Burke 1/11/12/82  
 CHECKED BY D. J. Lahowski 1/11-15-82  
 APPROVED BY Kenneth A. Matheny 1/12/11/82  
 Rev 1 on RAS 9.28.83  
 5 Rev 1 on JDC 01.03.84



PERKINS NUCLEAR POWER PLANT  
 UNITS 1 & 2  
 CONTROL COMPLEX  
 FLOOR RESPONSE SPECTRA  
 MAX. GROUND MOT. - SSE = 0.150g  
 EAST-WEST & NORTH-SOUTH  
 ELEVATION 1638'-6"

30 20 10 9 8 7 6 5 4 3 2 1 0



REACTOR NUCLEAR POWER PLANT  
LIMITS 1/2 Z  
CONCRETE COMPLEX  
FLOOR RESONANCE FREQUENCIES  
ALL AROUND ACCEL. SPECTRUM  
VERTICAL DIRECTION  
ELEVATION 658'-6"

FIG. C A-2


MAXIMUM WIDTH  
PLANT RESPONSE ENVELOPE

EQUIPMENT SHAKING  
0.01  
0.02  
0.04  
0.07


EQUIPMENT SHAKING  
0.01  
0.02  
0.04  
0.07

ACCELERATION (G)

PERIOD (SEC)







ACCELERATION POWER PLANT  
UNITS 1 & 2  
CONTROL SYSTEMS  
FLOOR RESPONSE SPECTRA  
WALL-BRACKET - ONE F.O.D.E.  
VERTICAL DIRECTION  
ELEMENT 535-5"

FIG. C.A. 1

EQUIPMENT  
DAMPING

0.01  
0.02  
0.04  
0.07

FLOOR RESPONSE  
ENVELOPE

0.01  
0.02  
0.04  
0.07

ACCELERATION (g)

SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: \_\_\_\_\_  
 1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_  
 2. NSSS: GENERAL ELECTRIC BWR: X \_\_\_\_\_  
 3. A/E: GILBERT/COMMONWEALTH Other \_\_\_\_\_

II. COMPONENT NAME: VALVE FOR COMBUSTIBLE GAS PURGING UNIT MSI F0010A(B)

1. Scope:  NSSS  BOP  Other  
 2. Model Number: 81300 Quantity: 2 UNIT 1, 2 UNIT 2  
 3. Size or Range: 4" ANSI CLASS 300  
 4. Vendor: BORG WARNER

5. If the component is a cabinet or panel, name and model Number of the devices included:  
N/A (NOT A CABINET OR PANEL)

6. Physical Description: LIMITORQUE SMB-00-5  
 a. Appearance: MOTOR OPERATED GLOBE VALVE  
 b. Dimensions: END-TO-END = 34.625", WIDTH = 20.125", HEIGHT = 51"  
 c. Weight: 423 LBS. W. ACTUATOR

7. Location: Building: REACTOR  
 Elevation: 670 FT.

8. Field Mounting Conditions  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)  
 Weld (Length CIRCUIT)  
 \_\_\_\_\_

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)  
PIPE MOUNTED WITH STEM VERTICAL

10. a. System in which located: MSI-COMBUSTIBLE GAS CONTROL  
 b. Functional Description: SYSTEM FLOW SHUT-OFF WHEN CLOSED, THROTTLE WHEN OPEN, PRESSURE RETENTION  
 c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other ACCIDENT

II. Pertinent Reference Design Specifications for Qualification Requirements:

SP 521-02

- a. Seismic Input  d. Service Conditions  
 b. Hydrodynamic Load Input  e. Qualified Life  
 c. Fatigue Considerations

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

- Yes  No  Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

- Test  Analysis  Combination of Test and Analysis

Qualification Report\*: NSR 81300, REV. C, 4-7-82, SEISMIC ANALYSIS  
(No., Title and Date): OF 4" 300LB CARBON STEEL MOTOR OPERATED GLOBE VALVE  
Company that Prepared Report: BORG WARNER  
Company that Reviewed Report: GILBERT/COMMONWEALTH  
Where Report is filed or available: PERRY NUCLEAR POWER PLANT  
Applicable Codes And/Or Standards: ASME B&PV CODE SECTION III, NB3200 & NC-3500, 1971 EDITION, ADDENDA TO WINTER 1972

V. VIBRATION INPUT:

1. Loads considered: a.  Seismic only  
b.  Hydrodynamic only  
c.  Vibration from normal operation  
d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

- Absolute Sum  SRSS  N/A (RRS NOT USED)  
(other, specify)

3. Required Response Spectra \*\* (attach the graphs): SEE PNPP VALVE QUALIFICATION PROGRAM DESCRIPTION, REV. 4, (TAB 6)

NOTE:

- \*If more than one report complete Items IV thru VII for each report.  
\*\*If other than RRS is used, describe method.

4. Damping Corresponding to RRS: OBE N/A SSE N/A  
*see V.3 page 2*

5. Required Acceleration in Each Direct:  
 ZPA  Other PEAK \*  
(specify)

OBBA or OBE S/S = < SSBA F/B = < SSBA V = < SSBA

SSBA or SSE S/S = ≤ 3g F/B = ≤ 3g V = ≤ 3g

6. Were fatigue effects considered:

Yes  No

If yes, describe how they were treated in overall qualification program: SEE PNPP VALVE FATIGUE LOADING

ANALYSIS (TAB G)

\* MAXIMUM ACCELERATION FROM PIPING ANALYSIS.

VI. IF QUALIFICATION BY TEST, THEN COMPLETE:

1.  Single Frequency  Multi-Frequency  random  
 sine beat  \_\_\_\_\_

2.  Single Axis  Multi-Axis  
 Independent Axis  In-phase motions

3. Number of Qualifications Tests:  
OBE \_\_\_\_\_ SSE \_\_\_\_\_ Other \_\_\_\_\_  
(specify)

4. Frequency Range: \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies  
 Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test  
 Yes (Attach TRS and RRS graphs)  
 No

8. Maximum Input g Level Test:  
 OBBA or OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_  
 SSBA or SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_
9. Laboratory Mounting:  
 a.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_ )  
 Weld (Length \_\_\_\_\_ )  \_\_\_\_\_  
 b. Orientation or Fixturing: \_\_\_\_\_
10. Functional operability verified:  
 Yes  No  Not Applicable
11. Test Results including modifications made: \_\_\_\_\_  
 \_\_\_\_\_
12. Other tests performed (such as aging or fragility test, including results):  
 \_\_\_\_\_  
 \_\_\_\_\_
13. Failure Modes (If appropriate) \_\_\_\_\_
14. Margins Available:  Input Spectrum  Fragility

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. Method of Analysis:  
 Static Analysis  Equivalent Static Analysis (1)  
 Dynamic Analysis (2)  Time--History  Response Spectrum
2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
 S/S = 40.57 F/B = 40.57 V = \_\_\_\_\_
3. Model Type:  3D  2D  1D  
 Finite Element (2)  Beam (1)  
 Closed Form Solution  Other \_\_\_\_\_

(1) EQUIVALENT STATIC ANALYSIS USED FOR STRESS CALCULATION  
 (2) DYNAMIC ANALYSIS USED TO DETERMINE NATURAL FREQUENCIES

4.  Computer Codes: SAP VI (DYNAMIC ANALYSIS)

Frequency Range and No. of Modes 0 - 100 Hz, 2 MODES OF INTEREST  
 Hand Calculations 0 - 110.5 Hz, 3 MODES ACTUALLY COMPUTED

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads: PIPING

Absolute Sum  SRSS  Other: \_\_\_\_\_  
 (specify)

6. Damping:  
 OBE N/A SSE N/A Basis for the damping used: NOT USED IN THIS ANALYSIS

7. Support Considerations in the model: FIXED AT WELD ENDS FOR  $f_n$   
SIMPLY SUPPORTED FOR STRESS CALCULATIONS

8. Critical Structural Elements:

a. Identification Location	Governing Load	Seismic Stress	Total Stress	Stress Allowable
	or Response Combination			
FOR MAXIMUM ACCELERATION FROM PIPING ANALYSIS SEE PG. 3 FOR STRESSES SEE REPORT NSR 81300 - SUMMARY SECTION, PG. 9				

b. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
<u>0.0142"</u>	<u>C.G. OF ACTUATOR</u>	<u>*</u>
<u>SEE NSR 81300 PG. 47</u>		

9. Failure Modes: DEFORMATION OR FAILURE OF BONDET FLANGE

10. Margins Available:  Input Spectrum  Stress or Deflection

\* MAXIMUM ALLOWABLE NOT GIVEN - MAXIMUM DISPLACEMENTS ARE SUFFICIENTLY SMALL AND VALUE MACHINING TOLERANCES ADEQUATELY ACCOMODATE MOVEMENTS. IN ADDITION, THE DYNAMIC MOVEMENT OF THE YOKE ASSEMBLY ASSOCIATED WITH A SEISMIC EVENT WOULD TEND TO FREE ANY BINDING THAT MIGHT OCCUR.

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
1	7-25-83	JAD	JDC	KAM
2	7-18-84	FCR	RAP	[Signature]
/	/	/	/	/

SP-521-02

REVIEWED BY J.A. DAISE / 4-4-83  
 CHECKED BY F.J. LAHOVSKI / 4-5-83  
 APPROVED BY K.A. MATHENY / 4-22-83

**SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT**

- I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE:
1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_
2. NSSS: GENERAL ELECTRIC BWR: X
3. A/E: GILBERT/COMMONWEALTH Other \_\_\_\_\_

II. COMPONENT NAME: EMERGENCY SERVICE WATER TRAVELING WATER SCREEN CONTROL PANEL  
OH51-P077(A), B

1. Scope:  NSSS  BOP  Other
2. Model Number: CONTROL BOX ON PEDESTAL Quantity: 2  
CUSTOM MADE
3. Size or Range: ATTACHMENT A (DRAWING OF BOX)
4. Vendor: REXARD CONTROL PRODUCTS

5. If the component is a cabinet or panel, name and model Number of the devices included:

RA GAI DWG 4547-22-074-15  
7 ITE IMPERIAL RELAY'S #J10A4012, 3 GE SELECTOR SW #CR2940-45203E, 1 GE SELECTOR SW #CR2940YB202G, 3 GE INDICATING LIGHT GRN ET-16, 4 GE INDICATING LIGHT RED ET-16, 2 GE TERMINAL BLK CR15-84, 1 GE TERMINAL BLK CR15-82

6. Physical Description: CR15-86, 3 GE TERMINAL BLK CR15-82
- a. Appearance: ATTACHMENT A
- b. Dimensions: ATTACHMENT A
- c. Weight: ATTACHMENT A

7. Location: Building: EMERGENCY SERVICE WATER PUMPHOUSE RA GAI DWG E-015-002  
Elevation: 586'-6"

8. Field Mounting Conditions  Bolt (No. 4, Size 1/2")  
 Weld (Length \_\_\_\_\_ )  
 \_\_\_\_\_

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)  
PEDESTAL MOUNTED, TO CONCRETE FLOOR

10. a. System in which located: EMERGENCY SERVICE WATER SCREEN WASH
- b. Functional Description: CONTROL PANEL FOR TRAVELING WATER SCREEN
- c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other POST ACCIDENT AND CONTINUATION OF NORMAL SHUTDOWN

II. Fertinent Reference Design Specifications for Qualification Requirements:

SP-505-4549-00 SP-750-4549-00

- a. Seismic Input
- d. Service Conditions
- b. Hydrodynamic Load Input
- e. Qualified Life
- c. Fatigue Considerations

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

- Yes
- No
- Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

- Test
- Analysis
- Combination of Test and Analysis

Qualification Report\*: SEISMIC STRUCTURAL ANALYSIS AND REPORT FOR CONTROL TANK

(No., Title and Date): JOB NUMBER 78321 REV. 1 5-31-79 99Q-369-1-0

Company that Prepared Report: LEROY A LUTZ COMPUTERIZED STRUCTURAL DESIGN, INC.

Rev 10.5.83

Company that Reviewed Report: GILBERT/COMMONWEALTH

Where Report is filed or available: PERRY NUCLEAR POWER PLANT

Applicable Codes And/Or Standards: IEEE 344-1975

V. VIBRATION INPUT:

1. Loads considered:
  - a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Vibration from normal operation
  - d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

- Absolute Sum
- SRSS
- \_\_\_\_\_  
(other, specify)

3. Required Response Spectra \*\* (attach the graphs): ATTACHMENT C

NOTE:

\*If more than one report complete Items IV thru VII for each report.

\*\*If other than RRS is used, describe method.



4. Damping Corresponding to RRS: OBE 2% SSE 3%

5. Required Acceleration in Each Direct:

ZPA  Other g levels at lowest natural frequencies.  
(specify)

OBBA or OBE S/S = 0.75 F/B = 1.25 V = 0.48

SSBA or SSE S/S = 0.96 F/B = 1.05 V = 0.68

6. Were fatigue effects considered:

Yes  No

If yes, describe how they were treated in overall qualification program: N/A

VI. IF QUALIFICATION BY TEST, THEN COMPLETE:

1.  Single Frequency  Multi-Frequency  random  
 sine beat  \_\_\_\_\_

2.  Single Axis  Multi-Axis  
 Independent Axis  In-phase motions

3. Number of Qualifications Tests:  
OBE \_\_\_\_\_ SSE \_\_\_\_\_ Other \_\_\_\_\_  
(specify)

4. Frequency Range: \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies  
 Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test  
 Yes (Attach TRS and RRS graphs)  
 No

8. Maximum Input g Level Test:

OBBA or OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

SSBA or SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

a.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_ )

Weld (Length \_\_\_\_\_ )  \_\_\_\_\_

b. Orientation and Fixturing: \_\_\_\_\_

10. Functional operability verified:

Yes  No  Not Applicable

11. Test Results including modifications made: \_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including results):

13. Failure Modes (If appropriate) \_\_\_\_\_

14. Margins Available:  Input Spectrum  Fragility

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. Method of Analysis:

Static Analysis  Equivalent Static Analysis

Dynamic Analysis:  Time-History  Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = 9.73 Hz F/B = 11.91 Hz V = 20.44 Hz *p11 Report # 78320*

3. Model Type:  3D  2D  1D  
 Finite Element  Beam *p11 Report # 78320*  
 Closed Form Solution  Other \_\_\_\_\_

4.  Computer Codes: COMPUTER PROGRAMS USED WERE WRITTEN BY ECOM ASSOCIATES FOR THE WANG 2200 AND WCS SYSTEMS AND SOLD NATIONALLY

REV 06  
REPORT 78320

Frequency Range and No. of Modes 4 MODES

Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads;

Absolute Sum       SRSS       Other: NO OTHER DYNAMIC LOADS  
(specify)

6. Damping:

OBE \* SSE \* Basis for the damping used: STATIC ANALYSIS SP-750-4549-00, REG. GUIDE 1.6.1

7. Support Considerations in the model: PEDestal AND ANCHOR BOLTS TO CONCRETE FLOOR

8. Critical Structural Elements:

a. Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
BASE PLATE ANCHOR BOLTS	(TENSION) OBE	162 #/BOLT		1000 lbs
	(TENSION) SSE	253.1 #/BOLT		1000 lbs
	(SHEAR) OBE	183 PSI		1000 lbs
	(SHEAR) SSE	295 PSI		1000 lbs
b. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability		

9. Failure Modes: CRITICAL ITEMS RELATING TO STRUCTURAL INTEGRITY OF CONTROL PANEL ARE ANCHOR BOLTS TO GAUGE PLATE ATOP THE WOLXIS, STIFFENERS IN BACK OF PANEL, STIFFENERS AT GAUGE PLATE

10. Margins Available:  Input Spectrum       Stress or Deflection


\* SEE ATTACHMENT B

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
/		/	/	
/		/	/	
/		/	/	

SP-505  
CONTROL PANEL  
REVIEWED BY [Signature] 14-25-83  
CHECKED BY S. J. Zahorski 14-29-83  
APPROVED BY [Signature] HA Puter 17-23-84  
7-23-84

# ATTACHMENT A

1/2



### Weights -

Pedestal -  $\frac{46}{12} (15) = 57.5 \#$

Top R  $2.5(3)(5.6) = 42$

Box - 96 lbs  
 (22A@4.2)

Sub panel - 30 lbs

### Relays -

2-4 POLE  $1.25(8) = 10 \text{ lbs}$

6 POLE  $1.5(7) = 10.5 \text{ lbs}$

Switches & Pilot Lights 3 lbs

Switches + Pilot lights - 3#

Terminals + Ducts - 2#


R Added to cover -


$3\frac{1}{2} (\frac{3}{16})(1.667)(3.4) = 3.7 \text{ lbs}$

Rs Added to sub panel -

$3\frac{1}{2} \times 3\frac{3}{16} (2.33)(3.4) = 5.2 \text{ lbs}$

$3\frac{1}{2} \times 3\frac{3}{16} (1)(3.4) = 2.2 \text{ lbs}$





ATTACHMENT A

2/2

$$18(.5) + 4(.866) = 12.46"$$

$$18(.866) - 4(.5) = 13.59"$$

$$18(.866) + 4(.5) = 17.59"$$

$$18(.5) - 4(.866) = 5.54"$$

Mass 1 -

- $\frac{1}{4}(57.5) = 14.4$  lbs Pedestal
  - $\frac{2}{3}(42) = 28$  lbs Top R
  - $\frac{1}{2}(96) = 48$  lbs Box
  - $\frac{1}{2}(30) = 15$  lbs Subpanel
- 
- 105.4 lbs  
24.5  

---

129.9 lbs

Component Breakdown -

Item	2	1	3
SAF: 2.6		1.7	0.9
" "	0.9	1.7	
5.2 R		5.2	
2.2 R	.4	1.8	
C-C pole	3.0	6.0	
5.7 R	1.9	1.8	
6-4 Pole 1-4 Pole	5.9	3.1	
2-4 Pole		1.0	1.5
Term & Dud	.6	1.0	.4
Switches & Pilot Lights	1.2	1.2	.6
	<hr/> 13.9#	<hr/> 24.5#	<hr/> 34#

Mass 2 -

- $\frac{1}{4}(57.5) = 14.4$  lbs
  - $\frac{1}{2}(42) = 21.0$
  - $\frac{1}{4}(96) = 24$
  - $\frac{1}{4}(30) = 7.5$
- 
- 52.9 lbs  
13.9  

---

66.8 lbs

Mass 3 -

$$52.9$$

$$3.4$$


---


$$56.3\#$$

Mass 4 -

$$\frac{1}{2}(57.5) = 28.8\#$$





Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT AUDITABLE FILE PACKAGE

CISID

PAGE

FRAGL

GP-505-4549-00

1

REV.

0

1

2

3

OF

MICROFILMED

PAGES

2

ORIGINATOR J S Smith

DATE 4-29-83

ATTACHMENT B

The lowest natural frequencies for the control panel are as follows;

North/South	11.9 Hz
East/West	9.7 Hz
Vertical	20.44 Hz

Listed below is a comparison of  $g$  loads taken from GAI's RRS curves at the above listed frequencies and the  $g$  input values used for the analysis of the control panel.

	OBE @ 2% Damping	SSE @ 3% Damping
North/South	0.75 $g$	0.96 $g$
East/West	1.25 $g$	1.05 $g$
Vertical	0.48 $g$	0.68 $g$
	OBE Input	SSE Input
North/South	0.925 $g$	1.38 $g$
East/West	1.2 $g$	1.65 $g$
Vertical	0.44 $g$	0.73 $g$

It is apparent that the values used in the analysis for the SSE condition envelope the Perry requirements, as does the North/South direction for the OBE. However, the East/West



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT AUDITABLE FILE PACKAGE

CONTRX PANEL

CISID

SP-505-4549

PAGE

2

OF

PAGES 2

REV.

0

1

2

3

MICROFILMED

ORIGINATOR J SMITH

DATE 4-29-83


and vertical directions for the OBE ~~was~~  
had of input values of 4% and 8.3%  
respectively, lower than design requirements.  
However, this is still considered qualified for  
OBE, because of the substantial margins  
on stresses in critical elements.

JEFFREY SMITH

GILBERT ASSOCIATES, INC		MADE	
ENGINEERS AND CONSULTANTS		CHK'D.	
READING, PENNA.		BY CF.	
		CF. DFN.	
		ENG.	
WORK ORDER	REV. CH. APP. DATE		
SIZE			
DRAWING			

SSE X-DIRECTION  
3% DAMPING

PERRY NUCLEAR POWER PLANT  
RRS AT WORST CASE DEVICE  
LOCATION  
CONTROL PANEELS






GILBERT ASSOCIATES, INC.  
ENGINEERS AND CONSULTANTS  
READING, PENNA.

MADE  
CHK'D.  
SQ. CP.  
CF. DFN.  
ENG.  
REV. CH. APP. DATE


WORK ORDER    SIZE    DRAWING    RE



SSE Y-DIRECTION  
3% DAMPING  
PERRY NUCLEAR POWER PLANT  
RR5 AT WORST CASE DEVICE LOCATION  
CONTROL PANEL

SSE 2-DIRECTION  
3% DAMPING

PERRY NUCLEAR POWER PLANT  
RRS AT WORST CASE DEVICE LOCATION  
CONTROL PANELS



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.	CHK'D.	SO. CF.	CF. DFN.	ENG.	REV. CH. APP. DATE
	MADE				
WORK ORDER	SIZE	DRAWING			

SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: MPL # 1R24 50032

1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_

2. NSSS: GENERAL ELECTRIC BWR: X

3. A/E: GILBERT/COMMONWEALTH Other \_\_\_\_\_

II. COMPONENT NAME: IE Motor Control Centers

1. Scope:  NSSS  BOP  Other  
 (S.O. Qual. Plan (SP 557-00-3))

2. Model Number: F24S Quantity: 5 Common, 13 each unit

3. Size or Range: N/A

4. Vendor: Eaton/Cutler-Hammer

5. If the component is a cabinet or panel, name and model Number of the devices included:  
 \_\_\_\_\_  
 \_\_\_\_\_

6. Physical Description: See #6, sheet 1A.5

a. Appearance: Long Switchgear lineup

b. Dimensions: \_\_\_\_\_

c. Weight: \_\_\_\_\_

7. Location: Building: See #7, Sheet 1A.5  
 Elevation: \_\_\_\_\_

8. Field Mounting Conditions  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)  
See B 50-12158 (C-H) and A 50-11119, sh 5 (C-H), attached  Weld (Length \_\_\_\_\_)

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)  
On Floor

10. a. System in which located: 480 Volt AC and 125 Volt DC systems  
Provide 480 Volt AC and 125 Volt DC to

b. Functional Description: IE electrical Equipment.

c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other \_\_\_\_\_



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT Seismic and Dynamic Qualification Summary of Equipment

IDENTIFIER

PAGE 1A OF 5 PAGES

REV.	0	1	2	3
MICROFILMED				
ORIGINATOR	HB			
DATE	6/9/83			

6 Physical Description

Motor Control Center	6b) Dimensions:			6c) Weight: (560 lb/section 7.3.4.6, Test Report)
	L	W	H	
OR24S0020	120 in.	24 in.	90 in.	2,800 lb.
OR24S0025	336 "	" "	" "	7,840 "
OR24S0035	192 "	" "	" "	4,480 "
OR24S0036	144 "	" "	" "	3,360 "
OR24S0037	72 "	" "	" "	1,680 "
1R24S0018	456 "	" "	" "	10,640 "
1R24S0019	120 "	" "	" "	2,800 "
1R24S0021	456 "	" "	" "	10,640 "
1R24S0022	120 "	" "	" "	2,800 "
1R24S0023	456 "	" "	" "	10,640 "
1R24S0024	144 "	" "	" "	3,360 "
1R24S0026	456 "	" "	" "	10,640 "
1R24S0028	120 "	" "	" "	2,800 "
1R24S0029	192 "	" "	" "	4,480 "
1R24S0030	48 "	" "	" "	1,120 "
1R24S0031	96 "	" "	" "	2,240 "
1R24S0032	96 "	" "	" "	2,240 "
1R42S0015	168 "	" "	" "	3,920 "

7 Location

MCC	Building	Elevation
OR24S0020	Control Complex	620'6"
OR24S0025	" "	" "
OR24S0035	" "	" "
OR24S0036	" "	" "
OR24S0037	" "	" "
1R24S0018	" "	" "
1R24S0019	" "	" "
1R24S0021	" "	" "
1R24S0022	" "	" "
1R24S0023	" "	" "
1R24S0024	" "	" "
1R24S0026	" "	" "
1R24S0028	" "	" "
1R24S0029	" "	" "
1R24S0030	Emergency Service Water Pumphouse	586'6"
1R24S0031	" " " "	" "
1R24S0032	" " " "	" "
1R42S0015	Control Complex	638'6"

II. Pertinent Reference Design Specifications for Qualification Requirements:

SP-557-4549-00, SP-750-4549-00

- a. Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

- Yes       No       Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

- Test       Analysis       Combination of Test and Analysis

Qualification Report\*: Technical Report PEI-TR-83-9; Seismic Qualification (title page 1)

(No., Title and Date): Class I E MCC's for PUPP Units 1 and 2; 3/24/83

Company that Prepared Report: Patel Engineers, Inc. Huntsville Alabama

Company that Reviewed Report: GILBERT/COMMONWEALTH

Where Report is filed or available: PERRY NUCLEAR POWER PLANT

Applicable Codes And/Or Standards: IEEE 344-1975

V. VIBRATION INPUT:

1. Loads considered:
- a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Vibration from normal operation
  - d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

- Absolute Sum       SRSS       \_\_\_\_\_  
(other, specify)


3. Required Response Spectra \*\* (attach the graphs): C4 \*\*\*


NOTE:

\*If more than one report complete Items IV thru VII for each report.  
\*\*If other than RRS is used, describe method.

\*\*\* C4 RRS curves (Control Complex, Elevation 638'6") envelope  
C3 (Control Complex, elevation 620'6") and E1 (Emergency Service Water,  
Elevation 586") RRS curves. 2


\*\*\* Analysis of effects of top entry of cables by calculation # 4.0.01-1 to 4.0.01-10  
GAI, 6/8/83





2 3 4 5 6 7 8 9 10 20 30

4 2 0 4 2 0 1



PERF. UNDER SUPERVISOR  
UNITS 1 & 2  
CONTROL COMPLEX  
ELECTRICAL SYSTEMS SECTION  
AIR GROUND BCKL. 555-0.1505  
VERTICAL POSITION:  
ELEVATION 6385.6'  
FIG. C-9-2

5-00-6557-00-5

8-15-79 REV. 0


FREQUENCY (CPS)

AMPLITUDE (G)



EUGENE DISTZGEN CO.  
MADE IN U. S. A.

NO. 340-L310 DISTZGEN GRAPH PAPER  
SEMI-LOGARITHMIC  
2 CYCLES X 10 DIVISIONS PER INCH



4. Damping Corresponding to RRS: OBE 4% SSE 7%

5. Required Acceleration in Each Direct: REF. RRS CURVES C4 | R1

ZPA  Other Peak  
(specify)

OBBA or OBE S/S = 1.47g F/B = 1.47g V = 1.55g

SSBA or SSE S/S = 1.6g F/B = 1.6g V = 1.55g

6. Were fatigue effects considered:

Yes  No

If yes, describe how they were treated in overall qualification program:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

VI. IF QUALIFICATION BY TEST, THEN COMPLETE: REF. PEI-TR-83-9, APP. II, SEC. III.4.2 | R1

1.  Single Frequency  Multi-Frequency  random  sine beat  \_\_\_\_\_

2.  Single Axis  Multi-Axis REF. SEC. III.4.2 | R1  
 Independent Axis  In-phase motions

3. Number of Qualifications Tests: REF. SEC. III.4.2 p.40 FIVE and ONE in each coordinate for a total of 6 RRS 2.10.83 | R1  
OBE 10 SSE 2 Other \_\_\_\_\_  
(specify)

4. Frequency Range: 1.0 Hz to 100 Hz REF. SEC. III.4.2d | R1

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): Tables IV.1.2b, Pg 80  
S/S = 17.8 Hz F/B = 18.9 Hz V = No test run IV.1.2a, Pg 79

6. Method of Determining Natural Frequencies REF. SEC. III.4.1 | R1  
 Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test REF. SEC. IV.2 | R1  
 Yes (Attach TRS and RRS graphs)  
 No

8. Maximum Input g Level Test: REF. TRS GRAPHS SEC. II.2

OBBA or OBE S/S = 3.36 F/B = 4.49 V = 2.29

SSBA or SSE S/S = 3.15 F/B = 2.41 V = 1.81

9. Laboratory Mounting:

a.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)

Weld (Length \_\_\_\_\_)  \_\_\_\_\_

{ See Attached Drawing  
SK 021583 (Sec. 3.0)  
Note Attachment A

b. Orientation and Fixturing: Welded to test table (Sec. III.3)

10. Functional operability verified: REF. SEC VI.5, VI.6

Yes  No  Not Applicable

11. Test Results including modifications made: Removed power line conditioning components - affected resonance of cabinets (Attachment A, Note 3)

REF. SEC. III.4.1, VI.5, VI.6

12. Other tests performed (such as aging or fragility test, including results):

N/A

13. Failure Modes (If appropriate) N/A

14. Margins Available:  Input Spectrum  Fragility

REF. TRS GRAPHS SEC. II.2

\* VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

Analysis performed to determine effects of top cable entry on MCC seismic qualification

1. Method of Analysis:

Static Analysis

Equivalent Static Analysis

Dynamic Analysis:

Time-History

Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): N/A

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

3. Model Type:

3D

2D

1D

Finite Element

Beam

Closed Form Solution

Other \_\_\_\_\_

\* GAI CALC. 40.01 (SEE SEC. 4 OF AFP)

4.  Computer Codes: N/A

Frequency Range and No. of Modes

Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads: N/A, not used

Absolute Sum       SRSS       Other: \_\_\_\_\_  
(specify)

6. Damping: N/A, Damping not used

OBE \_\_\_\_\_ SSE \_\_\_\_\_ Basis for the damping used: \_\_\_\_\_

7. Support Considerations in the model: MCC welded to steel embedments in concrete floor

8. Critical Structural Elements: Malleable Iron liquid tight connector

a. Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
<u>Top of MCC</u>		<u>19.82 ksi</u>	<u>19.82 ksi</u>	<u>27 ksi</u>

b. Maximum Critical Deflection \_\_\_\_\_ Location \_\_\_\_\_ Maximum Allowable Deflection to Assure Functional Operability \_\_\_\_\_

N/A

9. Failure Modes: Strain of malleable iron

10. Margins Available:       Input Spectrum       Stress or Deflection

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
<u>1</u>	<u>1/20/83</u>	<u>ETB</u>	<u>GSK</u>	<u>[Signature]</u>
<u>/</u>	<u>/</u>	<u>/</u>	<u>/</u>	<u>/</u>
<u>/</u>	<u>/</u>	<u>/</u>	<u>/</u>	<u>/</u>

REVIEWED BY Edward T. Burke 16/9/83  
 CHECKED BY James D. Chesley 16/9/83  
 APPROVED BY [Signature] 18/9/83

### SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: \_\_\_\_\_

1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_

2. NSSS: GENERAL ELECTRIC BWR: X

3. A/E: GILBERT/COMMONWEALTH Other: \_\_\_\_\_

II. COMPONENT NAME: VERTICAL PUMP [MFL] 1P45C002

1. Scope:  NSSS  BOP  Other

2. Model Number: VIT Quantity: 1

3. Size or Range: 8X12 JMC - 5 STG 5 STG P. 2713

4. Vendor: GOULDS PUMPS

5. If the component is a cabinet or panel, name and model Number of the devices included:

6. Physical Description:

a. Appearance: VERTICAL PUMP

b. Dimensions: 11 3/8" DIAMETER 41' - 9 1/8" HIGH GOULDS HAS 5000  
FLOW MODULAR  
DIV 9 23

c. Weight: 2,930 lbs DRY 3,730 lbs FLOODED p 2 MC 453

7. Location: Building: EMERGENCY SERVICE WATER PUMP HOUSE REFERENCE  
GAE DDG  
E-015-002

Elevation: 586" - 6"

8. Field Mounting Conditions  Bolt (No. 4, Size 1/2") p 17 ME453 EN  
 Weld (Length \_\_\_\_\_ )  
 \_\_\_\_\_

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)  
FLOOR

10. a. System in which located: EMERGENCY SERVICE WATER

b. Functional Description: SUPPLY ADEQUATE HEAD AND FLOW FOR COMPONENT COOLING

c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other POST-ACCIDENT

II. Pertinent Reference Design Specifications for Qualification Requirements:

SPECIFICATIONS SP-750-4549-00 REV. 1 DATED 3/11/74

SP-501-4549-00 REV. 2 SECTIONS 2 AND 3 DATED 11/11/76

- a. Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

- Yes
- No
- Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

- Test
- Analysis
- Combination of Test and Analysis

Qualification Report\*: SEISMIC ANALYSIS OF VERTICAL PUMP

(No., Title and Date): ME-453 SEPTEMBER 16, 1977 { 942-042-1-0 } PAR  
 { 942-042-2-0 }

Company that Prepared Report: MCDONALD ENGINEERING ANALYSIS COMPANY, INC.

Company that Reviewed Report: GILBERT/COMMONWEALTH

Where Report is filed or available: PERRY NUCLEAR POWER PLANT

Applicable Codes And/Or Standards: ASME SECTION III CLASS 3 SUBSECTION NF4 ADDENDA, AND SUBSECTION NF; AISC CODE

V. VIBRATION INPUT:

1. Loads considered:
  - a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Vibration from normal operation
  - d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

- Absolute Sum
- SRSS
- N/A

(other, specify)

3. Required Response Spectra \*\* (attach the graphs): ATTACHMENT 2

NOTE:

\*If more than one report complete Items IV thru VII for each report.

\*\*If other than RRS is used, describe method.

4. Damping Corresponding to RRS: OBE 2% SSE 3%

5. Required Acceleration in Each Direct:  
 ZPA  Other Required Acceleration Corresponding to natural frequencies  
(specify)

OBBA or OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_  
SSBA or SSE S/S = see attachment #3 F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Were fatigue effects considered:  
 Yes  No

If yes, describe how they were treated in overall qualification program:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

VI. IF QUALIFICATION BY TEST, THEN COMPLETE:

1.  Single Frequency  Multi-Frequency  random  sine beat  \_\_\_\_\_

2.  Single Axis  Multi-Axis  
 Independent Axis  In-phase motions

3. Number of Qualifications Tests:  
OBE \_\_\_\_\_ SSE \_\_\_\_\_ Other \_\_\_\_\_  
(specify)

4. Frequency Range: \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies  
 Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test  
 Yes (Attach TRS and RRS graphs)  
 No

8. Maximum Input g Level Test:

OBBA or OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

SSBA or SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

- a.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)
- Weld (Length \_\_\_\_\_)  \_\_\_\_\_

b. Orientation and Fixturing: \_\_\_\_\_

10. Functional operability verified:

- Yes
- No
- Not Applicable

11. Test Results including modifications made: \_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including results):  
\_\_\_\_\_  
\_\_\_\_\_

13. Failure Modes (If appropriate) \_\_\_\_\_

14. Margins Available:  Input Spectrum  Fragility

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. Method of Analysis:

- (1)  Static Analysis  Equivalent Static Analysis
- (2)  Dynamic Analysis:  Time-History  Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = 13.6 CPS F/B = 13.6 CPS V = 48.9 CPS pg ms 453

- 3. Model Type:  3D  2D  1D
- Finite Element  Beam
- Closed Form Solution  Other \_\_\_\_\_

(1) VERTICAL

(2) LATERAL



4.  Computer Codes: ICES - STRUDL p1 ME-453  
 Frequency Range and No. of Modes LATERAL 18 MODES 13.6 - 2086 cps  
VERTICAL 21 MODES 46.9 - 3158 cps p6 ME-453

Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

Absolute Sum       SRSS       Other: N/A  
(specify)

6. Damping:

OBE 2% SSE 2% Basis for the damping used: CONSERVATIVE INTERPRETATION OF SP-750-4549-00 - RG 1.61 p14 ME-453

7. Support Considerations in the model: SEISMIC SUPPORTS AND BASE PLATE MODELED

8. Critical Structural Elements: ATTACHED

a. Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
<u>ATTACHMENT 1</u>				

b. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
<u>ATTACHMENT 1</u>		

9. Failure Modes: DISCHARGE HEAD BASE PLATE STRESS

10. Margins Available:       Input Spectrum       Stress or Deflection

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
/		/	/	/
/		/	/	/
/		/	/	/

SP-501  
 REVIEWED BY [Signature] 1/10-21-82  
 CHECKED BY Z. J. Schowski 1/10-22-82  
 APPROVED BY [Signature] 7/18/84 18-21-82  
 EAS 7/16/84

SCRT 501-1

ME-453-14

ME-454-10-18-82

2. SUMMARY OF RESULTS  
ATTACHMENT 1  
page 1 of 1


<u>Components</u>	<u>Actual</u>	<u>Allowable</u>
Maximum Column Stress, PSI	19,561	22,500
Maximum Column Flange Stress, PSI	25,993	26,250
Bolt Stress, PSI	34,240	37,500
Maximum Pump Casing Flange Stress, PSI	20,865	21,000
Bolt Stress, PSI	33,193	42,000
Nozzle Stress, PSI	7,916	22,500
Anchor Bolt Stress, PSI - Tensile	22,510	40,000
- Shear	6,157	12,320
Shaft Key Stress, PSI	18,321	20,000
Pump Hold Down Bolt Stress, PSI - Tensile	22,088	25,000
- Shear	3,142	12,500
Motor Hold Down Bolt Stress, PSI - Tensile	6,466	20,000
- Shear	3,349	10,000
Discharge Head Base Plate Stress, PSI	26,155	26,250
Discharge Head Stress, PSI	17,506	22,500
Shaft Stress, PSI	29,174	30,000
Discharge Nozzle Flange Pressure, PSIG	229	275
Pump Casing Stress, PSI	4,434	14,000
Impeller Clearance, Inches	.0013	.014
Shaft Deflection, Inches	.0292	.05
Motor Mounting Plate Stress, PSI	8,263	26,250
Motor Support Weld Stress	10,127	11,400



FERRY NUCLEAR POWER PLANT  
UNITS 1 & 2  
EMERGENCY SERVICE WATER PUMP HOUSE  
FLOOR RESPONSE SPECTRA (OBE)  
VERTICAL DIRECTION AT  
ELEVATION 585.6"  
(MAX. GROUND ACCELERATION = 0.075g)

FIG. E2-6  
(SHEET 2 OF 2)


FLOOR RESPONSE ENVELOPES  
DI EQUIPMENT DAMPING



PERRY NUCLEAR POWER PLANT  
UNITS 1 & 2  
EMERGENCY SERVICE WATER PUMP HOUSE  
FLOOR RESPONSE SPECTRA (OBE)  
NORTH-SOUTH DIRECTION A.T.  
ELEVATION 586'-6"  
(MAX. GROUND ACCELERATION OBE=0.075G)

FIG. E2-5  
(SHEET 2 OF 2)


FLOOR RESPONSE ENVELOPE  
DE EQUIPMENT DAMPING



PERRY NUCLEAR POWER PLANT  
UNITS 1 & 2  
EMERGENCY SERVICE WATER PUMP MOTOR  
FLOOR RESPONSE SPECTRA (ORBE)  
EAST-WEST DIRECTION AT  
ELEVATION 586'-6"  
(MAX. GROUND ACCELERATION-ORBE=0.075G)

FIG. E2-4  
(SHEET 2 OF 2)


FLOOR RESPONSE ENVELOPE  
DE EQUIPMENT DAMPING



PERRY NUCLEAR POWER PLANT  
UNITS 1 & 2  
EMERGENCY SERVICE WATER PUMP NOISE  
FLOOR RESPONSE SPECTRA (SSE)  
VERTICAL DIRECTION AT  
ELEVATION 586'-6"  
(MAX. GROUND ACCELERATION - SSE - 0.180g)

FIG. E2-3  
(SHEET 2 OF 2)

FLOOR RESPONSE ENVELOPE  
D = EQUIPMENT DAMPING




FERRY NUCLEAR POWER PLANT  
UNITS 1 & 2  
EMERGENCY SERVICE WATER PUMP HOUSE  
FLOOR RESPONSE SPECIFICS (SEE)  
NORTH-SOUTH DIRECTION AT  
ELEVATION 586 ± 6"  
(MAX. GROUND ACCELERATION - SEE A506)

FIG. E2-2  
(SHEET 2 OF 2)

FLOOR RESPONSE ENVELOPE

D = EQUIPMENT DAMPING




PERRY NUCLEAR POWER PLANT  
UNITS 1 & 2  
EMERGENCY SERVICE WATER PUMP HOUSE  
FLOOR RESPONSE SPECTRA (SSE)  
EAST WEST DIRECTION AT  
ELEVATION 586'-6"  
(MAX. GROUND ACCELERATION - SSE = 0.15G)

FIG. E2-1  
(SHEET 2 OF 2)

FLOOR RESPONSE ENVELOPE

DE EQUIPMENT DAMPING





ATTACHMENT #3SEISMIC TABLE SSE

<u>Natural Frequency</u>	<u>Corresponding Input Required 3% Damping</u>			<u>Analysis Input Used 2% Damping</u>		
	<u>N-S</u>	<u>E-W</u>	<u>Vertical</u>	<u>N-S</u>	<u>E-W</u>	<u>Vertical</u>
13.6	.97	.52	.38	1.05	.72	.4
18.3	.44	.46	.38	.8	.6	.4
23.4	.30	.35	.38	.3	.35	.4
36.4	.24	.28	.38	.3	.3	.4
41.1	.24	.28	.38	.3	.3	.4
53.8	.24	.28	.38	.3	.3	.4

The Seismic Analysis performed uses acceleration levels from the Floor Response Spectra SSE curves at 2% damping. This input is determined at the frequencies corresponding to the natural frequencies of the assembly. The results of the seismic analysis are contained on attachment number 1 and show that the stresses developed in the components are all within allowable levels. The actual input accelerations required for qualification are those derived from the SSE curves at 3% damping (shown above). In all cases the accelerations used in the analysis are greater than the levels required. Thus, the analysis performed was conservative and as a result the assemblies are seismically qualified for our application.

SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

- I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: \_\_\_\_\_
1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_
2. NSSS: GENERAL ELECTRIC BWR: X
3. A/E: GILBERT/COMMONWEALTH Other \_\_\_\_\_

II. COMPONENT NAME: FORM WOUND VERTICAL MOTOR

1. Scope:  NSSS  BOP  Other
2. Model Number: FRAME 404VP Quantity: 2 (one for each unit) REF. Pg. 8 9-27-83 | R1
3. Size or Range: 75 HP
4. Vendor: SIEMENS ALLIS
5. If the component is a cabinet or panel, name and model Number of the devices included:  
N/A
6. Physical Description:
- a. Appearance: SEE ATTACHED DWG.
- b. Dimensions: SEE ATTACHED DWG.
- c. Weight: 1041 LBS REF. Pg. 8 | R1
7. Location: Building: ESW DUMPHOUSE  
Elevation: 540'-0
8. Field Mounting Conditions  Bolt (No. 4, Size 5/8) REF. Pg. 8 | R1  
 Weld (Length \_\_\_\_\_)  
 \_\_\_\_\_
9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)  
DIRECTLY ON THE PUMP
10. a. System in which located: EMERG. SERV. WATER SYSTEM  
b. Functional Description: SMALL ESW PUMP  
c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other PA

II. Pertinent Reference Design Specifications for Qualification Requirements:

SP-550-4549 & 7504549

- a. Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

- Yes
- No
- Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

- Test
- Analysis
- Combination of Test and Analysis

Qualification Report\*: EL-8-S134-90309-01 <sup>Rev 2</sup> dated 12/21/82

(No., Title and Date): \_\_\_\_\_

Company that Prepared Report: SIEMENS ALLIS

Company that Reviewed Report: GILBERT/COMMONWEALTH

Where Report is filed or available: PERRY NUCLEAR POWER PLANT

Applicable Codes And/Or Standards: IEEE-344-1975

V. VIBRATION INPUT:

1. Loads considered:
- a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Vibration from normal operation
  - d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

- Absolute Sum
- SRSS
- \_\_\_\_\_ (other, specify)

3. Required Response Spectra \*\* (attach the graphs): Attached

NOTE:

\*If more than one report complete Items IV thru VII for each report.

\*\*If other than RRS is used, describe method.

4. Damping Corresponding to RRS: OBE 2% SSE 2% REF. ATTACH. FIG. FI-1

5. Required Acceleration in Each Direct: 0.175 0.150 0.135  
 O/B 11/16/83 O/B 11/16/83 Att. A, Note 1  
 ZPA  Other PEAK (specify)

OBBA or OBE S/S =  $\frac{.175}{.478}$  F/B =  $\frac{.150}{.398}$  V =  $\frac{.135}{.538}$   
 SSBA or SSE S/S =  $\frac{0.3}{.848}$  F/B =  $\frac{0.3}{.808}$  V =  $\frac{0.25}{.988}$   
 O/B 11/16/83 O/B 11/16/83 O/B 11/16/83  
 REF. ATTACH. FIG. FI-1

6. Were fatigue effects considered:

Yes  No

If yes, describe how they were treated in overall qualification program:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

VI. IF QUALIFICATION BY TEST, THEN COMPLETE:

1.  Single Frequency  Multi-Frequency  random  sine beat  \_\_\_\_\_

2.  Single Axis  Multi-Axis  
 Independent Axis  In-phase motions

3. Number of Qualifications Tests:  
 OBE \_\_\_\_\_ SSE \_\_\_\_\_ Other \_\_\_\_\_ (specify)

4. Frequency Range: \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
 S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies  
 Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test  
 Yes (Attach TRS and RRS graphs)  
 No

8. Maximum Input g Level Test:

OBBA or OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

SSBA or SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

a.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)

Weld (Length \_\_\_\_\_)  \_\_\_\_\_

b. Orientation and Fixturing: \_\_\_\_\_

10. Functional operability verified:

Yes

No

Not Applicable

11. Test Results including modifications made: \_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including results):

13. Failure Modes (If appropriate) \_\_\_\_\_

14. Margins Available:

Input Spectrum

Fragility

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. Method of Analysis:

Static Analysis

Equivalent Static Analysis

Dynamic Analysis:

Time-History

Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = 74 Hz \* F/B = > 74 Hz \* V = > 74 Hz \* | R1

3. Model Type:

3D

2D

1D

Finite Element

Beam

Closed Form Solution

Other \_\_\_\_\_

\* REF. Pg. 3 of TEST REPORT (SUMMARY OF CALCS.) | R1

4.  Computer Codes: NOT AVAILABLE See Attached Program description (Att. B) | R2

Frequency Range and No. of Modes

Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

Absolute Sum

SRSS  
Pg 12 to 16  
of report

Other: N/A (specify) | R2

6. Damping:

OBE 2% SSE 2% Basis for the damping used: PER FIG. FI-1

7. Support Considerations in the model: Bolted to a rigid body

8. Critical Structural Elements:

a. Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
----------------------------	--	----------------	--------------	------------------

SEE ATTACHED SUMMARY OF CALCULATIONS

b. Maximum Critical Deflection

Location: rotor/stator gap

Maximum Allowable Deflection to Assure Functional Operability

\*\* 0.0010 IN.

\*\* 0.004 IN. | R1

9. Failure Modes: deflection of rotor to stator

10. Margins Available:  Input Spectrum  Stress or Deflection

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
1	1/7/1983	JRS	BSK	1/7/83
2	1/11/1983	CTB	J.D.C.	1/11/83
1		1	1	

REVIEWED BY J.R. Adams 1/2/83  
 CHECKED BY J.G. Schovski 12-7-83  
 APPROVED BY R.A. Matthews 12/14/83

\*\* REF. Pg. 17 OF TEST REPORT | R1<sup>5</sup>



Gilbert Associates, Inc.  
Reading, Pennsylvania

CALCULATION

SUBJECT SUPPLEMENTAL NOTES FOR  
SEISMIC AND DYNAMIC QUALIFICATION  
SUMMARY OF EQUIPMENT

IDENTIFIER  
SP-550-00-4

PAGE 1

OF

PAGES 1

REV. 0

1

2

3

MICROFILMED

ORIGINATOR EHB

DATE 11/16/83

## ATTACHMENT A

Note 1 ZPA is used because the lowest motor resonant frequency is 74 Hz. It was also necessary to revise the SSE ZPA values because the motor is mounted on the pump. Copies of the resonant characteristics of the pump/motor assembly, taken from the pump qualification analysis, are included with the RRS curves attached to the motor SART form. Since no OBE data is provided in the pump report, the OBE RRS ZPA values used are those obtained from the floor response OBE curves. (The pumps were purchased by SP-501-4549-00.)

SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

- I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: \_\_\_\_\_
1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_
2. NSSS: GENERAL ELECTRIC BWR: X
3. A/E: GILBERT/COMMONWEALTH Other \_\_\_\_\_

II. COMPONENT NAME: HVAC CONTROL PANEL 01451-P177A & 01451-P177B

1. Scope:  NSSS  BOP  Other
2. Model Number: B-809-076, B-209-081 Quantity: 2
3. Size or Range: SEE LB
4. Vendor: COMSIP
5. If the component is a cabinet or panel, name and model Number of the devices included:  
N/A
6. Physical Description:
- a. Appearance: FREE STANDING INSTRUMENT PANEL
- b. Dimensions: 90" X 36" X 24"
- c. Weight: 1250 LBS FOR 617 LBS = 1360# (1218 IN WEIGHT)
7. Location: Building: CONTROL COMPLEX  
Elevation: 679
8. Field Mounting Conditions  Bolt (No. 8, Size 1/2")  
 Weld (Length \_\_\_\_\_ )  
 \_\_\_\_\_
9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)  
FLOOR MOUNTING
10. a. System in which located: MCC ECT. HVAC AND BATT. RM EXH  
b. Functional Description: DAMPER AND FAN CONTROL PANEL  
c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other \_\_\_\_\_



11. Pertinent Reference Design Specifications for Qualification Requirements:

GAE SP 594

- a. Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

- Yes       No       Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

- Test       Analysis       Combination of Test and Analysis

Qualification Report\*: DYNAMIC AND SEISMIC ANALYSIS OF CONTROL PANEL  
1457-P177A  
 (No., Title and Date): 3-443-00/2680 SDS-APP475-S REV 1

Company that Prepared Report: CETIM

Company that Reviewed Report: GILBERT/COMMONWEALTH

Where Report is filed or available: PERRY NUCLEAR POWER PLANT

Applicable Codes And/Or Standards: IEEE 344, 1975

V. VIBRATION INPUT:

1. Loads considered:
- a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Vibration from normal operation
  - d.  Combination of (a), (b), and (c)

2. Method of Combining RRS: V/A 5-5-84
- Absolute Sum       SRSS       \_\_\_\_\_  
 (other, specify)

3. Required Response Spectra \*\* (attach the graphs): \*
- \* C8 (EL 707' - 8") WERE CONSERVATIVELY USED RATHER THAN C7 (EL 679' - 6")

NOTE:

\*If more than one report complete Items IV thru VII for each report.

\*\*If other than RRS is used, describe method.



8. Maximum Input g Level Test:

OBBA or OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

SSBA or SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

a.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)

Weld (Length \_\_\_\_\_)  \_\_\_\_\_

b. Orientation and Fixturing: \_\_\_\_\_

10. Functional operability verified:

Yes

No

Not Applicable

11. Test Results including modifications made: \_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including results):  
\_\_\_\_\_  
\_\_\_\_\_

13. Failure Modes (If appropriate) \_\_\_\_\_

14. Margins Available:

Input Spectrum

Fragility

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. Method of Analysis:

Static Analysis

Equivalent Static Analysis

P8

Dynamic Analysis:

Time-History

Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

P15

S/S = 735 HZ F/B = 777 HZ V = 777 HZ

3. Model Type:

3D

2D

1D

P8

Finite Element

Beam

Closed Form Solution

Other \_\_\_\_\_

4.  Computer Codes: CASTOR

Frequency Range and No. of Modes 77 HZ, 7 MODES

Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

P21  Absolute Sum  SRSS  Other: \_\_\_\_\_ (specify)

FOR X, Y AND Z COMPONENT

6. Damping:

OBE \* SSE 2% Basis for the damping used: RRS \*\*\*

7. Support Considerations in the model: 8 BOLTS FOR FLOOR MOUNTING

8. Critical Structural Elements:

a. Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
<u>STIFFENERS</u>	<u>SEISMIC</u>	<u>3.9 KSI</u>	<u>3.9 KSI</u>	<u>14.4 KSI</u>

b. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
<u>.00375</u>	<u>**</u>	<u>NOT CRITICAL</u>


9. Failure Modes: STRESS GREATER THAN ALLOWABLE


10. Margins Available:  Input Spectrum  Stress or Deflection

\* <sup>RRS</sup> OBE WAS NOT USED IN THE ANALYSIS, SSE IS MORE SEVERE.  
 \*\* AT THE CONDUIT CONNECTIONS  
 \*\*\* REG. GUIDE 1.61 RECOMMENDS 4% FOR SSE, BUT USING 2% IS CONSERVATIVE

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
/		/	/	
/		/	/	
/		/	/	

REVIEWED BY MAGEID GABALLA 11/15/83  
 CHECKED BY James D. Cahery 11/22/83  
 APPROVED BY NA Patre 15/8/87  
 #AS-72-77





ERRY WILKINSON ENGINEERING  
LAWYERS  
1000 WASHINGTON STREET  
NEW YORK, N. Y.  
10038

F15 C-12


MAXIMUM ACCELERATION  
FLIGHT RESPONSE  
ENVELOPE

EQUIPMENT RESPONSE


10.0  
5.0  
2.0  
1.0  
0.5  
0.25  
0.125

ACCELERATION (G)

FREQUENCY (CPS)



FREQUENCY (cps)





2046

## SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

- I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: \_\_\_\_\_
1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_
2. NSSS: GENERAL ELECTRIC BWR: X
3. A/E: GILBERT/COMMONWEALTH Other \_\_\_\_\_
- II. COMPONENT NAME: Air Handling Units / MPL #s 1 & 2 M39-B004
1. Scope:  NSSS  BOP  Other
2. Model Number: 39BA050 Quantity: 2 Total (see Reference List)
3. Size or Range: 2000 SCFM
4. Vendor: Carrier Air Conditioning Company
5. If the component is a cabinet or panel, name and model Number of the devices included:  
N/A
6. Physical Description:
- a. Appearance: See Attachment # 1'
- b. Dimensions: 11 1/8" dia. fan and see Attachment # 1'
- c. Weight: 705 lbs.
7. Location: Building: Auxiliary (AB-3)  
Elevation: 574'
8. Field Mounting Conditions  Bolt (No. 4, Size 1/2" dia.)  
 Weld (Length \_\_\_\_\_ )  
 \_\_\_\_\_
9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)  
floor mounted
10. a. System in which located: M39 ventilation system.  
b. Functional Description: To supply ventilation air and cooling air.  
c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other All modes of plant operation.

11. Pertinent Reference Design Specifications for Qualification Requirements:

Spec. 646-4549-00, Spec. 750-4549-00  
Spec. 551-4549-00

- a. Seismic Input  
 b. Hydrodynamic Load Input  
 c. Fatigue Considerations  
 d. Service Conditions  
 e. Qualified Life

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

Yes  No  Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

Test  Analysis  Combination of Test and Analysis

Qualification Report\*: No. JHA -76 -73 A

(No., Title and Date): Seismic Analysis of the 39BA050 Model Air Handler, date 12-29-78.

Company that Prepared Report: John Henry Associates, Inc.

Company that Reviewed Report: GILBERT/COMMONWEALTH

Where Report is filed or available: PERRY NUCLEAR POWER PLANT

Applicable Codes And/Or Standards: IEEE-344-75

V. VIBRATION INPUT:

1. Loads considered:
- a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Vibration from normal operation
  - d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

Absolute Sum  SRSS  \_\_\_\_\_  
(other, specify)

3. Required Response Spectra \*\* (attach the graphs): See attached curves. (A1)

NOTE:

\*If more than one report complete Items IV thru VII for each report.

\*\*If other than RRS is used, describe method.

See  
Attachment  
#3'

4. Damping Corresponding to RRS:

OBE 4% SSE 7%

5. Required Acceleration in Each Direct:

ZPA

Other "g" levels from RRS Curves at calculated frequencies.  
(specify)

OBBA or OBE S/S = from A1-4 RRS F/B = from A1-5 RRS V = from A1-6 RRS

SSBA or SSE S/S = from A1-1 RRS F/B = from A1-2 RRS V = from A1-3 RRS

6. Were fatigue effects considered:

Yes

No

If yes, describe how they were treated in overall qualification program:

N/A

VI. IF QUALIFICATION BY TEST, THEN COMPLETE:

1.  Single Frequency

Multi-Frequency

random

sine beat

\_\_\_\_\_

2.  Single Axis

Multi-Axis

Independent Axis

In-phase motions

3. Number of Qualifications Tests:

OBE \_\_\_\_\_ SSE \_\_\_\_\_ Other \_\_\_\_\_  
(specify)

4. Frequency Range: \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies

Lab Test

In-Situ Test

Analysis

7. TRS enveloping RRS using Multi-Frequency Test

Yes (Attach TRS and RRS graphs)

No

8. Maximum Input g Level Test:

OBBA or OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

SSBA or SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

a.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)

Weld (Length \_\_\_\_\_)  \_\_\_\_\_

b. Orientation and Fixturing: \_\_\_\_\_

10. Functional operability verified:

Yes

No

Not Applicable

11. Test results including modifications made: \_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including results):  
\_\_\_\_\_  
\_\_\_\_\_

13. Failure Modes (if appropriate) \_\_\_\_\_

14. Margins Available:

Input Spectrum

Fragility

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. Method of Analysis:

Static Analysis

Equivalent Static Analysis

Dynamic Analysis:

Time-History

Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = 28.8 Hz F/B = 14.6 Hz V = 6.1 Hz

3. Model Type:

3D

2D

1D

Finite Element

Beam

Closed Form Solution

Other \_\_\_\_\_

4.  Computer Codes: CDC 6600 computer code, Stardyne.  
 Frequency Range and No. of Modes 6.1 to 68.2 Hz, 8 modes.

Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

Absolute Sum       SRSS       Other: \_\_\_\_\_  
 (specify)

6. Damping:

OBE 4% SSE 7% Basis for the damping used: R.G. 1.61

7. Support Considerations in the model: Rigidly Mounted

8. Critical Structural Elements:

a. Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
<u>See Attachment 2a-b</u>				

b. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
<u>0.0034"</u>	<u>Between Jam Wheel (ID) &amp; Cone (OD)</u>	<u>0.25"</u>

9. Failure Modes: Membrane plus bending

10. Margins Available:       Input Spectrum       Stress or Deflection

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
/		/	/	
/		/	/	
/		/	/	

REVIEWED BY T.N. Rockwell 16-23-83  
 CHECKED BY V.D. Coherly 17-1-83  
 APPROVED BY [Signature] 13/1/84  
 2-29-84

# ATTACHMENT # 1


THE CLEVELAND ELECTRIC ILLUMINATING CO.	MADE JW	CHK'D RGL	GILBERT ASSOCIATES, INC.		
PERRY NUCLEAR POWER PLANT	DR. APP. JRG	ENG. APP. OTA	ENGINEERS AND CONSULTANTS READING, PA.		
BUILDING SERVICE	DATE	3-22-74	04 4549	S-915-027	A
RCIC PP. RM. COOLING AIR HANDLING UNIT	W.O.	044549-000	DRAWING NUMBER		REV.
IM39-B004	REV. CH. APP. DATE	SCALE: 1/4" = 1'-0"			

FOR REFERENCE ONLY.

- ← COIL PULL DIRECTION
  - ← DENOTES AIR FLOW
- IM39-B004

*Assembly Weight = 705#<sup>†</sup>*

*Gen H.L. = 90°*



<sup>†</sup> Reference Specification SP 646-4549-00 Bill of Materials

CONSTRUCTION BIDDING PURPOSES	ENGR.
RELEASED FOR	OTA
DATE	7-1-74

SECTION 2.0

ATTACHMENT 2a

SUMMARY OF RESULTS

LOWEST NATURAL FREQUENCIES (CPS)

FREQ.	DIRECTION	LOCATION	REF.
6.1	G3 V	NODE 149, FIG. 15	APP. C
14.6	G2 BP	NODE 151, FIG. 15	↓
17.8	G3 V	NODE 7, FIG. 3	↓
28.8	G1 SS	NODE 138, FIG. 15	↓

BEAM STRESSES (PSI)

BEAM	LOCATION	$\sigma_{M+B}$	ALLOW.	REF.
81	CS, FIG. 6	10491	18000	P. 62
		$\sigma_v$		
13	FLTS, FIG. 3	1481	15000	P. 62

PLATE STRESSES (PSI)

PLATE	LOCATION	$\sigma_{M+B}$	ALLOW.	REF.
36	FS, FIG. 14	7193	27000	P. 64
		$\sigma_v$		
36	FS, FIG. 14	5413	15000	P. 64

ANCHOR BOLT LOADS (LBS, IN-LBS)

LOCATION	TENSILE	SHEAR	TORQUE	REF.
FIG. 17	2262	1528	249	P. 69



ATTACHMENT 26

SUBSECTION NF ANALYSIS SUMMARY

The results of the Subsection NF Analysis are summarized below. These results indicate that the support structure for the OSO size RCIC Pump Room Air Handling Unit satisfies the requirements of Subsection NF of the ASME Boiler and Pressure Vessel Code (Ref. 7) when subjected to the loadings of the design specification (Ref. 1)

ITEM	STRESS (PSI)	LIMIT (PSI)	REF. PAGE
Maximum Plate Stress	7193	18,500	79
Max. Beam Axial Stress	1655	16,200	87
Max. Beam Shear Stress	222	12,000	87
Max. Beam Bending Stress	5075	18,000	88
Max. Bolt Stress	22,500	25,800	91
Max. Weld Throat Stress	8,416	9,000	90
Max. Weld Contact Stress	11,900	24,000	90



### Attachment #3'

The air handling units are rigidly mounted to the floor at elevation 574'-10". The difference in the analysis of this air handling unit (39BA050) as compared to that of units 39ED15 and 39ED18 is that this unit, 39BA050, has natural frequencies below 33 Hz thus requiring a dynamic analysis to be used.

RRS A1 Curves were used as the seismic input for the analysis since the base of the six foot high concrete platform is anchored to the floor at 568'-6" elevation.

Damping factors of 4% and 7% for OBE and SSE, respectively, were used since the air handling unit is basically a bolted structure consisting of beams, angle iron and plates.

SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

- I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: \_\_\_\_\_
1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_
2. NSSS: GENERAL ELECTRIC BWR: X
3. A/E: GILBERT/COMMONWEALTH Other \_\_\_\_\_

II. COMPONENT NAME: Horizontal A.C. Motor / MPL # 142 M39-B004

1. Scope:  NSSS  BOP  Other
2. Model Number: Frame 184T Quantity: 2 Total
3. Size or Range: 5 HP
4. Vendor: Reliance Electric
5. If the component is a cabinet or panel, name and model Number of the devices included:  
N/A

6. Physical Description:
- a. Appearance: See Attachment # 1"
- b. Dimensions: " " # 1"
- c. Weight: 85 #

7. Location: Building: Auxiliary Building (A/B-3)  
Elevation: 574'-10"

8. Field Mounting Conditions  Bolt (No. 4, Size 3/8" dia.)  
 Weld (Length \_\_\_\_\_ )  
 \_\_\_\_\_

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)  
Line mounted to the air handling unit

10. a. System in which located: M-39 cooling system
- b. Functional Description: Motor to run cooling system fan
- c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other All modes of plant operation.

II. Pertinent Reference Design Specifications for Qualification Requirements:

Spec. 646-454900 ; Spec. 750-4549-00  
Spec. 551-4549-00

- a. Seismic Input  
 b. Hydrodynamic Load Input  
 c. Fatigue Considerations  
 d. Service Conditions  
 e. Qualified Life

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

- Yes  No  Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

- Test  Analysis  Combination of Test and Analysis

Qualification Report\*: # 77-A-34  
(No., Title and Date): Summary Report - Seismic Analysis, Date 6-29-77  
Company that Prepared Report: Reliance Electric  
Company that Reviewed Report: GILBERT/COMMONWEALTH  
Where Report is filed or available: PERRY NUCLEAR POWER PLANT  
Applicable Codes And/Or Standards: IEEE - 344-1975

V. VIBRATION INPUT:

1. Loads considered: a.  Seismic only  
b.  Hydrodynamic only  
c.  Vibration from normal operation  
d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

- Absolute Sum  SRSS  \_\_\_\_\_  
(other, specify)

3. Required Response Spectra \*\* (attach the graphs): See Attached Curves (A2)

NOTE:

\*If more than one report, complete Items IV thru VII for each report.

\*\*If other than RRS is used, describe method.

4. Damping Corresponding to RRS: OBE 1% SSE 1%

5. Required Acceleration in Each Direct:  
 ZPA  Other acceleration at 14.6, 28.8, and 6.1 Hz (see ATTACH #3 and p 3-6 of C in Section 4)  
(specify)

OBBA or OBE S/S = 0.80 g's F/B = 0.52 g's V = 1.05 g's

SSBA or SSE S/S = 0.80 g's F/B = 0.52 g's V = 1.05 g's

6. Were fatigue effects considered:  
 Yes  No

If yes, describe how they were treated in overall qualification program: \_\_\_\_\_

N/A

VI. IF QUALIFICATION BY TEST, THEN COMPLETE:

1.  Single Frequency  Multi-Frequency  random  sine wave  \_\_\_\_\_

2.  Single Axis  Multi-Axis  
 Independent Axis  In-phase motions

3. Number of Qualifications Tests:  
OBE \_\_\_\_\_ SSE \_\_\_\_\_ Other \_\_\_\_\_  
(specify)

4. Frequency Range: \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies  
 Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test  
 Yes (Attach TRS and RRS graphs)  
 No

8. Maximum Input g Level Test:

OBBA or OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

SSBA or SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

a.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)

Weld (Length \_\_\_\_\_)  \_\_\_\_\_

b. Orientation and Fixturing: \_\_\_\_\_

10. Functional operability verified:

Yes  No  No+ Applicable

11. Test Results including modifications made: \_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including results):  
\_\_\_\_\_  
\_\_\_\_\_

13. Failure Modes (If appropriate) \_\_\_\_\_

14. Margins Available:  Input Spectrum  Fragility

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. Method of Analysis:

Static Analysis  Equivalent Static Analysis

Dynamic Analysis:  Time-History  Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = > 33 Hz F/B = > 33 Hz V = > 33 Hz

3. Model Type:

3D  2D  1D

Finite Element  Beam

Closed Form Solution  Other \_\_\_\_\_

4.  Computer Codes: N/A (PROPRIETARY)

Frequency Range and No. of Modes

Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

Absolute Sum       SRSS       Other: N/A (SEISMIC ONLY)  
(specify)

6. Damping:

OBE 1%      SSE 1%      Basis for the damping used: R.G. 1.61

7. Support Considerations in the model: BOLTED TO A RIGID BODY AHU w/  $f_n = 28.8, 14.6, \text{ and } 6.1$  BH 2.25.84

8. Critical Structural Elements:

a. Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
----------------------------	--	----------------	--------------	------------------

*(Attachment # 2<sup>nd</sup> a-e)*  
SEE ATTACHED computer sheets & Supporting Calculation (Sec. IV of AFP).

b. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
--------------------------------	----------	---

0.0038 in      rotor/stator air-gap      0.0094 in

9. Failure Modes: deflection of rotor relative to stator gap


10. Margins Available:       Input Spectrum       Stress or Deflection

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
/		/	/	
/		/	/	
/		/	/	

REVIEWED BY J.R. Dolino      1/6/24/83  
 CHECKED BY J.D. Caslerly      1/7/01/83  
 APPROVED BY PTJ 2-29-84 J.P. Matheny      1/31/84

## DUTY MASTER ALTERNATING CURRENT MOTORS SQUIRREL-CAGE INDUCTION

ENCLOSURE: TOTALLY ENCLOSED      COOLING: FAN COOLED  
ONE SIZE LARGER CAST IRON CONDUIT BOX  
MOUNTING: FOOT  
FRAMES 140T THRU 440T



3/8" - 16 GROUND SCREW HOLE

DIMENSIONS ARE IN INCHES

FRAME	A	D (2)	E	G	H	J	Q	P	AA	AB	AC	AF	BA	AE	K	T
182T - 184T	9.00	4.50	3.75	.44	.44	1.75	9.19	9.30	1	6.44	6.44	2.50	2.75	4.50	1.08	2.00
213T - 215T	10.50	5.25	4.75	.44	.44	2.00	10.69	10.69	1 1/4	10.15	7.75	3.00	3.50	5.25	1.08	2.00
254T - 256T	12.50	6.25	5.00	.50	.50	2.50	12.75	13.00	1 1/2	11.12	8.69	3.00	4.25	5.25	2.62	2.00
324T - 326T	13.75	7.00	5.50	.50	.50	2.50	14.25	14.50	2	12.69	9.54	3.62	4.75	7.00	2.75	2.50
324T - 326T	15.75	8.00	6.25	.62	.60	2.75	16.25	16.50	3	16.00	11.81	4.12	5.25	8.00	3.12	2.75
364T - 366T	17.00	9.00	7.00	.65	.65	2.75	18.50	19.00	4	17.14	13.75	4.12	5.88	9.00	4.00	2.94
424T - 426T	19.00	10.00	8.00	1.12	.91	3.25	21.31	21.75	4	19.78	15.00	4.12	6.62	10.00	3.25	2.94
440T - 442T	21.00	11.00	9.00	1.12	.91	3.25	23.62	25.00	4	23.38	18.12	7.00	7.50	11.00	3.25	3.25

(1)

FRAME	TYPE	C	B (3)	B	2F	BACK END SHAFT AND KEYWAY					SQ	FRONT END SHAFT AND KEYWAY					SQ	WEIGHT
						N	NW	U (3)	V	ES (MM)		KEY	FN	FN-FW	FU (3)	FV		
182T		34.56	2.25	6.00	4.50	2.94	2.75	1.1250	2.50	1.78	.25	3.10	2.25	8.750	2.00	1.41	19	65
213T		35.56	2.75	7.00	5.50	2.94	2.75	1.1250	2.50	1.78	.25	3.19	2.25	8.750	2.00	1.41	19	65
254T		37.25	2.75	7.00	5.50	3.55	3.38	1.3750	3.12	2.41	.31	3.75	2.75	1.1250	2.50	1.78	25	130
254T		39.25	3.50	7.50	7.00	3.55	3.38	1.3750	3.12	2.41	.31	3.75	2.75	1.1250	2.50	1.78	25	130
324T		42.75	4.12	10.25	8.25	4.25	4.00	1.625	3.75	2.91	.38	4.62	3.38	1.3750	3.12	2.41	31	230
324T		44.50	7.00	12.00	10.00	4.25	4.00	1.625	3.75	2.91	.38	4.62	3.38	1.3750	3.12	2.41	31	230
364T		45.94	4.75	11.50	9.50	4.88	4.62	1.875	4.38	3.28	.50	5.50	4.00	1.625	3.75	2.91	38	252
364T		47.20	4.75	11.50	9.50	3.50	3.25	1.625	3.00	1.91	.38	4.75	3.25	1.625	3.00	1.91	38	278
364T		47.14	5.50	13.00	11.00	4.08	4.62	1.875	4.38	3.28	.50	5.50	4.00	1.625	3.75	2.91	38	330
364T		49.00	5.50	13.00	11.00	3.50	3.25	1.625	3.00	1.91	.38	4.75	3.25	1.625	3.00	1.91	38	330
364T		49.04	5.25	13.25	10.50	5.50	5.25	2.125	5.00	3.91	.50	6.12	4.62	1.875	4.38	3.28	50	450
364T		47.14	7.25	13.25	10.50	4.00	3.75	1.875	3.50	2.03	.50	5.25	3.75	1.875	3.50	2.03	50	450
364T		48.62	6.00	14.75	12.00	5.50	5.25	2.125	5.00	3.91	.50	6.12	4.62	1.875	4.38	3.28	50	450
364T		48.04	6.00	14.75	12.00	4.00	3.75	1.875	3.50	2.03	.50	5.25	3.75	1.875	3.50	2.03	50	450
404T		51.44	6.12	15.25	11.25	6.12	5.88	2.375	5.62	4.28	.62	6.00	5.62	1.875	4.38	3.28	60	600
404T		51.31	6.12	15.25	11.25	4.00	3.75	1.875	3.50	2.03	.50	5.62	3.75	1.875	3.50	2.03	60	642
404T		53.44	6.12	15.25	12.25	6.12	5.88	2.375	5.62	4.28	.62	6.50	4.62	1.875	4.38	3.28	60	700
404T		51.31	6.12	15.25	12.25	4.00	3.75	1.875	3.50	2.03	.50	5.62	3.75	1.875	3.50	2.03	60	642
440T		56.02	6.12	14.50	12.25	7.82	7.25	2.875	7.00	5.65	.75	8.00	5.25	2.125	5.00	3.91	70	935
440T		53.81	6.12	14.50	12.25	4.62	4.25	2.125	4.00	2.78	.50	6.00	4.25	2.125	4.00	2.78	70	915
480T		58.31	6.68	16.00	13.75	7.62	7.25	2.875	7.00	5.65	.75	8.00	5.25	2.125	5.00	3.91	80	1100
480T		55.31	6.68	16.00	13.75	4.62	4.25	2.125	4.00	2.78	.50	7.00	4.25	2.125	4.00	2.78	80	1100
480T		52.62	7.25	17.00	14.50	8.34	8.50	3.375	8.25	6.91	.88	8.88	5.88	2.375	5.62	4.78	90	1350
480T		58.88	7.25	17.00	14.50	6.19	4.75	2.375	4.50	3.03	.62	7.75	4.75	2.375	4.50	3.03	90	1350
480T		44.62	8.25	19.00	16.00	8.94	8.50	3.375	8.25	6.91	.88	8.88	5.88	2.375	5.62	4.78	100	1500
480T		40.88	8.25	19.00	16.00	5.19	4.75	2.375	4.50	3.03	.62	7.75	4.75	2.375	4.50	3.03	100	1500

(1)

- (1) SPECIAL DIMENSIONS ON THIS LINE.
- (2) "D" VARIES +.00, -.03.
- (3) "U" & "FU" VARY UP TO 1.625 DIA. +.0000, -.0005.  
1.625 AND LARGER +.000, -.001.
- (4) CENTERLINE OF FOOT MOUNTING HOLE TO CENTERLINE OF TERMINAL HOUSING.

CONDUIT BOX LOCATED ON OPPOSITE SIDE WHEN F2, W1, W4, W5, W7 OR C1 MOUNTING IS SPECIFIED.

STANDARD DOUBLE SHAFT SUPPLIED ONLY WHEN SPECIFIED  
IF MOUNTING CLEARANCE DETAILS ARE REQUIRED, CONSULT FACTORY.

MAXIMUM PERMISSIBLE SHAFT RUNOUT WHEN MEASURED AT END OF STD. SHAFT EXTENSION IS .002 T.I.R. UP TO AND INCLUDING 1.625 DIA. AND .003 T.I.R. 1.625 TO 5 INCH DIA.

FRAME \_\_\_\_\_ TYPE \_\_\_\_\_ CERTIFIED FOR \_\_\_\_\_  
 ORDER \_\_\_\_\_ ITEM \_\_\_\_\_ HP \_\_\_\_\_ RPM \_\_\_\_\_ PH \_\_\_\_\_ HZ \_\_\_\_\_ VOLTS \_\_\_\_\_  
 RELIANCE SALES ORDER \_\_\_\_\_ APPROVED BY \_\_\_\_\_ DATE \_\_\_\_\_

**RELIANCE**  
ELECTRIC COMPANY  
CLEVELAND, OHIO 44117 U.S.A.

DIMENSION SHEET  
APRIL 27, 1976

602531-682


Attachment # 3<sup>'''</sup>

Three motors are mounted to the air handling units (142 M39-B004) that were analyzed to have natural frequencies below 33 Hz in the motor hold down brackets. The analysis in the Seismic Qualification Report (#77-A-34), assumed that the motors would be rigidly mounted and used a 0.3 g ZPA at 1% damping. Since the motors are rigidly attached to the brackets, the 0.3 g input had to be increased to the "g" level at the corresponding bracket natural frequency for the input to the motors. Also, to add more conservatism to the analysis, the RRS curves (A2) of the floor above 574'-10", elevation 599'-0", were used. This analysis is shown in Tab 4 of the AFP under "Supporting Calculations". The results of the analysis showed that there is still ample stress and deflection margin to qualify the equipment.

SEE p. 3, 4, 5 & 6 of G

RH. 2-28-84








PERCY NUCLEAR POWER PLANT  
 UNIT 1 & 2  
 BOILING REACTOR  
 FOUR REACTOR SPECIES  
 MAX. GRAVIMETER READING  
 EAST-MEAST  
 ELEVATION 599.50"


FIG. A2-1

NARROW BANDWIDTH  
 FLUOR RESINITE  
 ENVELOPE










8-15-79 REV. 0



PERRY NUCLEAR POWER PLANT  
 UNIT 1 & 2  
 AUXILIARY BLDG.  
 FLOOR RETRACTION TESTING  
 W/4000 LB. WEIGHT  
 VERTICAL DIRECTION  
 ELECTROD. 52210  
 FIG. A2-6

NARROW BANDWIDTH  
 FLOOR RETRACTION  
 ENVELOPE

SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

MPL # IMSI 5001  
IMSI 5002

- I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: \_\_\_\_\_
1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_
2. NSSS: GENERAL ELECTRIC BWR: X
3. A/E: GILBERT/COMMONWEALTH Other \_\_\_\_\_

II. COMPONENT NAME: POWER SUPPLY PANEL

1. Scope:  NSSS  BOP  Other
2. Model Number: N/A Quantity: 2
3. Size or Range: 75 kW (MAX. POWER)
4. Vendor: WESTINGHOUSE

5. If the component is a cabinet or panel, name and model Number of the devices included:  
WESTINGHOUSE DT-3 ISOLATION TRANSFORMER, CHR SCR PANEL W/INSTR. NO. 5201

6. Physical Description:  
WESTINGHOUSE AUXILIARY TRANSFORMER NO. 1F0991, WESTINGHOUSE MAGNETIC CONTROLLER TYPE A201

- a. Appearance: STANDARD AMCO INSTRUMENT RACK
- b. Dimensions: LENGTH 61" WIDTH 34 5/16" DEPTH 23 1/2"
- c. Weight: 950 lbs

7. Location: Building: CONTROL BUILDING  
Elevation: 620' - 6"

8. Field Mounting Conditions  Bolt (No. 8, Size 3/4")  
 Weld (Length \_\_\_\_\_ )  
 \_\_\_\_\_

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)  
FLOOR

10. a. System in which located: COMBUSTIBLE GAS CONTROL

b. Functional Description: SUPPLIES POWER TO HYDROGEN RECOMBINER

- c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other POST LOCA

p1-9  
HYDROGEN  
RECOMBINER  
TECHNICAL  
MANUAL  
p1-11/1-12  
HYDROGEN  
RECOMBINER  
TECHNICAL  
MANUAL  
GAS DIV.  
E-001-033

II. Pertinent Reference Design Specifications for Qualification Requirements:

SP-750-4549-00 SP-628-4549-00

- a) Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d) Service Conditions
- e.) Qualified Life

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

- Yes
- No
- Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

- Test
- Analysis
- Combination of Test and Analysis

Qualification Report\*: ELECTRIC HYDROGEN RECOMBINER

(No., Title and Date): WCAP 77096 AND SUPPLEMENTS 1-7

Company that Prepared Report: WESTINGHOUSE

Company that Reviewed Report: GILBERT/COMMONWEALTH

Where Report is filed or available: PERRY NUCLEAR POWER PLANT

Applicable Codes And/Or Standards: IEEE 323-1974 IEEE 344-1975

V. VIBRATION INPUT:

1. Loads considered:
  - a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Vibration from normal operation
  - d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

- Absolute Sum
- SRSS
- \_\_\_\_\_  
(other, specify)

3. Required Response Spectra \*\* (attach the graphs): ATTACHED

NOTE:

\*If more than one report complete Items IV thru VII for each report.

\*\*If other than RRS is used, describe method.



4. Damping Corresponding to RRS: OBE 2% SSE 2%

5. Required Acceleration in Each Direct:

ZPA  Other MAX. G  
(specify)

OBBA or (OBE) S/S = 2.5 F/B = 2.55 V = 0.85  
SSBA or (SSE) S/S = 2.8 3.4 F/B = 2.7 3.2 V = HT 1.3

SEE ATTACHED RRS CURVES

6. Were fatigue effects considered:

Yes  No

If yes, describe how they were treated in overall qualification program: N/A

VI. IF QUALIFICATION BY TEST, THEN COMPLETE:

1.  Single Frequency  Multi-Frequency  random  
 sine beat  \_\_\_\_\_

2.  Single Axis  Multi-Axis  
 Independent Axis  In-phase motions

P 3 WCAP 7709L SUPPLEMENT 7

3. Number of Qualifications Tests:

OBE 5 SSE 0 Other \_\_\_\_\_

BIAXIAL SINE BEAT PERFORMED AT EACH RESONANCE FREQUENCY AND AT THE FOLLOWING FREQUENCIES 1.25, 1.75, 2.5, 3.5, 5, 7, 9.5, 13, 18, 24.5, AND 33.5 Hz EACH SINE (specify) BEAT CONSISTED OF FIVE DRAWS EACH CONTAINING TEN CYCLES.

4. Frequency Range: 1.25 - 35 Hz

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): between 1.25 - 35 Hz

S/S = NONE F/B = 3.5 & 12.0 V = NONE

6. Method of Determining Natural Frequencies

Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test

Yes (Attach TRS and RRS graphs)

No

P 4 WCAP 7709L SUPPLEMENT 7

SEE ATTACHMENT A P 3 WCAP 7709L SUPPLEMENT 7

P 3 WCAP 7709L SUPPLEMENT 7

8. Maximum Input g Level Test:

OBBA or OBE S/S = 8.0 F/B = 8.0 V = 5.3  
SSBA or SSE S/S = 8.0 F/B = 8.0 V = 5.3

SEE ATTACHED TRS CURVE

9. Laboratory Mounting:

a.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_ )  
 Weld (Length \_\_\_\_\_ )  8-1/2" SOCKET HEAD CAP SCREWS

SEE NO. 9, 82 TELECON IN SECTION 6

b. Orientation and Fixturing: MOUNTED ON DRIVE PLATE OF THE VIBRATION TABLE

p3 UCAP-7709 SUPPLEMENT

10. Functional operability verified:

Yes  No  Not Applicable

11. Test Results including modifications made: EACH TEST SHOWED THE EQUIPMENT TO BE IN OPERATING CONDITION

p3 UCAP-7709 SUPPLEMENT

12. Other tests performed (such as aging or fragility test, including results):

THERMAL AGING

13. Failure Modes (if appropriate) N/A

14. Margins Available:  Input Spectrum  Fragility

SEE ATTACHED TRS AND RRS CURVES

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. Method of Analysis:

Static Analysis  Equivalent Static Analysis  
 Dynamic Analysis  Time-History  Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

3. Model Type:

3D  2D  1D  
 Finite Element  Beam  
 Closed Form Solution  Other \_\_\_\_\_

4.  Computer Codes: \_\_\_\_\_

Frequency Range and No. of Modes

Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

Absolute Sum       SRSS       Other: \_\_\_\_\_  
(specify)

6. Damping:

OBE \_\_\_\_\_ SSE \_\_\_\_\_ Basis for the damping used: \_\_\_\_\_

7. Support Considerations in the model: \_\_\_\_\_

8. Critical Structural Elements:

a.	Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable

b.	Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability

9. Failure Modes: \_\_\_\_\_

10. Margins Available:       Input Spectrum       Stress or Deflection

REV.NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
/	/	/	/	/
/	/	/	/	/
/	/	/	/	/

Sp 628  
 REVIEWED BY *[Signature]* 11-12-82  
 CHECKED BY *B. J. Zakowski* 11-23-82  
 APPROVED BY *[Signature]* 12/5/83



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT TESTING PERFORMED IN  
CONTROL PANEL AND POWER SUPPLY

CISID

SQRT 628-3

PAGE

1

OF

REV.

0

1

2

3

MICROFILMED

PAGES

1

ORIGINATOR J S S.M.H.

DATE 7-14-83

ATTACHMENT A

## Explanation of Testing Performed

The power supply and control panel which had previously undergone single-axis sine beat testing while in the nonenergized mode, (reported in WCAP 7709-L Supplement 2), was subjected to an additional test series consisting of a resonance frequency search plus five OBE's followed by an SSE. The input for the five OBE's was a biaxial, random frequency while the SSE was a biaxial, sine beat input.

While a sine beat input is not preferable for supporting qualification it should be noted the TRS for the OBE envelopes the SSE TRS. As a result the SQRT forms have been filled out with the sine beat SSE described under "other" (page 3 item 3), and a zero entered under SSE.

GAI believes the five OBE tests, which envelope the SSE requirements, plus the sine beat tests performed under WCAP 7709L Supplement 2, 7 provide adequate evidence of qualification.



Gilbert Associates, Inc.

Reading, Pennsylvania

CALCULATION

SUBJECT *IN-TEST MODIFICATIONS*

CISID

*SQRT 628-3*

PAGE

OF

REV.

*0*

*1*

*2*

*3*

MICROFILMED

PAGES *1*

ORIGINATOR *J S Smith*

DATE *7-14-83*

### ATTACHMENT B

#### IN-TEST MODIFICATIONS

WEAP 7709L SUPPLEMENT 7

SEISMIC TESTS OF POWER SUPPLY AND  
CONTROL PANEL TO IEEE 344-1975


The sine beat test was run four times. (Once for each equipment mounting direction) without component failure. It was necessary to add one wiring harness strap and to modify the temperature indicator mounting bracket early in the sine beat test, however, a total of four consecutive test were run with the equipment in its final configuration.

GAI contacted W to ensure that the above modifications had been incorporated into the control panel and power supply supplied to CEI. W confirmed that the modifications were made.

LOGSHEET 01-200-00  
MADE IN U. S. A.

NO. 340-0310 DRETZGEN GRAPH PAPER  
SEMI-LOGARITHMIC  
3 CYCLES X 10 DIVISIONS PER INCH

507618-3



PERRY NUCLEAR POWER PLANT  
UNIT 1-2  
MAIN BLDG.  
FLOOR RESPONSE CURVE  
MAX. GROUND ACCEL. 0.050 15%  
EAST-WEST  
ELEVATION 620'-6"  
FIG. A3-1

--- NARROW BANDWIDTH  
— FLOOR RESPONSE  
— ENVELOPE

EQUIPMENT  
DAMPING

0.01  
0.02  
0.04  
0.07

0-15179 REV.0


FREQUENCY (cps)

ACCELERATIONS (g)

MADE IN U. S. A.

NO. 340-100-0000-0000-0000  
SEMI-LOGARITHMIC  
3 CYCLES X 10 DIVISIONS PER INCH

SOFT COPY 3




8-15-79 REV. 0

8-15-79 REV. 0


FREQUENCY (Hz)

30 20 10 5 3 2 1 0

SOFT COPY'S



--- NARROW BANDWIDTH  
 = FLOOR RESPONSE  
 - - - ENVELOPE




Units 1 & 2  
 Auxiliary Bldg.  
 Floor Response Spectra  
 Max Ground Accel. See 0.1505  
 Vertical Direction  
 Section 620-5  
 FIG. A3-3



MADE IN U. S. A.

3 CYCLES X 10 DIVISIONS PER INCH

SEMI-LOGARITHMIC



CERRY NUCLEAR POWER PLANT  
 UNITS 1 & 2  
 AUXILIARY BLDG  
 FLOOR REINFORCEMENT  
 MAX. GROUND ACCEL. OBSERVED

EAST-WEST  
 ELEVATION 620'-6"  
 FIG. A3-4

--- NARROW BANDWIDTH  
 --- FLOOR RESPONSE  
 --- ENVELOPE

EQUIPMENT  
 RESPONSE

0.01  
 0.02  
 0.04  
 0.07  
 0.10  
 0.20  
 0.50  
 1.00


ACCELERATIONS (g)


FREQUENCY (CPS)

PERRY NUCLEAR POWER PLANT  
 UNIT 1-2  
 AUXILIARY BLDG.  
 FLOOR REPAIRS DEPT.  
 MAIN GROUND REEL-OPERATING  
 NORTH SOUTH  
 ELEVATION 620'-8"

FIG. A3-5

--- NARROW BANDWIDTH  
 --- FLOOR RESPONSE  
 --- ENVELOPE





SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

MPL# 0C4IN0415A

0C4IN0415B

- I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: \_\_\_\_\_
1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_
2. NSSS: GENERAL ELECTRIC BWR: X
3. A/E: GILBERT/COMMONWEALTH Other \_\_\_\_\_

II. COMPONENT NAME: LEVEL SWITCH

1. Scope:  NSSS  BOP  Other
2. Model Number: 580A-1 Quantity: 2
3. Size or Range: 0-30" H<sub>2</sub>O
4. Vendor: ITT BARTON
5. If the component is a cabinet or panel, name and model Number of the devices included:  
N/A
6. Physical Description:
- a. Appearance: SEE ATTACHMENT
- b. Dimensions: 7" x 6"
- c. Weight: 17 lbs
7. Location: Building: INT. BLOC  
Elevation: 620'
8. Field Mounting Conditions  Bolt (No. 4, Size 5/16" φ)  
 Weld (Length \_\_\_\_\_ )  
 \_\_\_\_\_
9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)  
MOUNTED ON POST ATTACHED TO FLOOR
10. a. System in which located: STANDBY LIQUID CONTROL  
b. Functional Description: SURGE TANK PUMP INTERLOCK INDICATING INSTRUMENT  
AUX MIXING TANK LEVEL INDICATOR  
c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other PART-LOCA

11. Pertinent Reference Design Specifications for Qualification Requirements:

SP-598

- a. Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

- Yes
- No
- Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

- Test
- Analysis
- Combination of Test and Analysis

Qualification Report\*: ITT BARTON QUALIFICATION REPORT No. R3-580A-9 #  
 (No., Title and Date): VOLS 1, 2, 3, & 4 DATED 12/23/83 99Q-683-2-0 (TAG C)  
AS SUPPLEMENT

Company that Prepared Report: ITT BARTON

Company that Reviewed Report: GILBERT/COMMONWEALTH

Where Report is filed or available: PERRY NUCLEAR POWER PLANT

Applicable Codes And/Or Standards: IEEE 344-1975

V. VIBRATION INPUT:

1. Loads considered:
- a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Vibration from normal operation
  - d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

- Absolute Sum
- SRSS
- \_\_\_\_\_  
(other, specify)

3. Required Response Spectra \*\* (attach the graphs): IB 4 (-1 THRU -C)

NOTE:

\*If more than one report complete Items IV thru VII for each report.

\*\*If other than RRS is used, describe method.

4. Damping Corresponding to RRS: OBE 2% SSE 2%

5. Required Acceleration in Each Direct:  
 ZPA  Other Peak  
(specify)

OBBA or OBE S/S = 1.08g F/B = 2.0g V = 2.0g  
SSBA or SSE S/S = 1.75g F/B = 2.64g V = 3.25g

6. Were fatigue effects considered:  
 Yes  No

If yes, describe how they were treated in overall qualification program:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

VI. IF QUALIFICATION BY TEST, THEN COMPLETE: (DETAILS ON R3-SB0A-9 p. IV-113 to end of Vol 2)

1.  Single Frequency  Multi-Frequency  random  
 sine beat  
 \_\_\_\_\_

2.  Single Axis  Multi-Axis  
 Independent Axis  In-phase motions

3. Number of Qualifications Tests:  
OBE 5 SSE 1 Other \_\_\_\_\_  
(specify)

4. Frequency Range: 1-100Hz Appx IV Section B p 6

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): NOT MONITORED  
S/S = — F/B = — V = —

Method of Determining Natural Frequencies N/A  
 Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test  
 Yes (Attach TRS and RRS graphs)  
 No

8. Maximum Input g Level Test: FIG. 10.37 FIG. 10.25 FIG. 10.26  
 OBBA or OBE S/S = 9.38 F/B = 9.89 V = 10.88  
 SSBA or SSE S/S = 9.11 F/B = 9.11 V = 11.88  
FIG. 10.47 FIG. 10.35 FIG. 10.36

9. Laboratory Mounting:

- a.  Bolt (No. 4, Size 5/16) SEC. 4 OF THE PACKAGE  
 Weld (Length \_\_\_\_\_)  \_\_\_\_\_

b. Orientation and Fixturing: SEE ATTACHED PHOTO

10. Functional operability verified:

- Yes  No  Not Applicable

P-15 R3-SPOA-9  
page IV-133

11. Test Results including modifications made: N/A

DN 7.13.84

12. Other tests performed (such as aging or fragility test, including results):

AGING, RADIATION AND LOCA TEST

13. Failure Modes (If appropriate) FAILURE TO FUNCTION

14. Margins Available:  Input Spectrum  Fragility

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. Method of Analysis:

- Static Analysis  Equivalent Static Analysis  
 Dynamic Analysis:  Time-History  Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ r/B = \_\_\_\_\_ V = \_\_\_\_\_

3. Model Type:

- 3D  2D  1D  
 Finite Element  Beam  
 Closed Form Solution  Other \_\_\_\_\_

4.  Computer Codes: \_\_\_\_\_

Frequency Range and No. of Modes

Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

Absolute Sum

SRSS

Other: \_\_\_\_\_

(specify)

6. Damping:

OBE \_\_\_\_\_ SSE \_\_\_\_\_ Basis for the damping used: \_\_\_\_\_

7. Support Considerations in the model: \_\_\_\_\_

8. Critical Structural Elements:

a.	Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable

b.	Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability

9. Failure Modes: \_\_\_\_\_

10. Margins Available:

Input Spectrum

Stress or Deflection

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
/	/	/	/	/
/	/	/	/	/
/	/	/	/	/

REVIEWED BY M. GABALLA 14-24-84

CHECKED BY J. D. Caherly 105/07/84

APPROVED BY RSS 7-23-84



PERRY NUCLEAR POWER PLANT  
UNITS 1 & 2

*WATERMEDIATE BUILDING*

FLOOR RESPONSE SPECTRA (SSE)

EAST-WEST DIRECTION AT

ELEVATION 639'-6"


(MAX. GROUND ACCELERATION - SSE = 0.150G)

Column Lines IB1 to IB7

FIG. *IBA-1*

*FLAME RESPONSE ENVELOPE*

D = EQUIPMENT DAMPING



36.00  
32.00  
28.00  
24.00  
20.00  
16.00  
12.00  
8.00  
4.00  
0.00

FREQUENCY (CPS)

8/10/76 REV. 1  
12/1/80 Rev. 2

PERRY NUCLEAR POWER PLANT  
UNITS 1 & 2

INTERMEDIATE BUILDING

FLOOR RESPONSE SPECTRA (SSE)

WEST-SOUTH DIRECTION AT

ELEVATION 539'-6"


(MAX. GROUND ACCELERATION - SSE = 0.150G)

Column Lines 1B1 to 1B7

FIG. 1B4-2


FLOOR RESPONSE SPECTRA

D = EQUIPMENT DAMPING



12/1/80  
REV. 2

8/10/76 REV. 1



FLOOR RESPONSE ENVELOPE  
 D = EQUIPMENT DAMPING

FIG. 1B4-3

PERKY NUCLEAR POWER PLANT  
 UNITS 1 & 2  
 INTERMEDIATE BUILDING  
 FLOOR RESPONSE SPECTRA (SSR)  
 VERTICAL DIRECTION AT  
 ELEVATION 639.6'  
 (MAX. GROUND ACCELERATION - SSE = 0.150G)  
 Column lines 1B1 to 1B7

12/1/80  
 8/10/76 REV. 1  
 Rev. 2

PERRY NUCLEAR POWER PLANT

UNITS 1 & 2

INTERMEDIATE BUILDING

FLOOR RESPONSE SPECTRA (ORF)

EAST-WEST DIRECTION AT

ELEVATION 639'-6"


(MAX. GROUND ACCELERATION -ORF = 0.075G)

Column Lines 101 to 1B7

FIG. IB4-4

RARE RESPONSE ENVELOPE

D - EQUIPMENT DAMPING



2/10/76 REV. 1

12/1/80 Rev. 2

PERRY NUCLEAR POWER PLANT

UNITS 1 & 2

INTERMEDIATE BUILDING

FLOOR RESPONSE SPECTRA (ORF)

NORTH-SOUTH DIRECTION AT

ELEVATION 639'-6"


(MAX. GROUND ACCELERATION -ORF = 0.075G)

Column Lines 1B1 to 1B7

FIG. 1B4-5

FLOOR RESPONSE ENVELOPE

D = EQUIPMENT DAMPING



8/10/76 REV. 1  
12/1/80 Rev. 2

PERRY NUCLEAR POWER PLANT

UNITS 1 & 2

*INTERMEDIATE BUILDING*

FLOOR RESPONSE SPECTRA (ORF)

VERTICAL DIRECTION AT

ELEVATION 659'-6"


(MAX. GROUND ACCELERATION -0.5E = 0.075G)

Column Lines IBI to B7

FIG. *IB4-6*

*LOSS RESPONSE ENVELOPE*

D = EQUIPMENT DAMPING



*8/10/76 ESU/1*

SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

HFL#1R72 Sc02  
RA# 10-1-83  
7-21-87

- I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: \_\_\_\_\_
1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_
2. NSSS: GENERAL ELECTRIC BWR: X
3. A/E: GILBERT/COMMONWEALTH Other: \_\_\_\_\_

II. COMPONENT NAME: Medium Voltage Modular Electrical Penetrations NON IE  
p. 20 PEN-TR-82-51  
RA# 10-1-83

1. Scope:  NSSS  BOP  Other  
REF. WEST. DESIGN DWGS.
2. Model Number: WX 333.28 Quantity: 2
3. Size or Range: 600 Ampere REF. WEST. DESIGN DWGS.
4. Vendor: Westinghouse
5. If the component is a cabinet or panel, name and model Number of the devices included:  
\_\_\_\_\_  
\_\_\_\_\_

6. Physical Description:
- \* a. Appearance: Cylinder with cables extending beyond ends | R1
- \* b. Dimensions: 18" in diameter, 128" long ALSO, see p A2 of | R1  
PEN-TR-82-51 RA# 10-1-83
- \* c. Weight: 1,200 lb | R1

7. Location: Building: Shield building and containment vessel  
Elevation: 659'

8. Field Mounting Conditions  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)  
 Weld (Length 56.55" full circumference)  
 \_\_\_\_\_

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)  
between shield building and containment vessel walls

10. a. System in which located: Electrical
- b. Functional Description: Maintain pressure boundary REF. SEC. 2.0  
of PEN-TR-82-51 | R1
- c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither  Other \_\_\_\_\_

\* REF. WESTINGHOUSE 1  
DESIGN DRAWINGS | R1

II. Pertinent Reference Design Specifications for Qualification Requirements:

SP-563-4549-000

- a. Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

- Yes
- No
- Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

- Test
- Analysis
- Combination of Test and Analysis

Qualification Report\*: PEN-TR-82-52 (Sections PEN-TR-78-02, PEN-TR-78-87) REF. TITLE A

(No., Title and Date): Technical Reports and Qualification Data, Med. Volt. Elec. Pen. 12/1/82

Company that Prepared Report: WESTINGHOUSE REF. TITLE B

Company that Reviewed Report: GILBERT/COMMONWEALTH

Where Report is filed or available: PERRY NUCLEAR POWER PLANT EIB 1/15/83

Applicable Codes And/Or Standards: IEEE 344-1975 REF. SEC. 1.1/PEN-TR-78-87

V. VIBRATION INPUT:

1. Loads considered:
  - a.  Seismic only EIB 2/15/83
  - b.  Hydrodynamic only 2/15/83 EIB
  - c.  Vibration from normal operation
  - d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

- Absolute Sum
- SRSS
- \_\_\_\_\_ (other, specify)

3. Required Response Spectra \*\* (attach the graphs): SP-563 RRS CURVES ATTACHED

NOTE:

\*If more than one report complete Items IV thru VII for each report.  
 \*\*If other than RRS is used, describe method.



4. Damping Corresponding to RRS: OBE 2%\* SSE 2%\*

5. Required Acceleration in Each Direct:  
 ZPA  Other Peak  
(specify)

OBBA or OBE S/S = 3.23g F/B = 3.23g V = 2.75g  
SSBA or SSE S/S = 4.5g F/B = 4.5g V = 3.35g

REF. ATTACHED CURVES

6. Were fatigue effects considered:  
 Yes  No

If yes, describe how they were treated in overall qualification program: The penetrations were exposed to 20 OBBA and 4 SBBA test accelerations; this is 4 times the number of events anticipated by NRC requirements for an operating power plant

VI. IF QUALIFICATION BY TEST, THEN COMPLETE:

1.  Single Frequency  Multi-Frequency  random  sine beat

REF. SEC. 6.1 of PEN-TR-7E-27 02 EFB 10/5/83 |R1

2.  Single Axis  Multi-Axis  In-phase motions  Independent Axis

REF. FIG. 4 of PEN-TR-7E-27 02 EFB 10/5/83 |R1

3. Number of Qualifications Tests: 20 OBE 4 SSE Other \_\_\_\_\_  
(specify)

REF. SEC. 6.1 of PEN-TR-7E-27 02 EFB 10/5/83 |R1

4. Frequency Range: 1 Hz to 100 Hz

REF. ATTACHED CURVES 02 EFB 10/5/83 |R1

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
S/S = 11 Hz, 1/6 Hz, 2/6 Hz F/B = 11 Hz, 1/6 Hz, 2/6 Hz V = 11 Hz, 1/6 Hz, 2/6 Hz

REF. SEC. 5.2 of PEN-TR-7E-27 02 EFB 10/5/83 |R1

6. Method of Determining Natural Frequencies  Lab Test  In-Situ Test  Analysis

REF. SEC. 5.0, 5.1 of PEN-TR-7E-27 02 EFB 10/5/83 |R1

7. TRS enveloping RRS using Multi-Frequency Test  Yes (Attach TRS and RRS graphs)  No

REF. SEC. 6.1 of PEN-TR-7E-27 02 EFB 10/5/83 |R1

\* 2% damping used for RRS, 2.5% for TRS

8. Maximum Input g Level Test: REF. ATTACHED FIG. 5+6 of PEN-TR-78-27 <sup>02 E/B 10/5/83</sup> |R1

OBBA or OBE S/S = 8.2g \* F/B = 8.2g \* V = 8.2g \*

SSBA or SSE S/S = 10.5g \* F/B = 10.5g \* V = 10.5g \*

9. Laboratory Mounting: REF. SEC. 3.0 of PEN-TR-78-87 |R1

a.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)

Weld (Length 37.7")  full circumference

b. Orientation and Fixturing: Welded to nozzle attached to test table

10. Functional operability verified: REF. SEC. 6.2 of PEN-TR-78-27 <sup>02 E/B 10/5/83</sup> |R1

Yes  No  Not Applicable

11. Test Results including modifications made: Penetration leak rate did not exceed maximum allowable per IEEE 317. REF. SEC. 6.2 of PEN-TR-78-27 |R1

12. Other tests performed (such as aging or fragility test, including results): <sup>02 E/B 10/5/83</sup>

Aging Ref: Sec. 3.4, PEN-TR-82-51 <sup>02 E/B 10/6/83</sup>

13. Failure Modes (If appropriate) \_\_\_\_\_

14. Margins Available:  Input Spectrum  Fragility  
REF. SEC. 6.1 of PEN-TR-78-27 <sup>02 E/B 10/5/83</sup> |R1

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE: <sup>02 E/B 10/5/83</sup>


1. Method of Analysis:
- Static Analysis  Equivalent Static Analysis
- Dynamic Analysis:  Time-History  Response Spectrum
2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
- S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_
3. Model Type:  2D  2D  1D
- Finite Element  Beam
- Closed Form Solution  Other \_\_\_\_\_

\* Test table oriented 45° to direction of motion, giving equal horizontal and vertical accelerations, REF. FIG. 4 of PEN-TR-78-27 <sup>02 E/B 10/5/83</sup> |R1

4.  Computer Codes: \_\_\_\_\_  
 Frequency Range and No. of Modes  
 Hand Calculations
5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:  
 Absolute Sum       SRSS       Other: \_\_\_\_\_  
 (specify)
6. Damping:  
 OBE \_\_\_\_\_ SSE \_\_\_\_\_ Basis for the damping used: \_\_\_\_\_
7. Support Considerations in the model: \_\_\_\_\_
8. Critical Structural Elements:
- | a. | Identification Location     | Governing Load or Response Combination | Seismic Stress  | Total Stress | Stress Allowable |
|----|-----------------------------|--|---|--------------|------------------|
| b. | Maximum Critical Deflection | Location                               | Maximum Allowable Deflection to Assure Functional Operability |              |                  |
9. Failure Modes: \_\_\_\_\_
10. Margins Available:       Input Spectrum       Stress or Deflection

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
1	1/7/24/83	ETB	BSK	RAM
/	/	/	/	/
/	/	/	/	/

REVIEWED BY Edward J. Burke 12/15/83  
 CHECKED BY D.G. Lahorski 12-24-83  
 APPROVED BY W.A. Matheny 1/10/7/83  
 RAS 10-6-83




PERRY PROJECT  
 NEW LOADS RESPONSE  
 SPECTRA  
 OBBA (2%) DRAWING  
 CASE I - OBE + GRVD  
 HORIZONTAL

SP-524  
 SP-523

CHIT NUSSEL ELECTRONICS  
 PENTAKINGS  
 FILING CODE 2  
 REV O LEWIS 6-11-83

Figure 2 SHI 1 of 4

3 CYCLES X 10 DIVISIONS PER INCH



PERY PROJECT  
 NEW LOADS RESPONSE  
 SPECTRA  
 OB 3A (1/2) 1/10/51  
 GASET-OBE+SRVD  
 VERT CAL


SP-524  
 SP-563  
 STMT VESSEL ELECTRICAL  
 PENETRATIONS  
 FILING CODE:  
 REV O LEWIS, 4/10/51

FIGURE 2 SHEET 2 OF 4


FREQUENCY (Hz)

ACCELERATION (G)

3 CYCLES X 10 DIVISIONS PER INCH



3 CYCLES X 10 DIVISIONS PER INCH



PERRY PROJECT  
 NEW LOADS RESPONSE  
 SPECTRA

SAFE SHUTDOWN BUILDING  
 ACCELERATION  
 VERTICAL

SP-522 SP-563  
 SRSS  
 (2% DAMPING)

CIMIT VESSEL ELECTRICAL  
 PENETRATIONS  
 FLING CODE 2  
 REV O LEADING 6-19-81

FIGURE 2 SHEET 1 OF 4  
 FREQUENCY (HZ)

SEISMIC AND DYNAMIC QUALIFICATION SUMMARY OF EQUIPMENT

- I. PLANT NAME: PERRY NUCLEAR POWER PLANT TYPE: \_\_\_\_\_
1. Utility: CLEVELAND ELECTRIC ILLUMINATING PWR: \_\_\_\_\_
2. NSSS: GENERAL ELECTRIC BWR: X
3. A/E: GILBERT/COMMONWEALTH Other \_\_\_\_\_

II. COMPONENT NAME: LIMITORQUE ACTUATORS

1. Scope:  NSSS  BOP  Other
2. Model Number: SMB, SB, SMP/HBC Qty: 215
3. Size or Range: SMB-000 TO SMB-4
4. Vendor: LIMITORQUE CORPORATION
5. If the component is a cabinet or panel, name and model Number of the devices included:  
N/A
6. Physical Description:
- a. Appearance: TOTALLY ENCLOSED MOTOR OPERATED ACTUATOR
- b. Dimensions: (AVG. SMB-1) L=37" W=10" H=11"
- c. Weight: 140 LBS TO 3750 LBS. (AVG. 560 LBS SMB-1)
7. Location: Building: REFER TO MECHANICAL MPL SORT FORM  
Elevation: REFER TO MECHANICAL MPL SORT FORM
8. Field Mounting Conditions  Bolt (No. 8, Size 5/8-11) (AVG. SMB-1)  
 Weld (Length \_\_\_\_\_ )  
 \_\_\_\_\_
9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)  
IN VALVE OR SLUICE GATE
10. a. System in which located: REFER TO MECHANICAL MPL SORT  
b. Functional Description: REFER TO MECHANICAL MPL SORT  
c. Is the equipment required for  Hot Standby  Cold Shutdown  
REFER TO MECHANICAL MPL SORT  
 Both  Neither  Other \_\_\_\_\_



11. Pertinent Reference Design Specifications for Qualification Requirements:

GAT SP-568-4549-00 AND PARENT SPECIFICATION TO WHICH IT IS ATTACHED

- (a) Seismic Input
- (b) Hydrodynamic Load Input
- (c) Fatigue Considerations
- (d) Service Conditions
- (e) Qualified Life

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:

- Yes
- No
- Partial or limited availability

IV. EQUIPMENT QUALIFICATION METHOD:

- Test
- Analysis
- Combination of Test and Analysis

Qualification Report\*: REPORT NO. B0115, HYDRODYNAMIC VIBRATION

(No., Title and Date): TESTING (NEW LOADS), DATED 6-24-82

Company that Prepared Report: LIMITROUVE CORPORATION

Company that Reviewed Report: GILBERT/COMMONWEALTH

Where Report is filed or available: PERRY NUCLEAR POWER PLANT

Applicable Codes And/Or Standards: IEEE-344-1975 IEEE-380-1972

V. VIBRATION INPUT:

1. Loads considered:
  - a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Vibration from normal operation
  - d.  Combination of (a), (b), and (c)

2. Method of Combining RRS:

- Absolute Sum
- SRSS
- \_\_\_\_\_  
(other, specify)

3. Required Response Spectra \*\* (attach the graphs): SEE "FNPP VALVE

QUALIFICATION PROGRAM DESCRIPTION" FOR VALVE MOUNTED ACTUATORS  
SEE SP-530 FOR SLICE GATE MOUNTED ACTUATORS.

NOTE:

\*If more than one report complete Items IV thru VII for each report.  
 \*\*If other than RRS is used, describe method.

PIPING ANALYSIS

4. Damping Corresponding to RRS: OBE 1% SSE 2% VALVES > 12" 2% VALVES < 12" 3%
5. Required Acceleration in Each Direct:

ZPA  Other PEAK  
(specify)

OBBA or OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_  
SSBA or SSE S/S = REFER TO MECHANICAL MPL SQRT F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Were fatigue effects considered:

Yes  No

If yes, describe how they were treated in overall qualification program:

SEE "LIMITING ACTUATOR QUALIFICATION!"  
FOR THE PERRY NUCLEAR POWER PLANT" SECTION 16  
HRM 10-13-83

VI. IF QUALIFICATION BY TEST, THEN COMPLETE:

1.  Single Frequency  Multi-Frequency  random  sine beat  \_\_\_\_\_
2.  Single Axis  Multi-Axis  Independent Axis  In-phase motions

3. Number of Qualifications Tests:

OBE \_\_\_\_\_ SSE \_\_\_\_\_ Other 5 BEAT - 15 CYCLE TEST OF B<sub>y</sub> AND C<sub>y</sub>  
(specify) @ 1/3 OCTAVE INTERVALS

4. Frequency Range: 2 TO 100 HERTZ

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = 2100 HZ F/B = 2100 HZ V = 2100 HZ SMB-2-60, SMB-1-60  
90 HZ 89 HZ 87 HZ SMB-00-15 / HZ BC

6. Method of Determining Natural Frequencies INDIVIDUAL ONLY 70-75 HZ, 90-95 HZ (MOTOR) 58 HZ, 74 HZ SMB-4-250  
47, 60 HZ (MOTOR) 36, 75 HZ (MOTOR) 66 HZ (MOTOR) SMB-000 W/MOTOR

Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test

Yes (Attach TRS and RRS graphs) N/A: MULTI-FREQUENCY  
 No TEST NOT USED

8. Maximum Input g Level Test: <sup>FOR RIM</sup>  
 OBBA or OBE S/S = 10g / 7g F/B = 10g / 7g V = 10g / 7g <sup>SMB 007E</sup>  
 SSBA or SSE S/S = 8g / 8g F/B = 8g / 8g V = 8g / 8g <sup>SMB-3</sup>  
<sup>SMB-4</sup>  
<sup>SMB/HAC</sup>

9. Laboratory Mounting:

- a.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_ )  
 Weld (Length \_\_\_\_\_ )  BOLTED TO AN ALUMINUM PLATE THEN RIGIDLY CLAMPED TO HYDRAULIC SHAKER
- b. Orientation and Fixturing: MOTOR AND LIMIT SWITCH COMPARTMENT IN THE HORIZONTAL PLANE

10. Functional operability verified:

- Yes  No  Not Applicable

11. Test Results including modifications made: THE TESTS DEMONSTRATED THAT THE UNITS ARE CAPABLE OF WITHSTANDING THE TESTED LOADS

12. Other tests performed (such as aging or fragility test, including results):

NONE

13. Failure Modes (if appropriate) NONE

14. Margins Available:  Input Spectrum  Fragility

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. Method of Analysis:  
 Static Analysis  Equivalent Static Analysis  
 Dynamic Analysis:  Time-History  Response Spectrum
2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):  
 S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_
3. Model Type:  3D  2D  1D  
 Finite Element  Beam  
 Closed Form Solution  Other \_\_\_\_\_

4.  Computer Codes: \_\_\_\_\_  
 Frequency Range and No. of Modes  
 Hand Calculations
5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:  
 Absolute Sum       SRSS       Other: \_\_\_\_\_  
 (specify)
6. Damping:  
 OBE \_\_\_\_\_ SSE \_\_\_\_\_ Basis for the damping used: \_\_\_\_\_
7. Support Considerations in the model: \_\_\_\_\_
8. Critical Structural Elements:
- a. 

Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
- b. 

Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
9. Failure Modes: \_\_\_\_\_
10. Margins Available:       Input Spectrum       Stress or Deflection

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
/		/	/	/
/		/	/	/
/		/	/	/

REVIEWED BY Steven R. Mannon 17-22-83  
 CHECKED BY James D. Caherly 17/29/83  
 APPROVED BY W.A. Bates 17/24/84  
 RA 7-2384



a. Pump (continued)

Size 47½" W X 62½" L X 49" H

Weight 6575 lbs

Mounting Method Pedestal Mounted on Base Plate

Required B.H.P. 825

Parameter	Design	Operating
Press	1525 psig	1450 psig
Temp	40°F-140°F	40°F-140°F
Flow	725 GPM	725 GPM
Head	2980'	2980'

Required NPSH at maximum

flow 20'

Available NPSH 21'

Operating Speed 4520 rpm

Critical Speed NC1 2725 RPM  
NC2 11578 RPM

List functional accessories: \* Provided by manufacturer.

b. Prime-mover (continued)

Size 7 ft. long, 6 ft. wide, 5 ft. high

Weight 5000 lbs. APPROXIMATE

Mounting Method BASE MOUNTED TO CONCRETE VIA 6-INCH DIAMETER BOLTS

H.P. 825 HP

Power requirements: (include normal, maximum and minimum).

Electrical 120 VDC ± 10%

Other REACTOR STEAM

If MOTOR list:

Duty cycle NA

Stall current \_\_\_\_\_

Class of insulation \_\_\_\_\_

List control signal inputs: Inputs are to pump driver. SYSTEM flow controller output (1.0-5.0 VDC) signal is the speed demand signal To the turbine control signal.

\*Functional accessories are those subcomponents not supplied by the manufacturer that are required to make the pump assembly operational, (e.g., coupling, lubricating oil system, etc.)

6. General Valve Data

a. Valve			b. Actuator (if not an integral unit)
Name	_____	_____	Name _____
Mfg.	_____	_____	Mfg. _____
Model	_____	_____	Model _____
S/N	_____	_____	S/N _____
Type	_____	_____	Type _____
Size	_____	_____	Size _____
Weight	_____	_____	Weight _____
Mounting Method	_____	_____	Mounting Method _____
Required Torque	_____	_____	Torque _____
<u>Parameter</u>	<u>Design</u>	<u>Operating</u>	Power requirements: (include normal, maximum and minimum).
Press	_____	_____	Electrical _____
Temp	_____	_____	_____
Flow	_____	_____	_____
Max $\Delta P$ across valve	_____	_____	_____
Closing time @ max $\Delta P$	_____	_____	Other: <input type="checkbox"/> Pneumatic <input type="checkbox"/> Hydraulic
Opening time @ max $\Delta P$	_____	_____	_____
Power requirements for functional accessories, (if any)	_____	_____	_____
_____	_____	_____	_____
List control signal inputs:	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

List functional accessories:\*

### III. FUNCTION

1. Briefly describe component's normal and safety functions: Normal function is to transport make-up water from the condensate storage tank to the reactor vessel to assure adequate core cooling takes place. Upon the reactor water level reaching a pre-determined low level, the RCIC system shall be initiated automatically. The turbine driven pump will supply demineralized make-up water from the condensate storage tank to the reactor vessel. An alternate source of water is available from the suppression pool.

2. The component's normal state is:  Operating  Standby

3. Safety function:

- |   |  |
|---|--|
| a. <input type="checkbox"/> Emergency reactor shutdown      | b. <input type="checkbox"/> Containment heat removal   |
| c. <input type="checkbox"/> Containment isolation           | d. <input type="checkbox"/> Reactor heat removal   |
| e. <input checked="" type="checkbox"/> Reactor core cooling | f. <input type="checkbox"/> Prevent significant release of radioactive material to environment |

g.  Does the component function to mitigate the consequences of one or more of the following events?  Yes  No  
If "Yes", identify.

- LOCA       HELB       MSLB  
Vessel isolation accompanied by loss of coolant,  
 Other control rod drop and ATWS conditions.

4. Safety requirements:

- |  |   |
|--|---|
| <input checked="" type="checkbox"/> Intermittent Operation | <input type="checkbox"/> During postulated event    |
| <input type="checkbox"/> Continuous Operation              | <input type="checkbox"/> Following postulated event |

If component operation is required following an event, give approximate length of time component must remain operational.

6 hours - ATWS Event  
12 hours - Isolation Event \_\_\_\_\_ (e.g., hours, days, etc.)

\*Functional accessories are those subcomponents not supplied by the manufacturer that are required to make the valve assembly operational, (e.g., limit switches).



5. For VALVES: NA
- does the component  Fail open  Fail closed  Fail as is
- Is this the fail safe position?  Yes  No
- Is the valve used for throttling purposes?  Yes  No
- Is the valve part of the reactor coolant pressure boundary?  
 Yes  No
- Does the valve have a specific limit for leakage?  Yes  No
- If "Yes" give limit: \_\_\_\_\_

IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: \_\_\_\_\_  
ASME B&PV Code Sections III & VIII Class II
  
2. Reference those qualification standards, used as a guide to qualify the component: \_\_\_\_\_  
Standards of the Hydraulic Institute and ASME Power Test Code, PTC 8.2
  
3. Identify those parts of the above qualification standards deleted or modified in the qualification program.  

Deleted:	Modified:
<u>NONE</u>	<u>NONE</u>
_____	_____
_____	_____
  
4. Have acceptance criteria been established and documented in the test plan(s) for the component?  Yes  No
  
5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? \_\_\_\_\_  
Driver fails to start.
  
6. Are the margins\* identified in the qualification documentation?  
 Yes  No

\*Margin is the difference between design basis parameters and the test parameters used for equipment qualification.

If component is PUMP, complete IV.7.

If component is a VALVE, complete IV.8.

7. Pump operability has been demonstrated by:  Analysis  
 Test  Combination

Identify PUMP tests performed:

- |  |   |
|--|---|
| a. <input checked="" type="checkbox"/> Shell hydrostatic<br>(ASME Section III)   | b. <input checked="" type="checkbox"/> Bearing temperature<br>evaluations   |
| c. <input checked="" type="checkbox"/> Seismic loading   | d. <input checked="" type="checkbox"/> Vibration levels   |
| e. <input type="checkbox"/> Exploratory vibration<br>(Fundamental freq. _____)   | f. <input checked="" type="checkbox"/> Seal leakage @ hydro press   |
| g. <input type="checkbox"/> Aging: <input type="checkbox"/> Thermal<br><input type="checkbox"/> Mechanical   | h. <input checked="" type="checkbox"/> Flow performance<br>Are curves provided <input type="checkbox"/> Yes<br><input checked="" type="checkbox"/> No |
| i. <input checked="" type="checkbox"/> Pipe reaction end<br>loads (nozzle loads)   | j. <input type="checkbox"/> Others _____<br>_____<br>_____  |
| k. <input type="checkbox"/> Extreme environment:<br><input type="checkbox"/> Humidity<br><input type="checkbox"/> Chemical<br><input type="checkbox"/> Radiation | _____<br>_____<br>_____   |

8. Valve operability has been demonstrated by:  Analysis  
 Test  Combination

Identify VALVE tests performed:

- |  |   |
|--|---|
| a. <input type="checkbox"/> Shell hydrostatic<br>(ASME Section III)            | b. <input type="checkbox"/> Cold cyclic List times:<br>Open _____<br>Closed _____ |
| c. <input type="checkbox"/> Seismic loading                                    | d. <input type="checkbox"/> Hot cyclic List times:<br>Open _____<br>Closed _____  |
| e. <input type="checkbox"/> Exploratory vibration<br>(Fundamental freq. _____) | f. <input type="checkbox"/> Mean seat leakage                                     |

- g.  Aging:  Thermal  Mechanical  
 h.  Back seat leakage
- i.  Pipe reaction end loading  
 j.  Disc hydrostatic loading
- k.  Extreme environment:  Humidity  
 Chemical  
 Radiation  
 l.  Flow interruption capability
- m.  Flow characteristics  
 n.  Others \_\_\_\_\_
- Are curves provided? \_\_\_\_\_  
 Yes  No

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified?  Yes  No  
 If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation.

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

10. Was the test component precisely identical (as to model, size, etc.) to the in-plant component?  Yes  No. If "No", is installed component  oversized or  undersized?
11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, Section 5.?  Yes  No  NOT PERFORMED.
12. Is component orientation sensitive?  Yes  No  Unknown  
 If "Yes", does installed orientation coincide with test orientation?  Yes  No
13. Is the component mounted in the same manner in-plant as it was during testing (i.e., welded, same number and size bolts, etc.)  Yes  No

14. Were the qualification tests performed in sequence and on only one component?  Yes  No
- If "Yes" identify sequence, (e.g., radiation, seismic, cyclic, thermal, etc.): None performed.
- 
15. If "aging"\* was performed, identify the significant aging mechanisms: None performed.
- 
16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed:
- a.  Plants (shutdown loads)      b.  Extreme environment
- c.  Seismic load                      d.  Others \_\_\_\_\_
- 
17. Have component design specifications been reviewed in-house to assure they envelope all expected operating, transient, and accident conditions?  Yes  No
18. Does the component utilize any unique or special materials? (Examples are special gaskets or packing, limitations on nonferrous materials, or special coatings or surfaces.)  Yes  No
- If "Yes", identify: \_\_\_\_\_
- 
19. Does component require any special maintenance procedures or practices, (including shorter periods between maintenance).  Yes  No
- If "Yes", identify: \_\_\_\_\_
- 
20. Is the qualified life for the component less than 40 years?  Yes  No If "Yes", what is the qualified life? \_\_\_\_\_

\*As outlined in Section 4.4.1 of IEEE-627 1980.

21. Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
AG-534	Q.C. Records Binder, Certificate of Hydrostatic Test		Bingham Willamette Pump Co.	General Electric Co. NPSED
	1. Outer Case	11/28/77	"	"
	2. Seal Circulation Piping	1/13/78	"	"
T-152100 30-1,	Performance Test Data (VPF 4060-63-1)	12/19/77	Bingham Willamette Pump Co.	General Electric Co. NPSED
3720-652	Pump Vendor Stress Report	8/17/77	BYRON-JACKSON	GENERAL ELECTRIC Co NPSED



a. Pump (continued)

Size 37" dia. x 367" length  
 (Wet) Weight 38,500  
 Mounting Method Bolted Flange  
 Required B.H.P. 1600

Parameter	Design	Operating
Suction (psi)	115	**
Discharge (psi)	600	330
Temp (°F)	212	40-212
Flow	6250	0-6250
Head (Ft)	760	760
Runout Flow (GPM)	7655	N/A

Required NPSH at maximum

flow 1.5 ft.

Available NPSH 5.0 ft.

Operating Speed 1780

Critical Speed 2040 CPM

List functional accessories:\* None

List control signal inputs: -LOCA signal from relay E21A-K12

\*Functional accessories are those subcomponents not supplied by the manufacturer that are required to make the pump assembly operational, (e.g., coupling, lubricating oil system, etc.)

\*\* Depends upon system piping configuration.

RWH:rf/G0241\*-2  
 2/4/83

b. Prime-mover (continued)

Size 42" dia. x 78" length  
 Weight 13,500  
 Mounting Method Bolted Flange  
 H.P. 1750

Power requirements: (include normal, maximum and minimum).

Electrical 4,000 volts

3-phase

60 Cycle

Other 222 Amps

If MOTOR list:

Duty cycle Continuous

Stall current 1443 Amps

Class of insulation F (VPI)

6. General Valve Data

a. Valve

b. Actuator (if not an integral unit)

Name \_\_\_\_\_

Name \_\_\_\_\_

Mfg. \_\_\_\_\_

Mfg. \_\_\_\_\_

Model \_\_\_\_\_

Model \_\_\_\_\_

S/N \_\_\_\_\_

S/N \_\_\_\_\_

Type \_\_\_\_\_

Type \_\_\_\_\_

Size \_\_\_\_\_

Size \_\_\_\_\_

Weight \_\_\_\_\_

Weight \_\_\_\_\_

Mounting Method \_\_\_\_\_

Mounting Method \_\_\_\_\_

Required Torque \_\_\_\_\_

Torque \_\_\_\_\_

Parameter      Design      Operating

Power requirements: (include normal, maximum and minimum).

Press \_\_\_\_\_

Electrical \_\_\_\_\_

Temp \_\_\_\_\_

\_\_\_\_\_

Flow \_\_\_\_\_

\_\_\_\_\_

Max  $\Delta P$  across valve \_\_\_\_\_

\_\_\_\_\_

Closing time @ max  $\Delta P$  \_\_\_\_\_

Other:  Pneumatic  Hydraulic

Opening time @ max  $\Delta P$  \_\_\_\_\_

\_\_\_\_\_

Power requirements for functional accessories, (if any) \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

List control signal inputs: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



List functional accessories: \* NA

III. FUNCTION

1. Briefly describe component's normal and safety functions: \_\_\_\_\_

To supply makeup water to the reactor core in the event of an accident. The primary purpose is to provide spray cooling and makeup water during large break accidents which the core could uncover.

2. The component's normal state is:       Operating     Standby

3. Safety function:

- a.  Emergency reactor shutdown
- b.  Containment heat removal
- c.  Containment isolation
- d.  Reactor heat removal
- e.  Reactor core cooling
- f.  Prevent significant release of radioactive material to environment

g.  Does the component function to mitigate the consequences of one or more of the following events?     Yes     No  
If "Yes", identify.

- LOCA                       HELB                       MSLB
- Other \_\_\_\_\_

4. Safety requirements:

- Intermittent Operation                       During postulated event
- Continuous Operation                       Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.

... 100 days (e.g., hours, days, etc.)

\*Functional accessories are those subcomponents not supplied by the manufacturer that are required to make the valve assembly operational, (e.g., limit switches).

5. For VALVES:

does the component  Fail open  Fail closed  Fail as is

Is this the fail safe position?  Yes  No

Is the valve used for throttling purposes?  Yes  No

Is the valve part of the reactor coolant pressure boundary?  
 Yes  No

Does the valve have a specific limit for leakage?  Yes  No

If "Yes" give limit: \_\_\_\_\_

IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: \_\_\_\_\_

ASME Section VIII & III, AISC Erection Spec, NEMA MG-1,

IEEE TP-85, ANSI B16.5, Hydraulic Institute Standards

2. Reference those qualification standards, used as a guide to qualify the component: \_\_\_\_\_

IEEE 98, 99, 101, 275, 323, 334, 344

3. Identify those parts of the above qualification standards deleted or modified in the qualification program.

Deleted:

Modified:

None

None

4. Have acceptance criteria been established and documented in the test plan(s) for the component?  Yes  No

5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? \_\_\_\_\_

Motor fails to start

6. Are the margins\* identified in the qualification documentation?  
 Yes  No

\*Margin is the difference between design basis parameters and the test parameters used for equipment qualification.

If component is a PUMP, complete IV.7.

If component is a VALVE, complete IV.8: *NA*

7. Pump operability has been demonstrated by:  Analysis  
 Test  Combination

Identify PUMP tests performed:

- |  |   |
|--|---|
| a. <input checked="" type="checkbox"/> Shell hydrostatic<br>(ASME Section III)   | b. <input checked="" type="checkbox"/> Bearing temperature<br>evaluations   |
| c. <input checked="" type="checkbox"/> Seismic loading   | d. <input checked="" type="checkbox"/> Vibration levels   |
| e. <input type="checkbox"/> Exploratory vibration<br>(Fundamental freq. _____)   | f. <input checked="" type="checkbox"/> Seal leakage @ hydro press   |
| g. <input type="checkbox"/> Aging: <input type="checkbox"/> Thermal<br><input type="checkbox"/> Mechanical   | h. <input checked="" type="checkbox"/> Flow performance<br>Are curves provided <input checked="" type="checkbox"/> Yes<br><input type="checkbox"/> No |
| i. <input checked="" type="checkbox"/> Pipe reaction end<br>loads (nozzle loads)   | j. <input type="checkbox"/> Others _____<br>_____<br>_____  |
| k. <input type="checkbox"/> Extreme environment:<br><input type="checkbox"/> Humidity<br><input type="checkbox"/> Chemical<br><input type="checkbox"/> Radiation | _____<br>_____<br>_____   |

8. Valve operability has been demonstrated by:  Analysis  
 Test  Combination

Identify VALVE tests performed:

- |  |   |
|--|---|
| a. <input type="checkbox"/> Shell hydrostatic<br>(ASME Section III)            | b. <input type="checkbox"/> Cold cyclic List times:<br>Open _____<br>Closed _____ |
| c. <input type="checkbox"/> Seismic loading                                    | d. <input type="checkbox"/> Hot cyclic List times:<br>Open _____<br>Closed _____  |
| e. <input type="checkbox"/> Exploratory vibration<br>(Fundamental freq. _____) | f. <input type="checkbox"/> Mean seat leakage                                     |

- g.  Aging:  Thermal  Mechanical
- h.  Back seat leakage
- i.  Pipe reaction end loading
- j.  Disc hydrostatic
- k.  Extreme environment:  Humidity  Chemical  Radiation
- l.  Flow interruption capability
- m.  Flow characteristics
- n.  Others \_\_\_\_\_
- Are curves provided? \_\_\_\_\_
- Yes  No

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified?  Yes  No  
 If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation.

Insignificant deviations only; PPT 456HA808.

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

10. Was the test component precisely identical (as to model, size, etc.) to the in-plant component?  Yes  No. If "No", is installed component  oversized or  undersized?
11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, Section 5.?  Yes  No
12. Is component orientation sensitive?  Yes  No  Unknown  
 If "Yes", does installed orientation coincide with test orientation?  Yes  No
13. Is the component mounted in the same manner in-plant as it was during testing (i.e., welded, same number and size bolts, etc.)  Yes  No  Unknown

14. Were the qualification tests performed in sequence and on only one component?  Yes  No

If "Yes" identify sequence, (e.g., radiation, seismic, cyclic, thermal, etc.): Thermal aging, operational aging, radiation, seismic, DBE, post accident,

15. If "aging"\* was performed, identify the significant aging mechanisms: Thermal aging in accordance with IEEE 275 using derived Arrhenius curves.

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed:

- a.  Plants (shutdown loads)
- b.  Extreme environment
- c.  Seismic load
- d.  Others \_\_\_\_\_

17. Have component design specifications been reviewed in-house to assure they envelope all expected operating, transient, and accident conditions?  Yes  No

18. Does the component utilize any unique or special materials? (Examples are special gaskets or packing, limitations on nonferrous materials, or special coatings or surfaces.)  Yes  No

If "Yes", identify: \_\_\_\_\_

19. Does component require any special maintenance procedures or practices, (including shorter periods between maintenance).  Yes  No

If "Yes", identify: \_\_\_\_\_

20. Is the qualified life for the component less than 40 years?  Yes  No If "Yes", what is the qualified life? \_\_\_\_\_

\*As outlined in Section 4.4.1 of IEEE-627 1980.

21. Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
456HA 898	Qualification Report	9/30/76	General Electric Company San Jose Motor Plant Small AC Motor Department	General Electric Company NEBC

B/M RJC-1

PUMP AND VALVE  
OPERABILITY ASSURANCE REVIEW

I. PLANT INFORMATION

1. Name: PERRY NPP Unit No. 1 & 2 2. Docket No.: 50-440 & 50-441
3. Utility: CLEVELAND ELECTRIC ILLUMINATING
4. NSSS: GENERAL ELECTRIC  PWR  BWP
5. A/E: GILBERT/COMMONWEALTH

II. GENERAL COMPONENT\* INFORMATION

1. Supplier:  NSSS  BOP
2. Location: a. Building/Room AUXILIARY  
 b. Elevation 574 FT.  
 c. System E-22 HIGH PRESSURE COAL SPRAY
3. Component number on in-house drawings: 1 E22 F010
4. If component is a  Pump complete II.5.  
 If component is a  Valve complete II.6.

5. General Pump Data

a. Pump	b. Prime-mover
Name _____	Name _____
Mfg. _____	Mfg. _____
Model _____	Model _____
S/N _____	S/N _____
Type _____	Type _____
Size _____	Size _____
Weight _____	Weight _____
Mounting Method _____	Mounting Method _____
Required B.H.P. _____	H.P. _____

NOTE:

\*The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

5. General Pump Data (Continued)

Parameter	Design	Operating
-----------	--------	-----------

Press	_____	_____
-------	-------	-------

Temp	_____	_____
------	-------	-------

Flow	_____	_____
------	-------	-------

Head	_____	_____
------	-------	-------

Power requirements: (include normal, maximum and minimum).

Electrical \_\_\_\_\_

Other \_\_\_\_\_

Required NPSH at maximum

If MOTOR list:

flow \_\_\_\_\_

Duty cycle \_\_\_\_\_

Available NPSH \_\_\_\_\_

Stall current \_\_\_\_\_

Operating Speed \_\_\_\_\_

Class of insulation \_\_\_\_\_

Critical Speed \_\_\_\_\_

List functional accessories:\*

List control signal inputs:

6. General Valve Data

a. Valve

Name TEST BY-PASS TO CONDENSATE STORAGE

Mfg. ANCHOR DARLING

Model NOT ASSIGNED BY VENDOR

S/N 53070

Type GLOBE

Size 10" ANSI CLASS 900

Weight 1760 LBS

Mounting Method WELD ENDS

Required Torque 3443 FT LBS

b. Actuator (if not an integral unit)

Name TEST BY-PASS TO CONDENSATE STORAGE ACTUATOR

Mfg. LIMITORQUE

Model SMB

S/N 385625-C 288336

Type WP

Size 4-200

Weight 1840 LBS

Mounting Method BOLTED

Torque 8300 FT. LBS

NOTE:

\*Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.)



6. General Valve Data (Continued)

Parameter	Design	MAXIMUM Operating
Press	1575 PSIG	1530 PSIG
Temp	212°F	148°F
Flow	*	6110 GPM
Max ΔP across valve	1575 PSI	
Closing time @ max ΔP	50 SEC.	
Opening time @ max ΔP	50 SEC.	
Power requirements for functional accessories, (if any)	NONE	
List control signal inputs:	NONE	
List functional accessories:*	NONE	

Power requirements: (include normal, maximum and minimum).

Electrical 460 V / 3 PHASE / 60 HZ

Other:  Pneumatic  Hydraulic

NONE

\* NOT CRITICAL TO VALVE APPLICATION. VALVE SPECIFIED SAME SIZE AS CONNECTING PIPE

III. FUNCTION

1. Briefly describe components normal and safety functions: \_\_\_\_\_

NORMAL - NOT OPERATING (SYSTEM ISOLATION)

SAFETY - NONE; VALVE IS USED ONLY DURING PUMP TEST.

NOTE: IF AN HPCS PUMP TEST WERE BEING PERFORMED

AT THE TIME OF AN ACCIDENT, VALVE WOULD BE REQUIRED TO CLOSE

2. The components normal state is:  Operating  Standby

3. Safety function: NONE

a.  Emergency reactor shutdown

b.  Containment heat removal

c.  Containment isolation

d.  Reactor heat removal

e.  Reactor core cooling

f.  Prevent significant release of radioactive material to environment

NOTE:

\*Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches).

## 3. Safety function: (Continued)

g.  Does the component function to mitigate the consequences of one or more of the following events?  Yes  No If "Yes", identify.

 LOCA HELB MSLB Other \_\_\_\_\_4. Safety requirements: *NONE* Intermittent Operation During postulated event Continuous Operation Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.

*N/A*

(e.g., hours, days, etc.)

## 5. For VALVES:

does the component

 Fail open Fail closed Fail as is

Is this the fail safe position?

 Yes No*N/A - NOT A SPRING LOADED VALVE*

Is the valve used for throttling purposes?

 Yes No

Is the valve part of the reactor coolant pressure boundary?

 Yes No

Does the valve have a specific limit for leakage?

 Yes No

If "Yes" give limit:

*100 CC/HR*

## IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards

applicable to the component: *SPEC SP-301-4508-∞, REV. I, 10-11-73;**ASME B&PT CODE, SECTION III, NB-3200 & NC-3500,**1971 EDITION, ADDENDA TO WINTER 1973.*

2. Reference those qualification standards, used as a guide to qualify the component: \_\_\_\_\_

*IEEE 323-74**NRC STANDARD REVIEW PLAN 3.9.3 (NUREG 0800)**REV. 1 (7-81)**NRC REG GUIDE 1.48 (3-81)*

3. Identify those parts of the above qualification standards deleted or modified in the qualification program.

Deleted:

NONE

Modified:

NONE

4. Have acceptance criterias been established and documented in the test plan(s) for the component?  Yes  No (ACTUATOR) (TEST NOT PERFORMED ON VALVE)

5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? PERMANENT DEFORMATION OR FAILURE OF YOKE LEGS

6. Are the margins\* identified in the qualification documentation?

Yes  No (ACTUATOR) (TEST NOT PERFORMED ON VALVE)

If component is a PUMP, complete IV.7.

If component is a VALVE, complete IV.8.

7. Pump operability has been demonstrated by:  Analysis

Test  Combination

Identify PUMP tests performed:

a.  Shell hydrostatic (ASME Section III)

b.  Bearing temperature evaluations

c.  Seismic loading

d.  Vibration levels

e.  Exploratory vibration (Fundamental freq. \_\_\_\_\_)

f.  Seal leakage @ hydro press

g.  Aging:  Thermal  Mechanical

h.  Flow performance

Are curves provided  Yes  No

i.  Pipe reaction end loads (nozzle loads)

j.  Others \_\_\_\_\_

k.  Extreme environment:

Humidity

Chemical

Radiation

NOTE:

\*Margin is the difference between design basis parameters and the test parameters used for equipment qualification.

8. Valve operability has been demonstrated by:  Analysis (SEE SHEET 8 & 9)

Test  Combination  
(ACTUATOR)

Identify VALVE tests performed:

a.  Shell hydrostatic

(ASME Section III)

b.  Cold cyclic List times:

Open \_\_\_\_\_

Closed \_\_\_\_\_

c.  Seismic loading (ACTUATOR)

d.  Hot cyclic List times:

Open \_\_\_\_\_

Closed \_\_\_\_\_

e.  Exploratory vibration

(Fundamental freq. \_\_\_\_\_)

f.  Main seat leakage

g.  Aging:  Thermal } (ACTUATOR)  
 Mechanical }

h.  Back seat leakage

i.  Pipe reaction end loading

j.  Disc hydrostatic

k.  Extreme environment (ACTUATOR)

l.  Flow interruption capability

Humidity

Chemical

Radiation

m.  Flow characteristics are

Are curves provided?

Yes  No

n.  Others STATIC DEFLECTION  
ANALYSIS (VALVE)

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified?  Yes  No If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation.

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

10. Was the test component precisely identical (as to model, size, etc.) to the in-plant

component?  Yes  No If "No", is installed component  oversized or

undersized? (ACTUATOR) (TEST NOT PERFORMED ON VALVE)

11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, SECTION 5.?

Yes       No      (ACTUATOR)

12. Is component orientation sensitive?  Yes     No     Unknown

If "Yes", does installed orientation coincide with test orientation?

Yes       No      (ACTUATOR)

13. Is the component mounted in the same manner in-plant as it was during testing (i.e., welded, same number and size bolts, etc.)?

Yes       No       Unknown      (ACTUATOR)

14. Were the qualification tests performed in sequence and on only one component?

Yes       No      (ACTUATOR)

If "Yes" identify sequence, (e.g., radiation, seismic, cyclic, thermal, etc.):

ACCORDING TO IEEE 323 (1974) 6.3.2, 1-6

15. If "aging" was performed, identify the significant aging mechanisms: ACTUATOR

THERMAL

MECHANICAL (CYCLING)

RADIATION (EXPOSURE TO GAMMA RADIATION)

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed:

a.  Plants (shutdown loads)

b.  Extreme environment (ACTUATOR)

c.  Seismic load (ACTUATOR & VALVE)

d.  Others

HYDRODYNAMICS (ACTUATOR ONLY)

17. Have component design specifications been reviewed in-house to assure

they envelope all expected operating, transient, and accident conditions?  Yes     No

NOTE:

\*As outlined in Section 4.4.1 of IEEE-627 1980.

18. Does the component utilize any unique or special materials? (Examples are special gaskets or packing, limitations on nonferrous materials, or special coatings or surfaces.)

Yes  No

If "Yes", identify: \_\_\_\_\_  
\_\_\_\_\_

19. Does component require any special maintenance procedures or practices, (including shorter periods between maintenance).

Yes  No

If "Yes", identify: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

20. Is the qualified life for the component less than 40 years?

Yes  No If "Yes", what is the qualified life? \_\_\_\_\_

\_\_\_\_\_

21. Information Concerning Qualification Documents for the Component

REPORT NUMBER	REPORT TITLE	DATE	COMPANY/ORGANIZATION PREPARING REPORT	COMPANY/ORGANIZATION REVIEWING REPORT
--	DESIGN CALCULATION FOR 10" 900 LB SUBE VALVE WITH SMB-4-200 MOTOR OPERATOR	2-15-83	AUGER DAEUNG VALVE Co.	GENERAL ELECTRIC
B00SB	LIMITORQUE VALVE ACTUATOR QUALIFICATION	1-11-80	LIMITORQUE CORP.	GILBERT COMMONWEALTH
SP-301-4508 00	SPECIFICATION - NUCLEAR STEAM SUPPLY SYSTEM	REV. 1 10-17-73	GILBERT COMMONWEALTH	GILBERT COMMONWEALTH
B011S	HYDRO DYNAMIC VIBRATION TESTING (NEW LOADS)	6-24-82	LIMITORQUE CORPORATION	GILBERT / COMMONWEALTH

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
/			/	/
/			/	/
/			/	/

REVIEWED BY [Signature] 1/18/84

CHECKED BY Stuart W. Litchfield 1/23/84

APPROVED BY [Signature] 1/23/84

THE CLEVELAND ELECTRIC ILLUMINATING COMPANY  
PERRY NUCLEAR POWER PLANT

MEMORANDUM

SO/10914

I no longer wish to  
receive this material.

G-2  
REV. 1-82

TO SQRT Audit File

FROM H. A. Putre

DATE July 24, 1984

SUBJECT PVORT Item B21F0047 (SRV's)

The Equipment Qualification Program for the subject Safety-Relief Valves is still in process. Therefore we are submitting only a partially completed PVORT form for these valves.

At this time Radiation, Aging and Seismic Tests are completed, and Post-LOCA Tests are underway. When completed, these tests will verify environmental, seismic and operability qualification. The Safety-Relief Valve Qualification Program is expected to be completed before Perry I fuel load.

*H. A. Putre*  
Senior Engineer, EQ



1B21F0047B

PUMP AND VALVE  
OPERABILITY ASSURANCE REVIEW

I. PLANT INFORMATION

1. Name: PERRY NPP Unit No. 1 & 2 2. Docket No.: 50-440 & 50-441
3. Utility: CLEVELAND ELECTRIC ILLUMINATING
4. NSSS: GENERAL ELECTRIC  PWR  BWR
5. A/E: GILBERT/COMMONWEALTH

II. GENERAL COMPONENT\* INFORMATION

1. Supplier:  NSSS  BOP
2. Location: a. Building/Room REACTOR - INSIDE DRYWELL  
b. Elevation 630'  
c. System MAIN STEAM
3. Component number on in-house drawings: 1B21F0047B
4. If component is a  Pump complete II.5.  
If component is a  Valve complete II.6.

5. General Pump Data

a. Pump	b. Prime-mover
Name _____	Name _____
Mfg. _____	Mfg. _____
Model _____	Model _____
S/N _____	S/N _____
Type _____	Type _____
Size _____	Size _____
Weight _____	Weight _____
Mounting Method _____	Mounting Method _____
Required B.H.P. _____	H.P. _____

## NOTE:

\*The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

5. General Pump Data (Continued)

Parameter	Design	Operating	Power requirements: (include normal, maximum and minimum).
Press	_____	_____	Electrical _____
Temp	_____	_____	_____
Flow	_____	_____	_____
Head	_____	_____	Other _____
Required NPSH at maximum flow _____			If <u>MOTOR</u> list:
Available NPSH _____			Duty cycle _____
Operating Speed _____			Stall current _____
Critical Speed _____			Class of insulation _____
List functional accessories:*	_____		
_____	_____		
_____	_____		
List control signal inputs:	_____		
_____	_____		

6. General Valve Data

a. Valve	b. Actuator (if not an integral unit)
Name <u>MAIN STEAM RELIEF/SAFETY</u>	Name <u>electro-pneumatic actuator</u>
Mfg. <u>DIKKERS</u>	Mfg. <u>SEMPRESS/SEITZ</u>
Model <u>G 471-6/125.04</u>	Model <u>VB 300/235 EWVS (cylinder)</u>
S/N <u>*</u>	S/N <u>* SEITZ 1166 (AIR VALVE) SEITZ 6A33 (solenoid)</u>
Type <u>DUAL FUNCTION RELIEF/SAFETY</u>	Type <u>pneumatic</u>
Size <u>8" x 10" pipe flange</u>	Size <u>2' x 1" cylinder</u>
Weight <u>~ 3050 lbs</u>	Weight <u>410 lbs.</u>
Mounting Method <u>flanged</u>	Mounting Method <u>bolted</u>
Required Torque <u>1400 ft. lbs. (inlet) 300 ft. lbs. (outlet)</u>	Torque <u>N/A</u>

Bolt

NOTE: \*MPL to S/N association not made until equipment is issued. SRV will not be installed until after system hydro.

\*Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.)

6. General Valve Data (Continued)

Parameter	Design	Operating	Power requirements: (include normal, maximum and minimum).
Press	1375	965 } at 100% PWR	Electrical <u>NONE</u>
Temp	585	540 } same as design	
Flow	811,170 <sup>1/2</sup> / hr	design	
Max ΔP across valve	1123 *		
Closing time @ max ΔP	N/A		Other: <input checked="" type="checkbox"/> Pneumatic <input type="checkbox"/> Hydraulic
Opening time @ max ΔP	N/A		<u>dry air ; 50 micron filtered, 100 psig (90-200 psig prior to operation)</u>
Power requirements for functional accessories, (if any)	125V DC (+10% -15%); .2 AMPS		
List control signal inputs:	<u>Automatic from system pressure, OR manual from the actuation of the solenoid/air cylinder</u>		
List functional accessories:	<u>Solenoid - SEITZ</u>		

\* 1123 relief set pressure for relief mode of SRV OPERATOR VIA THE ELECTRO MAGNETIC ACTUATOR.

III. FUNCTION

- Briefly describe components normal and safety functions: the valve limits the peak pressure in the reactor vessel by automatic relieving when system pressure is too high. the valve opens on signal to limit the thermal transient on the nuclear fuel and/or to depressurize the system to desired level. Normally closed for system integrity
- The components normal state is:  Operating  Standby
- Safety function:
 

a. <input type="checkbox"/> Emergency reactor shutdown	b. <input type="checkbox"/> Containment heat removal
c. <input type="checkbox"/> Containment isolation	d. <input checked="" type="checkbox"/> Reactor heat removal
e. <input type="checkbox"/> Reactor core cooling	f. <input checked="" type="checkbox"/> Prevent significant release of radioactive material to environment

NOTE:

\*Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches).

3. Safety function: (Continued)

g.  Does the component function to mitigate the consequences of one or more of the following events?  Yes  No If "Yes", identify.

- LOCA  HELB  MSLB  
 Other Small line break

4. Safety requirements:

- Intermittent Operation  During postulated event  
 Continuous Operation  Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.

100 days (e.g., hours, days, etc.)

5. For VALVES:

Does the component  Fail open  Fail closed  Fail as is

Is this the fail safe position?  Yes  No

Is the valve used for throttling purposes?  Yes  No

Is the valve part of the reactor coolant pressure boundary?

Yes  No

Does the valve have a specific limit for leakage?  Yes  No

If "Yes" give limit: 20 LL/HR. (EQUIVALENT PER INSTALLED VALVE FOR TOTAL PLANT COMPLIMENT.)

IV. QUALIFICATION

*The remaining portions cannot be completed at present. The equipment is "in test" and qualification is not complete.*

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: \_\_\_\_\_

*Not checked  
7/25/84 HAP/ptw*

2. Reference those qualification standards, used as a guide to qualify the component: \_\_\_\_\_

## PUMP AND VALVE OPERABILITY ASSURANCE REVIEW

### I. PLANT INFORMATION

1. Name: PERRY NPP Unit No. 1 & 2 2. Docket No.: 50-440 & 50-441
3. Utility: CLEVELAND ELECTRIC ILLUMINATING
4. NSSS: GENERAL ELECTRIC  PWR  BWR
5. A/E: GILBERT/COMMONWEALTH

### II. GENERAL COMPONENT\* INFORMATION

1. Supplier:  NSSS  BOP
2. Location: a. Building/Room CONTROL COMPLEX GAI DWG  
D-923-002  
b. Elevation 574' - 10"  
c. System CONTROL COMPLEX CHILLED WATER
3. Component number on in-house drawings: 0247-C001A (13) C
4. If component is a  Pump complete II.5.  
If component is a  Valve complete II.6.
5. General Pump Data
- | a. Pump  | b. Prime-mover                                       |
|--|--|
| Name <u>CONTROL COMPLEX CHILLED WATER PUMP</u>     | Name <u>CONTROL COMPLEX CHILLED WATER PUMP MOTOR</u> |
| Mfg. <u>INGERSOLL-RAND COMPANY</u>                 | Mfg. <u>WESTINGHOUSE</u>                             |
| Model <u>8X14SD</u>                                | Model <u>LIFELINE T</u>                              |
| S/N <u>0378-139 (140) 141</u>                      | S/N <u>- 7901-01-001</u>                             |
| Type <u>HORIZONTAL</u>                             | Type <u>SQUIRREL CAGE</u>                            |
| Size <u>1600 GPM CAPACITY</u>                      | Size <u>FRAME 405 T</u>                              |
| Weight <u>1,060 lbs (BEDPLATE 725 lbs)</u>         | Weight <u>915 lbs</u>                                |
| Mounting Method <u>BOLTED TO BEDPLATE ON FLOOR</u> | Mounting Method <u>BOLTED TO BEDPLATE ON FLOOR</u>   |
| Required B.H.P. <u>72</u>                          | H.P. <u>100</u>                                      |

ABOVE INFORMATION FOUND ON P. 2 OF I-R INSTRUCTION MANUAL

#### NOTE:

96-314-0-02

\*The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

5. General Pump Data (Continued)

Parameter Design Operating

Power requirements: (include normal, maximum and minimum).

DESIGN INFORMATION FOUND ON DSP 644-1

Press 150 PSIG 150 PSIG

Electrical \_\_\_\_\_

Temp 55°F 55°F

RATED VOLTAGE 460 V

OPERATING INFORMATION FOUND ON GAZ DIAG D-923-001

Flow 1600 gpm 1513 gpm

RATED FULL LOAD CURRENT 115 AMPS

Head 130 ft 130 ft

Other \_\_\_\_\_

MOTOR INFORMATION FOUND ON PI 1117-211

NOTE: DESIGN TEMP. IS 120°F FOR NON-OPERATING LOOP D-926-001

Required NPSH at maximum

If MOTOR list:

flow 10 ft

Duty cycle CONTINUOUS

Available NPSH 100 ft

Stall current RATED INRUSH CURRENT 710 AMPS

Operating Speed 1750 RPM

Class of insulation H

Critical Speed 6705 rpm PE-1C Report 016-36421

List functional accessories: \*

List control signal inputs: COMBINED LOCA, LOOP

Ref. GAZ DWG S-802-001 SH P47-02

P2 I-A INSTRUCTION MANUAL

P2 I-R INSTRUCTION MANUAL

Rev II

6. General Valve Data

a. Valve

b. Actuator (if not an integral unit)

Name \_\_\_\_\_

Name \_\_\_\_\_

Mfg. \_\_\_\_\_

Mfg. \_\_\_\_\_

Model \_\_\_\_\_

Model \_\_\_\_\_

S/N \_\_\_\_\_

S/N \_\_\_\_\_

Type \_\_\_\_\_

Type \_\_\_\_\_

Size \_\_\_\_\_

Size \_\_\_\_\_

Weight \_\_\_\_\_

Weight \_\_\_\_\_

Mounting Method \_\_\_\_\_

Mounting Method \_\_\_\_\_

Required Torque \_\_\_\_\_

Torque \_\_\_\_\_

NOTE:

\*Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.)

6. General Valve Data (Continued)

Parameter	Design	Operating	Power requirements: (include normal, maximum and minimum).
Press	_____	_____	Electrical _____
Temp	_____	_____	_____
Flow	_____	_____	_____
Max $\Delta P$ across valve	_____	_____	_____
Closing time @ max $\Delta P$	_____	_____	Other: <input type="checkbox"/> Pneumatic <input type="checkbox"/> Hydraulic
Opening time @ max $\Delta P$	_____	_____	_____
Power requirements for functional accessories, (if any)	_____	_____	_____
List control signal inputs:	_____		
List functional accessories:*	_____		

III. FUNCTION

1. Briefly describe components normal and safety functions: SUPPLY CHILLED WATER TO CONTROL COMPLEX HVAC SYSTEM COOLING COILS DURING NORMAL AND SAFETY OPERATION.

2. The components normal state is:  Operating  Standby ONE PUMP OPERATES AT ANY SPECIFIC TIME. OPERATING TIME SHARED BETWEEN THE THREE PUMPS.

3. Safety function:
- a.  Emergency reactor shutdown
  - b.  Containment heat removal
  - c.  Containment isolation
  - d.  Reactor heat removal
  - e.  Reactor core cooling
  - f.  Prevent significant release of radioactive material to environment
  - g.  OTHER PROVIDES ATMOSPHERIC COOLING TO SAFETY RELATED COMPONENTS.

NOTE:

\*Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches).

## 3. Safety function: (Continued)

g.  Does the component function to mitigate the consequences of one or more of the following events?  Yes  No If "Yes", identify.

 LOCA HELB MSLB Other \_\_\_\_\_

## 4. Safety requirements:

 Intermittent Operation During postulated event Continuous Operation Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.

180 days post LOCA (e.g., hours, days, etc.)

5. For VALVES: NA

does the component  Fail open  Fail closed  Fail as is

Is this the fail safe position?  Yes  No

Is the valve used for throttling purposes?  Yes  No

Is the valve part of the reactor coolant pressure boundary?

Yes  No

Does the valve have a specific limit for leakage?  Yes  No

If "Yes" give limit: \_\_\_\_\_

## IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards

applicable to the component: ASME SECTION III, SUBSECTION NB, ASME

SECTION II, SECTION IX AND SECTION XI ANSI B16.5-1973

USNRC REG. GUIDE 1.4B

2. Reference those qualification standards, used as a guide to qualify the component: \_\_\_\_\_

IEEE 323-1974, IEEE 344-1975, IEEE 334-1974

IEEE 117-1974



3. Identify those parts of the above qualification standards deleted or modified in the qualification program.

Deleted:

Modified:

NONE  
\_\_\_\_\_  
\_\_\_\_\_

NONE  
\_\_\_\_\_  
\_\_\_\_\_

4. Have acceptance criterias been established and documented in the test plan(s) for the component?  Yes  No

5. What is the expected failure mode that would keep the pump - valve assembly from performing its safety function? FEET SHEAR PINS

6. Are the margins\* identified in the qualification documentation?

Yes  No

If component is a PUMP, complete IV.7.

If component is a VALVE, complete IV.8.

7. Pump operability has been demonstrated by:  Analysis

Test  Combination

Identify PUMP tests performed:

a.  Shell hydrostatic (ASME Section III)

b.  Bearing temperature evaluations

c.  Seismic loading

d.  Vibration levels

e.  Exploratory vibration  
(Fundamental freq. \_\_\_\_\_)

f.  Seal leakage @ hydro press

g.  Aging:  Thermal  
 Mechanical

h.  Flow performance

Are curves provided  Yes  No

i.  Pipe reaction end loads  
(nozzle loads)

j.  Others \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

k.  Extreme environment:  
 Humidity  
 Chemical  
 Radiation

NOTE:

\*Margin is the difference between design basis parameters and the test parameters used for equipment qualification.

REV I

III

8. Valve operability has been demonstrated by:  Analysis

Test  Combination

Identify VALVE tests performed:

a.  Shell hydrostatic

(ASME Section III)

b.  Cold cyclic List times:

Open \_\_\_\_\_

Closed \_\_\_\_\_

c.  Seismic loading

d.  Hot cyclic List times:

Open \_\_\_\_\_

Closed \_\_\_\_\_

e.  Exploratory vibration

(Fundamental freq. \_\_\_\_\_)

f.  Main seat leakage

g.  Aging:  Thermal

Mechanical

h.  Back seat leakage

i.  Pipe reaction end loading

j.  Disc hydrostatic

k.  Extreme environment

Humidity

Chemical

Radiation

l.  Flow interruption capability

m.  Flow characteristics are

Are curves provided?

Yes  No

n.  Others \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified?  Yes  No If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation.

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

10. Was the test component precisely identical (as to model, size, etc.) to the in-plant

component?  Yes  No If "No", is installed component  oversized or

undersized? MOTORITE TEST REPRESENTATIVE OF MOTOR  
SEISMIC ANALYSIS BASE ON SAME SIZE MOTOR

11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, SECTION 5.?

- Yes       No (NOT TYPE TESTED)

12. Is component orientation sensitive?  Yes     No     Unknown

If "Yes", does installed orientation coincide with test orientation?

- Yes       No      (ANALYSIS BASED ON PLANT ORIENTATION)

13. Is the component mounted in the same manner in-plant as it was during

<sup>ANALYSIS</sup>  
~~testing~~ (i.e., welded, same number and size bolts, etc.)?

- Yes       No       Unknown

14. Were the qualification tests performed in sequence and on only one component?

- Yes       No      (MOTORETTE TEST)

If "Yes" identify sequence, (e.g., radiation, seismic, cyclic, thermal, etc.):

THERMAL, VOLTAGE, RADIATION, VIBRATION, HUMIDITY  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

15. If "aging" was performed, identify the significant aging mechanisms:

THERMAL  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed:

- a.  Plants (shutdown loads)                      b.  Extreme environment  
c.  Seismic load                                      d.  Others

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

17. Have component design specifications been reviewed in-house to assure they envelope all expected operating, transient, and accident conditions?  Yes     No

NOTE:

\*As outlined in Section 4.4.1 of IEEE-627 1980.

18. Does the component utilize any unique or special materials? (Examples are special gaskets or packing, limitations on nonferrous materials, or special coatings or surfaces.)

Yes  No

If "Yes", identify: \_\_\_\_\_  
\_\_\_\_\_

19. Does component require any special maintenance procedures or practices, (including shorter periods between maintenance).

Yes  No

If "Yes", identify: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

20. Is the qualified life for the component less than 40 years?

Yes  No If "Yes", what is the qualified life? \_\_\_\_\_  
\_\_\_\_\_

21. Information Concerning Qualification Documents for the Component

REPORT NUMBER	REPORT TITLE	DATE	COMPANY/ORGANIZATION PREPARING REPORT	COMPANY/ORGANIZATION REVIEWING REPORT
016-36421	STRUCTURAL INTEGRITY AND OPERABILITY ANALYSIS OF 8X145D PUMP	11-23-82	INGERSOLL-RAND COMPANY	GILBERT ASSOCIATES INC.
MM-9112	QUALIFICATION DOCUMENT CLASS IE MEDIUM A.C. MOTORS	1-18-80	WESTINGHOUSE	GILBERT ASSOCIATES INC.
<del>MM-9112</del>	<del>QUALIFICATION OF WESTINGHOUSE MEDIUM MOTOR AND GEARING DIVISION CLASS IE MOTORS</del>	<del>5-12-77</del>	<del>WESTINGHOUSE</del>	<del>GILBERT ASSOCIATES INC.</del>
-	INSTRUCTION FOR INSTALLATION-OPERATION AND MAINTENANCE OF "S" LINE GENERAL SERVICE PUMPS	2-23-79	INGERSOLL-RAND COMPANY	—

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
I	2-23-83	flf	lsh	pal
II	11-29-83	flf	lsh	pal
III	7-20-84	flf	lsh	lsh

57-644  
 REVIEWED BY J. Fleming 11-21-83  
 CHECKED BY J.F. Fleming 11-25-83  
 APPROVED BY pal JHA/ate 17-20-84

PUMP AND VALVE  
OPERABILITY ASSURANCE REVIEW

B/M RNI 203

I. PLANT INFORMATION

1. Name: PERRY NPP Unit No. 1 & 2 2. Docket No.: 50-440 & 50-441
3. Utility: CLEVELAND ELECTRIC ILLUMINATING
4. NSSS: GENERAL ELECTRIC  PWR  BWR
5. A/E: GILBERT/COMMONWEALTH

II. GENERAL COMPONENT\* INFORMATION

1. Supplier:  NSSS  BOP
2. Location: a. Building/Room AUXILIARY  
 b. Elevation 574 FT  
 c. System P-45 EMERGENCY SERVICE WATER
3. Component number on in-house drawings: 1 P45 FOSTI (A) & B
4. If component is a  Pump complete II.5.  
 If component is a  Valve complete II.6.

5. General Pump Data

a. Pump		b. Prime-mover	
Name	_____	Name	_____
Mfg.	_____	Mfg.	_____
Model	_____	Model	_____
S/N	_____	S/N	_____
Type	_____	Type	_____
Size	_____	Size	_____
Weight	_____	Weight	_____
Mounting Method	_____	Mounting Method	_____
Required B.H.P.	_____	H.P.	_____

NOTE:

\*The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

5. General Pump Data (Continued)

<u>Parameter</u>	<u>Design</u>	<u>Operating</u>	Power requirements: (include normal, maximum and minimum).
Press	_____	_____	Electrical _____
Temp	_____	_____	_____
Flow	_____	_____	_____
Head	_____	_____	Other _____
Required NPSH at maximum			If <u>MOTOR</u> list:
flow _____			Duty cycle _____
Available NPSH _____			Stall current _____
Operating Speed _____			Class of insulation _____
Critical Speed _____			_____
List functional accessories:*	_____		
	_____		
List control signal inputs:	_____		
	_____		

6. General Valve Data

a. Valve	b. Actuator (if not an integral unit)
Name <u>SERVICE WATER VALVE</u>	Name <u>NONE</u>
Mfg. <u>TARGET ROCK</u>	Mfg. _____
Model <u>764-006</u>	Model _____
S/N <u>1, 2</u>	S/N _____
Type <u>RELIEF VALVE</u>	Type _____
Size <u>1 1/2" - 150 x 2" - 150</u>	Size _____
Weight <u>35 LBS.</u>	Weight _____
Mounting Method <u>BOLTED</u>	Mounting Method _____
Required Torque <u>N/A</u>	Torque _____

NOTE:

\*Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.)

## 6. General Valve Data (Continued)

Parameter	Design	Operating	Power requirements: (include normal, maximum and minimum).
Press	150PSI	125PSIG SET PRESS.	Electrical <u>NONE</u>
Temp	150°F	150°F	
Flow	50AGPM	*	
Max $\Delta P$ across valve	17.5 psid		
Closing time @ max $\Delta P$	N/A		Other: <input type="checkbox"/> Pneumatic <input type="checkbox"/> Hydraulic
Opening time @ max $\Delta P$	N/A		<u>NONE</u>
Power requirements for functional accessories, (if any)	<u>NONE</u>		
List control signal inputs:	<u>NONE</u>		
List functional accessories:*	<u>NONE</u>		

\* VARIES WITH PRESSURE AND FLOW AT VALVE INLET

## III. FUNCTION

- Briefly describe components normal and safety functions: VALVE IS LOCATED BETWEEN ISOLATION VALVES OF RHR HEAT EXCHANGER TO PREVENT OVERPRESSURIZATION & POSSIBLE DAMAGE TO EQUIPMENT OR PIPING
- The components normal state is:  Operating  Standby
- Safety function:
  - Emergency reactor shutdown
  - Containment heat removal
  - Containment isolation
  - Reactor heat removal
  - Reactor core cooling
  - Prevent significant release of radioactive material to environment

## NOTE:

\*Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches).



3. Safety function: (Continued)

- g.  Does the component function to mitigate consequences of one or more of the following events?  Yes  No 'If Yes', identify.
- LOCA                       HELB                       MSLB
- Other \_\_\_\_\_

4. Safety requirements:

- Intermittent Operation                       During postulated event
- Continuous Operation                       Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.

N/A (e.g., hours, days, etc.)

5. For VALVES:

does the component N/A  Fail open                       Fail closed                       Fail as is

Is this the fail safe position? N/A  Yes                       No

(NOT APPLICABLE FOR RELIEF VALVE WITHOUT ACTUATOR)

Is the valve used for throttling purposes?  Yes                       No

Is the valve part of the reactor coolant pressure boundary?

Yes                       No

Does the valve have a specific limit for leakage?  Yes                       No

If "Yes" give limit: 15 CC/HR SEAT LEAKAGE (@ 90% OF SET PRESSURE FOR 15 MIN. DURATION - COMPLETED WITHIN 1 HR. AFTER ACTUATION PER SPEC. 523)

IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME BOILER & PRESSURE VESSEL CODE,

SECTION III, DIV. 1, 1974 EDITION TO SUMMER 1975

2. Reference those qualification standards, used as a guide to qualify the component: \_\_\_\_\_

GAI SPEC SP-523-4549-00

NRC STO. REVIEW PLAN 3.9.3

NRC REG. GUIDE 1.48 (3/81)

3. Identify those parts of the above qualification standards deleted or modified in the qualification program.

Deleted:

NONE

Modified:

NONE

4. Have acceptance criterias been established and documented in the test plan(s) for the component?  Yes  No

5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? PERMANENT DEFORMATION OF NECK

6. Are the margins\* identified in the qualification documentation?

Yes  No

If component is a PUMP, complete IV.7.

If component is a VALVE, complete IV.8.

7. Pump operability has been demonstrated by:  Analysis

Test  Combination

Identify PUMP tests performed:

a.  Shell hydrostatic (ASME Section III)

b.  Bearing temperature evaluations

c.  Seismic loading

d.  Vibration levels

e.  Exploratory vibration  
(Fundamental freq. \_\_\_\_\_)

f.  Seal leakage @ hydro press

g.  Aging:  Thermal  
 Mechanical

h.  Flow performance

Are curves provided  Yes  No

i.  Pipe reaction end loads  
(nozzle loads)

j.  Others \_\_\_\_\_

k.  Extreme environment:

Humidity

Chemical

Radiation

NOTE:

\*Margin is the difference between design basis parameters and the test parameters used for equipment qualification.

8. Valve operability has been demonstrated by:  Analysis

Test  Combination

Identify VALVE tests performed:

a.  Shell hydrostatic

(ASME Section III)

b.  Cold cyclic List times:

Open \_\_\_\_\_

Closed \_\_\_\_\_

c.  Seismic loading

d.  Hot cyclic List times:

Open \_\_\_\_\_

Closed \_\_\_\_\_

e.  Exploratory vibration

(Fundamental freq. \_\_\_\_\_)

f.  Main seat leakage

g.  Aging:  Thermal

Mechanical

h.  Back seat leakage

i.  Pipe reaction end loading

j.  Disc hydrostatic

k.  Extreme environment

l.  Flow interruption capability

Humidity

Chemical

Radiation

m.  Flow characteristics are

Are curves provided?

Yes  No

n.  Others SINE BEAT TEST  
RESONANT FREQUENCY  
SEARCH

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified?  Yes  No If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation.

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

10. Was the test component precisely identical (as to model, size, etc.) to the in-plant

component?  Yes  No If "No", is installed component  oversized or  undersized?

11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, SECTION 5.?

Yes N/A  No (NO ELECTRICAL COMPONENTS)

12. Is component orientation sensitive?  Yes  No  Unknown

If "Yes", does installed orientation coincide with test orientation?

Yes  No

13. Is the component mounted in the same manner in-plant as it was during testing (i.e., welded, same number and size bolts, etc.)?

Yes  No  Unknown

14. Were the qualification tests performed in sequence and on only one component?

Yes  No

If "Yes" identify sequence, (e.g., radiation, seismic, cyclic, thermal, etc.):

- (a) PRE-TEST INSPECTION & OPERATIONAL TESTS
- (b) RESONANT FREQUENCY SEARCH
- (c) INPUT MOTION TESTS (SINE BEAT)
- (d) POST-TEST INSPECTION & OPERATIONAL TESTS

15. If "aging" was performed, identify the significant aging mechanisms:

(NOT PERFORMED)

---



---



---

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed:

- a.  Plants (shutdown loads)
- b.  Extreme environment
- c.  Seismic load
- d.  Others

---



---



---

17. Have component design specifications been reviewed in-house to assure they envelope all expected operating, transient, and accident conditions?  Yes  No

NOTE:

\*As outlined in Section 4.4.1 of IEEE-627 1980.

18. Does the component utilize any unique or special materials? (Examples are special gaskets or packing, limitations on nonferrous materials, or special coatings or surfaces.)

Yes  No

If "Yes", identify: \_\_\_\_\_  
\_\_\_\_\_

19. Does component require any special maintenance procedures or practices, (including shorter periods between maintenance).

Yes  No

If "Yes", identify: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

20. Is the qualified life for the component less than 40 years?

Yes  No If "Yes", what is the qualified life? \_\_\_\_\_  
\_\_\_\_\_

21. Information Concerning Qualification Documents for the Component

REPORT NUMBER	REPORT TITLE	DATE	COMPANY/ORGANIZATION PREPARING REPORT	COMPANY/ORGANIZATION REVIEWING REPORT
SP. 523-4549-00	SPECIFICATION - DESIGN, FABRICATION, AND DELIVERY OF SAFETY RELATED RELIEF VALVES	REV. VIII 5-12-82	GILBERT / COMMONWEALTH	GILBERT / COMMONWEALTH
3636	SEISMIC QUALIFICATION TEST REPORT FOR PERRY NUCLEAR POWER PLANT.	REV. 0 11-10-82	TARGET ROCK CORP.	GILBERT / COMMONWEALTH
2196	IMPOSED LOADING REPORT FOR 76H VALVES, WITH ADDENDUM #1	REV. B 4-28-83	TARGET ROCK CORP.	GILBERT / COMMONWEALTH
2206	SEISMIC QUALIFICATION AND ASSURANCE OF OPERABILITY REPORT.	REV. E 7-11-83	TARGET ROCK CORP.	GILBERT / COMMONWEALTH
3672	SUMMARY REPORT "NEW LOADS" APPLIED TO PROJECT 76H	REV. 0 6-10-83	TARGET ROCK CORP.	GILBERT / COMMONWEALTH

REV. NO	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
1	8-3-83	JAD	RHN	KAM
2	87-20-84	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>
	/	/	/	/

REVIEWED BY A. HIRSHBERGER / 2-8-83

CHECKED BY R. H. NEWMAN / 2-9-83

APPROVED BY K. A. MATHEWY / 11-25-83

PUMP AND VALVE  
OPERABILITY ASSURANCE REVIEW

B/M RNN 9

I. PLANT INFORMATION

1. Name: PERRY NPP Unit No. 1 & 2 2. Docket No.: 50-440 & 50-441
3. Utility: CLEVELAND ELECTRIC ILLUMINATING
4. NSSS: GENERAL ELECTRIC  PWR  BWR
5. A/E: GILBERT/COMMONWEALTH

II. GENERAL COMPONENT\* INFORMATION

1. Supplier:  NSSS  BOP
2. Location: a. Building/Room REACTOR  
 b. Elevation 599 FT.  
 c. System P-50 CONTAINMENT VESSEL CHILLED WATER
3. Component number on in-house drawings: 1 P50 F0140
4. If component is a  Pump complete II.5.  
 If component is a  Valve complete II.6.

5. General Pump Data

a. Pump	b. Prime-mover
Name _____	Name _____
Mfg. _____	Mfg. _____
Model _____	Model _____
S/N _____	S/i. _____
Type _____	Type _____
Size _____	Size _____
Weight _____	Weight _____
Mounting Method _____	Mounting Method _____
Required B.H.P. _____	H.P. _____

NOTE:

\*The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

5. General Pump Data (Continued)

<u>Parameter</u>	<u>Design</u>	<u>Operating</u>	Power requirements: (include normal, maximum and minimum).
Press	_____	_____	Electrical _____
Temp	_____	_____	_____
Flow	_____	_____	_____
Head	_____	_____	Other _____
Required NPSH at maximum flow _____			If <u>MOTOR</u> list: _____
Available NPSH _____			Duty cycle _____
Operating Speed _____			Stall current _____
Critical Speed _____			Class of insulation _____
List functional accessories:*	_____		
	_____		
List control signal inputs:	_____		
	_____		

6. General Valve Data

a. Valve INBOARD CONTAINMENT ISOLATION

Name ISOLATION

Mfg. CONTRONATICS

Model C-W 25GG-BB

S/N 34772-16-1

Type BUTTERFLY VALVE

Size 6" - 150LB CLASS

Weight 250LB w/ ACTUATOR

Mounting Method PIPE MOUNTED BETWEEN FLANGES

Required Torque 83 FT-LBS

b. Actuator (if not an integral unit) INBOARD CONTAINMENT ISOLATION VALVE MOTOR OPERATOR

Name VALVE MOTOR OPERATOR

Mfg. LIMITORQUE

Model SMB-000-2 w 1403C

S/N 249096

Type SMB

Size 000-2

Weight 180 LBS

Mounting Method BOLTED

Torque 469 FT LBS

NOTE:

\*Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.)



## 6. General Valve Data (Continued)

Parameter	Design	Operating	Power requirements: (include normal, maximum and minimum).
Press	150 PSIG	±150 PSIG	Electrical 460V, 3φ, 60HZ
Temp	185°F	45-55°F	.13HP
Flow	600 gpm	±600 gpm	
Max ΔP across valve	150 PSI		
Closing time @ max ΔP	30 SEC		Other: <input type="checkbox"/> Pneumatic <input type="checkbox"/> Hydraulic
Opening time @ max ΔP	30 SEC		N/A
Power requirements for functional accessories, (if any)	NONE		
List control signal inputs:	NONE		
List functional accessories:*	NONE		

## III. FUNCTION

- Briefly describe components normal and safety functions:
 

NORMAL - OPEN, ALLOWING CHILLED WATER FLOW FOR CONTAINMENT VESSEL COOLING

SAFETY - CLOSED FOR CONTAINMENT ISOLATION
- The components normal state is:  Operating  Standby
- Safety function:
 

a. <input type="checkbox"/> Emergency reactor shutdown	b. <input type="checkbox"/> Containment heat removal
c. <input checked="" type="checkbox"/> Containment isolation	d. <input type="checkbox"/> Reactor heat removal
e. <input type="checkbox"/> Reactor core cooling	f. <input type="checkbox"/> Prevent significant release of radioactive material to environment

## NOTE:

\*Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches).

3. Safety function: (Continued)

g.  Does the component function to mitigate the consequences of one or more of the following events?  Yes  No If "Yes", identify.

- LOCA
- HELB
- MSLB
- Other \_\_\_\_\_

4. Safety requirements:

- Intermittent Operation
- During postulated event
- Continuous Operation
- Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.

\_\_\_\_\_ N/A \_\_\_\_\_ (e.g., hours, days, etc.)

5. For VALVES:

does the component  Fail open  Fail closer  Fail as is

Is this the fail safe position? N/A  Yes  No

NOT A SPRING LOADED VALVE

Is the valve used for throttling purposes?  Yes  No

Is the valve part of the reactor coolant pressure boundary?

- Yes
- No

Does the valve have a specific limit for leakage?  Yes  No

If "Yes" give limit: 18 cc/HR

IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component:

SPECIFICATION 534, ASME BOILER AND PRESSURE VESSEL CODE SECTION III DIV 1, SUBSECTION NC 3500

2. Reference those qualification standards, used as a guide to qualify the component:

NRC REGULATORY GUIDE 1.48 3/81  
NRC STANDARD REVIEW PLAN 393 (NUREG-0800)  
REV. 1 7/81

3. Identify those parts of the above qualification standards deleted or modified in the qualification program.

Deleted:

NONE

Modified:

NONE

4. Have acceptance criterias been established and documented in the test plan(s) for the component?  Yes  No

5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? NONE

6. Are the margins\* identified in the qualification documentation?

Yes  No

If component is a PUMP, complete IV.7.

If component is a VALVE, complete IV.8.

7. Pump operability has been demonstrated by:  Analysis

Test  Combination

Identify PUMP tests performed:

a.  Shell hydrostatic (ASME Section III)

b.  Bearing temperature evaluations

c.  Seismic loading

d.  Vibration levels

e.  Exploratory vibration  
(Fundamental freq. \_\_\_\_\_)

f.  Seal leakage @ hydro press

g.  Aging:  Thermal  
 Mechanical

h.  Flow performance

Are curves provided  Yes  No

i.  Pipe reaction end loads  
(nozzle loads)

j.  Others \_\_\_\_\_

k.  Extreme environment:

Humidity

Chemical

Radiation

NOTE:

\*Margin is the difference between design basis parameters and the test parameters used for equipment qualification.

8. Valve operability has been demonstrated by:  Analysis

Test  Combination

Identify VALVE tests performed:

a.  Shell hydrostatic VALVE  
(ASME Section III)

b.  Cold cyclic List times:

Open \_\_\_\_\_

Closed \_\_\_\_\_

c.  Seismic loading (VALVE AND ACTUATOR)

d.  Hot cyclic List times:

Open \_\_\_\_\_

Closed \_\_\_\_\_

e.  Exploratory vibration  
(Fundamental freq. \_\_\_\_\_)

f.  Main seat leakage (VALVE)

g.  Aging:  Thermal  
ACTUATOR.  Mechanical

h.  Back seat leakage

i.  Pipe reaction end loading

j.  Disc hydrostatic

k.  Extreme environment (ACTUATOR)

l.  Flow interruption capability

Humidity

Chemical

Radiation

m.  Flow characteristics are

Are curves provided?

Yes  No

n.  Others RESONANCE SURVEY TEST  
MULTIPLE FREQUENCY TEST } VALVE

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified?  Yes  No If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation.

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

10. Was the test component precisely identical (as to model, size, etc.) to the in-plant component?  Yes  No If "No", is installed component  oversized or  undersized?

CONTROLS QUALIFICATION BY SIMILARITY

SEE  
LIMIT  
TORQUE  
QUALI-  
FICATION

11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, SECTION 5.?

SEE  
LIMIT TORQUE  
QUALIFICATION

Yes  No

12. Is component orientation sensitive?  Yes  No  Unknown

If "Yes", does installed orientation coincide with test orientation?

Yes  No

13. Is the component mounted in the same manner in-plant as it was during testing (i.e., welded, same number and size bolts, etc.)?

Yes  No  Unknown

14. Were the qualification tests performed in sequence and on only one component?

SEE  
LIMIT TORQUE  
QUALIFICATION

Yes  No

If "Yes" identify sequence, (e.g., radiation, seismic, cyclic, thermal, etc.):

ACCORDING TO IEEE 323 (1974) 6.3.2, 1-6 (ACTUATOR)

15. If "aging" was performed, identify the significant aging mechanisms: (ACTUATOR)

THERMAL

MECHANICAL (CYCLING)

RADIATION (EXPOSURE TO GAMMA RADIATION)

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed:

a.  Plants (shutdown loads)

b.  Extreme environment (ACTUATOR)

c.  Seismic load (ACTUATOR & VALVE)

d.  Others

HYDRODYNAMIC

17. Have component design specifications been reviewed in-house to assure

they envelope all expected operating, transient, and accident conditions?  Yes  No

NOTE:

\*As outlined in Section 4.4.1 of IEEE-627 1980.

18. Does the component utilize any unique or special materials? (Examples are special gaskets or packing, limitations on nonferrous materials, or special coatings or surfaces.)

Yes  No

If "Yes", identify: \_\_\_\_\_  
\_\_\_\_\_

19. Does component require any special maintenance procedures or practices, (including shorter periods between maintenance).

Yes  No

If "Yes", identify: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

20. Is the qualified life for the component less than 40 years?

Yes  No If "Yes", what is the qualified life? \_\_\_\_\_  
\_\_\_\_\_

21. Information Concerning Qualification Documents for the Component

REPORT NUMBER	REPORT TITLE	DATE	COMPANY/ORGANIZATION PREPARING REPORT	COMPANY/ORGANIZATION REVIEWING REPORT
SP-524-4549-000 REV XIV	SPECIFICATION - DESIGN FABRICATION, AND DELIVERY OF SAFETY RELATED BUTTERFLY AND BALL VALVES	ORIG. 12/13/74 REV XIV 7/30/81	GILBERT/ COMMONWEALTH	GILBERT/ COMMONWEALTH
#B005B	LIMITORQUE VALVE ACTUATOR QUALIFICATION	1-11-80	LIMITORQUE CORP.	GILBERT/ COMMONWEALTH
16243-1	REPORT OF TEST FOR DYNAMIC TESTING OF 1, 8" CONTROMATICS VALVE ASSEMBLY	7-31-81	ENVIRONMENTAL TESTING CORP.	GILBERT/ COMMONWEALTH
B0115	HYDRODYNAMIC VIBRATION TESTING (NEW LOADS)	6-24-82	LIMITORQUE CORPORATION	GILBERT/ COMMONWEALTH

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
/		/	/	/
/		/	/	/
/		/	/	/

REVIEWED BY *[Signature]* 1/7/20/84

CHECKED BY *[Signature]* 1/7/23/84

APPROVED BY *[Signature]* 1/7/23/84

BM RNN 226

PUMP AND VALVE  
OPERABILITY ASSURANCE REVIEW

I. PLANT INFORMATION

1. Name: PERRY NPP Unit No. 1 & 2 2. Docket No.: 50-440 & 50-441
3. Utility: CLEVELAND ELECTRIC ILLUMINATING
4. NSSS: GENERAL ELECTRIC  PWR  BWR
5. A/E: GILBERT/COMMONWEALTH

II. GENERAL COMPONENT\* INFORMATION

1. Supplier:  NSSS  BOP
2. Location: a. Building/Room AUXILIARY
- b. Elevation 574 FT.
- c. System E12 RESIDUAL HEAT REMOVAL
3. Component number on in-house drawings: 1/2 E12 F000G (A) B
4. If component is a  Pump complete II.5.  
If component is a  Valve complete II.6.

5. General Pump Data

a. Pump	b. Prime-mover
Name _____	Name _____
Mfg. _____	Mfg. _____
Model _____	Model _____
S/N _____	S/N _____
Type _____	Type _____
Size _____	Size _____
Weight _____	Weight _____
Mounting Method _____	Mounting Method _____
Required B.H.P. _____	H.P. _____

NOTE:

\*The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.



5. General Pump Data (Continued)

<u>Parameter</u>	<u>Design</u>	<u>Operating</u>	Power requirements: (include normal, maximum and minimum).
Press	_____	_____	Electrical _____
Temp	_____	_____	_____
Flow	_____	_____	_____
Head	_____	_____	Other _____
Required NPSH at maximum flow _____			If <u>MOTOR</u> list:
Available NPSH _____			Duty cycle _____
Operating Speed _____			Stall current _____
Critical Speed _____			Class of insulation _____
List functional accessories:*	_____		
	_____		
List control signal inputs:	_____		
	_____		

6. General Valve Data

a. Valve

Name ISOLATION VALVE  
Mfg. BORG WARNER  
Model 81150  
1E12F0006A 53070  
S/N 1E12F0006B 51899  
Type GATE VALVE  
Size 18" - 300 LB.  
Weight 4600 REPORT NSR 81150  
Mounting Method WELD. END  
Required Torque 730 FT LBS

b. Actuator (if not an integral unit)

Name ISOLATION VALVE MOTOR OPERATOR  
Mfg. LIMITORQUE  
Model SMB  
1E12F0006A 288336  
S/N 1E12F0006B 288337  
Type W.P.  
Size 1-40  
Weight 450 LBS  
Mounting Method BOLTED  
Torque 850 FT. LBS

NOTE:

\*Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.)

6. General Valve Data (Continued)

Parameter	Design	Operating
Press	500 PSIG	16.5 PSIG
Temp	480°F	358°F
Flow	7100 GPM	7100 GPM
Max ΔP across valve	330 PSID	

Power requirements: (include normal, maximum and minimum).

Electrical 460 / 3 / 60  
2.6 HP

TIMES INDICATED ARE ACTUAL TEST TIMES DURING STATIC DEFLECTION. SPEC. RQMT IS 90 SEC.

Closing time @ max ΔP 87.2 SEC

Opening time @ max ΔP 86.8 SEC

Other:  Pneumatic  Hydraulic

NONE

Power requirements for functional accessories, (if any) NONE

List control signal inputs: NONE

List functional accessories: \* NONE

III. FUNCTION

1. Briefly describe components normal and safety functions: \_\_\_\_\_

NORMAL - NOT OPERATING

SAFETY - OPEN TO ALLOW CROSS-FLOW BETWEEN

RHR A & B LOOPS

2. The components normal state is:  Operating  Standby

3. Safety function:

a.  Emergency reactor shutdown

b.  Containment heat removal

c.  Containment isolation

d.  Reactor heat removal

e.  Reactor core cooling

f.  Prevent significant release of radioactive material to environment

NOTE:

\*Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches).

## 3. Safety function: (Continued)

g.  Does the component function to mitigate the consequences of one or more of the following events?  Yes  No If "Yes", identify.

 LOCA HELB MSLB Other \_\_\_\_\_

## 4. Safety requirements:

 Intermittent Operation During postulated event Continuous Operation Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.

FOR LENGTH OF POSTULATED EVENT (e.g., hours, days, etc.)  
(180 DAYS MAX)

## 5. For VALVES:

does the component

 Fail open Fail closed Fail as is

Is this the fail safe position?

 Yes No N/A NOT A SPRING LOADED VALVE

Is the valve used for throttling purposes?

 Yes No

Is the valve part of the reactor coolant pressure boundary?

 Yes No

Does the valve have a specific limit for leakage?

 Yes No

If "Yes" give limit: 180 CC/HR HYDROSTATIC LEAK PER SPEC  
17,100 CC/HR PNEUMATIC " 521-02

## IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards

applicable to the component: ASME BOILER & PRESSURE VESSEL  
CODE, SECTION III, NB 3200 & NC 3500, F71 EDITION  
TO WINTER 1972

2. Reference those qualification standards, used as a guide to qualify the component: \_\_\_\_\_

GAI SPEC. SP-521-02-4549-00IEEE 323-74NRC STD REVIEW PLAN 3.9.3NRC REG. GUIDE 1.48 (3/81)

3. Identify those parts of the above qualification standards deleted or modified in the qualification program.

Deleted:

Modified:

NONE  
\_\_\_\_\_  
\_\_\_\_\_

NONE  
\_\_\_\_\_  
\_\_\_\_\_

4. Have acceptance criterias been established and documented in the test plan(s) for the component?  Yes  No

5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? PERMANENT DEFORMATION OF BONNET FLANGE

6. Are the margins\* identified in the qualification documentation?

Yes  No

If component is a PUMP, complete IV.7.

If component is a VALVE, complete IV.8.

7. Pump operability has been demonstrated by:  Analysis

Test  Combination

Identify PUMP tests performed:

a.  Shell hydrostatic (ASME Section III)

b.  Bearing temperature evaluations

c.  Seismic loading

d.  Vibration levels

e.  Exploratory vibration  
(Fundamental freq. \_\_\_\_\_)

f.  Seal leakage @ hydro press

g.  Aging:  Thermal  
 Mechanical

h.  Flow performance

Are curves provided  Yes  No

i.  Pipe reaction end loads  
(nozzle loads)

j.  Others \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

k.  Extreme environment:  
 Humidity  
 Chemical  
 Radiation

NOTE:

\*Margin is the difference between design basis parameters and the test parameters used for equipment qualification.

8. Valve operability has been demonstrated by:  Analysis

Test  Combination

Identify VALVE tests performed:

a.  Shell hydrostatic

(ASME Section III)

b.  Cold cyclic List times:

Open \_\_\_\_\_

Closed \_\_\_\_\_

c.  Seismic loading

d.  Hot cyclic List times:

Open \_\_\_\_\_

Closed \_\_\_\_\_

e.  Exploratory vibration

(Fundamental freq. \_\_\_\_\_)

f.  Main seat leakage

h.  Back seat leakage

g.  Aging:  Thermal

Mechanical

} ACTUATOR

i.  Pipe reaction end loading

j.  Disc hydrostatic

k.  Extreme environment (ACTUATOR)

l.  Flow interruption capability

Humidity

Chemical

Radiation

m.  Flow characteristics are

Are curves provided?

Yes

No

n.  Others STATIC DEFLECTION (ASSEMBLY)

NSR 81150 REPORT

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified?  Yes  No If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation.

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

10. Was the test component precisely identical (as to model, size, etc.) to the in-plant component?  Yes  No If "No", is installed component  oversized or  undersized? ACTUATOR & VALVE

SGE  
LIMITARQUE  
QUALIFICATION

SEE LIMIT TORQUE QUALIFICATION

11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, SECTION 5.?

Yes  No ACTUATOR

12. Is component orientation sensitive?  Yes  No  Unknown

If "Yes", does installed orientation coincide with test orientation?

Yes  No

13. Is the component mounted in the same manner in-plant as it was during testing (i.e., welded, same number and size bolts, etc.)?

Yes  No  Unknown

14. Were the qualification tests performed in sequence and on only one component?

Yes  No ACTUATOR

If "Yes" identify sequence, (e.g., radiation, seismic, cyclic, thermal, etc.):

ACCORDING TO IEEE 323(1974) 6.3.2.1-6

SEE LIMIT TORQUE QUALIFICATION

15. If "aging" was performed, identify the significant aging mechanisms:

THermal

MECHANICAL (CYCLING)

RADIATION (EXPOSURE TO GAMMA RADIATION)

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed:

a.  Plants (shutdown loads)

b.  Extreme environment (ACTUATOR ONLY)

c.  Seismic load (ACTUATOR & VALVE)

d.  Others

HYDRODYNAMIC (ACTUATOR ONLY)

17. Have component design specifications been reviewed in-house to assure

they envelope all expected operating, transient, and accident conditions?  Yes  No

NOTE:

\*As outlined in Section 4.4.1 of IEEE-627 1980.

18. Does the component utilize any unique or special materials? (Examples are special gaskets or packing, limitations on nonferrous materials, or special coatings or surfaces.)

Yes  No

If "Yes", identify: \_\_\_\_\_  
\_\_\_\_\_

19. Does component require any special maintenance procedures or practices, (including shorter periods between maintenance).

Yes  No

If "Yes", identify: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

20. Is the qualified life for the component less than 40 years?

Yes  No If "Yes", what is the qualified life? \_\_\_\_\_  
\_\_\_\_\_

21. Information Concerning Qualification Documents for the Component

REPORT NUMBER	REPORT TITLE	DATE	COMPANY/ORGANIZATION PREPARING REPORT	COMPANY/ORGANIZATION REVIEWING REPORT
SP-21-02	SPECIFICATION-DESIGN, FABRICATION AND DELIVERY OF SAFETY RELATED GATE, GLOBE AND CHECK VALVES 2 1/2" & LARGER	6-10-75 (ORIG.) 3-4-82 Rev. XIV	GILBERT/ COMMONWEALTH	GILBERT/ COMMONWEALTH
NSR81150	SEISMIC ANALYSIS OF 18" BOOB CARBON STEEL MOTOR OPERATED GATE VALVE	REV. C 4-21-80	BORG WARNER	GILBERT/ COMMONWEALTH
BOO 58	LIMITROQUE VALVE ACTUATOR QUALIFICATION	1-11-80	LIMITROQUE CORP.	GILBERT/ COMMONWEALTH
BO115	HYDRODYNAMIC VIBRATION TESTING (NEW LOADS)	6-24-82	LIMITROQUE CORPORATION	GILBERT/ COMMONWEALTH

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
/		/	/	/
/		/	/	/
/		/	/	/

REVIEWED BY *[Signature]* 1/19/84  
 CHECKED BY *[Signature]* 1/23/84  
 APPROVED BY *[Signature]* 1/23/84



PUMP AND VALVE  
OPERABILITY ASSURANCE REVIEW

I. PLANT INFORMATION

1. Name: PERRY NPP Unit No. 1 & 2 2. Docket No.: 50-440 & 50-441  
3. Utility: CLEVELAND ELECTRIC ILLUMINATING  
4. NSSS: GENERAL ELECTRIC  PWR  BWR  
5. A/E: GILBERT/COMMONWEALTH

II. GENERAL COMPONENT\* INFORMATION

1. Supplier:  NSSS  BOP  
2. Location: a. Building/Room INTERMEDIATE  
b. Elevation 624'  
c. System MSI - COMBUSTIBLE GAS CONTROL  
3. Component number on in-house drawings: RNN 279 MSI F0110  
4. If component is a  Pump complete II.5.  
If component is a  Valve complete II.6.

5. General Pump Data

a. Pump

Name \_\_\_\_\_  
Mfg \_\_\_\_\_  
Model \_\_\_\_\_  
S/N \_\_\_\_\_  
Type \_\_\_\_\_  
Size \_\_\_\_\_  
Weight \_\_\_\_\_  
Mounting Method \_\_\_\_\_  
Required B.H.P. \_\_\_\_\_

b. Prime-mover

Name \_\_\_\_\_  
Mfg \_\_\_\_\_  
Model \_\_\_\_\_  
S/N \_\_\_\_\_  
Type \_\_\_\_\_  
Size \_\_\_\_\_  
Weight \_\_\_\_\_  
Mounting Method \_\_\_\_\_  
H.P. \_\_\_\_\_

NOTE:

\*The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

5. General Pump Data (Continued)

Parameter	Design	Operating	Power requirements: (include normal, maximum and minimum).
Press	_____	_____	Electrical _____
Temp	_____	_____	_____
Flow	_____	_____	_____
Head	_____	_____	Other _____
Required NPSH at maximum flow _____			If <u>MOTOR</u> list:
Available NPSH _____			Duty cycle _____
Operating Speed _____			Stall current _____
Critical Speed _____			Class of insulation _____
List functional accessories* _____			_____
_____			_____
_____			_____
List control signal inputs: _____			_____
_____			_____

6. General Valve Data

a. Valve

Name OUTBOARD CONTAINMENT ISOLATION VALVE

Mfg. ROCKWELL INTERNATIONAL

Model 150 14 MPT 2

S/N BH940

Type ANGLE-GLOBE

Size 2" 1500 LB CLASS

Weight 70 LB

Mounting Method PIPE MOUNTED

Required Torque 34 FT. POUNDS

b. Actuator (if not an integral unit)

Name OUTBOARD CONTAINMENT ISOLATION VALVE MOTOR ACTUATOR

Mfg. LIMIFORQUE

Model SMB-000-2

S/N 347412

Type SMB

Size 000-2

Weight 170 LB.

Mounting Method BOLTED TO VALVE YUKO FLANGE

Torque 56 FT. POUNDS  
AVAIL

NOTE:

\*Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.)

6. General Valve Data (Continued)

GAI DWG.  
302-831  
SP  
531-06

Parameter	Design	Operating
Press (IN. H <sub>2</sub> O) ABS.	1238	537
Temp (°F)	330	175
Flow (SEFM)	50	50
Max ΔP across valve	600 PSI	
Closing time @ max ΔP	MFR. STD.	
Opening time @ max ΔP	MFR. STD.	

Power requirements: (include normal, maximum and minimum).  
Electrical 460v, 3φ, 60Hz  
.13 HP  
Other:  Pneumatic  Hydraulic  
N/A

Power requirements for functional accessories, (if any) NONE  
List control signal inputs: NONE

List functional accessories: \* NONE

III. FUNCTION

1. Briefly describe components normal and safety functions:

NORMALLY OPEN  
CLOSE FOR CONTAINMENT ISOLATION

2. The components normal state is  Operating  Standby

3. Safety function

- a.  Emergency reactor shutdown
- b.  Containment heat removal
- c.  Containment isolation
- d.  Reactor heat removal
- e.  Reactor core cooling
- f.  Prevent significant release of radioactive material to environment

NOTE:

\*Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches).

3. Safety function: (Continued)

g.  Does the component function to mitigate the consequences of one or more of the following events?  Yes  No If "Yes", identify.

- LOCA  HZLB  MSLB  
 Other \_\_\_\_\_

4. Safety requirements:

- Intermittent Operation  During postulated event.  
 Continuous Operation  Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.

100 DAYS (e.g., hours, days, etc.)

5. For VALVES:

does the component  Fail open  Fail closed  Fail as is <sup>NOT A SPRING LOADED ACTUATOR</sup>  
 Is this the fail safe position?  Yes  No N/A

Is the valve used for throttling purposes?  Yes  No

Is the valve part of the reactor coolant pressure boundary?

Yes  No

Does the valve have a specific limit for leakage?  Yes  No

If "Yes" give limit: HYDROSTATIC SEAT LEAKAGE - 20 CC/HR. MAX.  
PNEUMATIC SEAT LEAKAGE 1900 CC/HR. MAX.

IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards

applicable to the component: SPECIFICATION SP 531-06, ASME  
B&PV Code, SECTION III, SUBSECTION NCA, NB  
& SECTION III APPENDICES, 1974 EDITION, WINTER 1972  
ADDENDA FOR CLASS 2 or 3 VALVES

2. Reference those qualification standards, used as a guide to qualify the component:

NRC REG. GUIDE 1.48 3/81  
NRC STD. REVIEW PLAN 3.93 (NUREG 0800)  
REV. 1 7/81  
IEEE 382-1980

3. Identify those parts of the above qualification standards deleted or modified in the qualification program.

Deleted:

Modified:

NONE  
\_\_\_\_\_  
\_\_\_\_\_

NONE  
\_\_\_\_\_  
\_\_\_\_\_

4. Have acceptance criterias been established and documented in the test plan(s) for the component?  Yes  No

5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? NONE APPARENT FROM REPORT  
UNE 83-27

6. Are the margins\* identified in the qualification documentation?

Yes  No

If component is a PUMP, complete IV.7.

If component is a VALVE, complete IV.8.

7. Pump operability has been demonstrated by:  Analysis

Test  Combination

Identify PUMP tests performed:

a.  Shell hydrostatic (ASME Section III)

b.  Bearing temperature evaluations

c.  Seismic loading

d.  Vibration levels

e.  Exploratory vibration  
(Fundamental freq. \_\_\_\_\_)

f.  Seal leakage @ hydro press

g.  Aging:  Thermal  
 Mechanical

h.  Flow performance

Are curves provided  Yes  No

i.  Pipe reaction end loads  
(nozzle loads)

j.  Others \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

k.  Extreme environment:

Humidity

Chemical

Radiation

NOTE:

\*Margin is the difference between design basis parameters and the test parameters used for equipment qualification.

8. Valve operability has been demonstrated by:  Analysis

Test  Combination

Identify VALVE tests performed:

a.  Shell hydrostatic

(ASME Section III)

b.  Cold cyclic List times:

Open \_\_\_\_\_

Closed \_\_\_\_\_

c.  Seismic loading (VALUE ANALYSIS)

d.  Hot cyclic List times:

Open \_\_\_\_\_

Closed \_\_\_\_\_

e.  Exploratory vibration

(Fundamental freq. \_\_\_\_\_)

f.  Main seat leakage

g.  Aging:  Thermal

Mechanical

h.  Back seat leakage

i.  Pipe reaction end loading (VALUE ANALYSIS)

j.  Disc hydrostatic

k.  Extreme environment (ACTUATOR ONLY)

l.  Flow interruption capability

Humidity

Chemical

Radiation

m.  Flow characteristics are

Are curves provided?

Yes  No

n.  Others MODAL TEST (VALUE)  
STATIC OPERABILITY TEST  
(VALUE)

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified?  Yes  No If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation.

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

10. Was the test component precisely identical (as to model, size, etc.) to the in-plant component?  Yes  No If "No", is installed component  oversized or  undersized?

SEE  
LIMITORQUE  
QUALIFICATION

SEE  
LIMITORQUE  
QUALIFICATION

11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, SECTION 5? ACTUATOR

SEE  
LIMIT-TORQUE  
QUALIFICATION

Yes  No

12. Is component orientation sensitive?  Yes  No  Unknown

If "Yes", does installed orientation coincide with test orientation?

Yes  No

13. Is the component mounted in the same manner in-plant as it was during testing (i.e., welded, same number and size bolts, etc.)?

Yes  No  Unknown

14. Were the qualification tests performed in sequence and on only one component?

Yes  No

If "Yes" identify sequence, (e.g., radiation, seismic, cyclic, thermal, etc.):

ACCORDING TO IEEE 323 (1974) G.3.2, I-G (ACTUATOR)

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

SEE  
LIMIT-TORQUE  
QUALIFICATION

15. If "aging" was performed, identify the significant aging mechanisms:

THERMAL

MECHANICAL CYCLING

RADIATION

\_\_\_\_\_  
\_\_\_\_\_

16. Identify loads imposed (assumed) on the component for the qualification

tests (analysis) performed:

a.  Plants (shutdown loads)

b.  Extreme environment (ACTUATOR)  
SEE LIMIT-TORQUE QUALIFICATION

c.  Seismic load

d.  Others

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

17. Have component design specifications been reviewed in-house to assure

they envelope all expected operating, transient, and accident conditions?  Yes  No

NOTE:

\*As outlined in Section 4.4.1 of IEEE-627 1980.

18. Does the component utilize any unique or special materials? (Examples are special gaskets or packing, limitations on nonferrous materials, or special coatings or surfaces.)

Yes  No

If "Yes", identify: \_\_\_\_\_  
\_\_\_\_\_

19. Does component require any special maintenance procedures or practices, (including shorter periods between maintenance).

Yes  No

If "Yes", identify: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

20. Is the qualified life for the component less than 40 years?

Yes  No

If "Yes", what is the qualified life? \_\_\_\_\_  
\_\_\_\_\_



21. Information Concerning Qualification Documents for the Component

REPORT NUMBER	REPORT TITLE	DATE	COMPANY/ORGANIZATION PREPARING REPORT	COMPANY/ORGANIZATION REVIEWING REPORT
SP-531-06 4549-000 REV VI	SPECIFICATION - DESIGN, FABRICATION, AND DELIVERY OF SAFETY RELATED GATE, GLOBE, AND CHECK VALVES	ORIGINAL 3/2/81 REV. VI 1/27/84	GILBERT/COMMON-WEALTH	GILBERT/COMMON-WEALTH
B0058	LIMITORQUE VALVE ACTUATOR QUALIFICATION	1-11-80	LIMITORQUE CORP.	GILBERT/COMMON WEALTH
WR 83-27 REV. B	QUALIFICATION OF FIVE MOTOR OPERATED VALVE ASSEMBLIES	12-2-83	WYLE LABORATORIES RESEARCH STAFF	GILBERT/COMMON WEALTH
WR 84-13 REV. B	QUALIFICATION OF A MOTOR OPERATED VALVE ASSEMBLY	6/84	WYLE LABORATORIES RESEARCH STAFF	GILBERT/COMMON WEALTH
B0115	HYDRODYNAMIC VIBRATION TESTING (NEW LOADS)	6-24-82	LIMITORQUE CORPORATION	GILBERT/COMMONWEALTH

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
/		/	/	/
/		/	/	/
/		/	/	/

REVIEWED BY L. H. Newman 1/7/84

CHECKED BY [Signature] 7/12/84

APPROVED BY [Signature] 7/23/84

PUMP AND VALVE  
OPERABILITY ASSURANCE REVIEW BM No. RUG 12

I. PLANT INFORMATION

1. Name: PERRY NPP Unit No. 1 & 2 2. Docket No.: 50-440 & J-441
3. Utility: CLEVELAND ELECTRIC ILLUMINATING
4. NSSS: GENERAL ELECTRIC  PWR  BWR
5. A/E: GILBERT/COMMONWEALTH

II. GENERAL COMPONENT\* INFORMATION

1. Supplier:  NSSS  BOP
2. Location: a. Building/Room REACTOR
- b. Elevation 664 FT.
- c. System DRYWELL VACUUM RELIEF
3. Component number on in-house drawings: MIG FOZO (A) & B
4. If component is a  Pump complete II.5.  
If component is a  Valve complete II.6.

~~5. General Pump Data~~

<del>a. Pump</del>		<del>b. Prime-mover</del>	
<del>Name</del>	<del>_____</del>	<del>Name</del>	<del>_____</del>
<del>Mfg.</del>	<del>_____</del>	<del>Mfg.</del>	<del>_____</del>
<del>Model</del>	<del>_____</del>	<del>Model</del>	<del>_____</del>
<del>S/N</del>	<del>_____</del>	<del>S/N</del>	<del>_____</del>
<del>Type</del>	<del>_____</del>	<del>Type</del>	<del>_____</del>
<del>Size</del>	<del>_____</del>	<del>Size</del>	<del>_____</del>
<del>Weight</del>	<del>_____</del>	<del>Weight</del>	<del>_____</del>
<del>Mounting Method</del>	<del>_____</del>	<del>Mounting Method</del>	<del>_____</del>
<del>Required B.H.P.</del>	<del>_____</del>	<del>H.P.</del>	<del>_____</del>

NOTE:

\*The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

5. General Pump Data (Continued)

<u>Parameter</u>	<u>Design</u>	<u>Operating</u>	Power requirements: (include normal, maximum and minimum).
Press	_____	_____	Electrical _____
Temp	_____	_____	_____
Flow	_____	_____	_____
Head	_____	_____	Other _____
Required NPSH at maximum flow _____	If <u>MOTOR</u> list:		
Available NPSH _____	Duty cycle _____		
Operating Speed _____	Stall current _____		
Critical Speed _____	Class of insulation _____		
List functional accessories:*	_____		
_____	_____		
_____	_____		
List control signal inputs: _____	_____		
_____	_____		

6. General Valve Data

a. Valve	b. Actuator (if not an integral unit) N/A (SEE SECTION II.G - CONTROL SIGNAL INPUTS)
Name <u>DRYWELL VACUUM BREAKER</u>	Name _____
Mfg. <u>GPE CONTROLS</u>	Mfg. _____
Model <u>LD-240-339</u>	Model _____
S/N <u>AA109305A</u>	S/N _____
Type <u>VACUUM RELIEF</u>	Type _____
Size <u>10" 150LB ANSI CLASS</u>	Size _____
Weight <u>164 LB</u>	Weight _____
Mounting Method <u>FLANGED HORIZONTAL PIPE</u>	Mounting Method _____
Required Torque <u>N/A</u>	Torque _____

NOTE:

\*Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational (e.g., coupling, lubricating oil system, etc.)

## 6. General Valve Data (Continued)

Parameter	Design	Operating	Power requirements: (include normal, maximum and minimum).
Press	25.0 PSIG	-0.5 PSIG	Electrical <u>N/A</u>
Temp	330°F	135°F	
Flow	N/A	NOT NORMALLY FLOWING	
Max $\Delta P$ across valve	21 PSI		
Closing time @ max $\Delta P$	NORMALLY CLOSED		Other: <input type="checkbox"/> Pneumatic <input type="checkbox"/> Hydraulic
Opening time @ max $\Delta P$	NOT SPECIFIED		<u>N/A</u>
Power requirements for functional accessories, (if any)	N/A		

List control signal inputs: VALVE IS EQUIPPED WITH A PNEUMATIC CYLINDER AND REMOTE ELECTRICAL SWITCH TO TEST OPEN/CLOSE CAPABILITY OF VALVE. THIS ARRANGEMENT IS NOT REQUIRED FOR THE VALVE TO PERFORM ITS SAFETY FUNCTION

List functional accessories: N/A

## III. FUNCTION

- Briefly describe components normal and safety functions:
  - SAFETY - VALVE REMAINS IN CLOSED POSITION
  - NORMAL - VALVE OPENS TO RELIEVE VACUUM IN DRYWELL WHEN ABNORMAL CONDITIONS EXIST
- The components normal state is:  Operating  Standby (CLOSED)
- Safety function:
  - Emergency reactor shutdown
  - Containment heat removal
  - Containment isolation
  - Reactor heat removal
  - Reactor core cooling
  - Prevent significant release of radioactive material to environment

## NOTE:

\*Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational (e.g., limit switches).

3. Safety function: (Continued)

g.  Does the component function to mitigate the consequences of one or more of the following events?  Yes  No If "Yes", identify.

LOCA  HELB  MSLB

Other REMAIN CLOSED TO ISOLATE DRYWELL FROM LOCA, HELB AND SMALL LINE BREAK

4. Safety requirements:

N/A SAFETY REQUIREMENT STATED ABOVE

NON-SAFETY  
OR  
NORMAL  
REQ'TS

- Intermittent Operation  During postulated event
- Continuous Operation  Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.

UNTIL VACUUM CONDITION IN DRYWELL NO LONGER EXISTS (180 DAYS MAX.) (e.g., hours, days, etc.)

5. For VALVES:

does the component  Fail open  Fail closed  Fail as is N/A (SEE NOTE BELOW\*)

Is this the fail safe position?  Yes  No N/A (SEE NOTE BELOW\*)

Is the valve used for throttling purposes?  Yes  No

Is the valve part of the reactor coolant pressure boundary?

Yes  No

Does the valve have a specific limit for leakage?  Yes  No

If "Yes" give limit: \_\_\_\_\_

IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards

applicable to the component: SPECIFICATION 635, ANSI B16.5-1973

ASME BOILER & PRESSURE VESSEL CODE, SECTION III

DIV. 1, SUBSECTION NC (FOR CLASS 2 COMPONENTS)

SEISMIC CLASS 1, 1974 THRU WINTER 1975

2. Reference those qualification standards, used as a guide to qualify the component: \_\_\_\_\_

NRC REGULATORY GUIDE 1.48 STANDARD

REVIEW PLAN 3.93 (NREG 0800)

\* NOTE : CHECK VALVES NOT CONSIDERED TO HAVE ANY PARTICULAR FAILURE MODE.

3. Identify those parts of the above qualification standards deleted or modified in the qualification program.

Deleted:

NONE

Modified:

NONE

4. Have acceptance criterias been established and documented in the test plan(s) for the component?  Yes  No N/A NO TEST

5. What is the expected failure mode that would keep the pump or valve assembly from performing its safety function? PERMANENT DISTORTION OF THE HINGE PIN

6. Are the margins\* identified in the qualification documentation?

Yes  No

If component is a PUMP, complete IV.7.

If component is a VALVE, complete IV.8.

7. Pump operability has been demonstrated by:  Analysis

Test  Combination

Identify PUMP tests performed:

a.  Shell hydrostatic (ASME Section III)

b.  Bearing temperature evaluations

c.  Seismic loading

d.  Vibration levels

e.  Exploratory vibration  
(Fundamental freq. \_\_\_\_\_)

f.  Seal leakage @ hydro press

g.  Aging:  Thermal  
 Mechanical

h.  Flow performance

Are curves provided  Yes  No

i.  Pipe reaction end loads  
(nozzle loads)

j.  Others \_\_\_\_\_

k.  Extreme environment:

Humidity

Chemical

Radiation

NOTE:

\*Margin is the difference between design basis parameters\* and the test parameters used for equipment qualification.

8. Valve operability has been demonstrated by:  Analysis

Test  Combination

ONLY a & f BELOW  
Identify VALVE tests performed:

a.  Shell hydrostatic  
(ASME Section III)

b.  Cold cyclic List times:  
Open \_\_\_\_\_  
Closed \_\_\_\_\_

c.  Seismic loading

d.  Hot cyclic List times:  
Open \_\_\_\_\_  
Closed \_\_\_\_\_

e.  Exploratory vibration  
(Fundamental freq. \_\_\_\_\_)

f.  Main seat leakage

g.  Aging:  Thermal  
 Mechanical

h.  Back seat leakage

i.  Pipe reaction end loading

j.  Disc hydrostatic

k.  Extreme environment  
 Humidity  
 Chemical  
 Radiation

l.  Flow interruption capability

m.  Flow characteristics are  
Are curves provided?  
 Yes  No

n.  Others \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

9. As a result of any of the tests (or analysis), were any deviations from design requirements identified?  Yes  No If "Yes", briefly describe any changes made in tests (or analysis) or to the component to correct the deviation.

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

10. Was the test component precisely identical (as to model, size, etc.) to the in-plant component?  Yes  No If "No", is installed component  oversized or  undersized?

11. If type test was used to qualify the component, does the type test meet the requirements of IEEE 323-1974, SECTION 5.?

Yes       No      N/A ANALYSIS

12. Is component orientation sensitive?  Yes     No     Unknown

If "Yes", does installed orientation coincide with <sup>ANALYSIS</sup> test orientation?

Yes       No

13. Is the component mounted in the same manner in-plant as it was during testing (i.e., welded, same number and size bolts, etc.)?

Yes       No       Unknown      N/A

14. Were the qualification tests performed in sequence and on only one component?

Yes       No      N/A

If "Yes" identify sequence, (e.g., radiation, seismic, cyclic, thermal, etc.):

---



---



---



---

15. If "aging" was performed, identify the significant aging mechanisms:

N/A

---



---



---



---

16. Identify loads imposed (assumed) on the component for the qualification tests (analysis) performed:

- a.  Plants (shutdown loads)
- b.  Extreme environment
- c.  Seismic load + HYDRODYNAMIC
- d.  Others

---



---



---

17. Have component design specifications been reviewed in-house to assure they envelope all expected operating, transient, and accident conditions?  Yes     No

NOTE:

\*As outlined in Section 4.4.1 of IEEE-627 1980.



18. Does the component utilize any unique or special materials? (Examples are special gaskets or packing, limitations on nonferrous materials, or special coatings or surfaces.)

Yes    No

If "Yes", identify: NORDEL EPT (EPDM) SEATS - ACCEPTABLE  
FOR RADIATION LEVELS PRESENT. (EPT SEATS GOOD TO  
1 x 10<sup>8</sup> RADS)

19. Does component require any special maintenance procedures or practices, (including shorter periods between maintenance).

Yes    No

If "Yes", identify: REMOTE MANUAL TESTING REQUIRED  
PERIODICALLY. I.E. OPEN / CLOSE VALVE WITH  
PNEUMATIC CYLINDER OPERATOR,

20. Is the qualified life for the component less than 40 years?

Yes    No   If "Yes", what is the qualified life? \_\_\_\_\_

21. Information Concerning Qualification Documents for the Component

REPORT NUMBER	REPORT TITLE	DATE	COMPANY/ORGANIZATION PREPARING REPORT	COMPANY/ORGANIZATION REVIEWING REPORT
SP-635 4599-00 REV. VII	CONTAINMENT AND DRYWELL VACUUM RELIEF VALVES SPECIFICATION	APRIL 9 1978 ORIGINAL  JAN. 5 1982 REV VIII	GILBERT/ COMMONWEALTH	GILBERT/ COMMONWEALTH
LA-241- 184-1 REV. 0 ADDENDUM 1	STRESS ANALYSIS FOR SEISMIC AND OPERATING CONDITIONS OF MODEL LD 240-339 VACUUM BREAKER	JULY 19 1978	GPE CONTROLS DIV. VAPOR CORP.	GILBERT/ COMMONWEALTH

REV. NO.	DATE	INITIALS		
		REVIEW	CHECKED	APPROVED
/		/	/	/
/		/	/	/
/		/	/	/

REVIEWED BY *[Signature]* 1/21/84

CHECKED BY *[Signature]* 1/23/84

APPROVED BY *[Signature]* 7/23/84