



**PUBLIC SERVICE COMPANY OF COLORADO**

P. O. BOX 840 · DENVER, COLORADO 80201

OSCAR R. LEE  
VICE PRESIDENT

July 25, 1984  
Fort St. Vrain  
Unit No. 1  
P-84230

50-267

Mr. Eric H. Johnson  
Reactor Project Branch Chief  
Region IV  
Nuclear Regulatory Commission  
611 Ryan Plaza Drive  
Suite 1000  
Arlington, Texas 76011

DOCKET NO. 50-267

SUBJECT: Fort St. Vrain Building 10

REFERENCE: NRC Letter Dated June 25, 1984  
from Mr. J. T. Collins to  
Mr. O.R. Lee (G-84208)

Dear Mr. Johnson:

This letter is in response to the NRC concerns, regarding Building 10 at Fort St. Vrain, as indicated in the referenced letter. PSC's reply to the individual concerns are contained in Attachment A.

The concept to construct additional facilities was finalized within PSC in 1981. The NRC was aware of the pending construction of Building 10 through conversations with PSC as early as the latter part of 1981. Over the years, additional equipment installed to meet requirements had filled all available space within the existing three-room complex. The 480 Volt Room was experiencing higher temperatures than PSC felt desirable for electrical equipment. The Auxiliary Electric Equipment Room was becoming crowded and additional equipment installation was extremely difficult. PSC arrived at the point where continuing requirements to add equipment dictated that additional space must be made available. Thus the concept of Building 10 was finalized, to relieve the crowding conditions which were compounding and to accommodate the equipment replacements being planned by PSC.

The function of Building 10 is to provide protection for safety related equipment, however access to Building 10 is not required

Hoos  
//

8408030168 840725  
PDR ADDCK 05000267  
F PDR

during emergency conditions to operate equipment for safe shutdown of the plant. Please refer to Table 2 of Attachment A for a listing of the safety related equipment that is installed in Building 10.

The design, construction and documentation of Building 10, its concomitant components and the operating equipment it houses were all accomplished by approved Change Notices and Controlled Work Procedures as stipulated by our approved procedures. A copy of the safety evaluation and design criteria/analysis portion for each of the change notices outlined below is included as Attachment B. A brief description of the CNs associated with Building 10 follows:

- CN-1460: Design and construct structural portion of Building 10 and Walkover Structure.
- CN-1461: Design and construct mechanical portion of HVAC and fire protection for Building 10.
- CN-1462: Install electrical equipment and devices in Building 10. General areas covered are: lighting, fire protection, grounding, cable trays, power, communication, ducts, relocation of underground obstructions, and HVAC.
- CN-1255: Upgrade 120V instrument power buses.
- CN-1332: Upgrade 120V instrument power buses.
- CN-1391: Replace station batteries 1A and 1B, and instrument battery 1C (PPS). NOTE: Portions of CN involving batteries 1A and 1B are not associated with the Building 10 project.
- CN-1781: Install fire protection wrap on portion of cable trays.

During preparation of the original safety evaluations (Attachment B) for this project, PSC determined that the design and construction of Building 10 did not require a change in the Technical Specifications and was not an unreviewed safety question. These evaluations were performed in accordance with the provisions of 10CFR50.59, and therefore the modification did not require prior Commission approval. The construction and use of Building 10 constitutes a modification that does not require an amendment of the operating license. As a result 10CFR50.92 does not apply, and a construction permit was not required.

If you have any questions on these items, please contact Mr. M.H. Holmes at (303) 571-8409.

Very truly yours,



O. R. Lee, Vice President  
Electric Production

ORL/JT:pa

Attachment

cc: J.T. Collins

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION


In the Matter

Public Service Company of Colorado  
Fort St. Vrain Unit No. 1

)  
)  
) Docket No. 50-267


AFFIDAVIT

O. R. Lee, being duly sworn, hereby deposes and says that he is Vice President of Public Service Company of Colorado; that he is duly authorized to sign and file with the Nuclear Regulatory Commission the attached response to the letter dated June 25, 1984, from J.T. Collins to O.R. Lee; that he is familiar with the content thereof; and that the matters set forth therein are true and correct to the best of his knowledge, information and belief.

  
\_\_\_\_\_  
O. R. Lee  
Vice President

STATE OF Colorado )  
COUNTY OF Denver )

Subscribed and sworn to before me, a Notary Public on this 25<sup>th</sup>  
day of July, 1984.

  
\_\_\_\_\_  
Notary Public  
4026 E. 113<sup>rd</sup> Place  
Denver, CO 80233

My commission expires August 19, 1987.

ITEM 1

NRC CONCERN

The safety evaluation contained in the Change Notice for the construction of Building 10 (CN-1460) concludes that the activity does not appear to involve an unreviewed safety question nor does it appear to be safety significant. We assume the basis for these conclusions is the statement that "the design criteria for the new structure meets or exceeds that applicable to the original plant." In order for us to determine your compliance with the provisions of 10 CFR Parts 50.59 and 50.92 we request that you provide a comparison of all applicable design criteria utilized for Building 10 to those of the original plant.

PSC RESPONSE

The Building 10 project consists of two structures, each of which is constructed separate and independent of the Turbine and Reactor Buildings and one another. The structure between the Turbine Building and Building 10 is referred to as the Walkover Structure. It provides shelter for electrical cables running between the two buildings, as well as an enclosed passageway for personnel.

The following change notices pertain to construction of Building 10: CN-1460 (Design and Construction of Structural Portion of Building 10 and Walkover Structure), CN-1461 (Design and Construction of Mechanical Portion for HVAC and Fire Protection for Building 10), and CN-1462 (Installation of Electrical Building Support Facilities in Building 10). Table 1 delineates the comparison between all applicable design criteria utilized for Building 10 per these change notices, and those corresponding to the original plant.\*

\*As modified by subsequent PSC regulatory commitments.

ITEM 2

NRC CONCERN

Provide a description of all of the safety related equipment located within Building 10 and briefly explain its function and/or significance; also include a discussion of any plans you may have for the installation of additional safety-related equipment.

PSC RESPONSE

The following change notices pertain to installation of specific safety related equipment within Building 10: CN-1255 and CN-1332 (Upgrade 120V Instrument Power Buses) and CN-1391 (Replace Station Batteries 1A and 1B, and Instrument Battery 1C). Note that batteries 1A and 1B are not within Building 10. Refer to Table 2 for a list and description of all of the subject safety related equipment and associated functions and/or significance. A comparison of applicable design criteria utilized for safety related equipment within Building 10 to design criteria for safety related equipment within the original plant, as they pertain to this equipment, is outlined in Table 3.

Building 10 has designated areas for installation of other safety related equipment. However, no other safety related equipment is scheduled for placement within Building 10 at the present time.

ITEM 3

NRC CONCERN

Provide a discussion on how the provisions of 10 CFR Part 50.48 are being fulfilled in the absence of a staff fire protection evaluation report accepting the adequacy of protection to BTP 9.5-1.

PSC RESPONSE

During initial design of Building 10, the fire protection features were reviewed to the same design criteria applicable to the remainder of the Fort St. Vrain plant (FSV): Branch Technical Position 9.5-1, Appendix A (BTP 9.5-1) and Appendix R to 10CFR50 (Sections III.G and III.J). A review of Building 10 to these criteria was performed by a fire protection consultant (see CN-1461A).

The application of Appendix R in its entirety to new construction features at FSV has been discussed in two meetings between the NRC and PSC (June 8, 1984 and July 10, 1984) with varying guidance being provided. Per an NRC request made at the June 8, 1984 meeting, PSC submitted on June 22, 1984 (P-84183) a set of Appendix R acceptance criteria applicable to the Fort St. Vrain plant. PSC plans to review Building 10 to these Fort St. Vrain Appendix R acceptance criteria. This review will be submitted to the NRC per the schedule also included in the June 22, 1984 submittal.

ITEM 4

NRC CONCERN

Since it would appear that changes may be necessary to at least one of the first four categories of information (Background, Generic Planning Base, Licensee Planning Base, Responsibility Matrix) and that changes to the safeguards contingency plan (together with detailed procedures and personnel training) are required, provide a discussion on how the provisions of 10 CFR Part 50.54(p) were fulfilled.

PSC RESPONSE

During the design of Building 10, PSC recognized that a revision to the Security System and the Security Plan would be required. The physical additions to the Security system were incorporated into the Building 10 design and construction. PSC, before and during construction of this facility, was in contact with the NRC Security Personnel discussing the proposed additions and certain compensatory measures which would be required during the 480 volt essential switchgear modification being performed at the same time Building 10 was being constructed. The compensatory measures were agreed to orally and implemented during construction.

The Security Plan, revised to include Building 10, was submitted to NRC, Region IV on January 31, 1984 (P-84039 Warembourg to Collins) under the provisions of 10CFR50.54(p).

TABLE 1  
COMPARISON OF APPLICABLE DESIGN CRITERIA  
FOR BUILDING 10 PROJECT AND THE ORIGINAL PLANT

STRUCTURAL			
ITEM	BUILDING 10 AND WALKOVER STRUCTURE DESIGN CRITERIA	ORIGINAL PLANT DESIGN CRITERIA	REMARKS
SEISMIC	Acceleration response spectra based on Reg. Guide 1.60. Maximum horizontal component of ground acceleration equal to 0.05g for OBE, 0.10g for DBE; ratio of vertical component to horizontal component varies from 2/3 to 1. Damping values per Reg. Guide 1.61.	Acceleration response spectra based on records of four actual earthquake events. (Fig. 14.1-1 of FSV FSAR). Maximum horizontal component of ground acceleration equal to 0.05g for OBE, 0.10g for DBE; ratio of vertical component to horizontal component equal to 2/3. Damping values per Table 14.1-2 of FSAR.	Reg. Guides 1.60 & 1.61 provide for a more conservative criteria. Reg. Guide earthquake spectra envelope FSAR earthquake spectra. (See Figures 1 and 2 on pages 8 and 9 of Attachment A for design ground acceleration response spectra comparisons).
TORNADO	As specified in FSV FSAR Section 14.1	As specified in FSV FSAR Section 14.1	Design criteria equal
MISSILE PROTECTION	As specified in FSV FSAR Section 14.1	As specified in FSV FSAR Section 14.1	Design criteria equal
FLOOR LIVE LOAD	Varies from 100 psf to 200 psf, depending on area, in order to safely support equipment or moveable loads	Varies as required to safely support equipment or prescribed uniformly distributed live loads	Design criteria equal
ROOF LIVE LOAD	30 psf	30 psf	Design criteria equal
BASIC DESIGN WIND	As specified in FSV FSAR Section 14.1	As specified in FSV FSAR Section 14.1	Design criteria equal



TABLE 1  
COMPARISON OF APPLICABLE DESIGN CRITERIA  
FOR BUILDING 10 PROJECT AND THE ORIGINAL PLANT

STRUCTURAL (CONTINUED)

ITEM	BUILDING 10 AND WALKOVER STRUCTURE DESIGN CRITERIA	ORIGINAL PLANT DESIGN CRITERIA	REMARKS
MATERIAL PROPERTIES	Reinforced Concrete - concrete strength $f_c' = 3500$ psi (min), reinforcing bars $f_y = 60,000$ psi; Structural Steel - minimum yield $F_y = 36,000$ psi	Reinforced Concrete - concrete strength $f_c' = 3500$ psi (min), reinforcing bars $f_y = 60,000$ psi; Structural Steel - minimum yield $F_y = 36,000$ psi	Design criteria equal; Material properties verified by type of certificates or test reports for all critical items (i.e. foundation, wall and floor slab concrete and reinforcing bars; structural steel; missile resistant doors and wall panels)
FOUNDATION	Foundations shall be designed to safely support all loadings to be considered, in conjunction with site soil engineering data contained in "Soil and Foundation Investigation Report" by Woodward-Clyde-Sherard and Assoc., dated July 8, 1966.	Foundations shall be designed to safely support all loadings to be considered, in conjunction with site soil engineering data contained in "Soil and Foundation Investigation Report" by Woodward-Clyde-Sherard and Assoc., dated July 8, 1966.	Design Criteria equal
PRIMARY CODES AND STANDARDS FOR DESIGN	AISC: 1980 8th Ed. of Manual Steel Construction ACI: 318-77 Bldg. Code Requirements for Reinforced Concrete, and 349-76 Code Requirements for Nuclear Safety-related Concrete Structures AWS: D1.1 1982 Structural Welding Code - Steel UBC: Uniform Building Code, 1979	AISC: 1963 6th Ed. of Manual Steel Construction ACI: 318-63 Bldg. Code Requirements for Reinforced Concrete AWS: D1.1 Structural Welding Code-Steel (most current issue of code at time of design/construction) UBC: Uniform Building Code, 1964	Bldg. 10 and remainder of plant conform to building industry practice of using most current issue of codes at time of construction

TABLE 1  
COMPARISON OF APPLICABLE DESIGN CRITERIA  
FOR BUILDING 10 PROJECT AND THE ORIGINAL PLANT

ELECTRICAL  
BUILDING SUPPORT FACILITIES

ITEM	BUILDING 10 AND WALKOVER STRUCTURE DESIGN CRITERIA	ORIGINAL PLANT DESIGN CRITERIA	REMARKS
ELECTRICAL	Specification 75-J-02	Specification 1-N-2	Specification 75-J-02 is equal to 1-N-2 or exceeds the requirements of 1-N-2

TABLE 1  
 COMPARISON OF APPLICABLE DESIGN CRITERIA  
 FOR BUILDING 10 PROJECT AND THE ORIGINAL PLANT

MECHANICAL  
 (NOTE: NON-SAFETY RELATED)

ITEM	BUILDING 10 DESIGN CRITERIA	ORIGINAL PLANT DESIGN CRITERIA	REMARKS
HVAC SYSTEM	Per Specification 75-J-02	Per Specification 1-J-09	Design criteria equal.
HVAC SYSTEM AND FIRE PROTECTION SYSTEM HANGERS	Designed so that hangers will not fail and allow damage to safety related equipment during a seismic event.	Designed so that hangers will not fail and allow damage to safety related equipment during a seismic event.	Design criteria equal.
FIRE PROTECTION SYSTEM	Designed per Building 10 fire hazards analysis in CN-1461A. Analysis was done per BTP 9.5-1 Appendix A, and 10CFR50 Appendix R sections III.G and III.J.	Designed per BTP 9.5-1, Appendix A, and 10CFR50 Appendix R sections III.G and III.J.	Design criteria equal.

Figure 1

HORIZONTAL ACCELERATION RESPONSE SPECTRUM  
FOR 0.05g MAXIMUM GROUND ACCELERATION




Figure 2

HORIZONTAL ACCELERATION RESPONSE SPECTRUM  
FOR 0.10g MAXIMUM GROUND ACCELERATION




TABLE 2  
SAFETY RELATED EQUIPMENT

EQUIPMENT	DESCRIPTION	LOCATION	FUNCTION AND/OR SIGNIFICANCE
N-9289	Inverter 1A	4791'-0" Building 10 - North	Invert 125V DC to 120V, single phase AC for Instrument Bus 1A
N-9290	Inverter 1B	4791'-0" Building 10 - South	Invert 125V DC to 120V, single phase AC for Instrument Bus 1B
N-9279	Inverter 1C	4800'-6" Building 10 - Mezz.	Invert 125V DC to 120V, single phase AC for Instrument Bus 1C
N-9277	Backup Power Transformer 1A-1	4791'-0" Building 10 - North	Supply instrument power to Bus 1A in the event of loss of 125V DC Bus 1A or Inverter 1A
N-9278	Backup Power Transformer 1B-1	4791'-0" Building 10 - South	Supply instrument power to Bus 1B in the event of loss of 125V DC Bus 1B or Inverter 1B
N-9269	Backup Power Transformer 1C-1	4800'-6" Building 10 - Mezz.	Supply instrument power to Bus 1C in the event of loss of 125V DC Bus 1C or Inverter 1C
N-92103	Distribution Panel 1A-1	4791'-0" Building 10 - North	Instrument Power Bus Non-interruptible
N-92104	Distribution Panel 1B-1	4791'-0" Building 10 - South	Instrument Power Bus Non-interruptible
N-92105	Distribution Panel 1C-1	4800'-6" Building 10 - Mezz.	Instrument Power Bus Non-interruptible
N-92125	1C Batteries	4791'-0" Bldg. 10 Battery Rm.	125V DC Power to N-9279, Inverter 1C
N-9253	Battery Charger 1C	4800'-6" Building 10 - Mezz.	Battery Charger for 1C Batteries
N-92118	Battery Test Switch	4791'-0" Building 10 - North	Provide method for discharge testing of batteries 1C
	Safety Related Cables	Building 10 and Walkover Structure	Equipment connection for non-interruptible instrument power

TABLE 3  
COMPARISON OF APPLICABLE DESIGN CRITERIA FOR  
SAFETY RELATED EQUIPMENT WITHIN BUILDING 10 AND THE ORIGINAL PLANT

ITEM	BUILDING 10 EQUIPMENT DESIGN CRITERIA	ORIGINAL PLANT EQUIPMENT DESIGN CRITERIA	REMARKS
SEISMIC QUALIFICA- TION	Equipment is qualified to withstand OBE and DBE seismic loading per amplified response spectra for the appropriate floor level as generated for Building 10	Equipment is qualified to withstand OBE and DBE seismic loading per amplified response spectra for the appropriate floor level as generated for the remainder of plant	Design criteria equal
ENVIRON- MENTAL QUALIFICA- TION	Equipment is qualified to function for total loss of HVAC (120 degrees F)	Equipment is qualified to function for total loss of HVAC (120 degrees F)	Design criteria equal
SEPARATION AND SEGREGATION	Meet requirements of 1-N-2	Meet requirements of 1-N-2	Design criteria equal

ATTACHMENT B  
to P-84230

SAFETY EVALUATIONS AND DESIGN PACKAGES FOR CHANGE NOTICES  
1460, 1461, 1462, 1255, 1332, 1391, and 1781





PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION

CV TCR / SCR / PC / TR  
1450

SAFETY EVALUATION

PAGE 1

<b>CRITERIA</b> TYPE: <input checked="" type="checkbox"/> OVERALL <input type="checkbox"/> SUBMITTAL <input type="checkbox"/> SETPOINT CHANGE REPORT <input type="checkbox"/> TEST REQUEST <input type="checkbox"/> TEMPORARY CONFIGURATION REPORT <input type="checkbox"/> PROCEDURE CHANGE (PEAR) <input type="checkbox"/> OTHER			
<b>CLASSIFICATION:</b> ARE THE SYSTEMS, EQUIPMENT OR STRUCTURES INVOLVED, OR DOES THE ACTIVITY AFFECT:			
CLASS I	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	ENGINEERED SAFEGUARD
SAFE SHUTDOWN	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	PLANT PROTECTIVE SYSTEM
SAFETY RELATED	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	SECURITY SYSTEM
REMARKS			
<b>EVALUATION</b>			
1. IS THE ACTIVITY IDENTIFIED IN THE PSAR OR TECH SPEC? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO LIST THE APPLICABLE SECTIONS REVIEWED. <i>This activity involved construction of an entirely new facility. As such, it is not identified in either the PSAR or Technical Specifications.</i>			
2. DOES THE ACTIVITY REQUIRE THAT CHANGES BE MADE TO THE PSAR OR TECH SPEC? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO LIST SECTIONS TO BE CHANGED AND THE CHANGES TO BE MADE. <i>PSAR Section 12.2 and Figures in Section 12 should be changed to reflect construction of the 3-loop complex addition. No technical specification changes are required for this construction.</i>			
3. DETERMINE WHETHER OR NOT THE ACTIVITY INVOLVED IS AN UNREVIEWED SAFETY QUESTION UTILIZING THE FOLLOWING GUIDELINES:			
(A) HAS THE PROBABILITY OF OCCURRENCE OR THE CONSEQUENCES OF AN ACCIDENT OR MALFUNCTION OF EQUIPMENT IMPORTANT TO SAFETY PREVIOUSLY EVALUATED IN THE PSAR BEEN INCREASED? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO STATE BASIS: <i>The design criteria for the new structure meets or exceeds that applicable to the original plant.</i>			
(B) HAS THE POSSIBILITY OF AN ACCIDENT OR MALFUNCTION OF A DIFFERENT TYPE THAN ANY EVALUATED PREVIOUSLY IN THE PSAR BEEN CREATED? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO STATE BASIS: <i>The design criteria for the new structure meets or exceeds that applicable to the original plant. Therefore, the possibility of accidents or malfunctions is the same as, or less than, that existing structures.</i>			
(C) HAS THE MARGIN OF SAFETY, AS DEFINED IN THE BASIS FOR ANY TECHNICAL SPECIFICATION OR IN THE PSAR BEEN REDUCED? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO STATE BASIS: <i>The new structure being designed and constructed to criteria equal to or better than any existing structures, provides the same or better margin of safety.</i>			
DOES THE ACTIVITY APPEAR TO: INVOLVE AN UNREVIEWED SAFETY QUESTION <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO BE SAFETY SIGNIFICANT <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO			
BY	<i>Jack Jan</i>	DATE	APPROVED
		3-16-82	<i>M. J. O'Brien</i>
			DATE
			9-19-82
(REQUIRED ONLY FOR CHANGE NOTICE)			

PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
NUCLEAR PROJECT DEPARTMENT

Electrical   
Mechanical   
Structural   
Safety Related   
Non Safety Related

DESIGN INPUT REQUIREMENTS

Sheet 1 of 1

Design a Three Room Complex Addition (3RCA) and Walkover Structure to be located directly East of the existing complex. The design shall be in accordance with the FSV Three Room Complex Addition structural design criteria. In general, the structural design criteria is from the Ft. St. Vrain FSAR.

The Main Building shall be of concrete construction, 30' wide X 40' long X 55' high and founded on drilled caissons anchored to bed rock.

The Walkover Structure is steel construction 10' wide X 22' long X 55'-6" high and founded on a spread footing.

Prepared By: /s/ Ed Nicks 9/8/82 Date Approved By: /s/ R. Gunnerson 9/8/82 Date

PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
NUCLEAR PROJECT DEPARTMENT

SAFETY RELATED DESIGN ANALYSIS  
Sheet 1 of 3

Electrical   
Mechanical   
Structural

I. Seismic Analysis:

The buildings were designed for seismic and found to meet the criteria of Attachment I, FSV Three Room Complex Addition Design criteria. For details of the seismic analysis see seismic book S2, Tab 9. New building response spectras were generated for this building using Reg. Guides 1.60 and 1.61. All Class I equipment for this building (see CN-1462) was ordered using the new response spectras.

II. Stress Analysis:

The Buildings were designed in accordance with Table 70.4 allowable structural stresses, FSV Three Room Complex Addition structural design criteria. For details of the stress analysis see seismic book S2, Tab 9. Table 70.4 is in the Blue Package of this CN. The design of this building is more conservative than that of the original main plant since a larger ground response spectra per Reg. Guide 1.60 was used vs the FSV Earthquake; for the analysis.

III. Piping/Hanger Analysis:

N/A See Mechanical CN-1461 And  
Electrical CN-1462

IV. Hydraulic/Pneumatic Analysis:

N/A

SAFETY RELATED DESIGN ANALYSIS (continued)  
Sheet 2 of 3

V. Thermal Analysis:

N/A

VI. Nuclear Analysis:

N/A

VII. Fire Protection Analysis:

N/A SEE MECHANICAL CN-1461

VIII. Environmental Analysis:

N/A

IX. Compatibility of Materials, Equipment and Processes:

N/A

SAFETY RELATED DESIGN ANALYSIS (continued)  
Sheet 3 of 3

X. Accessibility for In-Service Inspection, Maintenance and Repair:

N/A See Mechanical CN-1461 for accessibility requirements to maintain HVAC.

XI. Separation and Segregation Analysis:

N/A See Electrical CN-1462 for cable separation and segregation

XII. Electrical Analysis:

N/A See Electrical CN-1462 for Electrical analysis.

XIII. Accident Analysis:

No new or existing accident hazards would be created by this Change Notice.

CHECK LIST OF DESIGN VERIFICATION QUESTIONS  
FOR DESIGN REVIEW METHOD

- | <u>YES</u>                          | <u>NO</u>                | <u>N/A</u>                          |   |
|-------------------------------------|--------------------------|-------------------------------------|---|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 1. Were the inputs correctly selected and incorporated into design?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 2. Are assumptions necessary to perform the design activity adequately described and reasonable? Where necessary, are the assumptions identified for subsequent re-verifications when the detailed design activities are completed? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 3. Are the appropriate quality and quality assurance requirements specified?  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 4. Are the applicable codes, standards and regulatory requirements including issue and addenda properly identified and are their requirements for design met?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 5. Have applicable construction and operating experience been considered?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 6. Have the design interface requirements been satisfied?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 7. Was an appropriate design method used?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 8. Is the output reasonable compared to inputs?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 9. Are the specified parts, equipment, and processes suitable for the required application?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 10. Are the specified materials compatible with each other and the design environmental conditions to which the material will be exposed?   |
| <input type="checkbox"/>            | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 11. Have adequate maintenance features and requirements been specified?   |
| <input type="checkbox"/>            | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 12. Are accessibility and other design provisions adequate for performance of needed maintenance and repair?  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 13. Has adequate accessibility been provided to perform the in-service inspection expected to be required during the plant life?  |
| <input type="checkbox"/>            | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 14. Has the design properly considered radiation exposure to the public and plant personnel?  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 15. Are the acceptance criteria incorporated in the design documents sufficient to allow verification that design requirements have been satisfactorily accomplished?   |

CHECK LIST OF DESIGN VERIFICATION QUESTIONS - Cont'd.

YES NO N/A

- (X) ( ) ( ) 16. Have adequate pre-operational and subsequent periodic test requirements been appropriately specified?
- (X) ( ) ( ) 17. Are adequate handling, storage, cleaning and shipping requirements specified?
- (X) ( ) ( ) 18. Are adequate identification requirements specified?
- (X) ( ) ( ) 19. Are requirements for record preparation review, approval, retention, etc., adequately specified?

Note: If the answer to any question is no, provide additional information and resolution below:

RESOLUTION OF DESIGN DEFICIENCIES

UNCOVERED DURING THE DESIGN VERIFICATION PROCESS

*I have reviewed this CN and found it to be acceptable. Response spacing to be added by a reissue.  
Mark J. Juhl 9/10/82*

*No change to original design verification*

*Mark Lombard by Keith Bul*

*I have reviewed this CN reissue "D" and found it to be acceptable.*

*Mark J. Juhl 6/15/83*

*DESIGN DEFICIENCIES FOR REISSUE E DISCUSSED AND RESOLVED AS OUTLINED ON PAGE B6.1E.*

*J. A. Tan 9/20/83*

*Mark Mallon 9/23/83*

## CALCULATIONS FOR

PREPARED BY

DATE

REVIEWED BY

DATE

CALC. NO.

REF. DOCUMENTS:

CN 1400

BY TESNER

PAGE 86.1E

FORM NO. 372-30-2650

DESIGN DEFICIENCIES FOR REISSUE E

ITEM	DESCRIPTION	RESOLUTION
① BLUE PP. 94E, 96E	MIN. TENSILE STRENGTH FOR A-36 STEEL PLATE SHOWN AS 70 KSI IN BOLT BEARING STRESS CHECK.	CORRECT FIGURE OF 58 KSI USED IN EQUATION RESULTS IN BEARING STRESS STILL BELOW CODE ALLOWABLE.
② BLUE PP. 94E, 95E, 96.1E THROUGH 95.3E, 96E, 96.1E THROUGH 96.5E	NO CHECK MADE OF INDIVIDUAL PLATE EDGE DISTANCES (PER NORTHERN STEEL DNG. E-444-4) FOR MEETING STRENGTH RE- QUIREMENTS.	OF ALL 18 GUSSET PLATES, ONE (MARK 3-4) REQUIRED REINFORCING WITH WELDS. ALL OTHER EDGE DISTANCES ACCEPTABLE.
③ BLUE PP. 95.4E THROUGH 95.9E, 96.6E THROUGH 96.15E, 98E	STRESS ANALYSIS OF GUSSET PLATES AND THEIR WELDED CONNECTIONS TO COLUMNS WERE MADE WITHOUT DUE CONSIDERATION OF OFFSETS BETWEEN CENTROID OF PLATE/WELD AND LINE OF ACTION OF APPLIED FORCE IN DIAGONAL BRACE MEMBERS.	DETAILED CHECK OF BRACING GUSSET CONNECTIONS REVEALED THAT FOR TWO PLATES (MARK Y-4 AND J-4), ORIGINALLY FREE- SCRIBED WELDS AND/OR PLATES WERE OF INSUFFICIENT SIZE TO CARRY DESIGN LOADS. THESE CONNECTIONS WERE REDESIGNED TO SAFELY HANDLE DESIGN LOADS WITHIN A.S.A.R. STRUCTURAL STRESS LIMITS.

THE UNDERSIGNED ACKNOWLEDGE THAT THE ABOVE DEFICIENCIES WERE DISCOVERED AND INVESTIGATED IN THE COURSE OF THE INDEPENDENT REVIEW PROCESS AND WERE RESOLVED AS NOTED. FOR THOSE RESOLUTIONS REQUIRING FURTHER ACTION IN THE CONSTRUCTION / INSPECTION PHASE, APPROPRIATE ADDITIONS TO THE GREEN PACKAGE HAVE BEEN MADE. CALCULATIONS CONTAINED HEREIN ON PAGES 894E THROUGH 899E INCLUSIVE HAVE BEEN PREPARED AND INDEPENDENTLY REVIEWED (DETAILED CHECK) BY THE PARTIES BELOW.

John A. Tesner 9/19/83

Mark Muller 9/23/83



Structural Design Criteria  
 Ft. St. Vrain  
 Nuclear Generating Station  
 Public Service Company of Colorado  
Three Room Complex Addition

APPROVALS

Responsible Engineer	4/28/82 M.R. Lingle			
Lead/Structural Engineer	4/28/82 M.R. Lingle			
Independent Reviewer	J.A. Sanderson 4-28-82			
Licensing Engineer	W. K. Smith 4/28/82			
Chief Engineer Structural Division	A.J. Walsh 4/28/82			
Project Engineer	M.R. Lingle			
Date	4/28/82			
Revision	0	1	2	3

Structural Design Criteria  
 Fort St. Vrain  
 Three Room Complex Addition

I. Purpose

The purpose of this criteria is to provide the structural information required to design a new building to be constructed directly east of the existing three room complex. This new structure will be known as the FSV Three Room Complex Addition. In general, the structural design criteria from the Final Safety Analysis Report for Fort St. Vrain Nuclear Generating Station will be used.

II. Client-Furnished Criteria

- A. The structure except training room and its components is classified as Class I as defined in Section 14.1.1.1 of the FSAR.
- B. Attachment I is section 14.1 - Environmental Disturbance from the FSAR for the Fort St. Vrain Nuclear Generating Station. The information in the section shall be used for seismic and wind design criteria as modified in Section III.
- C. Attached as Attachment II is Document No. DC-70 issue F, dated 3/3/69. This document shall be used for general structural design criteria with regard to the Three Room Complex Addition.
- D. Attachment III is Table 3-1, Elastic Moduli Determination, from a report in Section II of the FSAR titled; "Geology and Seismology of Fort St. Vrain Nuclear Generating Station near Platteville, Colorado" by the Colorado School of Mines Foundation, Inc. This information shall be used to calculate soil spring constants.
- E. Attachment IV is the Soil and Foundation Investigation Report (without the figures) prepared by Woodward-Clyde-Sherard and Associates dated May 31, 1966. The drilled pier section shall be used for design.
- F. The following tabulation summarizes the information on the drawings:

<u>Elevation</u>	<u>Floor Live Load</u>
480 Volt Room, Elevation 4791'-0"	100 psf
Battery Room, Elevation 4791'-0"	200 psf
Mezzanine Floor, Elevation 4800'-6"	100 psf
Computer Room, Elevation 4812'-0"	100 psf
Office Room, Elevation 4824'-0"	100 psf
Equip. Room, Elevation 4824'-0"	100 psf
Training Room, Elevation 4835'-6"	100 psf
Roof, Elevation 4853'-0"	30 psf

Job No. 13569.04

CN 1460  
BY Sumner  
PAGE 89  
FORM NO. 372-30-2650

Roof Equipment	
Condensing Units	420 lbs. each
HVAC Unit	8770 lbs.
Computer Room	
HVAC Unit	1600 lbs. each
Battery Room	
60 batteries	187 lbs. each

- G. The design codes used for the design of the structure are as listed in the above attachments and as modified below.

### III. Modified Client-Furnished Criteria

- A. The 1979 Uniform Building Code shall be used for the design of the new building. Wind and seismic loading shall be as specified in Attachments I and II and as modified in this Section.
- B. Reinforced concrete shall be designed in accordance with the ACI 318-77 Building Code Requirements for Reinforced Concrete and the — ACI 349-76 Code Requirements for Nuclear Safety Related Concrete Structure.
- C. Structural steel shall be designed in accordance with the 1980 Eighth Edition of the AISC Manual of Steel Construction.
- D. Masonry walls shall be designed in accordance with the 1970 edition of the Specification for the Design and Construction of Load Bearing Concrete Masonry, National Concrete Masonry Association.
- E. The following materials shall be used:
1. Concrete strength  $f'_c$  shall be 3,500 psi.
  2. Reinforcing bars  $F_y$  shall be 60,000 psi.
  3. Structural steel  $F_y$  shall be 36,000 psi.
- F. Attachment V is a modification to table 70.4 of Attachment II. This modification is necessary to meet the requirements of item IIIB and IIIC above.
- G. The development of the building floor response spectra for both the Operating Base Earthquake (OBE) and the Safe Shutdown Earthquake (SSE) shall be based on the NRC Regulatory Guides 1.60 and 1.61.
- H. The vertical and horizontal earthquakes shall be combined as follows to provide a maximum earthquake load:
- a. 1.0 Horizontal North-South with 1.0 vertical
  - b. 1.0 Horizontal East-West with 1.0 vertical

Job No. 13569.04

CN 1460  
BY Gunn  
PAGE 810  
FORM NO. 372-30-2650

IV. SWEC Developed Criteria

- A. Bolts for structural steel members shall be 7/8" diameter ASTM-A325 high strength bolts. All bolts, nuts and washers shall conform to ASTM-A325.
- B. Bolts for stair stringers and girts shall be 3/4" diameter ASTM-A307, Grade A.
- C. Welding material shall be E70XX electrodes conforming to ASTM A233.
- D. All anchor bolts shall conform to ASTM-A307.
- E. Steel roof and floor deck shall be designed for the weight of wet concrete to be placed on the deck plus 25 psf for construction live load. Steel decking shall be at least 18 gauge.
- F. The roof shall have 2" of rigid insulation with a single membrane roofing system and 2" of gravel protection. The roof shall be pitched at 1/4" per foot and shall have scuppers and downspouts.
- G. Metal siding shall be 1 1/2" 22 gauge Robertson Huski-Rib metal siding with 3" of insulation
- H. Doors shall be full flush type 1 3/4" insulated hollow metal doors with 14 gauge pressed metal frames and mortise locksets. All assembled units shall have a 3 hour fire rated UL label.
- I. All grating and stair treads shall be 1 1/4 x 3/16 bar grating and shall be painted. All stair treads and top of landings shall have abrasive nosing. Stairs shall be designed for 100 psf or a concentrated load of 300 lbs on an area of 4 sq. inches at the center of the tread.
- J. All handrail shall be 1 1/4 standard weight pipe (1.66 nominal outside diameter) with posts not more than 8 ft. 0 in. on center. All pipes shall conform to ASTM A53, Grade B. Handrails shall be painted "safety yellow."
- K. In addition to the floor dead, live and seismic load combinations, all structural steel floor beams shall be designed with a 2 kip concentrated load placed at the center of the span.
- L. The structure shall be designed as five (5) separate fire areas each area having a three (3) hour fire rating. The five areas are as follows:
  1. Battery Room - Elevation 4791
  2. 480 volt Room - Elevation 4791 and Mezzanine Floor Elevation 4800'-6"
  3. Computer Floor Elevation 4812'0"
  4. Mezzanine Floor Elevation 4824'0"
  5. Training Room Elevation 4835'-6"

- M. All exterior doors shall be missile resistant except for the doors from the Training Room.

**Gulf General Atomic**  
Incorporated

ATTACHMENT II  
Structural Design Criteria  
Three Room Complex Addition  
L. O. No. 13569.04

DESIGN CRITERIA

Proj. No. 90      Document No. DC-70      Issue F      Date 3-31-69

CN 1460  
BY GUMPERT  
PAGE B12  
FORM NO. 372-30-2680

DESIGN CRITERIA  
STRUCTURES - GENERAL

SYSTEM 70

GGA FORM 541 9-67

Notations in this column indicate where changes have been made

# Gulf General Atomic Incorporated

## DESIGN CRITERIA

Proj. No. 90

Document No. DC-70

Issue F

Date 3-31-69

### TABLE OF CONTENTS

CN 1460  
BY GUMMIS  
PAGE B13  
FORM NO. 372-30-2650

1. GENERAL
2. PLANS AND DRAWINGS
3. LOADS AND FORCES
  - 3.1 Foundation
  - 3.2 Wind Loads and Tornadoes
  - 3.3 Seismic Loads
  - 3.4 Crane Loads
  - 3.5 Roof Load
  - 3.6 Floor Loads
  - 3.7 Allowable Stresses
4. DESIGN CODES AND PRACTICES
  - 4.1 Building Design
  - 4.2 Concrete Design
  - 4.3 Masonry Design
  - 4.4 Steel Design
  - 4.5 Platforms and Stairways
  - 4.6 Miscellaneous Design Information
5. ELEVATIONS
6. FIGURES AND TABLES
  - 6.1 Figure 70.1
  - 6.2 Table 70.1
  - 6.3 Table 70.2
  - 6.4 Table 70.3
  - 6.5 Table 70.4

Notations in this column indicate where changes have been made

sq  
sq  
sq

By

Approved

Approved

# Gulf General Atomic

Incorporated

CN 1460  
 BY Gunnison  
 PAGE 319  
 FORM NO. 372-30-2650

DESIGN CRITERIA: STRUCTURES - GENERAL (SYSTEM 70)

Proj. No.	Document No. DC-70	Issue F	Date 3-31-69
-----------	--------------------	---------	--------------

ISSUE SUMMARY

Issue	Date	Prepared	Approved By	Purpose of Issue/ Sections Changed
A		NVC	TEN	For Design
B	2/8/67	NVC	TEN	For Design/Added Spectrum Curve for Seismic Design and minor version in Wind Load Design requirements.
C	5/1/67	NVC	TEN	For Design/Revised Spectrum Curve for Seismic Design & Tornado Loads added.
D	1/15/68	NVC	TEN	For Design/Wind & Tornado Loads incorporated, Allowable Stress Table added, Revised Spectrum Curve for Seismic Design and added Tables for Tornado Vector and Missile velocities.
E	6/13/68	NVC/HLG	<i>F.P. RW JANKS RHF</i>	For Design/Added to Design Codes & Practices, Replaced Spectrum Curve for Seismic Design & made minor revisions in Allowable Stress Table.
F	3/31/69	COP	<i>COP CHZ</i>	For updating. See index for sections changed.

Notations in this column indicate where changes have been made



DESIGN CRITERIA: STRUCTURES - GENERAL (SYSTEM 70)

Proj. No. 90	Document No. DC-70	Issue F	Date 3-31-69
--------------	--------------------	---------	--------------

1. GENERAL

The design effort will be based on approved general arrangement drawings and technical information incorporated in the report titled "Preliminary Safety Analysis Report", dated September, 1966 and amendments thereto. The plant consists basically of a Reactor Building, Turbine Building, Cooling Towers, and an Electrical Switchyard. It is expected that additional and revised drawings and information will be issued as detailed design progresses including revisions to this criteria.

2. PLANS AND DRAWINGS

Structural drawings shall show load information, moments, shears, reactions or details of connections in crane girders, floor girders, columns, stresses in trusses and the size of all material.

3. LOADS AND FORCES

The steel frame, concrete floors and walls, and supporting substructure shall be designed to safely support all loading which may be applied.

3.1 Foundation

The basis for design of foundations will be the test borings, soil analyses, seismic data, ground water tests and investigation furnished by the Public Service Company of Colorado. This data, which includes the allowable bearing and shear values of various strata, is covered in "Soil and Foundation Investigation Report" by Woodward-Clyde-Sherard and Associates, Consulting Engineers of Denver, Colorado, dated July 8, 1966, and "Dynamic Soil Property Investigation" by Woodward-Clyde-Sherard and Associates, dated June 13, 1967.

3.1.1 The recommended foundation system for the Reactor Building and the Turbine Building is covered in Design Criteria DC-72-1 and DC-75, respectively.

3.1.2 The recommended foundation system for the Cooling Towers is a continuous concrete mat supported on medium dense sand.

3.1.3 The design of foundation shall take into consideration additional loads and pressures imposed by temporary construction operations.

3.1.4 All exposed surfaces of rock excavations shall be adequately protected from disintegration by a 1-1/2" to 3" thick layer of gunite concrete for long-term protection and Aerospray 52 Binder (American Cyanamid Company) for short-term protection.

3.2 Wind Loads and Tornadoes

The design of all structures, systems and components subjected to wind pressures induced by the basic wind or tornadoes will be in accordance with the provisions specified in the ASCE Paper No. 1269, "Wind Forces on

Notations in this column indicate where changes have been made

**Gulf General Atomic**  
Incorporated

CN 1460  
BY Gunnison  
PAGE 316  
FORM NO. 372-30-2680

DESIGN CRITERIA: STRUCTURES - GENERAL (SYSTEM 70)

Proj. No. 90	Document No. DC-70	Issue F	Date 3-31-69
--------------	--------------------	---------	--------------

Structures". The applied building wind pressure in psf is computed from  $0.002558 V^2$  multiplied by a shape factor of 1.4 (0.9 positive and 0.5 negative), where V is wind velocity in miles per hour. On this basis, the design pressure on the windward side of the building will be taken as 90% of the wind pressure and the suction loading on the leeward side as 50% of the wind pressure.

3.2.1 Basic Wind

The basic wind is 90 mph wind velocity based on 100-year period of recurrence with an additional 10% gust factor. The basic wind velocity will increase with height according to the following variations:

<u>Height Zone in Feet</u>	<u>Basic Wind Velocity in mph</u>
0 to 50	90
50 to 150	105
150 to 400	125

3.2.2 Design Tornado

The design of the plant will be made to withstand a design tornado of 202 mph total horizontal wind velocity with the siding and roofing remaining in place. The allowable stresses for the design tornado combined with other loads are given in Table 70.4.

3.2.3 Maximum Tornado

The design of the plant will be made to withstand a maximum tornado of 300 mph total horizontal wind velocity without interference with safe shutdown of the plant.

The total static pressure drop that would occur during the maximum tornado is assumed to be equal to 3 psi in 3 seconds.

The items listed in the safe shutdown list in Section 4.3 of DC-1-2 will be designed such that they are capable of withstanding this maximum tornado winds and missiles and associated pressure drop without loss of function. The maximum tornado winds and missiles shall be assumed to act prior to and subsequent to but not concurrent with the pressure transient.

The structures over the fire water pumps and service water pumps will be designed so the functional integrity of these pumps will be maintained in case the cooling towers should fall on them.

The allowable stresses for the maximum tornado combined with other loads are given in Table 70.4.

3.2.3.1 Above Refueling Floor of Reactor Building and Operating Floor of Turbine Building Except Deaerator Bay

- a) Siding and roof decking will be designed to blow off above 202 mph total horizontal wind velocity.

Notations in this column indicate where changes have been made

10-C 146 3-69

DESIGN CRITERIA: STRUCTURES - GENERAL (SYSTEM 70)

Proj. No. 90	Document No. DC-70	Issue F	Date 3-31-49
--------------	--------------------	---------	--------------

- b) Siding girts, roof purlins, and main structural framing will remain in place above 202 mph total horizontal wind velocity.

3.2.3.2 Below Refueling Floor of Reactor Building and Below Operating Floor of Turbine Building and Complete Deaerator Bay

- a) Siding and girts designed at yield stresses for 202 mph total horizontal wind velocity.
- b) Siding and girts in areas of the reactor and turbine buildings that contain Class I piping, electrical ducts and equipment necessary for safe shutdown will be designed for 300 mph total horizontal wind velocity at yield stresses.
- c) The structural framing will be designed for 300 mph total horizontal wind velocity at yield stresses.
- d) The reactor building structural framing can be assumed to lean against the PCRV, the hot service and refueling facility for maximum wind condition.
- e) The turbine building structural framing can be assumed to lean against the turbine pedestal and foundation.

3.2.4 Tornado Missile Protection

The Class I structures, equipment and components essential for safe shutdown of the plant as listed in DC-1-2, except as noted therein, will be protected from missiles generated by any tornado up to the maximum of 300 mph. The protection will consist of: 1) concrete walls; 2) special heavy steel siding; 3) the shielding effect of other massive structures such as the PCRV, fuel storage vaults, and turbine pedestal; 4) localized protection where necessary; 5) ample separation to assure that a single missile will not damage related items of essential equipment.

The list of objects which will become airborne missile when acted on by the design tornado and maximum tornado is presented in Table 70.2. The velocity of each of these missiles was calculated as a function of the elevation above ground level. The terminal free fall vertical velocity component is independent of the tornado intensity or the elevation above ground level.

The resultant likelihood to become airborne and the magnitude of lift attained for the various missiles considered is presented in Table 70.3.

Notations in this column indicate where changes have been made

DESIGN CRITERIA: STRUCTURES - GENERAL (SYSTEM 70)

Proj. No. 90	Document No. DC-70	Issue F	Date 3-31-69
--------------	--------------------	---------	--------------

**3.3 Seismic Loads**

3.3.1 Structures which are required to support the Class I components and systems, listed in DC-1-2, will be subjected to dynamic analyses, using the response spectra shown on Figure 70.1. This corresponds to a design earthquake of 5%g peak horizontal ground acceleration. The coincident vertical acceleration shall be assumed as 2/3 of the horizontal acceleration. The allowable stresses for combined seismic and other loads will be the design working stresses with no 1/3 increase for transient earthquake loading. The dynamic analyses will consider all factors such as soil and rock flexibility and torsion. To ensure an adequate factor of safety, the maximum earthquake of 10%g horizontal ground acceleration will be applied to the safe shutdown list given in DC-1-2. Refer to Table 7Q4 "Allowable Structural Stresses" for load combinations.

The values of damping for elastic vibrations to be used in design will take into consideration the size and shape of the structure, the method of support and the material of construction. The values of the damping factors are given below in percentage of the critical damping.

	<u>ξ</u>
Reinforced concrete shear-wall building . . . . .	5
Prestressed concrete structure supported on ground . . . . .	2
Bare welded steel frame structure . . . . .	1
Welded steel frame building . . . . .	2-1/2
Steel pipes on firm supports . . . . .	1
Vital steel piping on hanger supports . . . . .	1/2
Concrete support structure embedded in earth . . . . .	7

3.3.2 All plant structures other than for Class I shall be designed to meet the requirements for Seismic Zone 1, as defined in the Uniform Building Code, 1964.

**3.4 Crane Loads**

3.4.1 Crane and trolley loads will be governed by the Specification for the Design, Fabrication and Erection of Structural Steel for Buildings, AISI 1961. The lateral force on crane runways shall be provided by this specification or 10% of the wheel loads applied at the top of the rail on each side of the runway. Impact loads shall be considered applied to crane girders and their connections to the framework, but shall not be included in the design of supporting columns, column bases, and foundations. Where crane girders are carried on brackets, the impact and resulting moment shall be included in the design of the columns and anchor bolts, but not in the design of the foundation. Overstress and overload conditions will be considered for special cases, such as infrequent lifts of major equipment parts.

Notations in this column indicate where changes have been made

44 1000 372 30-2650

**Gulf General Atomic**  
 Incorporated

DESIGN CRITERIA: STRUCTURES - GENERAL (SYSTEM 70)

Proj. No. 90	Document No. DC-70	Issue F	Date 3-31-69
--------------	--------------------	---------	--------------

3.5 Roof Load

- 3.5.1 The roofs shall be designed for a uniformly distributed live load of 30 psf, in addition to dead loads.
- 3.5.2 In addition to specified live loads and dead loads, trusses shall be designed to withstand safely a suspended construction load of 2,000 lbs assumed to act at any one panel point of the lower chord.
- 3.5.3 Special provisions or investigation shall be made of roof areas where an abrupt change of elevation between adjacent roof levels may produce excessive accumulation of snow due to wind.

3.6 Floor Loads

- 3.6.1 Floors shall be designed to support safely the concentrated loads, impact loads, equipment weights or prescribed uniformly distributed live loads. A minimum live load of 100 psf shall be used for catwalks, elevated walkways, stairways, and service platforms. Refer to plant arrangement drawings for type of floor (concrete, checkered plate or steel grating).
- 3.6.2 Refer to plant arrangement drawings and layout criteria drawings for equipment weights. Manufacturer's recommendations for equipment loads will be followed with regard to design, loads and impact. When not specified by the manufacturer, the mass of the equipment foundation will be a minimum of 2-1/2 to 5 times the weight of the equipment depending upon whether it is centrifugal or reciprocating type of equipment. Effective areas of concrete floors acting with the foundations will be considered in the analysis.

The turbine-generator pedestal will be designed in conformance with manufacturer's recommendation with due regard to resonance.

3.7 Allowable Stresses

For allowable structural stresses to be used during design, see Table 70.4.

4. DESIGN CODES AND PRACTICES

4.1 Building Design

Unless specified otherwise, the design of the overall buildings and structures will have to comply with the local building ordinances and codes. In the absence of a local building code, the requirements of the Uniform Building Code (UBC) 1964 shall apply.

4.2 Concrete Design

Concrete design will be governed by good design practice and will be in conformance with the following codes, where applicable:

- 4.1.1 ASA A89.1-1964 Building Code Requirements for Reinforced Concrete.
- 4.1.2 ASTM Test and Codes
- 4.1.3 Portland Cement Association Bulletins.

By	Approved	Approved	Page 5 of 11
----	----------	----------	--------------

Notations in this column indicate where changes have been made

# Gulf General Atomic

Incorporated

CN 1460  
BY G. J. Johnson  
PAGE 320  
FORM NO. 372-30-2650

## DESIGN CRITERIA: STRUCTURES - GENERAL (SYSTEM 70)

Proj. No. 90	Document No. DC-70	Issue F	Date 3-31-69
--------------	--------------------	---------	--------------

### 4.3 Masonry Design

Masonry design will be governed by good design practice and will be in accordance with the following codes, where applicable:

- 4.3.1 ASA A41.1-1953 Building Code Requirements for Masonry
- 4.3.2 ASA A41.2-1960 Building Code Requirements for Reinforced Masonry
- 4.3.3 Portland Cement Association Bulletins
- 4.3.4 ASTM Test and Codes

### 4.4 Steel Design

Structural steel design will be governed by good design practice and will be in conformance with the following codes, where applicable:

- 4.4.1 Manual of the AISC, 1963
- 4.4.2 American Welding Society Codes
- 4.4.3 ASTM Test and Codes

### 4.5 Platforms and Stairways

4.5.1 Platforms, walkways, and stairways will be provided for access where required for operation, inspection or maintenance of the plant. These structures will be open grating.

4.5.2 Ladders will be used where they are the only possible means of access, but will be held to a minimum.

4.5.3 Grating panels will be removable, if necessary, for maintenance.

4.5.4 Abrasive nosing will be provided on stair treads and on platforms at the head of all stairways.

4.5.5 Stairs will preferably have a slope of not more than 38 degrees from the horizontal, and in no case will the slope exceed 42 degrees.

4.5.6 Except as otherwise provided, all handrailings for platforms and stairs will be fabricated from 1-1/4" diameter black iron standard pipe with neatly finished welded joints.

### 4.6 Miscellaneous Design Criteria

Supplemental miscellaneous structural design criteria prepared by the Architect-Engineer shall be submitted to Gulf General Atomic.

## 5. ELEVATIONS

5.1 Relative building elevations with respect to finished yard grade: see Plant Arrangement Drawings.

5.2 Finished yard grade elevation referenced to USCGS benchmark: 4790'-0" for areas immediately around Reactor and Turbine Buildings.

Notations in this column indicate where changes have been made

# Gulf General Atomic Incorporated

CN 1460  
 BY GURRISON  
 PAGE B21  
 FORM NO. 372-30-2650

DESIGN CRITERIA: STRUCTURES - GENERAL (SYSTEM 70)

Proj. No. 90	Document No. DC-70	Issue F	Date 3-31-69
--------------	--------------------	---------	--------------

Notations in this column indicate where changes have been made




Fig. 70.1

Notations in this column indicate where changes have been made

**TABLE 70.1**  
**WIND SPEED FOR THE DESIGN AND MAXIMUM TORNADO IN MPH**

Column 1	DESIGN TORNADO				MAXIMUM TORNADO
	Column 2	Column 3	Column 4	Column 5	Column 6
Elevation (ft)	Total Vector Velocity (Includes Translational Velocity)	Tangential Wind Speed	Total Horizontal Velocity = Tangential + Translational*	Building Design Horizontal Tornado Wind Load Without Exceeding Yield Stresses	Total Horizontal Wind Velocity Where Ultimate Stress or Buckling of Compression Members Will Not Occur**
≤6	148	89	139	202	300
25	172	103	153	202	300
50	172	103	153	202	300
75	217	129	179	202	300
100	217	152	202	202	300
125	217	152	202	202	300
≥150	240	152	202	202	300

\*Tornado translational velocity = 50 mph

\*\*Stresses in the basic building structure will not exceed 85% of ultimate stresses and buckling of compression members will not occur. Safe plant shutdown would not be impaired.

Proj. No. 90  
Document No. DC-70  
Issue F  
Date 2-31-69

DESIGN CRITERIA: STRUCTURES - GENERAL (SYSTEM 70)

**Gulf General Atomic**  
Incorporated

CN 1460  
BY *Summer*  
PAGE 822  
FORM NO. 372-10-2650



# Gulf General Atomic

Incorporated

CN 1460  
 BY G. M. ...  
 PAGE B23  
 FORM NO. 372-30-2650

DESIGN CRITERIA: STRUCTURES - GENERAL (SYSTEM 70)

Proj. No. 90	Document No. DC-70	Issue F	Date 3-31-69
--------------	--------------------	---------	--------------

TABLE 70.2

MAXIMUM MISSILE VELOCITY vs ELEVATION FOR "DESIGN" AND "MAXIMUM" TORNADOES  
 (Tornado Translational Velocity = 50 mph)

Missile	Elevation (ft)	<u>DESIGN TORNADO</u> Maximum Missile	<u>MAXIMUM TORNADO</u> Velocity in mph	Terminal Free Fall Vertical Velocity Component mph *
<u>Cooling Tower</u>	<6	130	181	
<u>Slab:</u>	25	154	218	
Corrugated Asbestos	50	154	218	
8 ft x 2 ft x .5 in,	75	199	285	
14 lbs	100	199	285	21
	125	199	285	
	150	224	325	
	175	224	325	
	200	224	325	
<u>Corrugated Metal</u>	<6	107	158	
<u>Sheet:</u>	25	131	195	
8 ft x 4 ft,	50	131	195	
100 lbs	75	176	195	
	100	176	262	41
	125	176	262	
	150	202	302	
	175	202	302	
	200	202	302	
<u>Fir Plank:</u>	<6	98	151	
12 ft x 1 ft x 4 in,	25	122	188	
105 lbs	50	122	188	
(Design Missile)	75	167	255	
	100	167	255	68
	125	167	255	
	150	193	295	
	175	193	295	
	200	193	295	
<u>Bolred Wood:</u>	<6	81	133	
<u>Grating:</u>	25	105	170	
12 ft x 4 ft x 4 in,	50	105	170	
450 lbs	75	150	237	
	100	150	237	71
	125	150	237	
	150	176	277	
	175	176	277	
	200	176	277	
<u>Cedar Fence</u>	<6	31	87	
<u>Post:</u>	25	31	46	
6 in x 6 in sq x 6 ft	50	-	46	
33 lbs	75	-	113	
	100	-	113	80
	125	-	113	
	150	-	153	
	175	-	153	
	200	-	153	

\*Note that missiles may simultaneously have a horizontal component up to the cosine of 20° for the 300 mph tornado and 17° for the 202 mph tornado times the maximum missile velocity stated above.

By	Approved	Approved	Page 9 of 11
----	----------	----------	--------------

Notations in this column indicate where changes have been made

**Gulf General Atomic**  
Incorporated

CN 1460  
BY G. M. ...  
PAGE B24  
FORM NO. 372-30-2650

DESIGN CRITERIA: STRUCTURES - GENERAL (SYSTEM 70)

Proj. No. 90	Document No. DC-70	Issue F	Date 3-31-69
--------------	--------------------	---------	--------------

TABLE 70.3

<u>Missile</u>	<u>Design Tornado</u> <u>202 mph Horizontal Velocity</u>		<u>Maximum Tornado</u> <u>300 mph Horizontal Velocity</u>	
	<u>Airborne</u>	<u>Lift</u>	<u>Airborne</u>	<u>Lift</u>
Cedar Fence Post	Yes	25 Feet	Yes	All elevations
Cooling Tower Slat	Yes	All elevations	Yes	All elevations
Corrugated Metal Sheet	Yes	All elevations	Yes	All elevations
Fir Plank (Design Missile)	Yes	All elevations	Yes	All elevations
Bolted Wood Grating	Yes	All elevations	Yes	All elevations
Subcompact Automobile	Yes	3 Inches	Yes	Very small
Full Size Automobile	No	None	Yes	Small
Railroad Flat Car	No	None	No	None
Locomotive	No	None	No	None

Notations in this column indicate where changes have been made

GA FORM 541 9-65

Notations in this column indicate where changes have been made

TABLE 70.4

ALLOWABLE STRUCTURAL STRESSES

LOADING CONDITIONS:	Structural Steel $F_y = 36,000 \text{ psi}$		Concrete $f'_c = 3500 \text{ to } 6000 \text{ psi}$		Reinforcing Bars $F_y = 60,000 \text{ psi}$	
	Tension = $F_t$ Bending = $F_b$	Compression = $F_a$	Basic Design Stress	Compressive Stress	$\% F_y$	Tensile Stress $F_a$
A) Dead Load (D.L.) + Live Load (L.L.)	$F_t = 22,000 \text{ psi}$ $F_b = 22,000 \text{ psi}$	$F_a$ from Table 1-36 of AISC** Specifications 1963	ACI† Build- ing Code (ACI 318-63)	$f_c = 0.45 f'_c$	$0.4 F_y$	24,000 psi
B) Portions of Structures Sup- porting Class 1 Equipment	$F_t = 22,000 \text{ psi}$	$F_a$ from Table				
1. D.L. + L.L. + Design Earthquake (E)	$F_b = 22,000 \text{ psi}$	1-36 of AISC Specifications	ACI 318-63	$f_c = 0.45 f'_c$	$0.4 F_y$	24,000 psi
2. D.L. + O.L. + Double Earthquake (E')	$F_t = 0.85 F_u^*$ $F_b = F_y$	$1.67 F_a$ from Table 1-36 AISC	$1.67 \times \text{ACI}$	$f_c = 0.85 f'_c$	$0.85 F_y$	51,000 psi
3. D.L. + L.L. + Design Wind (90 mph)	$F_t = 29,300 \text{ psi}$ $F_b = 29,300 \text{ psi}$	$1.33 F_a$ from Table 1-36 AISC	$1.33 \times \text{ACI}$	$f_c = 0.60 f'_c$	$0.53 F_y$	32,000 psi
4. D.L. + L.L. + Design Tornado Wind (202 mph)	$F_y$	$1.67 F_a$ from Table 1-36 AISC	$1.67 \times \text{ACI}$	$f_c = 0.85 f'_c$	$0.85 F_y$	51,000 psi
5. D.L. + O.L. + Maximum Tornado Wind (300 mph)	$F_t = 0.85 F_u^*$ $F_b = F_y$	$1.67 F_a$ from Table 1-36 AISC	$1.67 \times \text{ACI}$	$f_c = 0.85 f'_c$	$0.85 F_y$	51,000 psi

\* $F_u$  = Ultimate stress of steel

\*\*AISC = American Institute of steel Construction

†ACI = American Concrete Institute

O.L. = Operating load

Proj. No. 90  
Document No. DC-70  
Issue F  
Date 3-31-69

DESIGN CRITERIA: STRUCTURES - GENERAL (SYSTEM 70)

Gulf General Atomic  
Incorporated

CN 1460  
BY *Sumner*  
PAGE 525  
FORM NO. 372-30-2650

BY Approved Approved Page 11 of 11

TABLE 3-1

ELASTIC MODULI DETERMINATION

SITE	DEPTH	TRANSIT TIME milliseconds		$\sigma$ POISSON'S RATIO	MOIST DENSITY lbs/cu ft	VERTICAL VELOCITY ft/ms	"E" YOUNG'S MODULUS psi	"k" BULK MODULUS psi	"u" SHEAR MODULUS psi
		$t_s$	$t_L$						
UHI	20	42.0	5.9	0.49	110*	1.2	$< 3.4 \times 10^3$	$33 \times 10^3$	$< 8.5 \times 10^2$
	65	14.8	3.8	0.46	138**	7.4	$310 \times 10^3$	$1463 \times 10^3$	$104 \times 10^3$

SYMBOLS:  $t_s$  - transit time, shear wave       $t_L$  - transit time, longitudinal wave

\* 110 lbs/cu ft assumed.

\*\* 138 lbs/cu ft averaged from Woodward-Clyde-Sherard and Associates

CN 1460  
 BY Sumner  
 PAGE B26  
 FORM NO. 372-30-2650

ATTACHMENT III  
 Structural Design  
 Criteria  
 Fort St. Vrain  
 Three Room Complex Addl  
 J. O. No. 13569.04

DESIGN INPUT

PROVIDE A LAP SPLICE FOR CAISSON REINF STEEL FOR  
 3 ROOM COMPLEX ADDITION

ACI 318, 315

CRSI

REINFORCED CONCRETE FUNDAMENTALS, 2<sup>ND</sup> EDITION, PM FERGUSON Pg 689

ANALYSIS

THE BASIC DEVELOPMENT LENGTH PER ACI 318-77 Pg 50

DESIGN FOR #10 BARS

$$Bd = .04 A_b F_y / \sqrt{F_c}$$

$$F_y = 60,000 \text{ PSI}$$

$$F_c = 3500 \text{ PSI}$$

$$Bd = \text{BASIC LENGTH}$$

$$Bd = \frac{.04 \times 1.27 \times 60000}{\sqrt{3500}}$$

$$Bd = 51.52''$$

NO BAR SHALL BE LESS THAN  $.004d_b F_y$

$$.0004 \times 1.27 \times 60000$$

$$= 30.48''$$

SINCE THERE IS PERHAPS ONE TOP BAR IN THE VERTICAL  
 CAISSON I HAVE ASSUMED THAT THE DESIGN WILL  
 BE THE BASIC DEVELOPMENT LENGTH & CLASS  
 C SPLICE (ACI 318 pg 53)

$$\frac{A_s \text{ REQ'D}}{A_s \text{ PROVIDED}} = \frac{18.1 \text{ in}^2}{19.05 \text{ in}^2} = .95 < 1$$

USE CLASS C Tension lap splice per ACI 318

LAP SPLICE

CLASS C  $1.7 l_d$

$$1.7 \times 51.52 = 87.58'' \text{ MIN LENGTH}$$

$$87.58'' \div 1.27'' = 68.96 \text{ BAR DIAMETERS}$$

FOR MINIMUM LENGTH OF TENSION LAP SPLICE

USE 70 BAR DIAMETERS

BASIC DEVELOPMENT LENGTH =  $l_d$

$$l_d = \frac{.04 A_b F_y}{\sqrt{f_c}} = \frac{.04 \times .79 \times 60,000}{\sqrt{3500}} = 32.04" > 24"$$

$$l_d = .0004 \times 1 \times 60,000 = 24" \text{ bar SPlice SHALL NOT BE LESS THAN } 24"$$

$$l_d = 32.04 \times 1.4 = 44.856" \text{ (TOP BAR)}$$

DESIGN FOR A CLASS C SPlice

$$1.7 l_d$$

$$44.856 \times 1.7 = 76.25"$$


$$\frac{76.25"}{1"} = 76 \text{ BAR DIAMETERS}$$

USE 80 BAR DIAMETERS FOR HORIZONTAL BEAM BAR  
SPICES AS SHOWN ON DWG B 449-1  $\frac{1}{2}$  PER ACI 318

THE HANDRAILS IN BUILDING 10 ARE DESIGNED NOT TO FAIL AND WILL NOT REDUCE THE FUNCTION OF CLASS 1 COMPONENTS

( THE HANDRAIL WELDS WILL BE ABLE TO RESIST A SHEARING LOAD OF APPROXIMATELY 1200 POUNDS PER INCH, SO AN EXTREMELY HIGH FORCE CAN BE RESISTED BY THE HANDRAIL WELD )





JOINT 1 & 8 ELEV CABLE TRAY SUPPORT


$$\left. \begin{array}{l} X = -2524.49976 \text{ #} \\ Y = 1560.0 \text{ #} \end{array} \right\} \text{ FORCE} \quad \text{FOR FORCE CALCULATION SEE CN 1462 A}$$

$$Z = 166616.937 \text{ in } \cdot \text{lb} \quad \left. \right\} \text{ MOMENT}$$


STRESS 32.1731 PSI


DESIGN CABLE TRAY SUPPORT  
 MOUNTING BRACKET

CALCULATIONS FOR CABLE TRAY  
 HANGER SUPPORT, BUILDING 10



PLAN VIEW  
 CABLE TRAY SUPPORT FRAME





BEAM TO SUPPORT CABLE TRAY ANGLE SUPPORT  
 SEE AISC FOR DESIGN INPUT  
 $P = 1560 \div 2 = 780 \#$

$$M. Pa = 780 \times 12 = 9360 \text{ in}\#$$

$$S_m = \frac{9360}{22000} = .42 \text{ in}^3$$


$$\Delta_{MAX} = \frac{Pa}{24 EI} (3l^2 - 4a^2) = \frac{780 \times 12}{24 \times 29 \times 10^6 \times 1.51} (3 \times 72^2 - 4 \times 12^2)$$

$$.00000891 (15552 - 576)$$

.13" DEFLECTION

$$\frac{l}{360} = \frac{72}{360} = .2 \text{ " DEFLECTION}$$

USE  $\angle 3" \times 3" \times \frac{5}{16}" S_m = .707$



SUPPORT FOR CABLE TRAY ANGLE SUPPORT

$$P = 1560 \#$$

$$M = \frac{P l}{4} = \frac{1560 \times 12}{4} = 4680 \text{ in lbs}$$

$$S_m = \frac{4680}{22000} = .21 \text{ in}^3$$


BECAUSE 2 HOLES MAY BE REQD TO SUPPORT THE CABLE TRAY SUPPORT  
 MIN SIZE ANGLE IS 6x3x1/2"  $S_m = 1.53 \text{ in}^3$

DEFLECTION

$$\frac{P l^3}{48 E I} = \frac{1560 \times 12^3}{48 \times 29,000 \times 5.1} = .0003 \text{ \"}$$

ANCHOR BOLT DESIGN

$M = Pa$   
 $166,617 = P \cdot 12$   
 $P = 13914$



$P = 1360$

T = TENSION

$\frac{\sum M}{72} = \frac{1360 \times 12 + 166,617}{72} + \frac{1360 \times 60 + 166,617}{72} = \text{TENSION}$

$= \frac{185,337 \# + 260,217 \#}{72 \text{ in}} = 6188.25 \#$

TENSION = 6188.25 #

TRY WEI IT  $\frac{3}{4} \times 6 = 21530 \times .9875 \times .25 = 5315$   
 $\frac{5}{8} \times 6 = 14372 \times .9875 \times .25 = 3548$

$\frac{6189}{3548} = 1.74$  REQ'D # OF ANCHOR BOLTS

CHECK SHEAR  
 USE 6684.1# SHEAR

$\frac{2524.5}{.375} = 6684.1$   
 SF.

SHEAR  $\frac{3}{4}$ "  $27607 \# \div 4 = 6901.75 \# \times 2 = 13,803.5$

SHEAR  $\frac{5}{8}$ "  $25674 \# \div 4 = 6418.5 \# \times 2 = 12,837$

TENSION  $\frac{3}{4}$ "  $21530 \# \div 4 = 5382.5 \# \times 2 = 10,765 \#$  PER SIDE

USE  $\frac{3}{4}$ " x 6" WEI IT 6 REQ'D

THE  $\frac{3}{4}$ " x 6" WEI IT EXCEED THE LOAD REQUIREMENTS BY A S.F. (SAFETY FACTOR) OF GREATER THAN 3. USE THEREFORE SATISFACTORY

### WELD REQUIREMENT

DESIGN 3<sup>RD</sup> EDITION Pg 4-53 ELWYN SEELYE

$$\begin{aligned}M &= P \times a \\M &= 1560 \times 6 \\M &= 9360\end{aligned}$$

$$I_0 = \frac{L^3}{12} = \frac{12^3}{12} = 144$$

$$H = \frac{M}{I_0} \times \frac{L}{2} = \frac{9360}{144} \times \frac{12}{2} = 390$$

$$\text{MAX STRESS } Z = \sqrt{V^2 + H^2}$$

$$V = 2524 \quad \sqrt{2524^2 + 390^2}$$

$$Z = 2553.95$$

$$\frac{2553.95}{13600} \times \frac{1}{.707} = .265" \div 2 = .13"$$

USE  $\frac{3}{16}$ " WELD = .1875"

CALCULATION TITLE PAGE

\*SEE INSTRUCTIONS ON REVERSE SIDE

CN 146C A

BY HICKS

PAGE 837A

FORM NO. 372-30-2650

A 3010.84 (FRONT)

CLIENT & PROJECT <b>PSC - FSU 3 ROOM ADDITION</b>				PAGE 1 OF <b>6</b>		
CALCULATION TITLE (Indicative of the Objective): <b>MISCELLANEOUS DETAILS</b>				QA CATEGORY (✓) <input checked="" type="checkbox"/> I - NUCLEAR SAFETY RELATED <input type="checkbox"/> II <input type="checkbox"/> III <input type="checkbox"/> OTHER		
CALCULATION IDENTIFICATION NUMBER						
J. O. OR W. O. NO.	DIVISION & GROUP	CURRENT CALC. NO.	OPTIONAL TASK CODE	OPTIONAL WORK PACKAGE NO.		
<b>13569.04</b>	<b>S</b>	<b>C.I.B</b>	<b>510</b>	<b>N.A.</b>		
* APPROVALS - SIGNATURE & DATE				REV. NO. OR NEW CALC. NO.	SUPERSEDES * CALC. NO. OR REV. NO.	CONFIRMATION * REQUIRED (✓) YES NO
PREPARER(S)/DATE(S)	REVIEWER(S)/DATE(S)	INDEPENDENT REVIEWER(S)/DATE(S)				
<b>D. D KAWAMOTO</b> <b>12-8-82</b> <i>D Kawamoto</i>	<b>M. R. LINGLE</b> <b>12-8-82</b> <i>M. R. Lingle</i>	<b>J W McCOLLEY</b> <b>12-8-82</b> <i>J W McColley</i>	<b>0</b>			<input checked="" type="checkbox"/>

DISTRIBUTION \*

GROUP	NAME & LOCATION	COPY SENT (✓)	GROUP	NAME & LOCATION	COPY SENT (✓)
RECORDS MGT. FILES (OR FIRE FILE IF NONE)	<b>Project file ✓</b> <b>Fire file ✓</b> <b>Jdo book ✓</b>				





# CALCULATION SUMMARY

STONE & WEBSTER ENGINEERING CORPORATION

4501062

J.O./W.O./CALCULATION NO.

13569.04 SC1.8

REVISION

0

CN 1460A

BY HICKS

QA CATEG

PAGE B39A

FORM NO. 372-30-2650

CLIENT/PROJECT

FSU 3 ROOM ADDITION

SUBJECT/TITLE

MISCELLANEOUS DETAILS

OBJECTIVE OF CALCULATION

TO INVESTIGATE DETAILS "G" AND "J" SHOWN ON DRAWING  
13569.04 - FC - 1C.

CALCULATION METHOD/ASSUMPTIONS

- 1) ANCHOR BOLTS CONSIDERED PLAIN BAR AND FULL LENGTH WHICH GOVERNS OVER TAKING THE ALLOWABLE TENSILE STRESS ON THE AREA OF BOLT.

SOURCES OF DATA/EQUATIONS

- 1) AISC MANUAL OF STEEL CONSTRUCTION, 8th ED.
- 2) ACI 318-63, PARA 918 (h), ANCHORAGE REQUIREMENTS.
- 3) MASONRY WALL CALC 13569.04 SC1.6

CONCLUSIONS

RESULTS FOR DETAIL "G" SHOWN ON PAGE 4

RESULTS AND RECOMMENDATIONS FOR DETAIL "J" SHOWN ON PAGES 5, 6.

REVIEWER(S) COMMENTS

PREPARER

D. Kulkarni

DATE

12-7-72

REVIEWER/CHECKER

DATE

INDEPENDENT REVIEWER

DATE

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

AS010 61

J.O./W.O./CALCULATION NO.

13569.04

REVISION

0

CN 1460 A

BY HICKS

PAGE B 40 A

FORM NO. 372-30-2650

PREPARED / DATE

D. KAWAMOTO

12-7-82

REVIEWER / CHECKER / DATE


INDEPENDENT REV

SUBJECT / TITLE

MISCELLANEOUS DETAILS

QA CATEGC

INVESTIGATE DETAIL 'E' DWG 13569.04-FC-1C (MASONRY WALLS)



FROM PAGE A5, MASONRY WALLS

CALC  $\pm$  C.I.6

SIZE OF WELD  $< \frac{1}{8}$ " BY INSPECTION SINCE LOAD IS SMALL. ALLOWABLE WELD STRESS = 21,100 PSI

USE  $\frac{1}{8}$ " FILLET 2" LONG 12" O.C.

# CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

ASD10.51

J.O./W.O./CALCULATION NO.

13569.04

REVISION

C CN 1460 A

PREPARER/DATE

D. KAWAMOTO 12-7-82

REVIEWER/CHECKER/DATE

INDEPENDENT R

BY HICK'S

PAGE B41 A

SUBJECT/TITLE

MISCELLANEOUS DETAILS

QA DATE

FORM NO. 372-30-2650

INVESTIGATE DETAIL "J" DWG 13569.04-FC-10 (FLOOR SLAB)

a) FOR ALLOWABLE TENSION

- 1) USING ALLOWABLE TENSILE STRESS FOR A 36  $f_t = 19.1$  KSI
- 2) USING BOND ON PLAIN BARS FOR LENGTH DESCRIBED IN ACI 318-63 910 (h)  $\mu = 160$  psi (WSD)

FOR  $\frac{1}{2}$ "  $\phi$  BOLT IN 6" SLAB LENGTH OF BOLT =  $6 - \frac{1}{2} - .75 - .5 + 3 = 6.25$ "

a)  $T = \pi d^2/4 \times 19.1 = 375$  K (CROSS-SECTION OF BOLT)

b)  $T = \pi d \times 6.25 \times 160 = 1570$  # (BOND - WSD)

USE ALLOWABLE  $T = 1.57$  K (NO LOAD FACTORS FOR SEISMIC)

FOR  $\frac{3}{8}$ "  $\phi$  BOLT IN 6" SLAB

a)  $T = \pi (\frac{3}{8})^2/4 \times 19.1 = 2.11$  K (CROSS SECTION OF BOLT)

b)  $T = \pi (\frac{3}{8}) \times 6.25 \times 160 = 1.18$  K (BOND - WSD)

USE ALLOWABLE  $T = 1.18$  K (NO LOAD FACTORS FOR SEISMIC)

FOR  $\frac{1}{2}$ "  $\phi$  BOLT IN 12" SLAB LENGTH =  $12 - 3 - .75 - .5 + 3 = 10.75$ "

$T = \pi d \times 10.75 \times 160 = 2.7$  K (NO LOAD FACTORS FOR SEISMIC)

FOR  $\frac{3}{8}$ "  $\phi$  BOLT IN 12" SLAB

$T = \pi d \times 10.75 \times 160 = 2.03$  K (NO LOAD FACTORS FOR SEISMIC)

# CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

AS01051

J.O./W.O./CALCULATION NO.

13569.04

REVISION

CN 1460A

PREPARER/DATE

D KAWAMOTO 12-7-72

REVIEWER/CHECKER/DATE

INDEPENDENT REV

BY HICKS

SUBJECT/TITLE


MISCELLANEOUS DETAILS

QA CATEG


FORM NO. 372-30-2650

(FLOOR SLAB)

RECOMMENDED PROJECTION FOR  $\frac{1}{2}$ "  $\phi$  BOLT



RECOMMENDED PROJECTION FOR  $\frac{3}{8}$ "  $\phi$  BOLT



## DISCUSSION

ORIGINAL DESIGN FOR BUILDING 10 WALKOVER STRUCTURE FOUNDATION WAS A RAFT-TYPE REINFORCED CONCRETE FOOTING (OVERALL DIMENSIONS: 8 FT BY 38 FT IN PLAN BY 6 FT IN DEPTH)\* WHICH BEARS ON MEDIUM DENSE SAND AT THE PROPOSED LOCATION. BASED ON THE SITE'S SOIL REPORT (WOODWARD-CLYCE, JULY 1966), ANTICIPATED ALLOWABLE BEARING PRESSURE OF SOIL AT THE BASE OF THE FOUNDATION IS 6000 PSF.

UPON EXCAVATION OF THE AREA TO A DEPTH OF 6 FT BELOW GRADE, IT WAS NOTED THAT THE SOIL MATERIAL WAS QUITE LOOSE AND POSSIBLY NOT CAPABLE OF THE BEARING CAPACITY REQUIRED. FOUR TEST HOLES IN THE FOUNDATION AREA WERE DRILLED; DETAILS, RESULTS AND RECOMMENDATIONS OF THIS TESTING ARE FOUND ON PAGES B44D THROUGH B63D.

FINDINGS OF THE REPORT INDICATE THAT THE IN SITU SOIL AT DEPTH OF 6 FT BELOW GRADE IS CAPABLE OF PROVIDING ONLY 1000 PSF BEARING. A NUMBER OF ALTERNATIVE FOUNDATION SCHEMES WERE SUGGESTED (P. B45D) IN ORDER TO TRANSFER THE LOAD TO A MORE DENSE STRATUM. OF THESE, THE REMOVAL OF AN ADDITIONAL 9 FT OF SOIL TO BE FILLED WITH LEAN CONCRETE WAS CHOSEN DUE TO COST AND SCHEDULE CONSIDERATIONS. MINIMUM LEAN CONCRETE STRENGTH NECESSARY TO SAFELY RESIST DESIGN LOADS DELIVERED FROM THE RAFT FOUNDATION IS 42 PSI COMPRESSIVE STRENGTH (6000 PSF); THIS WAS ACHIEVED BY USING A FOUR-SACK MIX DESIGNED FOR 2000 PSI 28 DAY COMPRESSIVE STRENGTH.

TYPE II CEMENT IS SPECIFIED IN THE PLACING PROCEDURE (SEE P. G30D) BECAUSE OF ITS RESISTANCE TO SOIL SULFATE ATTACK. HOWEVER, DISCUSSIONS WITH SARGENT & LUNDY ENGINEERS ON 6/10/83 CONFIRMED THAT FOR ALL-CONCRETE BACKFILL OF THE TYPE PROPOSED, TYPE I CEMENT IS ACCEPTABLE AND FULFILLS THE REQUIREMENTS OF THE ORIGINAL CONCRETE WORK SPECIFICATION 1-J-30.1. CONCRETE WITH TYPE I CEMENT WAS USED FOR THE FIRST POUR (APPROXIMATELY 1/3 OF TOTAL VOLUME); THE REMAINDER UTILIZES TYPE II CEMENT.

DURING PLACEMENT OF THE LEAN CONCRETE FILL, SOIL IN THE AREA OF THE TURNING BUILDING/ACCESS BAY GRADE BEAM SWAMPED TO SEAR AGAINST THE TIMBER BRACING

## GENERAL ATOMIC COMPANY

CALCULATIONS FOR			CN <u>1460</u>
EQUIP. NO.	PROJ. NO.	CALC. NO.	BY <u>TESNER</u>
PREPARED BY	DATE	REF. DOCUMENTS:	PAGE <u>843.1 D</u>
REVIEWED BY	DATE		FORM NO. 372-30-2650
APPROVED BY	DATE		

ERECTED TO HOLD THE CUT IN PLACE. VOIDS BENEATH THE GRADE BEAM WERE FILLED AND RACKED WITH THE LEAN CONCRETE MIX AND THE POUR CONTINUED. AS A RESULT A REGION OF SOIL ESTIMATED TO BE 15 FT LONG BY 8 IN. WIDE IN PLAN AND 15 FT DEEP ENCLOSED THE CONCRETE BACKFILL VOLUME ALONG ITS WEST EDGE. IN ADDITION, A PORTION OF THE PLYWOOD COMPRISING THE SHORING REMAINS CAST IN THE BACKFILL WHEN SAID PLYWOOD STRIPPED AWAY FROM THE 4X4 TIMBER BRACING DURING ITS ATTEMPTED REMOVAL. IN LIGHT OF NUMEROUS CONSERVATISMS EXHIBITED IN THE DESIGN (LIMITING ACTUAL BEARING STRESS ON SOIL TO 6000 PSF AS OPPOSED TO THE SOIL REPORT'S CONCLUSION OF 9200 PSF ALLOWABLE BEARING ON SOIL 15 FT BELOW EXISTING GRADE [SEE P. 846D, 859D], GENEROUS FACTOR OF SAFETY IN LEAN CONCRETE STRENGTH) THE AS-INSTALLED BACKFILL WILL FUNCTION AS ADEQUATE FOUNDATION MATERIAL CAPABLE OF SAFELY SUPPORTING ALL DESIGN LOADS IMPOSED BY THE WALKOVER STRUCTURE.

PREPARED BY: J.A. Turner DATE: 6/10/83

\* ACTUAL DIMENSIONS OF FOUNDATION (REF. DWG. B-455): 7'-10" WIDE BY 36'-0" LONG BY 4'-0" DEEP STEPPED UP TO 6'-0" DEEP FOR THE MIDDLE 23'-2". USE OF DIMENSIONS INDICATED ON PREVIOUS PAGE WILL NOT SIGNIFICANTLY ALTER THE RESULTS OF CALCULATIONS OR CONCLUSIONS NOTED ON PAGES 843D THROUGH B-64D.



CN 1460  
BY TESNER  
PAGE B44D  
FORM NO. 372-30-2650

CTL/THOMPSON, INC.  
CONSULTING GEOTECHNICAL AND MATERIALS ENGINEERS

June 3, 1983

G.E. Johnson Construction Company  
16805A-WCR  
19 1/2 Road  
Platteville, Colorado 80651

Attention: Mr. Jim Buridge



Subject: Walk-Over Structure  
Fort St. Vrain Nuclear Generating Station  
Platteville, Colorado  
Job No. 9127

Gentlemen:

In accordance with your request, we have completed the geotechnical investigation for the subject structure. It is our understanding the walk-over structure is planned to be founded on a raft type foundation measuring 38 feet by 8 feet with a thickness of 6 feet. Loads imposed on the soil range from 1,500 psf under normal conditions to 6,000 psf during tornadic winds. No information was available concerning the superstructures, intended use, or structural details.

#### FIELD AND LABORATORY INVESTIGATION

The field investigation consisted of drilling and sampling 4 exploratory borings within the completed 6 foot excavation. The locations of the borings were selected by Public Service Company of Colorado and are shown on the attached Fig. 1. Borings extended from 25 to 52 feet below the bottom of the excavation. Standard Split-Spoon penetration tests (ASTM D 1586), California Drive Samples and Shelby tubes were used to obtain samples of the subsoils for testing. Graphical logs of the soils encountered, penetration resistance tests and laboratory test results are presented on Fig. 2. Gradation analyses are presented on Figs. 3 through 9.

The subsoils consist of 4 to 6 feet of sand fill underlain by clean to silty sands which extended to the full depth of borings TH-1, TH-2, and TH-4. Boring TH-3 extended to 52 feet and encountered a zone of gravelly sand extending from 33 to 42 feet below grade underlain by weathered and unweathered claystone bedrock. A bedrock sample contained approximately 78 percent clay and silt sized particles and testing indicates a liquid limit of 24 percent and a plasticity index of 12 percent. Cuttings suggest the material is a sedimentary formation commonly known as the "Denver Blue". A previous report published by

82-206-1-J

Woodward Clyde (Job No. 9594-9309) recommended allowable pressures for piers in the bedrock of 60,000 psf end bearing and 6,000 psf skin friction.

#### DISCUSSION

Considering the size of the raft, loads and subsurface conditions, we do not recommend placement of the raft on soils encountered in the excavation. Our preliminary analyses indicate the natural soils and fill will support loads of only 1,000 psf assuming a limiting settlement of 1 inch. Since this is far below the anticipated loads, we have considered several foundation alternatives for the structure. Four alternatives involves treatment of the subsoils and use of the designed raft foundation. The remaining two alternatives involve supporting the structure on pier or pile foundations.

1. Removal of 9 feet of the natural soils and fill and supporting the raft on lean concrete.
2. Removal and compaction of at least 9 feet of the natural soils and fill beneath the proposed raft.
3. Grouting the loose upper soils using a cementing grout to transfer loads of the raft to denser soils.
4. Compaction grouting to densify and strengthen the soils and fill beneath the raft.
5. Supporting the structure on driven piles founded in the sound bedrock.
6. Constructing the walk-over on drilled piers into bedrock.

Of the alternatives evaluated, the pile (5) and pier (6) options are the safest and most reliable. We understand that time requirements for re-engineering the foundation have precluded these options from consideration. Should conditions change, we will be happy to provide additional data.

The grouting alternatives (3) and (4) offer significant cost and speed advantages. Compaction grouting is performed by injecting sand-cement grout at the exterior boundaries of the excavation under high pressure. After the exterior is fully injected, additional points in the center of the pad are compaction grouted. This process is normally done on 3 to 6 foot centers using pressures ranging up to 1,500 psi. Cement grouting is normally done at pressures of 50 to 150 psi, depending upon conditions, using sand-cement or silicate chemical compounds. Cement grouting is normally more expensive than compaction grouting. Should either of these alternatives be selected for additional study, we will supply detailed recommendations.

82-206-1-5



The primary alternatives which were being considered by the owner and contractor were removal of 9 feet of material below the bottom of footing and replacement with compacted sand (2) or lean concrete (1). These alternatives require an excavation which will be a total depth of 15 feet from grade. At this elevation, the natural soils have a SPT value of about 14. The density of the soils increases with depth. The primary difficulties with these alternatives are; the possible loss of support for surrounding slab-on-grade construction, difficulty in bracing, and the hand work required. The benefits are that the labor and equipment is available and construction will not be further delayed. Our understanding is that the accepted scheme is to backfill with lean concrete.

ANALYSES AND RECOMMENDATIONS

We have performed our analyses of the proposed removal and replacement scheme using concrete. In effect, this will transfer the imposed raft loads down to the natural soils at a depth of 9 feet (15 feet below-grade). Three analysis methods were used to predict the foundation's behavior. The allowable stress on the natural soils was determined using the Terzaghi analysis method. The results indicate a maximum allowable pressure on the soil is 9,200 psf. The settlement potential was analyzed using a method contained in Hough's text Basic Soils Engineering and a second technique developed by Meyerhof and presented in Scott's text Foundation Analysis. The analyses are based upon results of Standard Penetration Test conducted in the exploratory borings. The analyses indicated a potential settlement of approximately 2.1 inches using Hough's method and up to 1.6 inches based on Meyerhof's method. Copies of the calculation sheets are contained in Appendix A.

Considering the potential for settlement, we recommend isolating the walk-over from adjacent buildings using flexible connections. Any plumbing, electrical or structural connections should be delayed until the majority of the dead load has been applied. It should be noted that construction and settlement of the foundation could affect other elements of the walk-over and adjacent building. An engineer familiar with the project details should carefully review the structural implications.

Our work on this project has been limited to determination of subsurface conditions, provision of foundation alternatives and analyses. Only limited information was available regarding the walk-over structure and the adjacent construction. Given the limited information, we have made the assumptions that the foundation under consideration is free of any other structure and acts as an independent unit. These assumptions should be verified.

NOTE: THE BUILDING 10 WALKOVER STRUCTURE AND ITS FOUNDATION HAVE BEEN ISOLATED FROM THE ADJACENT STRUCTURES BY USE OF FLEXIBLE-TYPE CONNECTIONS IN THE DESIGN AND A CLEARANCE OF 1" E FROM OTHER BUILDINGS.


82-206-1-J JAT  
6/10/83

If you have any questions concerning this information or require additional analyses, please call.

Very truly yours,

CTL/Thompson, Inc.

By \_\_\_\_\_  
Darrel V. Holmquist, P.E., Vice President



DVH:jc

(3 copies sent)

82-206-1-J

4791  
4785


TH-1  
EL.=4785

TH-2  
EL.=4785

TH-3  
EL.=4785

TH-4  
EL.=4785

82-206-1-5



CN 1460  
 BY TESHER  
 PAGE 248D  
 FORM NO. 372-30-2550

SAND, LOOSE TO SANDY, MEDIUM DENSE TO MEDIUM DENSE, MOIST, LIGHT BROWN, RUST, (SP-SM, SM)



SAND, GRAVELLY TO GRAVEL, SANDY, LOOSE TO MEDIUM DENSE, WET, BROWN (SP, GP)



SEVERELY WEATHERED CLAYSTONE WITH SANDSTONE LENSES, MEDIUM HARD, MOIST, BROWN, BLUE-GRAY



BEDROCK, CLAYSTONE, HARD, MOIST, BLUE-GRAY



INDICATES LEVEL OF FREE GROUND WATER AT THE TIME OF DRILLING.



STANDARD SPLIT SPOON SAMPLE. THE SAMPLER WAS INITIALLY DRIVEN 6 INCHES INTO THE RELATIVELY UNDISTURBED SOILS. THE SYMBOLS 2/6 AND 1/6 INDICATE THAT 2 BLOWS OF A 140 POUND HAMMER FALLING 30 INCHES WERE REQUIRED TO DRIVE A 2.0 INCH SAMPLER A SECOND 6 INCHES AND 1 BLOW WAS REQUIRED TO DRIVE THE SAMPLER A THIRD 6 INCHES.



DRIVE SAMPLE. THE SYMBOL 5/12 INDICATES THAT 5 BLOWS OF A 140 POUND HAMMER FALLING 30 INCHES WERE REQUIRED TO DRIVE A 2.5 INCH O.D. SAMPLER 12 INCHES.



SHELBY TUBE SAMPLE. THE SYMBOL 12 INDICATES THAT A 2.5 INCH I.D. THIN-WALLED TUBE WAS PUSHED 12 INCHES INTO THE RELATIVELY UNDISTURBED SOILS.



WC=20.3  
-200=78  
LL=24  
PI=12

4745

4740

4735

4730

NOTES:

1. THE BORINGS WERE DRILLED MAY 25 AND 26, 1983 WITH A 4-INCH DIAMETER CONTINUOUS FLIGHT POWER AUGER.
2. THESE LOGS ARE SUBJECT TO THE EXPLANATIONS, LIMITATIONS AND CONCLUSIONS AS CONTAINED IN THIS REPORT.
3. WC - INDICATES NATURAL MOISTURE CONTENT (X)  
DD - INDICATES DRY DENSITY (PCF)  
-200 - INDICATES PERCENT PASSING NO. 200 SIEVE  
LL - INDICATES LIQUID LIMIT (X)  
PI - INDICATES PLASTICITY INDEX (X).


82-206-1-5

LOGS OF EXPLORATORY BORINGS

JOB NO. 9127


CN 1460  
BY TESLER  
PAGE 249D  
FORM NO. 372-30-2650

FIG. 2




LOCATION OF EXPLORATORY BORINGS

82-206-1-5




CLAY (PLASTIC) TO SILT (NON-PLASTIC) ——— %  
 GRAVEL 0 % SAND 81 % SILT AND CLAY 19 %  
 LIQUID LIMIT ——— % PLASTICITY INDEX ——— %  
 SAMPLE OF SAND, SILTY (SM) FROM TH-1 AT 2 FEET




CLAY (PLASTIC) TO SILT (NON-PLASTIC) ——— %  
 GRAVEL 0 % SAND 86 % SILT AND CLAY 14 %  
 LIQUID LIMIT ——— % PLASTICITY INDEX ——— %  
 SAMPLE OF SAND, SILTY (SM) FROM TH-1 AT 4 FEET

GRADATION TEST RESULTS

82-206-1-J




GRAVEL 0 % SAND 89 % SILT AND CLAY 11 %  
 LIQUID LIMIT — % PLASTICITY INDEX — %  
 SAMPLE OF SAND, SILTY (SP-SM) FROM TH-1 AT 7.5 FEET




GRAVEL 0 % SAND 82 % SILT AND CLAY 18 %  
 LIQUID LIMIT — % PLASTICITY INDEX — %  
 SAMPLE OF SAND, SILTY (SM) FROM TH-1 AT 14 FEET

GRADATION TEST RESULTS

82-206-1-5



GRAVEL 0 % SAND 91 % SILT AND CLAY 9 %  
 LIQUID LIMIT — % PLASTICITY INDEX — %  
 SAMPLE OF SAND, SILTY (SP-SM) FROM TH-2 AT 4 FEET




GRAVEL 0 % SAND 92 % SILT AND CLAY 8 %  
 LIQUID LIMIT — % PLASTICITY INDEX — %  
 SAMPLE OF SAND, SILTY (SP-SM) FROM TH-2 AT 14 FEET

GRADATION TEST RESULTS


82-206-1-J

FORM 12






GRAVEL 0 % SAND 95% SILT AND CLAY 5 %  
 LIQUID LIMIT — % PLASTICITY INDEX — %  
 SAMPLE OF SAND, SILTY (SP-SM) FROM TH-2 AT 19 FEET




GRAVEL 0 % SAND 77 % SILT AND CLAY 23 %  
 LIQUID LIMIT — % PLASTICITY INDEX — %  
 SAMPLE OF SAND, SILTY (SM) FROM TH-3 AT 1 FOOT

GRADATION TEST RESULTS

82-206-1-J




GRAVEL 0 % SAND 63 % SILT AND CLAY 37 %  
 LIQUID LIMIT — % PLASTICITY INDEX — %  
 SAMPLE OF SAND, CLAYEY, SILTY FROM TH-3 AT 3 FEET  
 (SC, SM)




GRAVEL 0 % SAND 94 % SILT AND CLAY 6 %  
 LIQUID LIMIT — % PLASTICITY INDEX — %  
 SAMPLE OF SAND, SILTY (SP-SM) FROM TH-3 AT 7 FEET

GRADATION TEST RESULTS

82-206-1-5



GRAVEL 11 % SAND 74 % SILT AND CLAY 15 %  
 LIQUID LIMIT — % PLASTICITY INDEX — %  
 SAMPLE OF SAND, SILTY, SLIGHTLY FROM TH-4 AT 2 FEET  
 GRAVELLY (SM)




GRAVEL 26 % SAND 60 % SILT AND CLAY 14 %  
 LIQUID LIMIT — % PLASTICITY INDEX — %  
 SAMPLE OF SAND, GRAVELLY, SILTY FROM TH-4 AT 4 FEET  
 (SM)


GRADATION TEST RESULTS

82-206-1-J

FIGURE 14



GRAVEL 0 % SAND 92 % SILT AND CLAY 8 %  
 LIQUID LIMIT — % PLASTICITY INDEX — %  
 SAMPLE OF SAND, SILTY (SP-SM) FROM TH-4 AT 9 FEET



GRAVEL 0 % SAND 93 % SILT AND CLAY 7 %  
 LIQUID LIMIT — % PLASTICITY INDEX — %  
 SAMPLE OF SAND, SILTY (SP-SM) FROM TH-4 AT 12 FEET

GRADATION TEST RESULTS

82-206-1-J


CN 1460  
BY TESNER  
PAGE 5580  
FORM NO. 372-30-2650

APPENDIX A

82-206-1-J

JOB No. 9127  
 JOB NAME: ADDITION TO  
 CONTROL ROOM  
 CALCS. BY: RAP  
 REVIEWED BY: OVH

I. BEARING CAPACITY



ASSUMPTIONS:

- 1.) FOOTING FOUNDED IN SAND;  $N_{AVE.} = 14$  ;  $\gamma_T = 125$  PCF
- 2.) FOOTING DIMENSIONS;  $B = 8'$   $D_F = 15'$

FROM PECK, HANSON, & THORNBURN (1)

$$Q_d = \frac{1}{2} B \gamma_T N_q + \gamma_T D_F (N_q - 1) \quad \text{EQ. (14.8)}$$

WHERE  $Q_d$  = ULTIMATE BEARING CAPACITY (PSF)

$N_q = 10$  } FROM FIG. 14.2 (PECK, HANSON, THORNBURN)  
 $N_q = 13$  } FOR  $N = 14$

$$\begin{aligned} Q_d &= \frac{1}{2} (8 \times 125 \times 10) + (125 \times 15 \times 13 - 1) \\ &= 5000 + 22500 \\ &= 27500 \text{ psf} \end{aligned}$$

LET SAFETY FACTOR = 3

$Q_a$  = ALLOWABLE BEARING CAPACITY


$$Q_a = 27,500 / 3$$

$$\underline{\underline{Q_a = 9167 \text{ PSF}}} \quad (> 6000 \text{ PSF : PEAK STRESS})$$

JOB No. 9127  
 JOB NAME: ADDITION TO  
 CONTROL ROOM  
 CALCS. BY: RAP  
 REVIEWED BY: DVH

II. SETTLEMENT ESTIMATE

METHOD A: A<sub>3</sub> DESCRIBED  
 BY HOUGH (2)



ASSUMPTIONS :

- 1.) STRESS DISTRIBUTION BENEATH FOOTING IS DESCRIBED BY A TRAPEZOID HAVING SIDE SLOPES OF 1:2 (HORIZONTAL TO VERTICAL)
- 2.) GROUND WATER TABLE IS LOCATED AT DEPTH OF 25 FEET.
- 3.)  $S = \sum_0^Z \frac{H}{C} \text{Log}_{10} \left( \frac{H \Delta p}{p} \right)$

WHERE :

S = TOTAL SETTLEMENT (FEET)  
 H = THICKNESS OF LAYER (FEET)  
 C = BEARING CAPACITY INDEX  
 $\Delta p$  = PRESSURE INCREASE DUE TO FOOTING (PSF)  
 p = OVERBURDEN PRESSURE AT MIDPOINT OF LAYER (PSF)

4.)  $\Delta p = \frac{6000(B)}{(B+D)}$

WHERE :

D = DEPTH BELOW FOOTING (FEET)  
 6000 = PEAK APPLIED STRESS (PSF)

5.)  $p = \gamma_t(Z)$  ABOVE GWT

$p = (\gamma_c)(Z) - [(Z - 25)(125 - 62.4)]$  BELOW GWT ( $Z > 25$ )

WHERE :

$\gamma_t$  = TOTAL UNIT WEIGHT (PCF)  
 Z = DEPTH TO MIDPOINT OF LAYER (FEET)  
 62.4 = UNIT WEIGHT OF WATER (PCF)

JOB No. 9127  
 JOB NAME: ADDITION TO  
 CONTROL ROOM  
 CALCS. BY: RAP  
 REVIEWED BY: DVH

LAYER	D (Ft.)	N*	H (Ft.)	C**	p (psf)	A <sub>p</sub> (psf)	S (ft.)
①	2.5	15	5	38	2188	4571	0.064
②	10	21	10	43	3125	2667	0.062
③	25	25	20	50	4061	1455	0.053

\* : AVERAGE BLOW COUNT (SPT)

\*\* : FROM FIG. 9-6 (HUGH)

S = .0179 FEET.  
 = 2.1 INCHES


TOTAL ESTIMATED SETTLEMENT FOR PEAK STRESS  
 OF 6000 PSF = 2.1 INCHES



JOB No. 9127  
 JOB NAME: ADDITION TO  
 CONTROL ROOM  
 CALCS BY: RAP  
 REVIEWED BY: DVH

III. SETTLEMENT ESTIMATE

METHOD B: AS DESCRIBED  
 BY SCOTT (3)



ASSUMPTIONS:

- 1.) STRESS DISTRIBUTION BENEATH FOOTING IS DESCRIBED BY A TRAPEZOID HAVING SIDE SLOPES OF 1:2 (HORIZONTAL TO VERTICAL)
- 2.) EFFECT OF GROUND WATER TABLE IS TAKEN INTO ACCOUNT BY THE BLOW COUNT VALUE (N)

$$S_t = C_1 C_2 (\Delta p) \sum_{0}^{2B} \frac{I_z}{E_s} \Delta Z \quad (B = 8 \text{ FEET})$$

WHERE:

- $S_t$  = TOTAL SETTLEMENT (FEET)
- $C_1$  = FOOTING DEPTH FACTOR
- $C_2$  = TIME FACTOR (CREEP)
- $\Delta p$  = PRESSURE INCREASE DUE TO FOOTING (TSF)
- $I_z$  = VERTICAL STRAIN INFLUENCE FACTOR
- $E_s$  = COMPRESSION MODULUS
- $\Delta Z$  = THICKNESS OF SAND LAYER (FEET)

$$E_s = 4N$$

$$C_1 = 1 - 0.5 \frac{p_o}{\Delta p} \quad (1 > C_1 > 0.5)$$

- $p_o$  = OVERBURDEN PRESSURE AT MIDPOINT OF LAYER (PSF)
- $p_o = \gamma_s (Z)$
- $\gamma_s = 125 \text{ pcf}$
- $Z$  = DEPTH TO MIDPOINT OF LAYER (FEET)

$$C_2 = 1 + 0.2 \log_{10} (10t)$$

$t$  = TIME IN YEARS

4.) METHOD ASSUMES  $I_z = 0$  AT DEPTH EQUAL TO 2B BELOW THE BOTTOM OF FOOTING

42-102 100 SHEETS NATIONAL

$$5.) \Delta p = \frac{6000 (S)}{(B + D)}$$

WHERE: D = DEPTH BELOW FOOTING (F.)  
 6000 = PEAK APPLIED STRESS (P<sub>AP</sub>)

JOB No. 9127  
 JOB NAME: ADDITION TO  
 CONTROL ROOM  
 CALCS. BY: RAP  
 REVIEWED BY: OVH

LAYER	D (F.)	ΔP (P <sub>AP</sub> )	ΔP (T <sub>DP</sub> )	Z <sub>i</sub> (F.)	P <sub>o</sub> (P <sub>AP</sub> )	C <sub>i</sub> *	D/B	I <sub>z</sub> **	N	E <sub>s</sub>	ΔE (F.)	S (F.)
①	2.5	4571	2.29	17.5	2188	0.76	0.31	0.40	15	60	5	0.058
②	7.5	3097	1.55	22.5	2813	0.55	0.94	0.43	20	80	5	0.023
③	12.5	2341	1.17	27.5	3438	0.50	1.56	0.18	22	88	5	0.006

\*: C<sub>i</sub>: 1 > C<sub>i</sub> > 0.5  
 \*\*: FROM FIG. 7-4 (SCOTT)

S<sub>e</sub> = 0.087 FEET  
 = 1.04 INCHES

INCLUDING TIME FACTOR (C<sub>2</sub>)

t	C <sub>2</sub>	S <sub>e</sub> (IN.)
1	1.20	1.25
5	1.34	1.39
10	1.40	1.46
20	1.46	1.52
50	1.54	1.60

TOTAL ESTIMATED SETTLEMENT  
 FOR PEAK STRESS OF 6000 P<sub>AP</sub>

IV. REFERENCES

- (1) FOUNDATION ENGINEERING, PECK, RALPH B., HANSON, WALTER E., AND THORNBURN, THOMAS H., JOHN WILEY AND SONS, INC., NEW YORK, 1953.
- (2) BASIC SOILS ENGINEERING, HOUGH, B. K., THE RONALD PRESS COMPANY, NEW YORK, 1969.
- (3) FOUNDATION ANALYSIS, SCOTT, RONALD F., PRENTICE-HALL, INC., ENGLEWOOD CLIFFS, NEW JERSEY, 1981.

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

A501051

J.O./W.O./CALCULATION NO.

REVISION

CN 1460

PREPARER/DATE

J. TESNER 6/7/33

REVIEWER/CHECKER/DATE

INDEPENDENT RE

BY TESNER

PAGE B64D

SUBJECT/TITLE

QA GATE

FORM NO. 372-30-2650

WALKOVER STRUCTURE FOUNDATION SETTLEMENT

REF. METHOD A, P. B600 D

$$S = \sum_0^3 \frac{H}{C} \log_{10} \left( 1 + \frac{\Delta p}{p} \right)$$

$\Delta p$  BASED ON NORMAL BEARING PRESSURE AT BASE OF REINFORCED FOOTING OF 1500 PSF

S = TOTAL SETTLEMENT

H = THICKNESS OF LAYER

C = BEARING CAPACITY INDEX

$\Delta p$  = PRESSURE INCREASE DUE TO FOOTING (PSF)

p = OVERBURDEN PRESSURE AT MIDPOINT OF LAYER (PSF)

$$\Delta p = \frac{1500(8)}{(8+D)} \quad \text{FOR TRAPEZOID STRESS DISTRIBUTION WITH SIDE SLOPE OF 1:2}$$

$$\Delta p_1 = 471 \quad (D = 17.5 \text{ FT})$$

D = DEPTH BELOW FOOTING TO MIDPOINT OF LAYER

$$\Delta p_2 = 364 \quad (D = 25 \text{ FT})$$

$$\Delta p_3 = 250 \quad (D = 40 \text{ FT})$$

$$p_1 = (17.5)(125) = 2188 \text{ PSF}$$

$$p_2 = (25)(125) = 3125 \text{ PSF}$$

$$p_3 = (40)(125) - [(40-25)(125-62.4)] = 4061 \text{ PSF}$$

$$H_1 = 5 \text{ FT}$$

$$H_2 = 10 \text{ FT}$$

$$H_3 = 20 \text{ FT}$$

$$C_1 = 38$$

$$C_2 = 43$$

$$C_3 = 50$$

RELATED TO BLOW COUNT RECORD, REF. FOUNDATION CALCS.

$$S = \frac{5}{38} \log_{10} \left( 1 + \frac{471}{2188} \right) + \frac{10}{43} \log_{10} \left( 1 + \frac{364}{3125} \right) + \frac{20}{50} \log_{10} \left( 1 + \frac{250}{4061} \right)$$

$$= 0.011 + 0.011 + 0.010 = 0.032 \text{ FT} = 0.384 \text{ IN.}$$

THIS AMOUNT OF SETTLEMENT IS ACCEPTABLE; TIME DURATION FOR SUSTAINED LOADING ON STRUCTURE NEEDED TO ACHIEVE 1000 PSF BEARING UNDER EDGE OF FOOTING IS EXTREMELY SHORT (THIS IS DUE TO TORNADO WIND CONDITION). SETTLEMENTS OF THE MAGNITUDE CALCULATED ON P. B600-D-B630 ARE FOR THIS REASON HIGHLY IMPROBABLE.

**SARGENT & LUNDY**  
**ENGINEERS**

FOUNDED 1891

55 EAST MONROE STREET

CHICAGO, ILLINOIS 60603

(312) 269-2000

TWX 910-721-2807

August 5, 1983  
Project No. 6117-32

Public Service Company of Colorado  
Fort St. Vrain - Unit 1

Evaluation of Caisson #5 for Building #10

*JRC 8/15/83*  
Mr. J. R. Reesy  
Nuclear Design Manager  
Public Service Company of Colorado  
2420 W. 26th Avenue - Suite 100-D  
Denver, Colorado 80211

Dear Mr. Reesy:

As requested in your letter of July 21, 1983 (NDG-83-0553), we have reviewed the effect of rotation of the reinforcing steel cage which took place during construction of Caisson #5 for the new Building #10 at Fort St. Vrain.

Since the design of the caisson and of the building was performed by another engineering firm, our review was based on the following information provided in your letters NDG-83-0553, dated July 21, 1983, and NDG-83-0584, dated July 29, 1983, and telecons between Mr. J. Tesner of PSC and S. Wahlert of S&L:

1. The portion of the reinforcing bars projecting above the top of concrete have rotated 270° clockwise about the bar cage longitudinal axis as indicated by their position before and after temporary casing removal.
2. All projecting bars have an angle from plumb of 2° to 3° in a direction confirming a clockwise rotation of the reinforcing cage.
3. The top of the projecting reinforcing bars has dropped 7" to 8" from the time the cage was placed in the hole to casing removal.
4. The bottom of casing was set about 6" to 1'-0" into bedrock.
5. For other information used in our review, see attachments 'A' and 'B' which were furnished in the referenced letters.

Mr. J. R. Reesy  
Public Service Company of Colorado

August 5, 1983  
Page 2

The review was based on an assumed profile for the reinforcing. (see Page 3 of Attachment 'C'). The profile was based on the above information supplied by PSC, the conservative assumption that the maximum slope and maximum change in slope of the reinforcing occurs at the point of maximum bending moment, and the assumption that the portion of the cage below the bottom of the casing remained vertical and did not rotate.

#### Summary of Results

Calculations were performed to determine the effect of the twisted reinforcing cage on the load carrying capacity of the caisson. The calculations are included in attachment 'C'.

The increase in tensile stress, where the angle between the bars and vertical is maximum, was calculated to be less than 2%. The increase is negligible and the effect on the capacity of the caisson is not significant even assuming the reinforcing is stressed to its ultimate capacity.

For compression loads, it was assumed that the reinforcing steel is stressed to the maximum possible compressive force ( $N \neq f_c' A_{st}$ ). This force was conservatively assumed to occur at all bars and the outward force resulting from the twisting of the vertical bars was calculated. From the conservative approach, hoop tensile stresses in the #4@12 circular ties were calculated to be 21.9 ksi which is much less than the ultimate strength of the ties.

The shortening of the reinforcing steel agrees well with the shortening of the vertical bars which would result from the assumed profile. Therefore, it is unlikely that there was a collapse or constriction in the rebar cage as a result of the twisting.

#### Conclusion

Based on the data provided by PSC and the above assumptions, the effect of the twisted reinforcing steel cage on the capacity of the caisson is negligible.

Please call if you have any questions or would like to discuss this matter further.

Yours very truly,

*S. L. Wahlert*

S. L. Wahlert  
Structural Project Engineer

SLW:mk  
Enclosure  
Copies: Page 3

SARGENT & LUNDY  
ENGINEERS  
CHICAGO

CN 1460  
BY HICKS  
PAGE B67E  
FORM NO. 372-30-2650

Mr. J. R. Reesy  
Public Service Company of Colorado

August 5, 1963  
Page 3

Copies:


D. L. Leone  
O. Zaben  
N. Hingorani  
C. Peterson

# (ATTACHMENT 'A')


CN 1460  
 BY HICKS  
 PAGE 868 E  
 FORM NO. 372-30-2650

CALCULATIONS FOR		CALC. NO.
PREPARED BY	DATE	REF. DOCUMENTS:
REVIEWED BY	DATE	

NOTE: TOP ELEV. OF PROJECTED REBAR DROPPED 7" TO 8" FOR EACH BAR FROM TIME BAR CAGE WAS PLACED IN HOLE TO CASING REMOVAL



NOTE: C OF AS-BUILT CAISSON AND REBAR CAGE) WITHIN ±2" OF LAYOUT SURVEY LOCATION PRIOR TO DRILLING OF HOLE



DESIGN LOADS  
 (FACTORED FOR ULTIMATE STRENGTH DESIGN)

HORIZ. SHEAR  $V_u = 140 \text{ K (MAX)}$   
 VERT. AXIAL  $P_u = 940 \text{ K } \downarrow \text{ (MAX)}$   
 $= 66 \text{ K } \downarrow \text{ (MIN)}$   
 $M_u = 1025 \text{ FT. K (MAX)}$   
 (THIS MOMENT FROM OUTPUT OF COMPUTER RUN, MOMENT DUE TO SOIL PRESSURE FROM LOAD  $V_u$ )

MATERIALS - CONCRETE:  $f'_c = 3500 \text{ PSI}$   
 STEEL: GRADE 60

CAISSON SECTION

1/4 MAX # 12 BELOW

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

6501081

J.O./W.O./CALCULATION NO.

13569.04-3-C1.2

REVISION

CN 1460

PREPARER/DATE

K. CURTIS 5-13-82

REVIEWER/CHECKER/DATE

D.D. KAWAMOTO 5-19-82

INDEPENDENT RE

BY HICKS

PAGE B69E

SUBJECT/TITLE

Caisson Design

QA CATEG

FORM NO. 372-30-2650

ATTACHMENT 'B'


REF: ATTACHED LAT LOAD RUN JOB # 4147 05/14/82

FOR MOMENTS DUE TO SOIL PRESSURE,

'STRUCTURAL ENGINEERING HANDBOOK' 2<sup>nd</sup> ed BY GAYLORD & GAYLORD

OR COL INTERACTION DIAGRAMS (P. 11-34)

CONSIDER CAISSON ESSENTIALLY CONTINUOUSLY LATEROALLY SUPPORTED & SLIDING EFFECTS NEED NOT BE CONSIDERED





SIGNATURE & DATE FOR REV			SIGNATURE & DATE FOR REV			SIGNATURE & DATE FOR REV			SIGNATURE & DATE FOR REV. 0		
APPROVER	REVIEWER	PREPARER	APPROVER	REVIEWER	PREPARER	APPROVER	REVIEWER	PREPARER	APPROVER	REVIEWER	PREPARER

DESIGN CONTROL SUMMARY  
DESIGN VERIFICATION

**SARGENT & LUNDY**  
**ENGINEERS**

PAGE 1

ATTACHMENT 'C 1'


IDENTIFICATION OF PAGES PREPARED/REVISED/VOIDED & REVIEW METHOD

REVIEW METHOD

PROJECT NAME **FOIT ST, VANIN** UN  
PROJECT NO. **6117-32**  
CLIENT **PC C**  
CALC. NO. & DESCRIPTION **2.0.510-FDN5**  
CALC. FOR **270° ROTATION OF REBAR IN**  
**CAISSON #5, BUILDING 10**  
 SAFETY RELATED     NON SAFETY RELATED

CN **1460**  
BY **HILLES**  
PAGE **B70 E**  
FORM NO. 372-30-2950

COMMENTS



Calcs. For 270° ROTATION OF REBAR IN  
 CAISSON #5, BLDG. 10  
 Safety-Related       Non-Safety-Related

CN 1460  
 Ca BY HICKS  
 Re PAGE 871E  
 Pa FORM NO. 372-30-2650

Client PSC  
 Project FART ST. VRAIN  
 Proj. No. 6117-32      Equip. No.

Prepared by *A. H.*      Date 8-3-52  
 Reviewed by *[Signature]*      Date 8-5-52  
 Approved by *[Signature]*      Date

PURPOSE OF CALCULATION

THE PURPOSE OF THIS CALCULATION IS TO DETERMINE THE EFFECTS OF A 270° ROTATION OF REINFORCING STEEL WITHIN CAISSON #5 OF BUILDING 10.

PSC HAS PROVIDED THE GEOMETRY AND LOAD (SEE PAGE 10). AT THE TOP THE BARS ARE 2° TO 3° FROM VERTICAL PER PSC'S LETTER OF 7-21-83.

METHOD OF CALCULATION

THIS CALCULATION WILL EXAMINE THE EFFECTS OF THE ROTATION BY ACCOMPLISHING THE FOLLOWING 3 ITEMS:



1. SHOW THAT THE DIAMETER OF THE REBAR CAGE HAS NOT SIGNIFICANTLY CHANGED. THIS WILL MEAN THAT THE GEOMETRY USED FOR THE ORIGINAL ANALYSIS IS STILL VALID.
2. SHOW THAT THE REBARS ARE ADEQUATE FOR THEIR TENSION LOADS IN THE ROTATED STATE.
3. SHOW THAT ADDITIONAL BURSTING FORCES DUE TO THE CURVATURE OF REBAR IN COMPRESSION ARE ADEQUATELY CONSTRAINED BY THE TIES.

Client	PSC
Project	FORT ST. VRAIN
Proj. No.	6117-32
Equip. No.	

Prepared by	<i>A. Hicks</i>	Date	3-3-83
Reviewed by	<i>[Signature]</i>	Date	3-5-83
Approved by	<i>[Signature]</i>	Date	

CALCULATIONS

POSITION OF A SINGLE ROTATED VERTICAL REBAR




ASSUME CURVATURE CHANGES AT POINT OF MAX. MOMENT. THIS IS CONSERVATIVE FOR CALCULATIONS OF BURSTING FORCES.

CURVATURE MUST CHANGE BECAUSE  $52.6 \tan 3^\circ = 33' < 3(31.22)$

6'-0" OF CONCRETE WAS ASSUMED WHEN BARS TWISTED. ASSUME BARS ARE VERTICAL BELOW THIS POINT.

DEVELOPED ELEVATION



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc	CN 1460
Rev.	BY HICKS
Page	PAGE B3E
FORM NO. 372-30-2650	

Client	PCS
Project	FORT ST. VRAIN
Proj. No.	6117-32
Equip. No.	

Prepared by	<i>Lo Ting</i>	Date	8-3-92
Reviewed by	<i>[Signature]</i>	Date	8-5-92
Approved by	<i>[Signature]</i>	Date	

ITEM #1

CALCULATE HEIGHT THAT THE TOP OF THE BARS SHOULD DROP IF CAGE DOES NOT CONSTRICT. ASSUME PROFILE SHOWN ON DEVELOPED ELEVATION. ACTUAL PROFILE IS NOT KNOWN EXACTLY.

$$\text{LENGTH OF PROFILE} = 6' + \sqrt{13^2 + (5.45/12)^2} = \sqrt{39.5^2 + ([3(31.22) - 5.45]/12)^2} = 59.186'$$

$$\text{HEIGHT OF DROP} = (59.186' - 58.5') \times 12 = 8.23 = 8\frac{1}{4}"$$

$$\text{MEASURED DROP} = 7" \text{ TO } 8" \approx 8\frac{1}{4}" \checkmark$$

— THEREFORE, THE CAGE DID NOT CONSTRICT. THE DIAMETER OF THE CAGE IS THE SAME AS BEFORE IT TWISTED. —




Cairs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

Calc	CN <u>M60</u>
Rev	BY <u>HICKS</u>
Page	PAGE <u>B74E</u>
FORM NO. 372-30-2650	

Client	<u>PSC</u>
Project	<u>FORT ST. VRAIN</u>
Proj. No.	<u>6117-32</u> Equip. No.

Prepared by	<u>L. H.</u>	Date	<u>2-3-53</u>
Reviewed by	<u>Edwin Williams</u>	Date	<u>3-5-53</u>
Approved by	<u>[Signature]</u>	Date	

ITEM #2  
CHECK TENSION ON REBAR



LOAD REQUIRED IN BAR TO RESIST "P" =  $P / \cos 10.5^\circ$   
 $= 1.017 P$   
 $1.017 - 1.0 = .017$


→ ANGULARITY INCREASES LOAD ON BAR < 2%. THEREFORE THE EFFECT ON THE ADEQUACY OF THE BAR IS NEGLIGABLE.

Client	PSC
Project	FORT ST. VRAIN
Proj. No.	6117-32
Equip. No.	

Prepared by	<i>A. King</i>	Date	6-5-93
Reviewed by	<i>Charles Williams</i>	Date	8-5-93
Approved by	<i>[Signature]</i>	Date	

ITEM #3

FOR REBARS IN COMPRESSION THE CURVATURE OF THE REBAR CAUSES BURSTING FORCES TO APPEAR. FOR A 1'-0" VERTICAL LENGTH:



THE LATERAL COMPONENT OF THE FORCES EXERTS A FORCE OUTWARDS TOWARDS THE #4 TIE

TO ASSUME THE TIE TAKES ALL OF THE LOAD IS CONSERVATIVE BECAUSE THE CONCRETE WILL RESTRAIN THE VERTICAL BAR TO SOME DEGREE

CALCULATION OF A DIM.

IN PLAN A 1'-0" VERTICAL SECTION WILL ARC

$$\left(\frac{1'}{39.5'}\right) \frac{[3(31.22) - 5.45]}{124.83} (360^\circ) = 6.438'$$

Calcs. For \_\_\_\_\_

Safety-Related       Non-Safety-Related

Cal CN 1460

Rev BY HICKS

Paq PAGE B76E

FORM NO. 372-30-2650

Client PSC

Project FORT ST. VRAIN

Proj. No. 6117-32      Equip. No. \_\_\_\_\_

Prepared by A. H. J.      Date 3-4-93

Reviewed by Charles J. [Signature]      Date 3-5-93

Approved by [Signature]      Date \_\_\_\_\_


REF. AISC P. 6-18

$$\text{RISE, } A = \frac{\text{CHORD}}{2} \tan\left(\frac{\text{ARC}}{4}\right)$$


$$A = \frac{12''}{2} \tan\left(\frac{6.438^\circ}{4}\right)$$

$$A = 0.169''$$

APPROXIMATE LOAD BY:



V = TOTAL LATERAL LOAD



$$\tan 1.61^\circ = \frac{V/2}{P}$$

$$V = .0563P$$



Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

C:	CN 1460
R:	BY HICKS
P:	PAGE B7E
	FORM NO. 372-30-2650

Client	PSC
Project	FORT ST. VRAIN
Proj. No.	6117-32
Equip. No.	

Prepared by	A. J.	Date	8-4-93
Reviewed by	<i>[Signature]</i>	Date	8-5-93
Approved by	<i>[Signature]</i>	Date	

TAKE 'P' TO BE MAXIMUM POSSIBLE COMPRESSIVE FORCE

$$\text{MAX. POSSIBLE STRESS} = n \phi f'_c$$

$$E_c = 57000 \sqrt{3500} = 3.37 \times 10^6 \text{ psi}$$

REF. ACI 318-77, SECT. 8.5  
317-80 § 9.5.1

$$n \phi f'_c = \frac{29 \times 10^6}{3.37 \times 10^6} (.85)(3.5) = 25.6 \text{ ksi}$$

$$P = 1.27 \text{ in}^2 (25.6 \text{ ksi}) = 32.5 \text{ k}$$

$$0.0563P = .0563(32.5) = 1.83 \text{ k}$$

TAKE 15 BARS @ 1.83k. THIS IS VERY CONSERVATIVE BECAUSE WITH THE MOMENT ACTING ON THE SECTION THE MAXIMUM BAR FORCE WOULD NOT ACT ON ALL BARS.

$$\text{TIE DIAMETER} = 41.5''$$

$$\text{UNIFORM PRESSURE} = \frac{15(1.83)}{\pi 41.5} = 0.211 \text{ k/inch DIAMETER}$$

$$\text{FORCE IN TIE} = \frac{1}{2} (41.5'') (0.211 \text{ k/in}) = 4.38 \text{ k}$$

$$\text{STRESS IN \#4 TIE} = \frac{4.38 \text{ k}}{201 \text{ in}^2} = 21.9 \text{ ksi} < 60 \text{ ksi}$$

$$V_u = 140 \text{ k MAX.}$$

$$\text{SHEAR STRESS IN SECTION} = \frac{140,000 \text{ lb}}{\pi 21^2} = 101 \text{ psi AT TOP} < 2 \sqrt{3500} = 118 \text{ psi}$$


SHEAR STRESS IS LOWER AT POINT OF MAXIMUM MOMENT.

\*4 TIES ARE NOT REQUIRED FOR SHEAR. 21.9 ksi FOR TIE IS NOT COMBINED WITH SHEAR STRESS, 21.9 < 60 ksi, OK USING A VERY CONSERVATIVE APPROACH.

→ THEREFORE, THE TIES ARE ADEQUATE TO RESIST THE BURSTING FORCES THAT RESULT FROM THE CURVATURE OF COMPRESSION REBAR.

Form 00-3.08.1 Rev. 2





Calcs. For	
<input checked="" type="checkbox"/> Safety-Related	<input type="checkbox"/> Non-Safety-Related

C	CN 1460
F	BY HICKS
F	PAGE B78E
F	FORM NO. 372-30-2650

Client	PSC		
Project	FORT ST. VRAIN		
Proj. No.	6117-32	Equip. No.	

Prepared by	L. The	Date	8-2-83
Reviewed by	[Signature]	Date	8-5-83
Approved by	[Signature]	Date	


CONCLUSION

THE 270° ROTATION OF REINFORCING STEEL WITHIN CAISSON #5 OF BUILDING 10 DOES NOT HAVE ANY SIGNIFICANT EFFECT ON THE STRUCTURAL ADEQUACY OF THE CAISSON. THIS CONCLUSION IS BASED ON CALCULATIONS THAT DEMONSTRATE:

1. THE DIAMETER OF THE REBAR CAGE HAS NOT SIGNIFICANTLY CHANGED.
2. THE EFFECT ON THE CAPACITY OF THE REBARS IN TENSION IS NEGLIGABLE (<2%).
3. ADDITIONAL BURSTING FORCES DUE TO CURVATURE OF REBARS IN COMPRESSION ARE ADEQUATELY RESTRAINED BY THE TIES.

Client	PSC	CN	1460
Project	FORT ST. VRAIN	BY	HICKS
Proj. No.	6117-32	Equip. No.	PAGE 879E
FORM NO.	372-30-2650		
CALCULATIONS FOR			
PREPARED BY			
REVIEWED BY			
	<input checked="" type="checkbox"/> Safety-Related		

NOTE: TOP ELEV. OF PROJECTED REBAR DECREASED 7" TO 5" FOR EACH BAR FROM TIME BAR CAGE WAS PLACED IN HOLE TO CASING REMOVAL.



NOTE:  $\phi$  OF AS-BUILT CAISSON (CONCRETE AND REBAR CAGE) WITHIN  $\pm 2"$  OF LAYOUT SURVEY LOCATION PRIOR TO DRILLING OF HOLE

DESIGN LOADS (FACTORED FOR ULTIMATE STRENGTH DESIGN)

HORIZ. SHEAR  $V_u = 140 \text{ K (MAX)}$   
 VERT. AXIAL  $P_u = 940 \text{ K } \downarrow \text{ (MAX)}$   
 $= 66 \text{ K } \downarrow \text{ (MIN)}$   
 $M_u = 1025 \text{ FT. K (MAX)}$   
 (THIS MOMENT FROM OUTPUT OF COMPUTER RUN, MOMENT DUE TO SOIL RESISTANCE FROM LOAD  $V_u$ )

CAISSON SECTION

MATERIALS - CONCRETE:  $f'_c = 3500 \text{ PSI}$   
 STEEL: GRADE 60

$M_u$  MAX @ 13'-0" (FROM TOP)

MARK FINTEL  
1833A WILDBERRY DRIVE  
GLENVIEW, IL. 60025  
312/998-9822

August 8, 1983

Mr. Robert A. Gunnerson  
Supervisor, Nuclear Projects  
Public Service Co.  
2420 W. 26th Ave., Suite 100D  
Denver, Colorado 80211


Dear Mr. Gunnerson:

Enclosed is my report on Rotation of Reinforcing Steel in Caisson #5  
for Building 10.

It took several times more effort than initially anticipated to solve this  
seemingly simple problem.

Please let me know if you have some additional questions.

Sincerely,



Mark Fintel


MARK FINTEL  
 1833A WILDBERRY DRIVE  
 GLENVIEW, IL. 60025  
 312/998-9822

INVESTIGATION OF EFFECTS OF ROTATION OF THE LONGITUDINAL  
 REINFORCING STEEL IN A 58'-6" LONG DRILLED PIER

The longitudinal reinforcing cage consisting of 15 #10 bars distributed along the periphery of the 4'-0" diameter, 58'-6" long drilled pier (Fig. 1) of the Fort St. Vrain plant site has rotated as a unit approximately 270° clockwise about the longitudinal axis of the bar cage. This amount of cage rotation of the top relative to the base of the cage was noted by visual observation of the flags attached to some bars, and by measuring a difference of 7" to 8" in the elevations of the tops of the bars before and after casting of the pier.

1. Computation of drop of top of bar elevations to correspond to an assumed cage rotation of 270°:

Periphery of the bar cage at bar centerlines:  
 Diameter 48" - 2 x 3" - 1.26" = 40.74 in  
 Periphery  $2\pi r = \pi \times 40.74 = 428.0$  in  
 Length of periphery corresponding to 270°  
 $128 \frac{270}{360} = 96$  in



Expected drop of top of bar elevation for a horizontal displacement of 96 in along the periphery:

Original length of bar = 58'-6" + 2'-3" = 60'-9" = 729 in

height after rotation =  $\sqrt{729^2 - 96^2} = 722.6$  in.

drop of bar = 729 - 722.6 = 6.4 in.


The observed flag rotation of 270° correlates reasonably well with the measured drop in the elevation of the tops of the bars. The angle of inclination of the bars from the vertical

$$\sin \alpha = \frac{96}{729} = .13169$$

$$\alpha = 7\frac{1}{2}^\circ$$

$$\cos \alpha = .9912913; \tan \alpha = .1328441$$

2. This angle of bar inclination corresponding to 270° cage rotation will be used for computation of the horizontal and vertical components of forces in the reinforcing bars. The individual bars are subjected to compression or tension due to the combined action of axial load and moment. Since the bars are inclined the horizontal component of the force in each bar is  $F_{Hi} = F_{Si} \times \sin \alpha = F_{Vi} \times \tan \alpha$ . These horizontal forces cause twisting of the pier. Compressive forces twist the pier clockwise. Tensile forces twist it counterclockwise. The torsional (twisting) moment of the forces in all bars



$$M_T = \sum_{i=1}^n F_{Hi} \times r_s \quad (r_s = \text{radius to center of longitudinal reinforcement, } n = \text{number of bars})$$

causes a torsional stress in the pier:

$$\tau = \frac{M_T \times r}{J}$$

$$J = \text{polar moment of inertia} = \frac{\pi \cdot r^4}{2} = \frac{\pi \cdot 24^4}{2} = 521,152 \text{ in}^4$$

According to Section 11.6 of ACI 318-77, if the torsional stress  $\tau$  due to factored torsional moment is less than  $1.5\sqrt{f'_c}$ , torsional effects can be neglected.

3. Computation of forces in the bars, torsional moments and torsional stresses.

Two load combinations were investigated:

$$\max P_U = 940 \text{ k}; \quad M_U = 1025 \text{ ft.k.}$$

$$\min P_U = 66 \text{ k}; \quad M_U = 1025 \text{ ft. k.}$$

Determining the forces in the reinforcing bars of the circular pier under either of the load combinations shown above requires the simultaneous solution of two integral equations, as shown in Fig. 2. A direct solution is extremely difficult to achieve. A numerical iterative solution is the logical choice. Such a solution was accomplished with the aid of an HP 9845 computer. The circular geometry was closely approximated by a polygon with 50 sides. For a given axial load, balance of forces was achieved for a number of given values of sectional curvature ( $\epsilon_{cm}/c$ ). The corresponding bending moments, as given by the moment equilibrium equation, were computed. After two curvature values that yielded moments just smaller than and just larger than the given moment were determined, computations were made for intermediate curvature values until the computed bending moment nearly coincided with the given bending moment on the section. Under both load combinations, both concrete and steel remained within the elastic range. The computer output is enclosed, and illustrates the iterative process of computation.

With the values of neutral axis depth and extreme compression fiber strain, as determined above, the stresses in the various layers of reinforcement were computed as shown in Tables 1 and 2. The horizontal components of forces in the various reinforcement layers were computed from the above stresses. The torsional moments caused by the horizontal forces and the resulting torsional stresses were also calculated as shown in Tables 1 and 2. The torsional stress produced by loading combination 1 is 6.18 psi, while that produced by load combination 2 is 36.09 psi. Both values are well within the allowable limit of  $1.5\sqrt{f'_c}$ .

4. Conclusion:

The torsional stresses of 6.18 psi (clockwise) and 36.09 psi (counterclockwise) for the two load combinations are considerably below the level of  $1.5\sqrt{f'_c} = 89$  psi, thus allowing torsional effects to be neglected according to ACI 318-77. According to the ACI Committee 438 report "Tentative Recommendations for the Design of Reinforced Concrete Members to Resist Torsion", (ACI Journal Proceedings, V. 66, Jan. 1969, pp. 1-8), a torsional stress of  $1.5\sqrt{f'_c}$  will not produce significant reduction in ultimate strength in either flexure or shear. Obviously, a stress of 36.0 psi, which is only 40% of that level, should be of no concern.



CALCULATIONS FOR		CN 1460
PREPARED BY		BY HIGGS
REVIEWED BY		PAGE B85E
DATE	DATE	FORM NO. 372-30-2650
		CALC. NO.
		REF. DOCUMENTS:

NOTE: TOP ELEV. OF PROJECTED REBAR DROPPED 7" TO 8" FOR EACH BAR FROM TIME BAR CAGE WAS PLACED IN HOLE TO CASING REMOVAL





Fig. 1





$$dA = 2x dy = 2 \sqrt{r^2 - y^2} dy$$

$$P = \int_{r-c}^r 2 \sqrt{r^2 - y^2} dy \cdot \frac{\epsilon_{cm}}{c} [y - (r-c)] E_c + \sum_{i=1}^n \frac{\epsilon_{cm}}{c} (c - d_i) E_s A_{s_i}$$

(n = total no. of reinf. layers)

$$= 2 \frac{\epsilon_{cm}}{c} E_c \left[ \int_{r-c}^r \sqrt{r^2 - y^2} \cdot y dy - (r-c) \int_{r-c}^r \sqrt{r^2 - y^2} dy \right] + \frac{\epsilon_{cm}}{c} E_s \sum_{i=1}^n (c - d_i) A_{s_i}$$

$$M = \int_{r-c}^r 2 \sqrt{r^2 - y^2} dy \cdot \frac{\epsilon_{cm}}{c} [y - (r-c)] E_c \cdot [y - (r-c)] + \sum_{i=1}^n \frac{\epsilon_{cm}}{c} (c - d_i) E_s A_{s_i} (c - d_i)$$

$$= \frac{2 \epsilon_{cm} E_c}{c} \int_{r-c}^r \sqrt{r^2 - y^2} dy [y^2 - 2y(r-c) + (r-c)^2] + \sum_{i=1}^n \frac{\epsilon_{cm}}{c} E_s (c - d_i)^2 A_{s_i}$$

$$= 2 \frac{\epsilon_{cm}}{c} E_c \left[ \int_{r-c}^r \sqrt{r^2 - y^2} y^2 dy - 2(r-c) \int_{r-c}^r \sqrt{r^2 - y^2} y dy + (r-c)^2 \int_{r-c}^r \sqrt{r^2 - y^2} dy \right] + \frac{\epsilon_{cm}}{c} E_s \sum_{i=1}^n (c - d_i)^2 A_{s_i}$$

Fig. 2

TABLE 1. Case 1:  $P_u = 940 \text{ k}$ ,  $M_u = 1025 \text{ ft-k}$

$$e = 29.81 \text{ in.}, \epsilon_{cm} = 0.000459$$

CN 1460  
 BY HICKS  
 PAGE B87E  
 FORM NO. 372-30-2650

Reinf. Layer, $i$	Distance from Top, $d_i$ , in.	$c - d_i$ , in.	$\sigma_{si} = \frac{c - d_i}{e} \epsilon_{cm} E_s$ ksi	Area of Reinf. Layer, $A_{si}$ , in <sup>2</sup>	Vertical Force in Reinf. Layer $F_{vi} = A_{si} \sigma_{si}$ kips	Horizontal Force in Reinf. Layer $F_{hi} = F_{vi} \tan \alpha$ kips
1	3.6	26.21	11.70	1.27	14.86	1.974
2	5.4	24.41	10.90	2.57	27.69	3.678
3	10.3	19.51	8.71	2.57	22.13	2.940
4	17.7	12.11	5.41	2.57	13.73	1.824
5	26.1	3.71	1.66	2.57	4.21	0.559
6	34.2	-4.39	-1.96	2.57	-4.97	-0.660
7	40.5	-10.69	-4.77	2.57	-12.12	-1.610
8	43.9	-14.09	-6.29	2.57	-15.98	-2.123

$$\sum F_{hi} = 6.582$$

$$M_T = \sum F_{hi} \times r_s$$

↙ cover to center of reinf.

$$= 6.582 \times (24 - 3.625) = 6.582 \times 20.375$$

$$= 134.108 \text{ in-kips}$$

$$\tau = \frac{M_T \times \gamma}{J} = \frac{134,108 \times 24}{521,152} = 6.18 \text{ psi} < 1.5 \sqrt{f'_c} = 89 \text{ psi}$$

TABLE 2. Case 2:  $P_u = 66 \text{ k}$ ,  $M_u = 1025 \text{ ft-k}$

$e = 12.96 \text{ in.}$   $\epsilon_{cm} = 0.000616$

CN 1460  
 BY HICKS  
 PAGE B88E  
 FORM NO. 372-30-2650

Reinf. Layer, $i$	Distance from Top, $d_i$ , in.	$e - d_i$ in.	$\sigma_{si} = \frac{e - d_i}{e} \epsilon_{cm} E_s$ ksi	Area of Reinf. Layer $A_{si}$ , in <sup>2</sup>	Vertical Force in Reinf. Layer $F_{vi} = A_{si} \sigma_{si}$ kips	Horizontal Force in Reinf. Layer $F_{hi} = F_{vi} \tan \alpha$ kips
1	3.6	9.36	12.90	1.27	16.38	2.176
2	5.4	7.56	10.42	2.54	26.47	3.516
3	10.3	2.66	3.67	2.54	9.31	1.237
4	17.7	-4.74	-6.53	2.54	-16.60	-2.205
5	26.1	-13.14	-19.11	2.54	-46.00	-6.111
6	34.2	-21.24	-29.28	2.54	-74.36	-9.878
7	40.5	-27.54	-37.96	2.54	-96.42	-12.869
8	43.9	-30.94	-42.65	2.54	-108.32	-14.390

$\sum F_{hi} = -38.464$

$M_e = \sum F_{hi} \times r_s$

$= 38.464 \times 20.375 = 783.704 \text{ in.-kips}$

$\tau = \frac{M_e \times r}{J} = \frac{783,704 \times 24}{521,152} = 36.09 \text{ psi} < 1.5 \sqrt{f'_c}$   
 $= 89 \text{ psi}$


\*\*\* CONCRETE \*\*\*

WIDTH (IN)	DEPTH (IN)	TYPE
0.000	0.000	1
19.180	2.000	1
26.530	4.000	1
31.750	6.000	1
35.780	8.000	1
38.980	10.000	1
41.570	12.000	1
43.630	14.000	1
45.250	16.000	1
46.470	18.000	1
47.330	20.000	1
47.830	22.000	1
48.000	24.000	1
47.830	26.000	1
47.330	28.000	1
46.470	30.000	1
45.250	32.000	1
43.630	34.000	1
41.570	36.000	1

38.980	38.000	1
35.780	40.000	1
31.750	42.000	1
26.530	44.000	1
19.180	46.000	1
0.000	48.000	1

\*\*\* REINFORCEMENT \*\*\*

AREA (SQ. IN.)	DEPTH (IN.)	TYPE
1.2700	3.600	2
2.5400	5.400	2
2.5400	10.300	2
2.5400	17.700	2
2.5400	26.100	2
2.5400	34.200	2
2.5400	40.500	2
2.5400	43.900	2
1.0000	24.000	3



\*\*\* MATERIAL STRESS-STRAIN RELATIONSHIPS \*\*\*

TYPE 1

STRAIN MILLIONTHS	STRESS PSI
-1000000	-3400
-2000	-3400
-887	-3400
0	0
1000000	0

\*\*\* MATERIAL STRESS-STRAIN RELATIONSHIPS \*\*\*

TYPE 2

STRAIN MILLIONTHS	STRESS PSI
-1000000	-60000
-2000	-60000
0	0
2000	60000
1000000	60000

\*\*\* MATERIAL STRESS-STRAIN RELATIONSHIPS \*\*\*

TYPE 3

STRAIN MILLIONTHS	STRESS PSI
-1000000	940000
1000000	940000

Case L:  $P_u = 940 \text{ k}$ ,  $M_u = 1025 \text{ ft-k}$

	***** CROSS SECTION PROPERTIES *****				
	TOP STRAIN	KD	MOMENT	CURVATURE	STEEL STRESS
	MILLIONTHS	INCHES	INCH-LBS	MILLIONTHS	PSI
1	-222	55.56	4349601	-4.00	940000
2	-357	35.71	9619751	-10.00	940000
3	-415	31.94	11239148	-13.00	940000
4	-433	30.95	11737544	-14.00	940000
5	-451	30.10	12171798	-15.00	940000
6	-454	30.04	12178763	-15.10	940000
7	-455	29.96	12219986	-15.20	940000
8	-457	29.88	12258100	-15.30	940000
9	-459	29.81	12300131	-15.40	940000
10	-461	29.73	12341741	-15.50	940000
11	-469	29.32	12585266	-16.00	940000
12	-487	28.62	12980456	-17.00	940000
13	-508	26.88	14048610	-20.00	940000
14	-693	23.11	17280681	-30.00	940000
15	-940	21.00	20028717	-40.00	940000
16	-980	19.60	22664966	-50.00	940000
17	-1122	18.69	25018416	-60.00	940000
18	-1416	17.70	28932610	-80.00	940000

Case 2:  $P_u = 66 \text{ k}$ ,  $M_u = 1025 \text{ ft-k}$

***** CROSS SECTION PROPERTIES *****					
	TOP STRAIN	KD	MOMENT	CURVPTURE	STEEL STRESS
	MILLIONTHS	INCHES	INCH-LBS	MILLIONTHS	PSI
1	-89	17.76	1970077	-5.00	66000
2	-152	15.25	3212367	-10.00	66000
3	-215	14.32	4435081	-15.00	66000
4	-277	13.83	5655682	-20.00	66000
5	-400	13.32	8097576	-30.00	66000
6	-523	13.07	10532215	-40.00	66000
7	-584	12.99	11744152	-45.00	66000
8	-597	12.99	11969934	-46.00	66000
9	-609	12.96	12228691	-47.00	66000
10	-616	12.96	12341932	-47.50	66000
11	-622	12.96	12455173	-48.00	66000
12	-634	12.93	12716134	-49.00	66000
13	-646	12.91	12967029	-50.00	66000
14	-768	12.81	15402333	-60.00	66000
15	-883	12.62	17392388	-70.00	66000
16	-983	12.29	18449834	-80.00	66000



CALCULATION TITLE PAGE

\*SEE INSTRUCTIONS ON REVERSE SIDE

CN 1460  
 BY TESNER  
 PAGE 893.1E

A-5010.54 (FRONT)

CLIENT & PROJECT <u>PUBLIC SERVICE CO. OF COLORADO / 3 ROOM COMPLEX - FORT ST. YRAIN</u>	PAGE 1	FORM NO. 372-30-2650 <u>8</u>
---	--------	----------------------------------

CALCULATION TITLE (Indicative of the Objective): <u>CHECK OF CAISSON CAPACITY FOR BUILDING 10</u>	QA CATEGORY (✓) <input checked="" type="checkbox"/> I - NUCLEAR SAFETY RELATED <input type="checkbox"/> II <input type="checkbox"/> III <input type="checkbox"/> OTHER
--	--

CALCULATION IDENTIFICATION NUMBER				
J.C. OR W.C. NO.	DIVISION & GROUP	CURRENT CALC. NO.	OPTIONAL TASK CODE	OPTIONAL WORK PACKAGE NO.
<u>13569.04</u>	<u>S</u>	<u>CI. 9</u>	<u>N/A</u>	<u>N/A</u>

*APPROVALS - SIGNATURE & DATE				REV. NO. OR NEW CALC. NO.	SUPERSEDES *CALC. NO. OR REV. NO.	CONFIRMATION *REQUIRED (✓)	
PREPARER(S)/DATE(S)	REVIEWER(S)/DATE(S)	INDEPENDENT REVIEWER(S)/DATE(S)				YES	NO
<u>R.C. STANNETT</u> <u>RE [Signature]</u> <u>7-14-83</u>	<u>C.M. DeFize</u> <u>[Signature]</u> <u>7-14-83</u>	<u>TL TUENOCK</u> <u>[Signature]</u> <u>7-14-83</u>		<u>0</u>			✓

--	--	--	--

DISTRIBUTION *					
GROUP	NAME & LOCATION	COPY SENT (✓)	GROUP	NAME & LOCATION	COPY SENT (✓)
RECORDS MGT. FILES (OR FIRE FILE IF NONE)					



**CALCULATION SUMMARY**

STONE & WEBSTER ENGINEERING CORPORATION

ASD 10 82

J.O./W.O./CALCULATION NO.

13569.04 - SCI. 9

REVISION

0

CN 1460

BY TESNER

CLIENT / PROJECT

PUBLIC SERVICE CO. OF COLORADO / 3 ROOM COMPLEX FOR

QA GATE

I

PAGE 898.3 E

FORM NO. 372-30-2650

SUBJECT / TITLE

CHECK OF CAISSON CAPACITY

**OBJECTIVE OF CALCULATION:**

To determine the moment carrying capacity of the 4' caissons, and to determine the reserve capacity for the caissons.

**CALCULATION METHOD/ASSUMPTIONS:**

Basic statics are employed to find the caisson's capacity using the "strain compatibility" method. Assumptions concerning the ultimate stresses and strains are given in ACI 318-77, Sec. 10.2.

**SOURCE OF DATA / EQUATIONS:**

SWEC Calc. 13569.04-S-C1.7 (Rev. 0)  
 SWEC Dwg. 13569.04-FY-1A-0  
 ACI 318-77 Building Code  
 Reinforced Concrete Design, 2<sup>nd</sup> Ed., by Wang & Salmon, 1973.

**CONCLUSIONS:**

The capacity of the 4' caissons was found to be  $M_u = 1560 k'$  when  $P_u = 0k$ .

**REVIEWER (S) COMMENTS:**

PREPARED:

R. Stinnett

DATE

7-14-83

REVIEWED / CHECKED:

NOTED (C) BERNIER JUL 14 1983

DATE

INDEPENDENT REVIEWER

TL TURNOCK

DATE

7-14-83

4810.67

J.O. / W.O. / CALCULATION NO.

13569.04 - SC 1.9

REVISION

CN 1460

PREPARED / DATE

R. Stinnett / 7-13-83

REVIEWER / CHECKER / DATE

NOTED C.M. DEFRUE JUL 14 '83

INDEPENDENT R

TL TUCK

BY TESNER

PAGE 893.4E

SUBJECT / TITLE

Caisson Check


QA DATE

I

FORM NO. 372-30-2650

### CAISSON REINFORCEMENT

$$D = 48 - 2 \times \text{clearance} - 2 \times \text{tie dia.} - d_b = 48 - 2(3) - 2(0.5) - 1.27 = 39.73''$$



## CALCULATION SHEET

J.O./W.O./CALCULATION NO.

13569.04 - SC 1.9

REVISION

CN 1460

48010 81

PREPARER/DATE

R. Stinnett / 7-13-83

REVIEWER/CHECKER/DATE

NOTED C.M. DEFRIEZ JUL 14 1983

INDEPENDENT R

TL TUC

BY TESNER

PAGE 893.5E

SUBJECT/TITLE

Caisson Check

QA DATE

I

FORM NO. 372-30-2650

STRESSES IN RESTEEL NEGLECTING CONCRETE

Calculate max. stress in the resteel neglecting the strength of the concrete. Assume the concrete and ties prevent any buckling of the bars.

$$I_{STEEL} = \sum Ad^2$$

$$I_{STEEL} = 1.27 \{ 19.87^2 + 2(19.43)^2 + 2(18.15)^2 + 2(16.07)^2 + 2(13.29)^2 \\ + 2(9.93)^2 + 2(6.14)^2 + 2(2.08)^2 \}$$

$$I_{STEEL} = 3759 \text{ in}^4$$

$$c = \frac{39.73}{2} = 19.86 \text{ in}$$

$$M_u = 1025 \text{ k'} = 12,300 \text{ k''} \quad [\text{REF: SWEC Calc. 13569.04-S-C1.7 (Rev. 0)}]$$

$$f_{max} = \frac{M_u c}{I_{STEEL}} = \frac{12,300(19.86)}{3759} = 64.98 \text{ ksi}$$

$$f_{max} = 64.98 \text{ ksi} > f_y = 60 \text{ ksi}$$

N.G.

∴ MUST CONSIDER CONCRETE STRENGTH

CALCULATION SHEET

J.O. / NO. / CALCULATION NO.

13569.04 - SC1.9

REVISION

CN 1460

BY TESNER

PAGE 893.6E

45010.81

PREPARED / DATE

R. Stipnett / 7-13-83

REVIEWER / CHECKER / DATE

NOTED C.W. DEFRIT III 14 83

INDEPENDENT RE

TL TURN

SUBJECT / TITLE

CAISSON Check


QA CATES

I

FORM NO. 372-30-2650

CAISSON REINFORCEMENT - ULTIMATE STRAINS & STRESSES

$$D = 48 - 2 \times \text{clearance} - 2 \times \text{tie dia.} - d_b = 48 - 2(3) - 2(0.5) - 1.27 = 39.73''$$



# CALCULATION SHEET

STC:IE & WEBSTER ENGINEERING CORPORATION

45010.01

J.O. / W.O. / CALCULATION NO.

13569.04 - SC 1.9

REVISION

CN 1460

BY TESNER

PAGE 893.7E

FORM NO. 372-30-2650

PREPARED / DATE

D. Stirrett / 7-14-83

REVIEWER / CHECKER / DATE

NOTED C.W. DEFRINT JUL 14 1983

INDEPENDENT RI

TL TLR

SUBJECT / TITLE

Coisson Check

QA CATE

I


## ULTIMATE MOMENT CAPACITY ( $P_u = 0k$ )

[REF: Reinforced Concrete Design, 2<sup>nd</sup> Ed., p. 412]

$$A = \text{Area of Segment} = \frac{h^2}{4} [\alpha - \sin \alpha \cos \alpha]$$

$$M = \text{First Moment of Area} = \frac{h^3}{12} [\sin^3 \alpha]$$

$$\bar{x} = \text{Centroidal Distance} = \frac{M}{A}$$



Assume  $x = 9.78''$ . (Determined by trial and error.)

$$c = \beta_1 x = 0.85(9.78) = 8.313''$$

$$\alpha = \cos^{-1} \left[ \frac{24 - 8.313}{24} \right] = 0.858 \text{ rad.}$$

$$A = \frac{48^2}{4} [0.858 - \sin 0.858 \cos 0.858] = 209.5 \text{ in}^2$$

$$M = \frac{48^3}{12} [\sin^3 0.858] = 3995 \text{ in}^3$$

$$\bar{x} = \frac{3995}{209.5} = 19.07''$$

$$C_c = 0.85 f_c' A = 0.85(3.5)(209.5) = 623.3k$$

$$\epsilon_y = \frac{f_y}{E_s} = \frac{60}{29,000} = 0.00207 \text{ (Yield strain for steel)}$$

Force	$\epsilon_s$	Does steel Yield?	$f_s = E_s \epsilon_s \leq 60 \text{ ksi}$	$A_s$	$F = f_s A_s$	Arm	$F \times \text{Arm}$
T <sub>1</sub>	.00132	No	38.16	2.54	96.9	4.29	416
T <sub>2</sub>	.00372	Yes	60.00	2.54	152.4	12.14	1850
T <sub>3</sub>	.00625	Yes	60.00	2.54	152.4	20.36	3103
T <sub>4</sub>	.00844	Yes	60.00	2.54	152.4	27.51	4193
T <sub>5</sub>	.00993	Yes	60.00	2.54	152.4	32.37	4933
T <sub>6</sub>	.01046	Yes	60.00	1.27	76.2	34.09	2598
C <sub>1</sub>	.00057	No	16.46	2.54	-41.8	1.35	77
C <sub>2</sub>	.00160	No	46.35	2.54	-117.7	5.21	613
C <sub>c</sub>	-	-	-	-	-623.3	4.85	3023
					-0.1k		20,806k

$$P_n = \Sigma F \approx 0k \text{ (As assumed)} \rightarrow P_u = \phi P_n = 0k$$

$$M_n = \Sigma (F \times \text{Arm}) = 20,806k'' = 1734k' \rightarrow M_u = \phi M_n = 0.9(1734) = 1560k'$$

$$M_u = 1560k' \text{ (for } P_u = 0k)$$

CALCULATION SHEET

J.O./W.O./CALCULATION NO. 13569.04 - SC 1.9		REVISION CN 1460
PREPARED BY/DATE R. Stinnett / 7-14-83	REVIEWER/CHECKER/DATE NOTED C.M. DEFRIEZ JUL 14 1983	INDEPENDENT RE TL TURN PAGE 893.8E
SUBJECT/TITLE Coisson Check		QA CATEG I FORM NO. 372-30-2650

COMPARISON OF ACTUAL LOADS WITH CALCULATED CAPACITIES

$(M_u)_{ACTUAL} = 1025 k'$  [REF: SWEC Calc. 13569.04-S-C1.7 (Rev. 0)]


$(M_u)_{CAPACITY} = 1560 k'$

Reserve Moment Capacity =  $535 k'$  (34%)



Connections - 4 1/2 in. ...

A) Diagonal bracing in X-Y Plane, Connection to Column Gusset Pl.



MAXIMUM AXIAL LOAD IN TRUSS MEMBERS T1/T2/T9/T10  
 (PEF: STRUDL MCAUTO RUN DATED 2/15/03, TIME 09:44:43)  
 got

req'd Bolt Capacity = 41.9 k/Bolt  
 ∴ Use 1" ∅ Bolts

$F_{v,all} = 47.1^k > 41.5^k$

(AISC Table 1-D)

Check Bearing:

$R_b = 1.5 F_u D t$   
 $= 1.5 (70)(1)(3/8)$   
 $= 65.6^k > 41.5^k$

$F_u = 58 \text{ KSI FOR A-36 PL}$   
 SEE BELOW

O.k. got

Min. Edge Dist. = 1 1/4" (AISC TABLE 1.10.5.1, 8TH EDITION)

NOTES:

- 1) ALL CHECKS OF BOLTED CONNECTIONS BASED ON USE OF A-325 BOLT MATERIAL IN BEARING-TYPE CONNECTION WITH THREADS EXCLUDED FROM SHEAR PLANE.
- 2) SINCE DIAGONAL COLUMN BRACING CONSISTS OF BACK-TO-BACK ANGLES SEPARATED BY A 5/8 IN. THICK GUSSET PLATE, SHEAR ALLOWABLES ( $F_v, all.$ ) LISTED ARE FOR DOUBLE SHEAR PLANE CONDITION.
- 3) FOR ALL DIMENSIONAL DATA REFER TO NORTHERN STEEL DRAWINGS E-4441-1, E-4441-2, E-4441-3 AND E-4441-4.

CHECK BEARING:  $R_b = 1.5 F_u D t$   
 $= (1.5)(58 \text{ KSI})(1.0 \text{ IN})(5/8 \text{ IN}) = 54.4^k > 41.9^k \text{ OK}$

BEARING STRESS ON ANGLES IS MUCH LOWER, THEREFORE BEARING ON GUSSET GOVERNS

CHECK EDGE DISTANCE [AISC 1.10.5.2] SEE EVALUATION  
 FOR GUSSET:  $L_e = \frac{2P}{F_u t} = \frac{(2)(41.9^k)}{(58 \text{ KSI})(5/8 \text{ IN})} = 2.3 \text{ IN. NEXT PAGE}$

CHECK CENTER-TO-CENTER SPACING [AISC 1.10.4.2]  
 $L_e' = L_e + d/2 = 2.3 + 1 \text{ IN}/2 = 2.8 \text{ IN; ACTUAL } 3 \text{ IN}$   
 OK

got




**PUBLIC SERVICE COMPANY OF COLORADO**  
**FORT ST. VRAIN NUCLEAR GENERATING STATION**  
**"CALCULATION WORKSHEET"**

CN 1460  
 BY TESNER  
 PAGE B95 E  
 FORM NO. 372-30-2650

Form 344-24-4308

CALCULATION FOR		CALCULATION NUMBER			
PREPARED BY <u>TESNER</u>	DATE <u>9/9/83</u>	CALC. REV.		PAGE	OF
REVIEWED BY	DATE	CALC. REV.		PAGE	OF



GUSSETS FOR 2L7x4x $\frac{3}{8}$

REQUIRED EDGE DISTANCE = 2.3 INCHES

A. FOR PLATE MARK Y-4 ACTUAL EDGE DISTANCE IS APPROXIMATELY 2.44 IN > 2.3 IN. OK

B. FOR PLATE MARK Z-4 AVERAGE EDGE DISTANCE IS APPROX. 1.52 IN < 2.3 IN - REINFORCE CONNECTION WITH FILLET WELDS (SEE NEXT 3 PAGES)




**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE 895.1 E  
 FORM NO. 372-30-2650

Form 344-24-4339

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>TESNER</u>	DATE <u>9/14/83</u>		
REVIEWED BY	DATE	CALC. REV.	PAGE OF



$$a = 1.52 \text{ IN. (PREVIOUS PAGE)}$$

$$b = (3 \text{ IN}) \left( \frac{7}{12} \right) = 1.75 \text{ IN}$$

$$c = (1.25 + 3) - (1.75 - 1.52) = 4.02 \text{ IN SAY } 4 \text{ IN}$$

CHECK EDGE DISTANCE ON ANGLES FOR BOLT 1:

$$L_e = \left( \frac{2P}{F_u t} \right) \left( \frac{1}{2} \right)^* = \frac{41.9 \text{ k}}{(58 \text{ KSI})(3/4 \text{ IN})} = 0.96 \text{ IN} < 1.25 \text{ IN OK}$$

MAXIMUM LOAD ON BOLT 2 IS GOVERNED BY TEAR OUT OF GUSSET PLATE:

$$P = \frac{(L_{ACT})(F_u)(t)}{2} = \frac{(1.52 \text{ IN})(58 \text{ KSI})(5/8 \text{ IN})}{2} = 27.6 \text{ k}$$

\* BOLT LOAD IS DISTRIBUTED TO TWO ANGLES OF EQUAL EDGE DISTANCE




**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE 895.2 E  
 FORM NO. 372-30-2650

Form 344-24-4309

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY TESNER	DATE 9/14/83		
REVIEWED BY	DATE	CALC. REV.	PAGE OF

TRY TO DESIGN WELD AT CONNECTION TO CARRY TOTAL LOAD



A+B = 7 IN  
 C+D = 4 IN

$$A = \frac{7^2}{2(7+4)} = 2.23 \text{ IN}$$

$$B = 7 - A = 7 - 2.23 = 4.77 \text{ IN}$$

$$C = \frac{4^2}{2(4+7)} = 0.73 \text{ IN}$$

$$D = 4 - C = 4 - 0.73 = 3.27 \text{ IN}$$

$$E = B - 2.51 = 4.77 - 2.51 = 2.26 \text{ IN}$$

$$L_w = (2)(7+4) = 22 \text{ IN}$$

$$J_w = \left[ \frac{(b+d)^3 - 6b^2d^2}{12(b+d)} \right] (2) *$$

$$= \left[ \frac{(4+7)^3 - 6(4^2)(7^2)}{12(4+7)} \right] (2)$$

$$= \left[ \frac{14641 - 4704}{132} \right] (2)$$

$$= 150.6 \text{ IN}^3$$

\* DOUBLED FOR WELD ON EACH L7x4

REACTIONS ON WELD:

$$F_z = 83.8 \text{ k}$$

$$M_x = (83.8 \text{ k})(2.26 \text{ IN}) = 189 \text{ IN-K}$$



**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE 895.3 E  
 FORM NO. 372-30-2650

Form 344-24-4309

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>TESNER</u>	DATE <u>9/14/83</u>		
REVIEWED BY	DATE	CALC. REV.	PAGE OF

STRESS IN WELD = MAXIMUM STRESS OCCURS AT TIP POINT 1

$$f_{Wx} = 0$$

$$f_{Wy} = \frac{(M_x)(C)}{J_w} = \frac{(189 \text{ IN-K})(0.73 \text{ IN})}{150.6 \text{ IN}^3} = 0.92 \text{ KIPS/IN}$$

$$f_{Wz} = \frac{(M_x)(B)}{J_w} + \frac{F_z}{L_w} = \frac{(189 \text{ IN-K})(4.77 \text{ IN})}{150.6 \text{ IN}^3} + \frac{83.8 \text{ K}}{22 \text{ IN}}$$

$$= 5.99 + 3.81 = 9.80 \text{ KIPS/IN}$$

$$f_{WRES} = \sqrt{(0.92)^2 + (9.80)^2} = 9.84 \text{ KIPS/IN}$$

LOAD IN TRUSS MEMBERS T1/T2/T9/T10 FROM STRUDL  
 MCAUTO RUN DATED 2/15/83 (TIME 09:44:43) =

LOAD CASE 1 (WIND LOAD) = 81.8 K MAX

LOAD CASE 2 (DL + LL) = 1.9 K MAX

LOAD COMB. 3 (LC1 + LC2) = 83.8 K MAX

SINCE APPROX. 98% OF STRESS IS DUE TO WIND, INCREASE  
 ALLOWABLE STRESS BY 1/3 PER AISC SECT. 1.5.6.

$$\text{ALLOW. STRESS ON WELD THROAT} = (0.3)(70 \text{ KSI})^{(4/3)}$$

$$= 28 \text{ KSI [E70 ELECTRODE]}$$

$$\text{ALLOW. STRESS ON BASE METAL} = (0.4)(36 \text{ KSI})^{(4/3)} / 0.707$$

$$= 27.2 \text{ KSI [A36 STEEL, STRESS CALCULATED ON WELD THROAT AREA]}$$

$$t_w = \frac{f_{WRES}}{0.707 t} ; t = \frac{f_{WRES}}{(0.707)(\sigma_{WALL})} = \frac{9.84 \text{ KIPS/IN}}{(0.707)(27.2 \text{ KSI})} = 0.51 \text{ IN}$$

SPECIFY 1/2" FILLET, BOLTS PROVIDE ADDED FACTOR  
 OF SAFETY FOR COLLECTION.




**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE 895.4E  
 FORM NO. 372-30-2650

Form 344-24-4309

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>TESNER</u>	DATE <u>9/14/83</u>		
REVIEWED BY	DATE	CALC. REV.	PAGE OF

CHECK WELD ON GUSSET # Z4 TO COLUMN FLANGE



$P_V = 42.2^k$   $P = 83.8^k$   
 $P_H = 72.4^k$

$A = 2.1875 \text{ IN}$   
 $B = (6.6875)(7/12) = 3.90 \text{ IN}$   
 $C = A + B = 6.09 \text{ IN}$

SINCE WELD CENTROID IS LOCATED AT MIDPOINT OF PLATE DEPTH,  
 $e = \frac{13}{2} - 6.09 = 0.41 \text{ IN}$

$M = (P_H)(e) = (72.4^k)(0.41 \text{ IN})$   
 $= 29.7 \text{ IN-K}$

WELD PROPERTIES:  $L_w = (2)(13 \text{ IN}) = 26 \text{ IN}$   
 $S_w = \frac{(13 \text{ IN})^2}{3} = 56.33 \text{ IN}^2$

STRESS IN WELD:  $f_{WH} = \frac{P_H}{L_w} + \frac{M}{S_w} = \frac{72.4^k}{26 \text{ IN}} + \frac{29.7 \text{ IN-K}}{56.33 \text{ IN}^2}$

$= 2.79 + 0.53 = 3.32 \text{ KIPS/IN}$

$f_{WV} = \frac{P_V}{L_w} = \frac{42.2^k}{26 \text{ IN}} = 1.62 \text{ KIPS/IN}$

$f_{WRES} = \sqrt{(3.32)^2 + (1.62)^2} = 3.69 \text{ KIPS/IN}$

$t = \frac{f_{WRES}}{(0.707)(\sigma_{TLL})} = \frac{3.69 \text{ KIPS/IN}}{(0.707)(27.2 \text{ KSI})} = 0.19 \text{ IN}$   $\frac{3}{8} \text{ IN}$  FILLET BOTH SIDES OK

CHECK PLATE STRESS:  $A_{net} = 0.85 A_{gross}$  [AISC 1.14.2.3]  
 $= (0.85)(13 \text{ IN})(0.625 \text{ IN}) = 6.91 \text{ SQ IN}$

TENSION (AXIAL)  $\sigma = \frac{72.4^k}{6.91 \text{ SQ IN}} = 10.5 \text{ KSI} < 0.60 F_y$  [AISC 1.5.1.1] CONSERVATIVE



**PUBLIC SERVICE COMPANY OF COLORADO**  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
CALCULATION WORKSHEET

CN 1460  
BY TESNER  
PAGE 895.5E  
FORM NO. 372-30-2650

Form 344-24-4309

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>TESNER</u>	DATE <u>9/14/83</u>		
REVIEWED BY	DATE	CALC. REV.	PAGE OF

CHECK PLATE STRESS (CONT'D)

$$\text{SHEAR} - \tau = \frac{(42.2^k)(0.85)}{6.91 \text{ SQ IN}} = 5.2 \text{ KSI} < 0.40 F_y \text{ [AISC 1.5.1.2.1]}$$

$$\text{COMPRESSION (AXIAL)} - \sigma = \frac{72.4^k}{(13 \text{ IN})(0.625 \text{ IN})} = 8.91 \text{ KSI}$$

ALLOWABLE STRESS  
(AXIAL COMPRESSION)

$$K = 2.1 \quad L = 8 \text{ IN (CONS.V.)}$$

$$I = \frac{(13 \text{ IN})(0.625 \text{ IN})^3}{12} = 0.264 \text{ IN}^4$$

$$A = (13 \text{ IN})(0.625 \text{ IN}) = 8.125 \text{ SQ IN}$$

$$r = \sqrt{I/A} = \sqrt{0.264/8.125} = 0.180 \text{ IN}$$

$$\frac{KL}{r} = \frac{(2.1)(8 \text{ IN})}{0.180 \text{ IN}} = 93.3$$

$$F_a = 13.8 \text{ KSI FOR A-36}$$

$$F_a' = 1.67 F_a = 23 \text{ KSI [DC-70 TABLE 70.4] OK}$$

$$\text{BENDING} - M = 29.7 \text{ IN-K}$$

$$S = \frac{(0.625 \text{ IN})(13 \text{ IN})^2}{6} = 17.6 \text{ IN}^3$$

$$\sigma = \frac{M}{S} = \frac{29.7 \text{ IN-K}}{17.6 \text{ IN}^3} = 1.7 \text{ KSI}$$

AXIAL COMPRESSION AND BENDING STRESSES ARE SUFFICIENTLY SMALL TO PRECLUDE ANY BUCKLING OF PLATE




**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE 895.6 E  
 FORM NO. 372-30-2650

Form 344-24-4309

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>TESNER</u>	DATE <u>9/14/83</u>	CALC. REV.	PAGE
REVIEWED BY	DATE	CALC. REV.	OF

BY INSPECTION (LARGE LOAD AND HIGH ECCENTRICITY) 5/8" x 7"  $\Phi$  CROSS-SECTION WELDED ON BOTH SIDES OF T-EDGE WITH 3/8" FILLET IS INADEQUATE. TRY THE FOLLOWING FIX.  
EVALUATE WELDS AT GUSSET  $\Phi$  Y-4 TO SPICE  $\Phi$  V-4 (COLUMN)



$$P_H = (P) \frac{12}{\sqrt{12^2 + 7^2}} = 72.4 \text{ k}$$

$$P_V = (P) \frac{7}{\sqrt{12^2 + 7^2}} = 42.2 \text{ k}$$

$$A = (8.5625) \left( \frac{7}{12} \right) = 4.99 \text{ in}$$

$$B = A + 1.375 = 6.37 \text{ in}$$





# PUBLIC SERVICE COMPANY OF COLORADO


FORT ST. VRAIN NUCLEAR GENERATING STATION

## CALCULATION WORKSHEET

CN 1460  
BY TESNER  
PAGE 95.7E  
FORM NO. 372-30-2650

Form 344-24-4308

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>TESNER</u>	DATE <u>9/14/83</u>		
REVIEWED BY	DATE	CALC. REV.	PAGE OF



LOCATE CENTROID OF WELD

$$C = \frac{(6.5)^2}{8 + (2)(6.5)} = 2.01 \text{ IN}$$

$$D = 6.5 - C = 4.49 \text{ IN}$$

SINCE LINE OF ACTION OF LOAD P INTERSECTS PLANE OF WELD AT A DISTANCE OF 6.37 IN FROM BOTTOM OF PLATE Y-4, ECCENTRICITY THROUGH WHICH  $P_H$  ACTS IS  $6.37 - 4.49 = 1.88 \text{ IN}$

REACTIONS ON WELD:

$$F_z = P_H = 72.4 \text{ k}$$

$$F_y = P_V = 42.2 \text{ k}$$

$$M_x = (72.4 \text{ k})(1.88 \text{ IN}) = 136 \text{ IN-K}$$

PROPERTIES OF WELD:

$$L_w = 8 + (2)(6.5) = 21 \text{ IN}$$

$$S_w = \frac{(6.5^3)(2)(8) + 6.5^3}{(3)(8 + 6.5)} = 21.9 \text{ IN}^2 \quad \text{TO HIGH POINT OF STRESS AT BOTTOM OF WELD}$$

STRESS IN WELD (MAXIMUM) =

$$f_{wx} = 0$$

$$f_{wy} = \frac{F_y}{L_w} = \frac{42.2 \text{ k}}{21 \text{ IN}} = 2.01 \text{ KIPS/IN}$$

$$f_{wz} = \frac{F_z}{L_w} + \frac{M_x}{S_w} = \frac{72.4 \text{ k}}{21 \text{ IN}} + \frac{136 \text{ IN-K}}{21.9 \text{ IN}^2} = 3.45 + 6.21 = 9.66 \text{ K/IN}$$

$$f_{wRES} = \sqrt{(2.01)^2 + (9.66)^2} = 9.87 \text{ KIPS/IN}$$

$$t = \frac{f_{wRES}}{(0.707)(27.2 \text{ KSI})} = \frac{9.87 \text{ KIPS/IN}}{19.23 \text{ KSI}} = 0.51 \text{ IN} \rightarrow \text{USE } 1/2 \text{ IN FILLET}$$




**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE 895.8E  
 FORM NO. 3'2-30-2650

Form 344-24-308

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>TESNER</u>	DATE <u>9/14/83</u>		
REVIEWED BY	DATE	CALC. REV.	PAGE OF

DESIGN T-SECTION AS STIFFENED BEAM SEAT



AXIAL LOAD IN TRUSS 2L'S  
 $7 \times 4 \times \frac{3}{4}$  (83.8 k) IS REDUCED  
 TO VERTICAL AND HORIZONTAL  
 FORCE WITH VERTICAL REACTION  
 ACTING THROUGH AN EFFECTIVE  
 ECCENTRICITY  $e_s$  OF

$$e_s = (1.88 \text{ IN}) \frac{P_H}{P_V}$$

$$= (1.88 \text{ IN}) \left( \frac{72.4}{42.2} \right)$$

$$= 3.23 \text{ IN}$$

REF. DESIGN OF WELDED STRUCTURES  
 BY O.W. BLODGETT, SECTION 5.3.1

ASSUME ONE HALF OF TOTAL LENGTH OF BRACKET IS EFFECTIVE  
 IN RESISTING LOAD. THEREFORE  $L_H = 5.5 \text{ IN}$ ,  $R = P_V = 42.2 \text{ k}$ ,  
 $e_s = 3.23 \text{ IN}$ ,  $\phi = 90^\circ$  AND  $\sigma_{\text{ALLOW}} = 22 \text{ KSI}$  (ASSUMED; TO  
 BE CHECKED LATER). REQUIRED THICKNESS FOR VERTICAL  
 PLATE (MK Y-4) IS

$$t \approx \frac{R(6e_s - 2L_H)}{\sigma L_H^2 \sin^2 \phi} = \frac{(42.2 \text{ k})((6)(3.23 \text{ IN}) - (2)(5.5 \text{ IN}))}{(22 \text{ KSI})(5.5 \text{ IN})^2 \sin^2 90^\circ} = 0.53 \text{ IN}$$

ACTUAL PLATE IS  $\frac{5}{8}$ " THICK OK

FOR AXIAL TENSION/COMPRESSION,  $P = 72.4 \text{ k}$

$$A = (8 \text{ IN})(0.5 \text{ IN}) + (6.5 \text{ IN})(0.1025 \text{ IN}) = 8.06 \text{ SQ IN}$$

FOR TOTAL T CROSS-SECTION

$$\sigma = \frac{P}{A} = \frac{72.4 \text{ k}}{8.06 \text{ SQ IN}} = 9.0 \text{ KSI}$$

THIS VALUE IS ACCEPTABLE BY JUDGEMENT SINCE  $\frac{KL}{r}$  WILL BE  
 RELATIVELY LOW AND ALLOWABLE CAN BE INCREASED BY 1.67 FOR TORNAO



PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
CALCULATION WORKSHEET

CN 1460  
BY TESNER  
PAGE 895.9E  
FORM NO. 372-30-2650

Form 344-24-4309

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>TESNER</u>	DATE <u>9/14/83</u>		
REVIEWED BY	DATE	CALC. REV.	PAGE OF

CHECK WIDTH-TO-THICKNESS RATIOS [AISC 1.9.1.2]

FOR WEB PLATE, WORST CASE  $b/t = \frac{11\text{IN}}{0.625\text{IN}} = 17.6 < 127/\sqrt{F_y}$   
(21.2)

FOR FLANGE PLATES,  $b/t = \frac{4\text{IN}}{0.5\text{IN}} = 8.0 < 95/\sqrt{F_y}$  (15.8)

THEREFORE ASSUMPTION FOR ALLOWABLE BENDING = 22 KSI OK  
SINCE UNSTIFFED ELEMENTS FULLY EFFECTIVE FOR COMPRESSION

FOR SHEAR,  $\tau = \frac{42.2\text{k}}{(7\text{IN})(0.625\text{IN})} = 9.65 \text{ KSI} < 0.4 F_y$  OK


USE 2  $\phi$  3 3/4" x 1/2" x 0'-11 FOR FLANGE, ONE EACH ON  
EITHER SIDE OF  $\phi$  MK-Y4.

WELD BETWEEN FLANGE  $\phi$ 'S AND WEB TO HAVE EQUAL  
STRENGTH TO HORIZONTAL WELD BETWEEN FLANGE  $\phi$ 'S  
AND COLUMN (APPROX. 8 IN. OF 1/2" FILLET); SEE AISC  
8TH ED. PAGE 4-48.

MINIMUM WELD SIZE FOR 5/8" MATERIAL = 1/4 [AISC 1.17.2]

22 LINEAR INCHES OF WELD IS POSSIBLE AT THIS JOINT  
SO 1/4 IN FILLET IS SATISFACTORY

B) Diagonal Bracing  $4 \times 3 \times \frac{3}{16}$ , Connection @ Column Gusset PL



Required Bolt Capacity = 15.25 k

$\therefore$  Use  $\frac{3}{8}$ "  $\varnothing$  Bolts  $F_u = 19.4 \text{ k/Bolt} > 15.25 \text{ k/Bolt}$

check Bearing =  $1.5(F_u)(D)t$   
 $= 1.5(70)(\frac{3}{8})(\frac{5}{16}) = 41.0 \text{ k/Bolt} > 15.25 \text{ k/Bolt}$  OK  
 $F_u = 58 \text{ KSI FOR A-36 PL -}$   
 MINOR DECREASE ACCEPTABLE BY INSPECTION *off*

Min. Edge Dist. =  $\frac{7}{8}$ " (AISC TABLE 1.10.5.1, 8TH EDITION)

CHECK EDGE DISTANCE [AISC 1.10.5.2]

$$L_e = \frac{2P}{F_u t} = \frac{(2)(15.25)}{(58 \text{ KSI})(\frac{5}{16})} = 0.84 \text{ IN}$$

MIN. EDGE DISTANCE PER AISC TABLE 1.10.5.1 GOVERNS

ACTUAL EDGE DISTANCE (MINIMUM) = 1.32 IN (PLATE D-4) OK  
 SEE NEXT 5 PAGES

ALL CENTER-TO-CENTER ACTUAL DIMENSIONS = 3" OK BY INSPECTION

gdt




**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1400  
 BY TESNER  
 PAGE 890.1E  
 FORM NO. 372-30-2650

Form 344-24-4309

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>J. TESNER</u>	DATE <u>9/9/83</u>		
REVIEWED BY	DATE	CALC. REV.	PAGE OF



OF PLATES C-4 AND D-4,  
 EDGE DISTANCE ON D-4  
 GOVERNS. AVERAGE EDGE  
 DISTANCE FOR D-4 IS  
 $(15 - 13.75) \frac{\sqrt{4^2 + 12^2}}{12} = 1.3214$

OF PLATES E-4 AND F-4,  
 EDGE DISTANCE ON F-4  
 GOVERNS. AVERAGE EDGE  
 DISTANCE FOR F-4 IS  
 $(17 - 15.3125) \frac{\sqrt{3.75^2 + 12^2}}{12} = 1.7714$

GUSSETS FOR 2 L4 x 3 x 1/2





**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE B96.2E  
 FORM NO. 372-30-2650

Form 344-24-4308

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>J. TESNER</u>	DATE <u>9/9/83</u>		
REVIEWED BY	DATE	CALC. REV.	PAGE OF



BY SIMILAR TRIANGLES,

$$\frac{d_1 + 0.234}{2.0625} = \frac{15}{12}$$

$$(12)(d_1 + 0.234) = (15)(2.0625)$$

$$12d_1 = 28.13$$

$$d_1 = 2.34 \text{ IN}$$

ALSO,

$$\frac{d_2 + 0.417}{1.375} = \frac{15}{9}$$

$$(9)(d_2 + 0.417) = (15)(1.375)$$

$$9d_2 = 16.875$$

$$d_2 = 1.875 \text{ IN}$$

$$d_{AVE} = \frac{d_1 + d_2}{2}$$

$$= \frac{2.34 + 1.875}{2} = 2.11 \text{ IN}$$




**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1400  
 BY TESNER  
 PAGE 896.3E  
 FORM NO. 372-30-2650

Form 344-24-4008

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>J. TESNER</u>	DATE <u>9/9/83</u>		
REVIEWED BY	DATE	CALC. REV.	PAGE OF



OF PLATES W-4 AND X-4,  
 EDGE DISTANCE ON X-4  
 GOVERNS. AVERAGE EDGE  
 DISTANCE FOR X-4 IS  
 $(17-15.375) \frac{\sqrt{3.4375^2 + 12^2}}{12}$   
 = 1.69 in

OF PLATES AF-4 AND AG-4,  
 EDGE DISTANCE ON AF-4  
 GOVERNS. AVERAGE EDGE  
 DISTANCE FOR AF-4 IS  
 $(7-5.4375) \frac{\sqrt{7.8125^2 + 12^2}}{12}$   
 = 1.86 in



PUBLIC SERVICE COMPANY OF COLORADO

FORT ST. VRAIN NUCLEAR GENERATING STATION


CALCULATION WORKSHEET

CN 1460  
BY TESNER  
PAGE 596.4E  
FORM NO. 372-30-2650

Form 344-24-4309

CALCULATION FOR		CALCULATION NUMBER	
-----------------	--	--------------------	--

PREPARED BY J. TESNER	DATE 9/9/83		
REVIEWED BY	DATE	CALC. REV.	PAGE



AVERAGE EDGE DISTANCE FOR BOTH PLATES G-4 AND H-4 =

$$(8 - 5.6875) \frac{\sqrt{4.125^2 + 12^2}}{12}$$

$$= 2.45 \text{ IN}$$

OF PLATES J-4 AND K-4, EDGE DISTANCE ON K-4 GOVERNS. AVERAGE EDGE DISTANCE FOR K-4 IS

$$(7 - 5.75) \frac{\sqrt{5.75^2 + 12^2}}{12}$$

$$= 1.39 \text{ IN}$$






**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE 896.5E  
 FORM NO. 372-30-2650

Form 344-24-4308

CALCULATION FOR		CALCULATION NUMBER			
PREPARED BY	<u>J. TESNER</u>	DATE	<u>9/9/83</u>		
REVIEWED BY		DATE		CALC. REV.	PAGE OF

W 24 x 55  
 $d = 23 \frac{5}{8}''$



OF PLATES N-4 AND M-4, EDGE DISTANCE ON N-4 GOVERNS. AVERAGE EDGE DISTANCE FOR N-4 IS

$$(15 - 13.5) \frac{\sqrt{5.125^2 + 12^2}}{12}$$

= 1.63 IN




**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE 396.6E  
 FORM NO. 372-30-2650

Form 344-24-4308

CALCULATION FOR Analysis of Column-Gusset Welds for Walk over Structure.		CALCULATION NUMBER	
PREPARED BY Mullen	DATE 8-12-83		
REVIEWED BY	DATE	CALC. REV.	PAGE / OF



Note: By inspection, PC4 will control analysis.

Max. Axial Force = 1.45k  
 Gussets Mk #'s = C4, D4  
 Members: T15, T16, T7, T8

$$x = \frac{4}{12.65}(10.25) = 3.24 \text{ in (conservative)}$$

$$M_x = (3.24 \text{ in})(1.45 \text{ k}) = 4.70 \text{ in-k}$$

$$F_x = 1.45 \text{ k} \left( \frac{4}{12.65} \right) = .46 \text{ k}$$

$$F_y = 1.45 \text{ k} \left( \frac{12.25}{12.65} \right) = 1.38 \text{ k}$$

Check Weld Stress:

Weld Length =  $l_w = 14 \text{ in}$   
 $S_w = \frac{7}{3} = 16.33 \text{ in}^2$

$$(S_w)_x = \frac{F_x}{l_w} + \frac{M_x}{S_w} = \frac{.46 \text{ k}}{14 \text{ in}} + \frac{4.70 \text{ in-k}}{16.33 \text{ in}^2} = .32 \text{ k/in}$$

$$(S_w)_y = \frac{F_y}{l_w} = \frac{1.38 \text{ k}}{14 \text{ in}} = 0.1 \text{ k/in}$$

$$(S_w)_z = 0$$

By inspection of the component weld focus, it is apparent that that the resulting stress is much less than the allowable weld stress of 20.4 ksi.

∴ Use 3/8" Fillet weld, both sides of Gusset.

\*1) The following calculations reference Northern Steel Drawing NO E-4441-4 Sht. 4 of 4

2) Assume E70 Electrode Mat'l




**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE 896.7E  
 FORM NO. 372-30-2680

Form 344-24-4338

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>Mullen</u>	DATE		
REVIEWED BY	DATE	CALC. REV.	PAGE <u>2</u> OF



Gussets MK # : E4, F4  
 Members : T21, T22, T23, T24  
 Max. Axial Force = 5.1 k

Note: By inspection, R E4 will control analysis.

$$x = 9.618 \left( \frac{3.75}{12.572} \right) = 2.87 \text{ in.}$$

Reaction @ Web

$$M_z = 5.1 \text{ k} (2.87 \text{ in}) = 14.6 \text{ in-k}$$

$$F_x = 5.1 \text{ k} \left( \frac{3.75}{12.572} \right) = 1.52 \text{ k}$$

$$F_y = 5.1 \text{ k} \left( \frac{12}{12.572} \right) = 4.87 \text{ k}$$

Weld Length = 14 in.  
 $S_w = \frac{49}{3} = 16.33 \text{ in}^2$

Check Weld Stress

$$(S_w)_x = \frac{F_x}{2w} + \frac{M_z}{S_w} = \frac{1.52 \text{ k}}{14 \text{ in}} + \frac{14.6 \text{ in-k}}{16.33 \text{ in}^2} = 1.0 \text{ k/in}$$

$$(S_w)_y = \frac{F_y}{2w} = \frac{4.87 \text{ k}}{14} = 0.35 \text{ k/in}$$

$$(S_w)_z = 0$$

$$(S_w)_R = \sqrt{(1.0)^2 + (0.35)^2} = 1.06 \text{ k/in.}$$

$$\Sigma_w = \frac{1.06 \text{ k/in}}{(0.707)(0.375 \text{ in})} = 4.0 \text{ KSI} < \frac{4(36)}{1.707} = 20.4 \text{ KSI}$$

∴ Use 3/8" Fillet Weld, both sides of Gusset.




**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE 896.8E  
 FORM NO. 372-30-2650

Form 344-24-4308

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>Mullen</u>	DATE		
REVIEWED BY	DATE	CALC. REV.	PAGE <u>3</u> OF



Gusset Mk #: G4  
 Members : T11, T12  
 Max. Axial Force: 16.1k

$$x = .06 \left( \frac{12}{2.69} \right) \approx .06 \text{ in}$$

$$M_x = .06 \text{ in} (16.1 \text{ k}) = 0.97 \text{ in-k}$$

Negligible

$$F_x = 16.1 \left( \frac{12}{2.69} \right) = 15.22 \text{ k}$$

$$F_y = 16.1 \left( \frac{4.125}{2.69} \right) = 5.23 \text{ k}$$

$$L_w = 16 \text{ in.}$$

$$(S_w)_x = \frac{F_x}{L_w} = \frac{15.22 \text{ k}}{16 \text{ in}} = .95 \text{ k/in}$$

$$(S_w)_y = \frac{F_y}{L_w} = \frac{5.23 \text{ k}}{16 \text{ in}} = .33 \text{ k/in}$$

Weld is acceptable by inspection.

∴ Use  $\frac{3}{8}$ " Fillet, both sides of Gusset.




**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE 890.9E  
 FORM NO. 372-30-2650

Form 344-24-4309

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>Mullen</u>	DATE	CALC. REV.	PAGE <u>4</u> OF
REVIEWED BY	DATE		



Gusset MK #: H4  
 Members : T11, T12  
 Max. Axial Force: 16.1 k

$$x = \frac{12}{12.689} (3.05)$$

$$x = 2.88 \text{ in.}$$

$$M_z = 16.1 \text{ k} (2.88 \text{ in.}) = 46.4 \text{ in-k.}$$

$$F_x = 16.1 \text{ k} \left( \frac{12}{12.689} \right) = 15.23 \text{ k}$$

$$F_y = 16.1 \text{ k} \left( \frac{4.25}{12.689} \right) = 5.23 \text{ k}$$

$$l_w = 26 \text{ in.}$$

$$S_w = \frac{l_w^3}{3} = 56.33 \text{ in}^3$$

$$(f_w)_x = \frac{F_x}{l_w} + \frac{M_z}{S_w} = \frac{15.23 \text{ k}}{26 \text{ in.}} + \frac{46.4 \text{ in-k}}{56.33 \text{ in}^3} = 1.41 \text{ k/in}$$

$$(f_w)_y = \frac{F_y}{l_w} = \frac{5.23 \text{ k}}{26 \text{ in.}} = 0.2 \text{ k/in}$$

$$(f_w)_z = 0$$

$$(f_w)_R = \sqrt{(1.41)^2 + (0.2)^2} = 1.43 \text{ k/in}$$

$$\sigma_w = \frac{1.43 \text{ k/in}}{(0.07)(0.375 \text{ in.})} = 5.4 \text{ KSI} < 20.4 \text{ KSI} \quad \text{Ok.}$$

$\therefore$  Use  $3/8$ " Fillet, both sides of gusset.




**PUBLIC SERVICE COMPANY OF COLORADO**  
**FORT ST. VRAIN NUCLEAR GENERATING STATION**  
**CALCULATION WORKSHEET**

CN 1460  
 BY TESNER  
 PAGE 890.10E  
 FORM NO. 372-30-2650

Form 344-24-430B

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>Mullen</u>	DATE		
REVIEWED BY	DATE	CALC. REV.	PAGE <u>5</u> OF



Gusset MK #: 54  
 Members: T17, T18, T19, T20  
 Max. Axial Force: 305k

$$x = 4.6 \left( \frac{12}{13.31} \right)$$

$$x = 4.15 \text{ in}$$

$$M_x = 305k (4.15 \text{ in}) = 126.68 \text{ in-k}$$

$$F_x = 305k \left( \frac{12}{13.31} \right) = 27.58k$$

$$F_y = 305k \left( \frac{5.22}{13.31} \right) = 13.18k$$

$$L_w = 14 \text{ in} \quad S_w = \frac{7^2}{3} = 16.33 \text{ in}^2$$

$$(S_w)_x = \frac{F_x}{S_w} + \frac{M_x}{L_w} = \frac{27.58k}{14 \text{ in}} + \frac{126.68 \text{ in-k}}{14 \text{ in}} = 9.72 \text{ k/in}$$

$$(S_w)_y = \frac{F_y}{S_w} = \frac{13.18k}{14 \text{ in}} = 0.94 \text{ k/in}$$

$$(S_w)_z = 0$$

$$(S_w)_R = \sqrt{(9.72)^2 + (0.94)^2} = 9.77 \text{ k/in}$$

$$\tau_w = \frac{9.77 \text{ k/in}}{(0.375)(.707)} = 36.8 \text{ kSI} > \frac{(1.4)(36)}{.707} \times \frac{4}{3} = 27.2 \text{ kSI}$$

~ Fy Base Metal  
 Increase allowed for  
 wind and AISC 15.6

N.G.

Actual Weld size = 1/2" Fillet (To be field verified)

$$\therefore \tau_w = \frac{9.77}{(0.5)(.707)} = 27.6 \approx 27.2 \quad \text{O.K. By Engineering Judgment}$$




**PUBLIC SERVICE COMPANY OF COLORADO**  
**FORT ST. VRAIN NUCLEAR GENERATING STATION**  
**CALCULATION WORKSHEET**

CN 1460  
 BY TESNER  
 PAGE B96.11E  
 FORM NO. 372-30-2650

Form 344-24-430B

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>Mullen</u>	DATE	CALC. REV.	PAGE <u>6</u> OF
REVIEWED BY	DATE		



By inspection,  $P_L$  N-4 will control Analysis

Gussets Mk #s: M4, N4  
 Members: T3, T4  
 Max. Axial Force: 9.8k

$$x = 5.72 \left( \frac{12}{13.05} \right) = 5.26 \text{ in}$$

$$M_z = 9.8k (5.26 \text{ in}) = 51.6 \text{ in-k}$$

$$F_x = 9.8k \left( \frac{12}{13.05} \right) = 9.01k$$

$$F_y = 9.8k \left( \frac{5.26}{13.05} \right) = 3.85k$$

$$L_w = 16 \text{ in.}$$

$$S_w = \frac{L_w^2}{2} = 21.33 \text{ in}^2$$

$$(f_w)_x = \frac{F_x}{L_w} + \frac{M_z}{S_w} = \frac{9.01k}{16 \text{ in}} + \frac{51.6 \text{ in-k}}{21.33 \text{ in}^2} = 2.98 \text{ k/in.}$$

$$(f_w)_y = \frac{F_y}{L_w} = \frac{3.85k}{16 \text{ in}} = 0.24 \text{ k/in}$$

$$(f_w)_z = 0$$

$$(f_w)_R = \sqrt{(2.98)^2 + (0.24)^2} = 2.99 \text{ k/in}$$

$$f_w = \frac{2.99 \text{ k/in}}{(0.707)(0.375 \text{ in})} = 11.3 \text{ kSI} < \frac{4(36)}{507} = 20.4 \text{ kSI}$$

$\therefore$  Use  $3/8$ " Fillet, both sides of Gusset.




**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE 896.12E  
 FORM NO. 372-30-2650

Form 344-24-4308

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>Mullen</u>	DATE	CALC. REV.	PAGE <u>7</u> OF
REVIEWED BY	DATE		



Gusset MK # : K4  
 Members : T17, T18, T19, T20  
 Max. Axial Force: 30.5 k

$$X = 0.65 \left( \frac{12}{13.31} \right)$$

$$X = 0.59$$

$$M_z = 30.5^k (0.59 \text{ in}) = 18 \text{ in-k}$$

$$F_x = 30.5^k \left( \frac{12}{13.31} \right) = 27.5^k$$

$$F_y = 30.5^k \left( \frac{5.778}{13.31} \right) = 13.2^k$$

$$l_w = 20 \text{ in}$$

$$S_w = \frac{10^2}{3} = 33.33 \text{ in}^2$$

$$(f_w)_x = \frac{M_z}{S_w} + \frac{F_x}{l_w} = \frac{18 \text{ in-k}}{33.33 \text{ in}^2} + \frac{27.5^k}{20 \text{ in}} = 1.92^k/\text{in}$$

$$(f_w)_y = \frac{F_y}{l_w} = \frac{13.2^k}{20 \text{ in}} = 0.66^k/\text{in}$$

$$(f_w)_z = 0$$

$$(f_w)_R = \sqrt{(0.66)^2 + (1.92)^2} = 2.03^k/\text{in}$$

$$f_w = \frac{2.03^k/\text{in}}{(0.707)(0.375 \text{ in})} = 7.66 \text{ ksi} < 20.4 \text{ ksi} \quad \text{O.k.}$$

$\therefore$  Use  $3/8$ " Fillet weld, both sides of Gusset.





**PUBLIC SERVICE COMPANY OF COLORADO**  
**FORT ST. VRAIN NUCLEAR GENERATING STATION**  
**CALCULATION WORKSHEET**


CN 1460  
 BY TESNER  
 PAGE 890.13E  
 FORM NO. 372-30-2650

Form 344-24-4308

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>Mullen</u>	DATE	CALC. REV.	PAGE <u>8</u> OF
REVIEWED BY	DATE		

H)

By Inspection, R W-4 will Control



Gussets Mk #: W4, X4  
 Members : T5, T6  
 Max. Axial Force: 9.0k

$$x = 9.52 \left( \frac{3716}{1248} \right)$$

$$x = 2.62 \text{ in.}$$

$$M_z = 9k (2.62 \text{ in}) = 23.6 \text{ in-k}$$

$$F_x = 9k \left( \frac{3716}{1248} \right) = 2.48k$$

$$F_y = 9k \left( \frac{1248}{1248} \right) = 8.65k$$

$$I_w = 14 \text{ in}^4$$

$$S_w = \frac{I_w}{3} = \frac{14}{3} = 4.67 \text{ in}^3$$

$$(S_w)_x = \frac{M_z}{S_w} + \frac{F_x}{A_w} = \frac{23.6 \text{ in-k}}{4.67 \text{ in}^3} + \frac{2.48k}{14 \text{ in}^2} = 1.62 \text{ k/in}$$

$$(S_w)_y = \frac{F_y}{A_w} = \frac{8.65k}{14 \text{ in}^2} = 0.62 \text{ k/in}$$

$$(S_w)_z = 0$$

$$(S_w)_R = \sqrt{(1.62)^2 + (0.62)^2} = 1.73 \text{ k/in}$$

$$\tau_{wR} = \frac{1.73 \text{ k/in}}{(0.707)(0.375 \text{ in})} = 6.52 \text{ KSI} < 20.4 \text{ KSI} \quad \text{O.K.}$$

∴ Use 3/8" Fillet Weld, both sides of Gusset.

Note:

Connections of R's Mk AD4, AE4, AF4 and AG4 are adequate by inspection because of small loading.



**PUBLIC SERVICE COMPANY OF COLORADO**  
**FORT ST. VRAIN NUCLEAR GENERATING STATION**  
**CALCULATION WORKSHEET**

CN 1460  
 BY TESNER  
 PAGE B90.14E  
 FORM NO. 372-30-2650

Form 344-20-4308

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>Mullen</u>	DATE		
REVIEWED BY	DATE	CALC. REV.	PAGE <u>9</u> OF


Examine R Stress for Gusset J4:

$$M = 126.6 \text{ in-k}$$

$$F_x = 27.5 \text{ k}$$

$$F_y = 13.18 \text{ k}$$

$$A = \left(\frac{5}{8}\right)(7") = 4.38 \text{ in}^2$$



Axial Compression:

$$S_a = \frac{F_x}{A} = \frac{27.5 \text{ k}}{4.38 \text{ in}^2} = 6.27 \text{ KSI}$$

$$k = 2.1$$

$$l = 9.615"$$

$$r = \dots = \dots$$

$$I = \frac{bd^3}{12} = \frac{7(6.25)^3}{12} = 1.82 \text{ in}^4$$

$$r = \sqrt{I/A} = \sqrt{\frac{1.82}{4.38}} = 0.18$$

$$\frac{kl}{r} = \frac{2.1(9.615)}{0.18} = 112.2$$

$$\therefore F_c = 11.37 \text{ KSI}$$

$$F_a = 11.37 \times 1.67$$

$$= 18.89 \text{ KSI}$$

[AISC Table 3-36]

[DC70, Issue F]

Bending:

$$S_b = \frac{M}{S} = \frac{126.6 \text{ in-k}}{5.10 \text{ in}^3} = 24.83 \text{ KSI}$$

$$S = \frac{bd^2}{6} = \frac{7(6.25)^2}{6} = 5.10 \text{ in}^3$$

$$F_b = \frac{60}{1.67} F_y$$

$$= 33 \text{ KSI}$$

The R is categorized per AISC 15.1.4.5 para. 2b w/ FS = 1.67. For members falling under AISC 15.1.4.1, w/ FS = 1.52,  $F_b = F_y$  per DC-70. Therefore the above equation gives  $F_b$  by a FS ratio.



PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
CALCULATION WORKSHEET

CN 1460  
BY TESNER  
PAGE 896.15E  
FORM NO. 372-30-2650

Form 344-24-03B

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>Mullen</u>	DATE		
REVIEWED BY	DATE	CALC. REV.	PAGE <u>10</u> OF

Check Interaction:

$$\frac{f_x}{F_x} = \frac{6296}{19,000} = 0.33 > 0.15 \quad \therefore \text{USE AISC Eq 16-1a + 1b}$$

Eq 16-1a:

$$\frac{f_x}{F_x} + \frac{C_m f_y}{(1 - \frac{f_y}{F_y}) F_y} \leq 1.0$$

WHERE:  $C_m = 0.6$   
 $F_y' = \frac{12,700^2 (29,000 \text{ ksi})}{23 (112.2)^2}$   
 $= 11,860$

$$0.33 + \frac{0.6 (24.8)}{(1 - \frac{24.8}{11,860}) 33} = 1.29 \geq 1.0 \quad \underline{\underline{\text{N.G.}}}$$

Eq 16-1b:

$$\frac{f_x}{0.6 F_y} + \frac{f_y}{F_y} \leq 1.0$$

$$\frac{629}{0.6 (36)} + \frac{24.8}{33} = 1.04 \geq 1.0 \quad \underline{\underline{\text{N.G.}}}$$

Note: 1) Although AISC 15.1.4.5 Para. 2 requires lateral bracing @ intervals not exceeding  $\frac{20b_f}{\sqrt{f_y}}$ , it is assumed that in this case the 4x3x $\frac{1}{2}$  double angles will provide adequate lateral support.

2) All other PL's are adequate by inspection, as indicated by low weld stresses.



**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE B96.10E  
 FORM NO. 372-30-2650

Form 344-24-63R


CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>Mullen</u>	DATE		
REVIEWED BY	DATE	CALC. REV.	PAGE <u>//</u> OF

From Previous Pages  
 (P. B96.10)

$$F_y = 27.5 \text{ k}$$

$$F_x = 13.2 \text{ k}$$

Assume 2 PL's added to top of Gusset PL J-4,  
 2-PL 3<sup>3</sup>/<sub>4</sub>" x 1/2" x 1'-1", similar to PL MK Y-4 Pg. B95.6  
 THRU B95.9



Centroid of Web:

$$C = \frac{(65)^2}{8 + 2(65)} = 2.01 \text{ in. Conservative}$$

$$D = 65 - 2.01 = 4.49 \text{ in}$$

Line of action of load P intersects plane  
 of weld at a distance of 8.1 in.  
 from bottom of PL J-4, eccentricity  
 through which  $F_x$  acts is:  
 $8.1 - 4.49 = 3.61 \text{ in.}$

Note: Weld as analyzed on previous pages Ok. - Conservative  
 (REF. P. B96.10)



**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE 896.17  
 FORM NO. 372-30-2650


Form 344-24-430B

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>Mullen</u>	DATE		
REVIEWED BY	DATE	CALC. REV.	PAGE <u>12</u> OF

From Previous Page:

$P = 120 \text{ k}$   
 $F_x = 27.5 \text{ k}$   
 $F_y = 13.2 \text{ k}$

Assume 2-PL  $3\frac{3}{8}$ " x  $\frac{1}{2}$ " x  $L = 13$ " added to top of Gusset  
 PL J-4, similar to PL Mk Y-4 Pg. 895.6



Effective eccentricity =

$$e_e = (3.61 \text{ in}) \frac{F_x}{F_y}$$

$$= (3.61) \frac{27.5}{13.2} = 7.52 \text{ in.}$$

Assume  $\frac{1}{2}$  of total length of Gusset is effective in resisting load. Therefore,  $L_e = 6.5 \text{ in}$ ,  $R = F_y = 13.2 \text{ k}$ ,  $e_e = 7.52 \text{ in}$ ,  $\phi = 90^\circ$   
 $\downarrow$   $\sigma_{all} = 22 \text{ ksi}$ . Required thickness for PL J-4 is:

$$t = \frac{R(6e_e - 2L_e)}{\phi L_e^2 \sin^2 \phi} = \frac{13.2 \text{ k} (6(7.52 \text{ in}) - 2(6.5 \text{ in}))}{(22 \text{ ksi})(6.5 \text{ in})^2 \sin^2 90} = 0.46 \text{ in.}$$

Actual PL thickness =  $\frac{5}{8}$ " O.k.

Since  $F_x + F_y$  on PL Mk J-4 are significantly less than on PL Mk Y-4 and the plate dimensions are approximately the same, the use of the same flange PL's as designed for PL Mk Y-4 will be conservative. Refer to page <sup>895.8</sup> 895.9 for a more detailed analysis



**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET


CN 1460  
 BY TESNER  
 PAGE 896.18E  
 FORM NO. 372-30-2650

Form 344-24-4328

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY <u>Millen</u>	DATE	CALC. REV.	PAGE
REVIEWED BY	DATE		OF

Check Double Angle Brace Connection to Girth P<sub>2</sub>:

1) L7x4x3/4, Worst Case @ PE MK S-2:



Note:

- A) Spliced brace as shown above will control design
- B) Assume 7/16" Fillet weld
- C) Increase allowable stresses by 1/3 due to wind loading
- D) Weld is designed to withstand shear caused by the axial load

Determine weld length required for axial load:

$$\text{Allowable Weld stress: } \frac{405}{1.707} \left(\frac{1}{3}\right) = \frac{405}{1.707} \left(\frac{1}{3}\right) = 27.2 \text{ KSI}$$

$$\therefore 27.2 \text{ KSI} = \frac{83.8k}{(1.707)(7/16)(L_w)}$$

$$L_w = \frac{83.8k}{(1.707)(7/16)(27.2 \text{ KSI})}$$

$$L_w = 13.94 \text{ in. Required}$$

Since long leg of  $\angle$  is 7in. and welded to the P<sub>2</sub>, the L<sub>w</sub> for both  $\angle$ 's on the 7in. side will be 14in. > 13.94in

Cont'd →



**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE 896.19E  
 FORM NO. 372-30-2650

Form 344-24-4308

CALCULATION FOR		CALCULATION NUMBER	
PREPARED BY	DATE		
REVIEWED BY	DATE	CALC. REV.	PAGE OF

Since actual weld is all around the double  $\&$ 's the actual  $l_w$  will be significantly larger than 14 in. Therefore, the weld is adequate + conservative.

2)  $L 4 \times 3 \times \frac{1}{2}$ , worst case @ R MK-EZ:

$$P_R = 30.5^k$$

$$E_c = 1-2'' \times \frac{5}{16}'' \times 2'-0''$$

Double  $\&$   $4 \times 3 \times \frac{1}{2}$   
 Assume  $\frac{5}{16}''$  Fillet

$$\therefore l_w \text{ required} = l_w(\text{req'd w/ } P_R = 83.8^k) \left[ \frac{P_R \text{ actual}}{P_R = 83.8^k} \right]$$

$$l_w = 13.94 \text{ in.} \left[ \frac{30.5^k}{83.8^k} \right]$$

$$= 5.07 \text{ in. req'd.}$$

Since long leg of  $\&$  is 4 in + welded to the  $P_R$ , the  $l_w$  for both  $\&$ 's on the 4 in. side will be 8 in.  $> 5.07$  in. Actual weld is all around double  $\&$ 's, therefore the actual  $l_w$  will be significantly larger than 8 in.

$\therefore \frac{5}{16}''$  Fillet is adequate and conservative.

3) Check Stitch  $P_R$  Stress:

Note: 1) Effective  $P_R$  width is assumed to equal the length of the angle attached to it. [Conservative]

2) The plate is assumed not to be laterally supported [Conservative]

REVIEWER'S COMMENT:  $K=1$  IS USED FOR  $P_R$  ANALYSIS, WHICH IMPLIES PINNED SUPPORTS AT BOTH ENDS (PROVIDED BY ANGLES). WITH CONTINUOUS  $\&$  WELDED FULL LENGTH ON BACK SIDE OF THIS DETAIL, FOLLOWING APPROACH IS VERY

CONSERVATIVE. GOT



**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE B96.20E  
 FORM NO. 372-30-2650

Form 344-24-408

CALCULATION FOR			CALCULATION NUMBER	
PREPARED BY	DATE			
REVIEWED BY	DATE	CALC. REV.	PAGE	OF

1) AP S-7 w/ 2 x 7" x 4" x 3/4":

$$P_g = 83.8^k$$

$$L = 14 \text{ in.}$$

$$A = 7 \text{ in} \left( \frac{5}{8} \text{ in} \right) = 4.375 \text{ in}^2$$

$$k = 1 \quad (\text{Ref. AISC Table C1.8.1})$$

$$r = \sqrt{\frac{I}{A}}$$

$$= \sqrt{\frac{10.42}{4.375}}$$

$$= 0.18 \text{ in}$$

$$r = \frac{bd^3}{12} = \frac{7 \cdot (0.625)^3}{12} = 0.142 \text{ in}^4$$

$$\therefore \frac{kL}{r} = \frac{1(14 \text{ in})}{0.18 \text{ in}} = 77.8$$

$$F_g = 15.58 \times \frac{4}{3} = 20.77 \quad [\text{AISC Table 3-36}]$$

<sup>2</sup> Increase for wind load. NOTE: CAN BE INCREASED BY 1.67 INSTEAD OF 4/3 BY TABLE 70.4 OF DC-70. GOT

$$S_g = \frac{P}{A} = \frac{83.8^k}{4.375 \text{ in}^2}$$

$$= 19.15 \text{ KSI} < 20.77 \text{ KSI}$$

O.K.

Tensile stress acceptable by Inspection

All other  $P$  stresses are acceptable by inspection of the low axial loads and the effective plate areas.




Column Base IP Weld:

Controlling Forces:

$$\left. \begin{aligned} \text{Axial} &= -140.5 \text{ k} \\ V_x &= -40.3 \text{ k} \\ V_z &= 0.002 \text{ k} \end{aligned} \right\}$$

BASED ON SUPPORT JOINTS MODELLED AS PINNED. FOR FIXED BASE REACTIONS SEE ANALYSIS NEXT PAGE. GOT

Column = W24x68  
 $b = 8.965$ ,  $d = 23.73$



Weld Stress: Assume 1/4" Fillet all around

$$S_w = bd + \frac{d^2}{3} = (8.965)(23.73) + \frac{23.73^2}{3} = 400.4$$

$$(S_w)_y = \frac{140.5 \text{ k}}{65.4 \text{ in}} = 2.15 \text{ k/in}$$

$$(S_w)_x = \frac{40.3 \text{ k}}{65.4 \text{ in}} = 0.62$$

$$(S_w)_z = \frac{0.002 \text{ k}}{65.4} = \text{Negligible}$$

$$(S_w)_R = \sqrt{(2.15)^2 + (0.62)^2} = 2.24 \text{ k/in}$$

$$\bar{S}_w = \frac{2.24 \text{ k/in}}{(0.25)(0.707)} = 12.7 \text{ KSI} < 20.4 \text{ KSI}^*$$

CONSERVATIVE - FOR ALL AROUND FILLET ON I-BEAM  $S_w = 2bd + \frac{d^2}{3}$  PER BUDGETT'S DESIGN OF WELDED STRUCTURE: TABLE 5 P 7.4-7

ALSO LENGTH OF WELD  
 $= (2)(23.73) + (4)(8.965)$   
 $= 83.32 \text{ in}$ , USE OF 65.4 IN IS CONSERVATIVE

GOT

∴ Use a 1/4" Fillet All Around

\* 20.4 KSI = Allowable Stress =  $\frac{(40)F_y}{0.707} = \frac{40(35)}{0.707}$

FOR W24x68,  $t_w = 7/16"$ ,  $t_f = 9/16"$

MINIMUM FILLET WELD SIZE PER AISC TABLE 1.17.2A FOR 9/16" THICK MATERIAL IS 1/4" OR

GOT



**PUBLIC SERVICE COMPANY OF COLORADO**  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CALCULATION WORKSHEET

CN 1460  
 BY TESNER  
 PAGE 897.1E  
 FORM NO. 372-30-2650

Form 344-24-4308

CALCULATION FOR		CALCULATION NUMBER			
PREPARED BY <i>Mullen</i>	DATE	CALC. REV.		PAGE	OF
REVIEWED BY	DATE	CALC. REV.		PAGE	OF


Column Base A Welds Continued:

Design weld w/ Fixed structure model per Mc Auto  
 STRUDL run 5/07/82 Time 14.52.23.

Examine largest Jt. reactions in worst loading combination for conservatism.

∴ Controlling Reactions =

$F_x = -43.4^k$	$M_x = \text{Negligible}$
$F_y = +113.0^k$	$M_y = \text{Negligible}$
$F_z = +2.9^k$	$M_z = 255 \text{ ft-k}$ $= 3060 \text{ in-k}$



Properties of Weld Treated as a line:

$$S_w = 2bd + \frac{a^2}{3}$$

$$= 2(8.965)(23.73) + \frac{(23.73)^2}{3}$$

$$= 613.2 \text{ in}^2$$

$$L_w = 833 \text{ in.}$$

check Weld Stress:

$$(S_w)_x = \frac{43.4^k}{833 \text{ in}} = 0.521 \text{ k/in}$$

$$(S_w)_y = \frac{113^k}{833 \text{ in}} + \frac{3060 \text{ in-k}}{613.2 \text{ in}^2} = 6.346 \text{ k/in}$$

$$(S_w)_z = \frac{2.9^k}{833 \text{ in}} = 0.0035 \text{ k/in}$$

$$(S_w)_R = \sqrt{(0.521)^2 + (6.346)^2 + (0.0035)^2}$$

$$= 6.37 \text{ k/in}$$

Assume  $\frac{3}{8}$ " Fillet, All Around:

$$\tau_w = \frac{6.37 \text{ k/in}}{(0.375 \text{ in})(1.707)} = 24.0 \text{ KSI} < \frac{.4(36 \text{ KSI})}{1.707} \frac{4}{3} = 27.2 \text{ KSI}$$

\* Allowable increased because of large stress induced by wind load

∴ Use  $\frac{3}{8}$ " Fillet Weld

NOTE: CALCULATIONS ON THIS PAGE HAVE BEEN SUPERCEDED BY A CASE-BY-CASE EXAMINATION OF GUSSET # TO COLUMN WELD STRESS FOR EACH GUSSET, AS CONTAINED IN THIS CN ON PAGES B95.4E, B95.6E, B95.7E AND B96.6E

CN 1460  
 BY HICKS  
 PAGE B98E  
 FORM NO. 372-30-2650

Gusset # to Columns

THROUGH B96.13E, INCLUSIVE.

907

Control Miss Errors:

$$V_y = 43.419^k$$

$$M_y = 0.0388 \text{ ft-k} = 0.4556 \text{ in-k}$$

$$V_z = 0.00178^k$$

$$M_z = 16.3165 \text{ ft-k} = 195.798 \text{ in-k}$$

$$V_x = 72.331^k$$

$$M_x = 0$$

Assume  $\frac{1}{4}$ " fillet 2 edges, both sides:

$$S_w = \frac{1/4 \times 60}{6} = \frac{15}{6} = 30 \text{ in}^2 \times 2 = 60 \text{ in}^2 \quad (\text{StJ pg. 234})$$

$$(S_w)_y = \frac{43.419^k}{24} + \frac{0.4556}{60} = 1.809 + 0.0078 = 1.817 \text{ k/in}$$

$$(S_w)_z = \frac{195.798}{24} + \frac{16.3165}{60} = 8.158 + 0.272 = 8.43 \text{ k/in}$$

$$(S_w)_x = \frac{72.331}{24} = 3.014 \text{ k/in}$$

$$(S_w)_R = \sqrt{(1.817)^2 + (8.43)^2 + (3.014)^2} = 8.80 \text{ k/in}$$

$$\tau_{sw} = \frac{8.80 \text{ k/in}}{(0.25)(0.707)} = 49.6 \text{ kSI} > 20.4 \text{ kSI}$$

N.G.

Try  $\frac{3}{8}$ " fillet:

$$\left. \begin{aligned} (S_w)_y &= 1.817 \text{ k/in} \\ (S_w)_z &= 8.43 \text{ k/in} \\ (S_w)_x &= 3.014 \text{ k/in} \end{aligned} \right\} (S_w)_R = 8.80 \text{ k/in}$$

$$\tau_{sw} = \frac{8.80 \text{ k/in}}{(0.375)(0.707)} = 33.8 \text{ kSI} < 20.4 \text{ kSI}$$

O.K.


$\therefore \frac{3}{8}$ " fillet

NOTE: CALCULATIONS ON THIS PAGE HAVE BEEN SUPERCEDED BY A DETAILED ANALYSIS OF STITCH PLATES/WELDS FOR BOTH L7x4 AND L4x3 BRACING CONNECTIONS, AS CONTAINED IN THIS CN ON PAGES B96.18 THRU B96.20.

CN 1460  
 BY HICKS  
 PAGE B99E  
 FORM NO. 372-30-2650

Stitch ~~Pl~~ For Diagonal Bracing:

got



Use same Fillet as Page 4.

$$S_w = bd = 42 \times 2 = 84$$

$$(S_w)_y = \frac{43,419}{24} + \frac{0,4656}{84} = 1.82 \text{ k/in}$$

$$(S_w)_x = \frac{22,331}{24} = 3.01 \text{ k/in}$$


$$(S_w)_z = \frac{0,000}{24} + \frac{105,709}{84} = 2.33 \text{ k/in}$$

$$(S_w)_R = \sqrt{(1.82)^2 + (3.01)^2 + (2.33)^2} = 4.22 \text{ k/in}$$

$$\tau_w = \frac{4.22}{(0.75)(0.707)} < 20.4 \text{ ksi}$$

$$\therefore t = \frac{4.22}{(0.707)(20.4)} = 0.29 \quad \text{USE } \frac{5}{16} \text{ FILLET}$$

$$\tau_w = \frac{4.22}{(0.75)(0.707)} = 19.1 \text{ ksi} < 20.4 \text{ ksi} \quad \text{O.K.}$$





# COMMERCIAL TESTING LABORATORIES

A DIVISION OF CTL-THOMPSON

September 14, 1983

CN 1460  
BY TESNER  
PAGE 899.1E  
FORM NO. 372-30-2650

G. E. Johnson Construction Company  
P.O. Box 1497  
Longmont, Colorado 80501

Attention: Mr. Jim Hanley

Subject: Ultrasonic Pulse Velocity Tests  
South Wall of the Building 10 Addition  
Fort St. Vrain Nuclear Power Plant  
Platteville, Colorado  
Job No. Q-3403

Gentlemen:

In accordance with your request, we have performed an investigation to evaluate the integrity of the first lift of the south wall of the Building 10 addition at the Fort St. Vrain power plant near Platteville, Colorado. Non-destructive, ultrasonic tests were performed to determine if the honeycombing observed on faces of four walls extended into the wall concrete. The initial portion of our field investigation was performed on August 2, 1983, but because of equipment failure, was not completed until August 17, 1983.

Tests were performed using V-Meter equipment consisting of an ultrasonic wave energy source, a receiver, and an electronic clock to record the time for the ultrasonic pulse to travel from the source to the receiver. Direct transmission testing of the south wall was performed by placing the source on the wall exterior and the receiver directly in line with the source on the interior of the wall to provide a direct velocity measurement between the two points. The wall thickness was measured at openings in the wall. Pulse velocity was then computed by dividing the wall thickness by the pulse travel time. The general test configuration was specified by Mr. Ed Hicks, Public Service Company of Colorado. Three-foot test grids were laid out on interior and exterior faces of the south wall by our personnel based on elevations provided by G.E. Johnson Construction Company. A total of 30 points were tested.

## Ultrasonic Pulse Velocity Test Results

The ultrasonic pulse velocity generally varies directly with concrete compressive strength and density. The presence of voids, low strength concrete zones, cracks or discontinuities are indicated by low ultrasonic pulse velocities. Results of the ultrasonic pulse velocity measurements and the test configuration are presented on Fig. 1. An

average pulse velocity of 13,110 feet per second (fps) and a standard deviation of 226 fps were calculated for the 30 measurement points. Pulse velocities ranged from a low of 12,560 fps to a high of 13,530 fps. Our test grid was located to minimize the effects of reinforcing steel in the wall on pulse velocity measurements.

Conclusions and Recommendations

1. Ultrasonic pulse velocity measurements indicate good concrete of normal strength and density at all test points tested for the first lift of the south wall of the addition to Building 10.
2. Velocities, in our opinion, do not indicate presence of voids or other discontinuities.
3. In our opinion, the honeycombing and void systems can be located by inspection of the interior and exterior wall surfaces.

Please advise us if we can be of further service in discussing the contents of this report, or in the analyses of the concrete quality of walls of this structure.

Very truly yours,

Commercial Testing Laboratories, Inc.

By Larry D. Olson, Staff Engineer

Reviewed by Carl J. Ray, Jr., P.E., President



LDO:CJR:jc

(2 copies sent)

2cc: Public Service Company of Colorado  
2420 West 26th Avenue  
Suite 100B  
Denver, Colorado 80211

Ultrasonic Pulse Velocity Test Results for the South Wall of the Addition to Building 10

Average Pulse Velocity: 13,110 feet per second (fps)

Standard Deviation: 226 fps

High: 13,530 fps      Low: 12,560 fps




Fig. 1

This reissue incorporates all of the following deviation requests. All DRs have been approved by Engineering. The DRs do not compromise the requirements of the FSAR.

82-206-1-H	No changes in design intent.
82-206-1-J	See engineering evaluation [Pgs. B44D through B64D (Ref.), B101E]
82-206-1-K	No change in design intent.
82-206-1-L	See engineering evaluation (Pg. B102E)
82-206-1-N	No change in design intent.
82-206-1-O	
82-206-1-Q	
82-206-1-P	
82-206-1-S	
82-206-1-T	
82-206-1-U	
82-206-1-V	
82-206-1-W	
82-206-1-Y	
82-206-1-Z	
82-206-1-AA	
82-206-1-AC	
82-206-1-AE	
83-76-1-A	
83-76-1-B	
83-76-1-C	
83-76-1-D	
83-76-1-F	
83-76-1-G	
83-76-1-H	
83-76-1-I	
83-76-1-J	
83-76-1-K	
83-76-1-L	
83-76-1-M	
83-76-1-N	
83-76-1-O	
83-76-1-P	
83-76-1-Q	No change, the battery room is held by main structural steel not battery room roof.
83-76-1-R	No changes in design intent.



Procedure For Excavating and Placing Lean Concrete  
Backfill at Walkover Structure Foundation  
Revision 1

1. Excavate and shore sections of the excavation on three (3) foot lifts down to elevation 4776.0. Properly shore all walls as lifts are excavated.
2. When the bottom of excavation is complete (El 4776'-0"±) the engineer will inspect and approve excavation before placement of lean concrete is made.
3. All dirt that is not shored shall be cut back to prevent dirt from falling into concrete.
- 3A. See attached report from Consulting Geotechnical & Materials Engineer dated 6/3/83 for the soil bearing test.
4. Order lean concrete from Mobile Premix, 220 Mix Design, 3/4" aggregate, Type II L.A. Cement.
5. Discharge concrete directly from back of mixer trucks and layer concrete in (2) foot lifts.
6. No shoring shall be left in concrete.
7. Vibrate the concrete to be sure no voids are left.
8. Top of lean concrete backfill (Elevation 4785'-0"+1) shall be vibrated to form a smooth level top. ( $\pm \frac{1}{2}$ " ) or as otherwise directed by the engineer.
9. Provide tests of lean concrete for Slump 4"  $\pm$  1", Air 5%  $\pm$  1%, Compressive strength 500 PSI at 28 days, Compression cylinders. MIN of 5. Temperature Max 90 degrees F.
10. Forming of walkover foundation may begin the next day. **AFTER THE LEAN CONCRETE BACKFILL HAS BEEN COMPLETED**
11. To prevent the backfill from filling the excavated cavity concrete backfill may be placed in rectangular blocks ( Min Volume 240 C.F.) at the bottom of the excavation with a maximum height of 5'. A continuous concrete cap shall be placed across the top of the blocks. Thus cap shall be a height of 4'±.



DRY-PACK GROUT PROCEDURE  
(DR 82-206-1-L)

Material:

Cement, Type II  
Sand, natural or manufactured  
as approved by engineer  
Proportioning

1 part Portland Cement to 3 parts sand  
by weight. Water content shall be such  
that a mass of mortar squeezed in the  
hand retains its shape.

Placing:

Place dry pack grout against soil.  
Packing shall be performed by ramming  
with paddles of suitable size, shape  
and length. The space between the  
base and grade beam shall be filled with  
dry pack grout.

Curing:

Cure edges of concrete in a manner  
similar to that used for concrete.

Before grout work is started be sure  
that all surfaces are clean to the  
satisfaction of the engineer.

Installer shall be careful in placing  
dry pack grout that existing dirt  
does not spall or cave in.



# PUBLIC SERVICE COMPANY OF COLORADO

FORT ST. VRAIN NUCLEAR GENERATING STATION

CN TCR / SCR / PC / TR

NO. 1461 E

PAGE 2

## SAFETY EVALUATION

### CATEGORY

TYPE:

- CN OVERALL     CN SUBMITTAL     SETPOINT CHANGE REPORT     TEST REQUEST  
 TEMPORARY CONFIGURATION REPORT     PROCEDURE CHANGE (FSAR)     OTHER

CLASSIFICATION: ARE THE SYSTEM(S) EQUIPMENT OR STRUCTURES INVOLVED, OR DOES THE ACTIVITY AFFECT:

- |                |   |  |                         |                              |  |
|----------------|---|--|-------------------------|------------------------------|--|
| CLASS I        | <input type="checkbox"/> YES            | <input checked="" type="checkbox"/> NO | ENGINEERED SAFEGUARD    | <input type="checkbox"/> YES | <input checked="" type="checkbox"/> NO |
| SAFE SHUTDOWN  | <input type="checkbox"/> YES            | <input checked="" type="checkbox"/> NO | PLANT PROTECTIVE SYSTEM | <input type="checkbox"/> YES | <input checked="" type="checkbox"/> NO |
| SAFETY RELATED | <input checked="" type="checkbox"/> YES | <input type="checkbox"/> NO            | SECURITY SYSTEM         | <input type="checkbox"/> YES | <input checked="" type="checkbox"/> NO |

REMARKS Design and analysis treated as safety related with respect to fire protection.

### EVALUATION

USE ADDITIONAL SHEETS IF REQUIRED.

1 IS THE ACTIVITY IDENTIFIED IN THE FSAR OR TECH SPEC?  YES  NO  
 LIST THE APPLICABLE SECTIONS REVIEWED. This activity involves construction of HVAC and fire protection systems in a new facility (Building 10). As such, it is not identified in either the FSAR or Tech Specs. However, general criteria for fire protection are identified in FSAR Sections 14.1.3, 9.12 and App C, Crit. 3, and Tech Spec LCO 4.10 and SR 5.10 <sup>w/AFE</sup> applicable to similar existing systems.

2 DOES THE ACTIVITY REQUIRE THAT CHANGE(S) BE MADE TO THE FSAR OR TECH SPEC?  YES  NO  
 LIST SECTIONS TO BE CHANGED AND THE CHANGES TO BE MADE. FSAR Sections 9.12, 10.2.7 should be changed to reflect installation of these systems. No changes are required to the Technical Specifications (see attached pages 2.1, 2.2).

3 DETERMINE WHETHER OR NOT THE ACTIVITY INVOLVED IS AN UNREVIEWED SAFETY QUESTION UTILIZING THE FOLLOWING GUIDELINES.

(A) HAS THE PROBABILITY OF OCCURRENCE OR THE CONSEQUENCES OF AN ACCIDENT OR MALFUNCTION OF EQUIPMENT IMPORTANT TO SAFETY PREVIOUSLY EVALUATED IN THE FSAR BEEN INCREASED?  
 YES  NO STATE BASIS: see pages 2.1, 2.2

(B) HAS THE POSSIBILITY OF AN ACCIDENT OR MALFUNCTION OF A DIFFERENT TYPE THAN ANY EVALUATED PREVIOUSLY IN THE FSAR BEEN CREATED?  YES  NO STATE BASIS: see pages 2.1, 2.2

(C) HAS THE MARGIN OF SAFETY, AS DEFINED IN THE BASIS FOR ANY TECHNICAL SPECIFICATION OR IN THE FSAR BEEN REDUCED?  YES  NO STATE BASIS: No defined margin of safety in the Tech Specs.

DOES THE ACTIVITY APPEAR TO: INVOLVE AN UNREVIEWED SAFETY QUESTION  YES  NO  
 BE SAFETY SIGNIFICANT  YES  NO

BY Nancy Blichmann (SIGNATURE) 2/6/89 (DATE) \*APPROVED JR John (SIGNATURE) 2-6-84 (DATE)

\*REQUIRED ONLY FOR CHANGE NOTICE

# SAFETY EVALUATION

CN 1461  
BY Blichmann  
PAGE 2.1  
FORM NO. 372-30-2650

2. continued...

No changes to the technical specifications are required as a result of the installation of these systems.

The Halon fire suppression system was not installed to meet regulatory requirements, but strictly for insurance purposes. A fire protection review of Building 10 (then named the Three Room Control Complex Addition) was performed by Proto-Power Management Corporation. The resulting report concluded that the fire protection meets the requirements of Branch Technical Position (BTP) 9.5-1, and 10CFR 50, Appendix R, as it applies to Fort St. Vrain, without taking credit for the Halon fire suppression system. As such, no additions concerning Halon or fire dampers must be added to the Tech Specs.

The maximum temperature which could be reached as a result of HVAC system failure was evaluated in NDS-83-0297. Calculations show that the maximum temperature does not exceed the environmental qualification of the equipment. No Technical Specification change concerning the temperature limits of Building 10 is required.

Ionization type detectors installed in Building 10 do not require a Technical Specifications change. LCO 4.10.3 concerns smoke detectors and alarms for the Three Room Control Complex and congested cable areas. The control room is included because of its particular importance to safe plant operation. The other areas, including the auxiliary electric equipment room and the 480 V switchgear room, were included because they contain congested cable areas. The basis for LCO 4.10.3 states "The system alerts the operator to the possibility of a fire in congested cable areas and to the necessity of investigation of conditions in these areas." The redundant trains of cables in Building 10 will be

BY: Nancy Blichmann 2/6/84 APPROVED: JZ Johns 2-6-84  
DATE DATE

2. continued

Wrapped to provide a one hour fire barrier, as required in 10CFR50, App. R 6.2(c) and as recommended by the Proto Power Fire Analysis shown on pages B53A - B69A of this CN.

3a). The probability of damage to safety related equipment has not increased. The Proto-Power Fire Analysis (pages B53A-B69A) states that the ionization detectors provide sufficient indication of fire. Mitigation is provided by dry chemical fire extinguishers, and by a Halon fire suppression system. The Fire Analysis mentioned above verified that portable dry chemical extinguishers are sufficient to meet the criteria in BTP 9.5-1, App. A and 10CFR50, App R as it applies to FSV. However, the Halon system does provide additional fire mitigation and increases safety.

Recommendations made by Proto-Power concerning wrapping redundant cables B1L1 and B1L2, and fixed emergency lighting have been included in the design. Because the design meets these criteria, possibility of damage to safety related equipment, which has been analyzed in the FSAR, has not been increased.

b) There are no cable spreading areas in Building 10, therefore existing fire protection systems are adequate. The possibility or consequence of an accident has not been increased by this addition, and effective protection systems have been installed.

BY Nancy Blichmann 2/6/84 APPROVED JR Johns 2-6-84  
DATE DATE DATE

PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
NUCLEAR PROJECT DEPARTMENT

Electrical   
Mechanical   
Structural   
Safety Related   
Non Safety Related

DESIGN INPUT REQUIREMENTS

Sheet 1 of 1

This CN will cover the mechanical portion of the construction of the Three Room Complex Addition. All mechanical work will be performed in accordance with section 15000 of specification 75-J-02. The work to be done by this CN is not safety related but will be treated as such as far as an independent design review is concerned. The Uniform Mechanical Code 1979 Edition and the Uniform Plumbing Code 1978 Edition, will be used as guidelines for the ~~HVAC system installation~~ fire protection system will be designed and installed per NFPA 12A and UL Requirements.

A fire hazards analysis was performed by Proto Power Management Corp. to verify that the proposed fire protection for Building 10 (New name for the Three Room Complex Addition) is in compliance with Branch Technical Position 9.5-1. This analysis is included as pages B-53A thru B-69A. Also see p. B-70A for a discussion of this analysis.

*add. info 12/14/82*

Added by CN-1481A

Prepared By: /s/ [Signature]  
Date

Approved By: /s/ F. Wilson 10-6-82  
Date

7. Wilson 12-15-82

PUBLIC SERVICE COMPANY OF COLORADO  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 NUCLEAR PROJECT DEPARTMENT

- Electrical   
 Mechanical   
 Structural   
 Safety Related   
 Non Safety Related

DESIGN ANALYSIS  
 Sheet 1 of 51

As stated in the Design Input Requirements, all work will be done per specification 75-5-02, section 15000. Calculations are included here for HVAC unit and duct sizing and also for duct hanger sizing to insure that duct runs will not fall on safety related equipment during a seismic event.

HVAC calculations:

Note: All formulas and constants are taken from ASHRAE Fundamentals, 1977, Transit. Conditioning Manual, 1981, and SMACNA Low Pressure Duct Construction Standards, 1976.

I. Calculations for U, overall heat transfer coefficient.

A. Walls	R
Concrete, 12" thick	1.86
Fiberglass, 3" thick	9.5
Inside surface (still air)	0.68
Outside surface (15 mph wind)	0.17
Total	$12.21 \frac{\text{hr} \cdot \text{ft}^2 \cdot \text{°F}}{\text{Btu}}$

$$U = \frac{1}{R} \therefore U_w = \frac{1}{12.21} = .082 \frac{\text{Btu}}{\text{hr} \cdot \text{ft}^2 \cdot \text{°F}}$$

B. Outside Doors

$$U_{30} = .29 \frac{\text{Btu}}{\text{hr} \cdot \text{ft}^2 \cdot \text{°F}} \quad (\text{From ASHRAE Handbook, 1977 Edition})$$

Prepared By: /s/ M. Lampard 9/15/82  
 Date

SAFETY RELATED  
DESIGN ANALYSIS  
 Sheet 2 of 51

C. ROOF

	<u>R</u>
Outside surFace (15 mph wind)	0.17
2" insulation, outside	10.00
12" Concrete	1.86
6" insulation, inside	19.00
Inside surFace, still air	0.68
Total	<u>31.71</u> $\frac{h \cdot 51.20 F}{Btu}$

$\therefore U_R = \frac{1}{R} = .032 \frac{Btu}{h \cdot 51 F}$

D. Floor, grade level

	<u>R</u>
Concrete, 12" thick	1.86
Inside surFace, still air	.68
Total	<u>2.54</u> $\frac{h \cdot 51.20 F}{Btu}$

$\therefore U_{RGL} = \frac{1}{2.54} = .39 \frac{Btu}{h \cdot 51.20 F}$

E. 1'3" Floor/Ceiling

	<u>R</u>
Top surFace, still air	.68
Concrete, 15" thick	2.33
Bottom surFace, still air	.68
Total	<u>3.69</u> $\frac{h \cdot 51.20 F}{Btu}$

$U_{15" HC} = \frac{1}{3.69} = .27 \frac{Btu}{h \cdot 51.20 F}$

F. 6" Floor/Ceiling

Top surFace, still air	.68
6" Concrete	.93
Bottom surFace, still air	.68
Total	<u>2.29</u> $\frac{h \cdot 51.20 F}{Btu}$


$U_{6" HC} = \frac{1}{2.29} = .44 \frac{Btu}{h \cdot 51.20 F}$

Prepared By: 1st [Signature] 9/15/62  
 Date





SAFETY RELATED  
DESIGN ANALYSIS  
 Sheet 3 of 51

II. Building Diagram



Door Details



Prepared By: 1st [Signature] 9/15/52  
 Date

SAFETY RELATED  
DESIGN ANALYSIS  
 Sheet 4 of 51

III. Heat Loss Calculations

A. 480 V Room

1. Walls

$$A_w = 2(20 \times 41) + 2(20 \times 30) = 2840 \text{ ft}^2$$

$$U_w = .082$$

$$\Delta T = 70 - (6.5) = 75$$

$$q_w = U_w A_w \Delta T = .082 (2840) (75)$$

$$q_w = 17,466 \text{ Btu/h}$$

2. Floor

$$A = 41 \times 30 = 1230 \text{ ft}^2 \text{ (some 500 cfm Slopes and ceilings)}$$

$$U = .39 \quad \Delta T = 75$$

$$q_f = .39 (1230) (75) =$$

$$q_f = 35,980 \text{ Btu/h}$$

3. Ceiling

$$A = 1230, U = .44, \Delta T = 0$$

$$\therefore q = 0$$

4. Exhaust from battery room,  $V = 8 \times 15 \times 9 = 1080 \text{ ft}^3$ , 3 air changes

$$Q = 100 \text{ cfm}, \Delta T = 75$$

per hour = 3240 cfm = 54 cfm, say 100 cfm to be safe.

$$q_s = 108 Q \Delta T$$

$$q_s = 108 (100) (75)$$

$$q_s = 8100 \text{ Btu/h}$$

$$q_L = .7 Q \Delta T$$

$$q_L = .7 (100) (110.7 - 6.5)$$

$$q_L = 7360 \text{ Btu/h}$$

$$q_s + q_L = 15,460 \text{ Btu/h}$$

Prepared By: 1st Thammasat 9/15/62  
 Date

SAFETY RELATED  
DESIGN ANALYSIS  
Sheet 5 of 51

B. Auxiliary Electric Room

1. Walls

$$A_w = 2(13 \times 4) + 2(13 \times 30) = 1846 \text{ S.F.}^2$$
$$U = .082 \quad \Delta T = 70 - (-5) = 75$$

$$q_w = .082(1846)(75)$$
$$q_w = 11,350 \text{ Btu/h}$$

2. Floor

$$U = .44 \quad \Delta T = 0$$
$$\therefore q = 0$$

3. Ceiling

$$\Delta T = 0$$
$$\therefore q = 0$$

C. Office and Equipment Room

1. Walls

$$A_w = 2(11.5 \times 40) + 2(11.5 \times 30)$$
$$A_w = 1610 \text{ S.F.}^2$$
$$U = .082 \quad \Delta T = 75$$
$$q = .082(1610)(75)$$
$$q = 9900 \text{ Btu/h}$$

2. Floor

$$\Delta T = 0$$

$$q = 0$$

3. Ceiling

$$\Delta T = 0$$

$$q = 0$$

Prepared By: 1st [Signature] 9/15/52  
Date

SAFETY RELATED  
DESIGN ANALYSIS  
Sheet 6 of 51

D. Training Room

1. Walls

$$A_w = 2(17.5 \times 41) + 2(17.5 \times 30)$$

$$A_w = 2485.5 \text{ ft}^2$$

$$U = .082, \Delta T = 75$$

$$q_w = .082(2485.5)(75)$$

$$q_w = 15,280 \text{ Btu/h}$$

2. Floor

$$\Delta T = 0$$

$$q = 0$$

3. Ceiling

$$U = .032, \Delta T = 75, A = 1230$$

$$q = U A \Delta T$$

$$q = .032(1230)(75)$$

$$q = 2950 \text{ Btu/h}$$

Prepared By: 1st Lt. J. H. [Signature] 9/15/82  
Date

SAFETY RELATED  
DESIGN ANALYSIS  
 Sheet 7 of 51

E. Exfiltration Through Door Cracks

Single door:  $A = 21 \text{ ft}^2$ ,  $P = 20 \text{ ft}$   
 Double door:  $A = 42 \text{ ft}^2$ ,  $P = 33 \text{ ft}$  (inch crack down middle)

1. 480V Room

1 double door, 1 single door

$\Delta T = 75^\circ \text{F}$

a. crack loss

assume 11 cfm per linear ft. of crack

$P_{\text{Total}} = 20 + 33 = 53 \text{ ft}$

$Q = 53(11) = 583 \text{ cfm}$

$f_{\text{leak}} = .7 Q (\text{c.f.m.})$

$f_{\text{sensitive}} = 1.09 Q \Delta T$

$f_{\text{leak}} = .7(583)(11.7 - 55)$

$f_{\text{sensitive}} = 1.09(583)(75)$

$f_{\text{leak}} = 42,930 \text{ Btu/h}$

$f_{\text{sensitive}} = 47,225 \text{ Btu/h}$

$f_{\text{leak}} + f_{\text{sensitive}} = 90,155 \text{ Btu/h}$

b. conduction

$U = .29$ ,  $\Delta T = 75$ ,  $A = 42 + 21 = 63 \text{ ft}^2$

$q_c = U A \Delta T$

$q_c = .29(63)(75)$

$q_c = 1370 \text{ Btu/h}$

$f_{\text{Total}} = 90,155 + 1370 = 91,525 \text{ Btu/h}$

Prepared By: 1st [Signature] Date 9/15/82

SAFETY RELATED  
DESIGN ANALYSIS  
 Sheet 8 of 51

2. Auxiliary Electric Room

same as 480V Room,  $q_{total} = 91,525 \text{ Btu/h}$

3. Office ; Equipment Room

1 single door,  $A = 21 \text{ ft}^2$ ,  $P = 20 \text{ ft}$

a. crack loss

$$Q = P(A) = 20(21) = 220 \text{ CFM}$$

$$q_L = .7 Q \Delta T$$

$$q_L = .7(220)(70.7 - 55)$$

$$q_L = 16,200 \text{ Btu/h}$$

$$q_s = 108 \theta \Delta T$$

$$q_s = 108(220)(75)$$

$$q_s = 17,820 \text{ Btu/h}$$

$$q_s + q_L = 34,020 \text{ Btu/h}$$

b. conduction loss

$$U = .29, A = 21, \theta = 75$$

$$q_c = U A \theta$$

$$q_c = .29(21)(75)$$

$$q_c = 460 \text{ Btu/h}$$

$$q_{total} = q_c + q_s + q_L = 460 + 34,020$$

$$q_{total} = 34,480 \text{ Btu/h}$$

Prepared By: 1st [Signature]  
 Date: 9/15/72

SAFETY RELATED  
DESIGN ANALYSIS  
Sheet 9 of 51

4. Training Room

same as 480V Room,  $\{Total = 91,525 \text{ Btu/h}$

IV Summary of Heat Loss Calculations

A. 480V Room

Walls	17,466 Btu/h
Floor	35,980
Ceiling	0
Battery Room Exhaust	15,460
Doors	91,525
Total	<u>160,431 Btu/h</u>

B. Auxiliary Electric Room

Walls	11,350 Btu/h
Floor	0
Ceiling	0
Doors	91,525
Total	<u>102,875 Btu/h</u>

Prepared By: 1st [Signature] 9/15/82  
Date

SAFETY RELATED  
DESIGN ANALYSIS  
Sheet 10 of 51

C. Office & Equipment Room

Walls	9900 Btu/h
Floor	0
Ceilings	0
Doors	<u>34,480</u>
Total	44,380 Btu/h

D. Training Room

Walls	15,280 Btu/h
Floor	0
Ceilings	2,950
Doors	<u>91,525</u>
Total	109,755 Btu/h

Total heating load = 417,441 Btu/h (entire building)

Prepared By: 1st Lt. J. L. Lumbard  
Date: 1/5/82



SAFETY RELATED  
DESIGN ANALYSIS  
 Sheet 11 of 51

IV. Cooling Load Calculations

1. 480V Room

a. Equipment

$$45 \text{ kW} = 45 \times 10^3 \text{ W} (3.412) \frac{\text{Btu/h}}{\text{W}} = 153,450 \text{ Btu/h}$$

b. Walls

Conduction,  $U = .052$ ,  
 $A = 2(20 \times 4) + 2(20 \times 30) = 2840 \text{ ft}^2$

$\Delta T = 95 - 78 = 17 \text{ }^\circ\text{F}$

$$q = U A \Delta T$$

$$q = .052 (2840) (17)$$

$$q = 4000 \text{ Btu/h}$$

Solar gain on walls

$$A_N = 20(30) = 600 \text{ ft}^2$$

$$A_S = A_N = 600 \text{ ft}^2$$

$$A_E = 20(4) = 80 \text{ ft}^2$$

$$A_W = A_E = 80 \text{ ft}^2$$

Temp. Diffentials (From book, Tables 3-41 & 3-43)

$$TD_N = 10$$

$$TD_S = 27$$

$$TD_E = 20$$

$$TD_W = 16$$

$$q = U A T_D$$

$$q_N = (.052)(600)(10)$$

$$q_N = 500 \text{ Btu/h}$$

$$q_E = .052(80)(20)$$

$$q_E = 1350 \text{ Btu/h}$$

$$q_S = (.052)(600)(27)$$

$$q_S = 1330 \text{ Btu/h}$$

$$q_W = .052(80)(16)$$

$$q_W = 1100 \text{ Btu/h}$$

$$q_N + q_S + q_W + q_E = 500 + 1330 + 1100 + 1350 = 4300 \text{ Btu/h}$$

$$\therefore q_{\text{total}} = 4000 + 4300 = \underline{8300 \text{ Btu/h}}$$

Prepared By: 1st [Signature] Date 7/15/42

SAFETY RELATED  
DESIGN ANALYSIS  
 Sheet 12 of 51

c. Floor

$$U = .39, A = 1230, \Delta T = 17$$

$$q = U A \Delta T =$$

$$q = .39(1230)(17)$$

$$q = 8160 \text{ Btu/h}$$

d. Ceiling

$$U = .44, A = 1230, \Delta T = 70 - 78 = -8^\circ F$$

$$q = U A \Delta T$$

$$q = .44(1230)(-8)$$

$$q = -4330 \text{ Btu/h}$$

e. Doors, 1 double door, 1 single door

$$P = 53 \text{ ft}^2$$

$$Q = 53(11) = 583 \text{ cfm}$$

$$U = .29$$

$$A = 63 \text{ ft}^2$$

$$\Delta T = 95 - 78 = 17^\circ F$$

insulation

$$q_1 = 1.08 Q \Delta T$$

$$q_2 = .7 Q \Delta H R$$

$$q_1 = 1.08(583)(17)$$

$$q_2 = .7(583)(257.1 - 140)$$

$$q_1 = 10,710 \text{ Btu/h}$$

$$q_2 = 45,340 \text{ Btu/h}$$

$$q_1 + q_2 = 56,050 \text{ Btu/h}$$

conduction

$$q = U A \Delta T$$

$$q = .29(63)(17)$$

$$q = 310 \text{ Btu/h}$$

$$q_{\text{total}} = 56,050 + 310 = \underline{\underline{56,360 \text{ Btu/h}}}$$

Prepared By: Isl M. Lander / 9/15/57

Date

SAFETY RELATED  
DESIGN ANALYSIS  
 Sheet 13 of 51

f. Lighting

$4W/5ft^2$  average  
 $A = 30(4) + 30(23) = 1920$

$4(1920) = 7680 W$

$g = W(3.4)(12)$  (Trans book, p. 31)

$g = 7680(3.4)(12)$

$g = 31,335 Btu/h$

g. People

assume 5 people maximum

$g_s = 5(240) = 1200 Btu/h$  (Trans Handbook)

$g_L = 5(510) = 2550$   
 $3750 Btu/h$

$5 cfm/person = 25 cfm$

25 cfm

$g_s = 108(25)(17)$

$g_s = 460 Btu/h$

$g_L = .7(25)(111)$

$g_L = 1950 Btu/h$

$g_s + g_L = 2410 Btu/h$

$g_{total} = 3750 + 2410 = 6160 Btu/h$

h. Battery Room Ventilation

100 cfm

$Q = 100 cfm$

$g_s = 108(100)(17)$

$g_s = 1840 Btu/h$

$g_L = .7(100)(111)$

$g_L = 7800 Btu/h$

$g_s + g_L = 9640 Btu/h$

Prepared By: Isl [Signature] 9/15/82  
 Date

SAFETY RELATED  
DESIGN ANALYSIS  
 Sheet 14 of 51 -

2. Auxiliary Electric Room

a. Equipment

$$206W = 20 \times 10^3 W (3.4121) = 68240 \text{ Btu/h}$$

b. Walls

conduction

$$U = .082, \Delta T = 95 - 70 = 25$$

$$A = 2(13 \times 40) + 2(13 \times 30) = 1846 \text{ ft}^2$$

$$q = U A \Delta T$$

$$q = .082 (1846) (25)$$

$$q = 3790 \text{ Btu/h}$$

slab gain

$R_N = 13(30) = 260 \text{ ft}^2$	$T_{DN} = 10$
$R_S = R_N = 260 \text{ ft}^2$	$T_{DS} = 27$
$R_E = 13(40) = 520 \text{ ft}^2$	$T_{DE} = 20$
$R_W = R_E = 520 \text{ ft}^2$	$T_{DW} = 16$

$$q_N = .082 (260) (10)$$

$$q_N = 215 \text{ Btu/h}$$

$$q_E = .082 (520) (20)$$

$$q_E = 855 \text{ Btu/h}$$

$$q_S = .082 (260) (27)$$

$$q_S = 580 \text{ Btu/h}$$

$$q_W = .082 (520) (16)$$

$$q_W = 685 \text{ Btu/h}$$

$$q_N + q_S + q_E + q_W = 215 + 580 + 855 + 685 = \underline{2335 \text{ Btu/h}}$$

$$\therefore q_{total} = 3790 + 2335 = \underline{6125 \text{ Btu/h}}$$

Prepared By: 1st [Signature] 9/5/82  
 Date

SAFETY RELATED  
DESIGN ANALYSIS  
 Sheet 15 of 51

c. Floor

$$\Delta T = 78 - 70 = 8^\circ F \quad U = .44, \quad A = 1230$$

$$q = UA\Delta T$$

$$q = .44(1230)(8)$$

$$q = 4330 \text{ Btu/h}$$

d. Ceilings

$$\Delta T = 78 - 70 = 8, \quad U = .44, \quad A = 1230$$

$$q = 4330 \text{ Btu/h}$$

e. Doors,  $\theta = 583252, \Delta T = 25$

$$q_1 = 108(583)(25) \quad q_2 = .7(583)(25)(1-1107)$$

$$q_3 = 15,745 \text{ Btu/h} \quad q_4 = 59,745 \text{ Btu/h}$$

$$q_1 + q_2 = 75,492 \text{ Btu/h}$$

Conduction

$$q = .29(583)(25) = 460 \text{ Btu/h}$$

$$\therefore q_{\text{total}} = 75,950 \text{ Btu/h}$$

f. Lighting

$$A = 4(1230) = 1230 \text{ ft}^2, \quad 4 \text{ W/ft}^2$$

$$4(1230) = 4920 \text{ W}$$

$$q = W(3.4)(12)$$

$$q = 4920(3.4)(12)$$

$$q = 20,075 \text{ Btu/h}$$

g. People

This room will not be permanently occupied, therefore  $q = 0$ .

Prepared By: 1st Lt. J. Lombard 9/15/92  
 Date

SAFETY RELATED  
DESIGN ANALYSIS  
 Sheet 16 of 51

3. Office and Equipment Room

a. Equipment

$$10 kW = 10 \times 10^3 W (3.4121) = 34,125 \text{ Btu/h}$$

b. Walls

Conduction

$$A = 2(11.5 \times 4) + 2(11.5 \times 30) = 1835 \text{ ft}^2$$

$$U = .082, \Delta T = 95 - 78 = 170^\circ F$$

$$q = U A \Delta T$$

$$q = .082(1835)(17)$$

$$q = 2280 \text{ Btu/h}$$

Solar gain

$$R_N = 11.5(30) = 345 \text{ ft}^2$$

$$TD_N = 10$$

$$R_S = R_N = 345 \text{ ft}^2$$

$$TD_S = 27$$

$$R_E = 11.5(4) = 472 \text{ ft}^2$$

$$TD_E = 20$$

$$R_W = R_E = 472 \text{ ft}^2$$

$$TD_W = 16$$

$$q_N = .082(345)(10)$$

$$q_E = .082(472)(20)$$

$$q_N = 285 \text{ Btu/h}$$

$$q_E = 775 \text{ Btu/h}$$

$$q_S = .082(345)(27)$$

$$q_W = .082(472)(16)$$

$$q_S = 765 \text{ Btu/h}$$

$$q_W = 620 \text{ Btu/h}$$

$$q_{\text{total}} = q_N + q_E + q_S + q_W = 285 + 765 + 775 + 620 = 2445 \text{ Btu/h}$$

$$q_{\text{total}} = 2280 + 2445 = \underline{4725 \text{ Btu/h}}$$

Prepared By: 1st T. Lowland 7/15/82  
 Date

SAFETY RELATED  
DESIGN ANALYSIS  
 Sheet 17 of 51

C. Floor

$\Delta T = 70 - 78 = -8^\circ F$ ,  $U = .44$ ,  $A = 1230$   
 $q = U \Delta T$   
 $q = .44(1230)(-8)$   
 $q = -4330 \text{ Btu/h}$

d. Ceilings

$\Delta T = 0$ ,  $q = 0$

e. Doors

1 single door  
 $A = 215 \text{ ft}^2$ ,  $p = 20 \text{ ft}$ ,  $Q = 11(20) = 220 \text{ cfm}$ ,  $U = .29$ ,  $\Delta T = 17$ ,  $\Delta \text{HR} = 111.1$   
 infiltration

$q_s = 1.08 Q \Delta T$	$q_L = .76 Q \Delta T$
$q_s = 1.08(220)(17)$	$q_L = .76(220)(111.1)$
$q_s = 4040 \text{ Btu/h}$	$q_L = 17,110 \text{ Btu/h}$
$q_s + q_L = 21,150 \text{ Btu/h}$	

Conduction

$q = U \Delta T$   
 $q = .29(21)(17)$   
 $q = 105 \text{ Btu/h}$

$q_{\text{total}} = 105 + 21,150 = \underline{21,255 \text{ Btu/h}}$

S. Lighting

same as Auxiliary Electric Room  
 $q = 20,075 \text{ Btu/h}$

Prepared By: 1st [Signature] 9/15/82  
 Date

SAFETY RELATED  
DESIGN ANALYSIS  
 Sheet 18 of 57

g. People

10 max (OSSIC only)

$$g_s = 10(240) = 2400$$

$$g_L = 10(510) = 5100$$

$$7500 \text{ Btu/h}$$

5 CSF/person = 100 CSF

$g_s = 1050 \text{ BT}$	$g_L = .7 \text{ BONE}$
$g_s = 109000(17)$	$g_L = .7(100)(1111)$
$g_s = 1840 \text{ Btu/h}$	$g_L = 7780 \text{ Btu/h}$

$$g_{\text{total}} = 7500 + 1840 + 7780$$

$$g_{\text{total}} = \underline{17,120 \text{ Btu/h}}$$

4. Training Room

a. Equipment

10 kW (simulator estimated load), same as OSSIC + Equipment Room

$$g = 34,125 \text{ Btu/h}$$

b. Walls

conduction

$$A = 2(17.5 \times 41) + 2(17.5 \times 30) = 2485 \text{ ft}^2$$

$$U = .082, \text{ } \Delta T = 17$$

$$g = UA \Delta T$$

$$g = .082(2485)(17)$$

$$g = 3465 \text{ Btu/h}$$

Prepared By: 1st P. Lombard 9/15/82  
 Date



SAFETY RELATED  
DESIGN ANALYSIS  
 Sheet 19 of 51 -

Solar gain,  $U = 0.82$

$R_N = 17.5(30) = 525 \text{ ft}^2$	$T_{DN} = 10$
$R_S = R_N = 525 \text{ ft}^2$	$T_{DS} = 27$
$R_E = 17.5(4) = 720 \text{ ft}^2$	$T_{DE} = 20$
$R_W = R_E = 720 \text{ ft}^2$	$T_{DW} = 16$

$q_N = 0.82(525)(10)$

$q_N = 435 \text{ Btu/h}$

$q_S = 0.82(525)(27)$

$q_S = 1165 \text{ Btu/h}$

$q_E = 0.82(720)(20)$

$q_E = 1185 \text{ Btu/h}$

$q_W = 0.82(720)(16)$

$q_W = 945 \text{ Btu/h}$

$q_S + q_N + q_E + q_W = 1165 + 435 + 1185 + 945 = 3730 \text{ Btu/h}$

$q_{\text{total}} = 3465 + 3730 = \underline{7195 \text{ Btu/h}}$

Prepared By: 1st [Signature] 9/25/82  
 Date

SAFETY RELATED  
DESIGN ANALYSIS  
 Sheet 20 of 51

C. Floor  
 $\sigma T = 0, g = 0$

d. Ceilings  
 $\sigma T = 17, U = .032, V = 1230$   
 $g = U \rho \sigma T$   
 $g = .032(1230)(17)$   
 $g = 670 \text{ Btu/h}$

e. Doors  
 same as 480V Room  
 $g = 56,360 \text{ Btu/h}$

f. Lighting  
 same as Auxiliary Electric Room  
 $g = 20,075 \text{ Btu/h}$

g. People  
 25 max  
 $q_c = 25(240) = 6000$   
 $q_r = 25(510) = 12,750$   
 $q_{pr} = 18,750 \text{ Btu/h}$

5 csa/person = 125 csa  
 $q_s = 1.05(125)(17) \quad q_{lc} = .7(125)(11.1)$   
 $q_s = 2295 \text{ Btu/h} \quad q_{lc} = 9,725 \text{ Btu/h}$   
 $q_s + q_{lc} = 2295 + 9725 = 12,020 \text{ Btu/h}$

$g_{\text{total}} = 12,020 + 18,750 = 30,770 \text{ Btu/h}$

Prepared By: 1st M. J. [Signature] 9/15/82  
 Date

SAFETY RELATED  
DESIGN ANALYSIS  
Sheet 21 of 51

VI Summary of Cooling Load Calculations

1. 480 V Room

Equipment	153,450 Btu/h
Walls	8,300
Floor	8,160
Ceiling	-4,330
Doors	56,360
Lighting	31,335
People	6,180
Ventilation - Battery Room	9,640
	<u>269,075 Btu/h</u>

2. Auxiliary Electric Room

Equipment	68,240 Btu/h
Walls	6,125
Floor	4,330
Ceiling	4,330
Doors	75,950
Lighting	20,075
People	0
Total	<u>179,050 Btu/h</u> (no to be supplied by computer room units)

Prepared By: 1st [Signature] 9/15/82  
Date

SAFETY RELATED  
DESIGN ANALYSIS  
Sheet 22 of 51

3. Office and Equipment Room

Equipment	34,125	Bruh
Walls	4,725	
Floor	-4,330	
Ceiling	0	
Doors	21,255	
Lighting	20,075	
People	17,120	
Total	92,970	Bruh

4. Training Room

Equipment	34,125	Bruh
Walls	7195	
Floor	0	
Ceiling	670	
Doors	58,360	
Lighting	20,075	
People	30,770	
Total	149,195	Bruh

Total Cooling Load 690,290 Bruh, of this load, 179,050 Bruh

(14.8 tons) is to be supplied by the computer room HVAC system, and the remainder, 511,240 Bruh (42.6 tons) will be supplied by the rooftop HVAC unit.

Prepared By: 1st Lt. J. J. Hall 9/15/82  
Date

SAFETY RELATED DESIGN ANALYSIS  
 Sheet 23 of 51

VII Room air flow requirements

$$\Delta T = \frac{q}{108G} \therefore G = \frac{q}{108\Delta T}$$

A. 480V Room,  $\Delta T = 23$   
 $q = 269,075 \text{ Btu/h}$

$$G = \frac{269,075}{108(23)} = 10,832 \text{ CFM}$$

(11,955 used to allow for expansion and error)

B. Auxiliary Electrical Room  
 $q = 179,050 \text{ Btu/h}, \Delta T = 20$

$$G = \frac{179,050}{108(20)} = 8290 \text{ CFM}$$

(8290 CFM will be delivered by each unit for redundancy)

C. Office and Equipment Room  
 $q = 92,970 \text{ Btu/h}, \Delta T = 23$

$$G = \frac{92,970}{108(23)} = 3750 \text{ CFM}$$

(4000 CFM used for expansion and error)

D. Training Room  
 $q = 149,150 \text{ Btu/h}, \Delta T = 23$

$$G = \frac{149,150}{108(23)} = 6000 \text{ CFM}$$

(6000 CFM used due to for that load was included for simulation)

Total for rooftop unit = 20,450 CFM, unit will supply 22,000 CFM to allow for expansion and error.

Total for computer room units 16,580 CFM for both.

Prepared By: 1st [Signature]  
 Date

SAFETY RELATED DESIGN ANALYSIS  
Sheet 24 of 51

VIII Unit Fan Sizing

A. RooStop

Supply - From computer run data for supply system, static pressure loss through duct is 2.12" not including RooStop unit and roof curb losses.

Return - 55 ft of duct @ 1"/100ft. .06"  
Single elbow .12"  
double elbow .34"  
insulated duct, .6"/100ft @ 40ft = .24"  
total = .76"

RooStop unit roof curb losses are approximately .12" for both supply and return, therefore required fan capacities are:

Supply  $2.12 + .12 = 2.24"$   
Return  $.76 + .12 = .88"$

B. Computer Room

static pressure loss through the raised computer room floor is assumed to be constant at .5" (From floor vendor data)

Prepared By: 1st W. Lambert 9/15/82  
Date

SAFETY RELATED  
DESIGN ANALYSIS  
Sheet 25 of 51

IX HVAC Final Design Considerations

In order to insure complete redundancy in the computer rooms, there will be one HVAC unit on each side and each unit will be sized to supply the total cooling for both sides should one unit fail completely. There will be an emergency damper installed under the raised floor to direct airflow from one side to the other should this situation arise.

The supply air system is of the variable air volume type which modulates the airflow to each zone as needed to keep up with load demand. Airflow control boxes in the training room and office area will be supplied with electric reheat coils to insure comfort during the winter months. All other areas will be supplied with cooling only control boxes due to the fact that cooling loads in these areas far surpass heating loads throughout the year. Supply system ductwork was designed using the Trane Company supply duct design computer program, a copy of which is included as part of this blue package. Supply duct system will be supplied and installed as detailed in specification 75-5-02 and as shown on drawings M-435 and M-436.

The return duct system was designed using a Trane Ductulator, and will be made of rectangular duct. Return system will be supplied and installed per specification 75-5-02 and drawings M-435 and M-436. A constant friction loss of .1" / 100ft. duct was used for the return duct sizing.

Prepared By: 1st [Signature]  
Date

SAFETY RELATED  
DESIGN ANALYSIS  
Sheet 26 of 51

HVAC equipment will be supplied and installed as detailed in spec. 75-5-02 and as shown on drawings M-437. The rooftop HVAC unit will supply 511,240 Btuh which translates to a 42.3 ton capacity, therefore a 50 ton unit will be used. (45 ton units are not generally available, especially with a variable air delivery system). All HVAC electrical work will be done per GM-1462 and section 1800 of spec. 75-5-02.

HVAC in the computer rooms will be supplied by two units, one on each side, to be supplied and installed per spec. 75-5-02. Each computer room unit shall have the capability of supplying the cooling load for the entire floor, or 179,050 Btuh (14.9 tons). Two 15 ton units will be used for this floor. Each will be connected to a separate condenser to maintain redundancy. Condenser units will be mounted on the roof of the building.

All HVAC installations will comply with the UniSpec Mechanical Code, 1979 Edition, and spec. 75-5-02.

Supply water piping will be routed to the computer room HVAC units per spec. 75-5-02 and drawings M-437 and B-445. Drain and vent lines will be run per the same spec. and drawings. Drain line from the computer room floor drains was routed to drain through the wall of the new building per Ed Nick's instructions. Piping installation will comply with the UniSpec Plumbing Code, '78 Edition.

Prepared By: 1st Mark J. Fabel 9/16/82  
Date



SAFETY RELATED DESIGN ANALYSIS  
 Sheet 27 of 51

Re-energization piping from the computer room HVAC units to the rooftop condensing units will be installed per spec. 75-J-02, drawing 47-437, and Uniform Mechanical Code, 1979 Edition requirements.

X. Hanger Design - Seismic

Hangers for horizontal duct runs must be designed to withstand a vertical seismic loading so as not to fall on safety related equipment. There will not be any safety related equipment above the equipment room at El. 4824'0", so hangers will be analyzed at this elevation as a worst case to make sure spans, supports and bolting as called out in 75-J-02 will be sufficient.

HVAC hangers will be just below El. 4835'6", so the vertical seismic acceleration at this elevation will be used and is equal to 1.1g. It is assumed that, due to their configuration, hangers will not support loading in the horizontal direction, therefore they will only be checked for strength in the vertical direction. Equations from "Mechanical Engineering Design" by Shigley, acceleration and static coefficient from Snee and Websters 3RCA design calculations.

A. Rectangular Duct


1. 22" x 13" duct

6 Sp/5105 run, 26 gauge, .75 lb/Sp<sup>2</sup>

W = 4.5 lb/5105 run = distributed load

Prepared By: ISL [Signature] 9/11/82  
 Date

SAFETY RELATED DESIGN ANALYSIS  
 Sheet 28 of 51



a. Vertical Loading

$$w = 4.5 \text{ lb/ft}, \text{ span} = 6 \text{ ft} = l$$

$$R_v = \frac{w \cdot l}{2} = \frac{(4.5)(6)}{2} = 13.5 \text{ lb} = \text{vertical reaction}$$

seismic loading,  $R_s = R_v (S.C.)$

$a_v$  = dead weight acceleration plus given seismic acceleration  
 $a_v = 1.0 + 1.1 = 2.1g$ , S.C. = 1.5 (static coefficient)

$$R_s = (13.5)(2.1)(1.5) = 42.5 \text{ lb} = \text{seismic reaction}$$

$$\sigma = 20,000 \text{ psi} \quad d = ?$$

$$A_b = \frac{R_s}{\sigma} = \frac{42.5 \text{ lb}}{20,000 \text{ psi}} = .0021 \text{ in}^2 = \text{bolt area}$$

$\sigma$  = conservative allowable steel stress

$$d = .052 \text{ in} = \text{bolt diameter}$$

w. 11 use  $d = .375$ ", safety factor = 7.2

Maximum Moment =  $M_{max}$  will be at  $x = l/2$ ,  $F = 2R_s$ .

$$M_{max} = \frac{F \cdot l}{2} = \frac{2R_s(l/2)}{2} = \frac{R_s \cdot l}{2} = \frac{(42.5)(6)}{2} = 42.5 \text{ ft-lb}$$

$$\text{section modulus } Z = \frac{M_{max}}{\sigma} = \frac{42.5 \text{ ft-lb} (12 \text{ in/ft})}{20,000 \text{ lb/in}^2} = .0255 \text{ in}^3$$

Z for 1" x 1/4" angle (as called out in spec. 75J-02)

is .05, so safety factor is 2.0


2. 28" x 18" duct

27 lb/ft run, 20 ga., 1.25 lb/ft<sup>2</sup>

5.8 lb/ft run, span = 6 ft

$$R_v = \frac{w \cdot l}{2} = \frac{(5.8)(6)}{2} = 17.4 \text{ lb}$$

$$R_s = 17.4(2.1)(1.5) = 54.8 \text{ lb}$$



Prepared By: 1st Lt. [Signature] Date 9/15/80

SAFETY RELATED DESIGN ANALYSIS

Sheet 29 of 51

$\sigma = 20,000$

$R_b = \frac{R_s}{\sigma} = \frac{54.8}{20,000} = .0027 \text{ in}^2$       $A = \pi r^2$       $R = \sqrt{\frac{A}{\pi}}$       $\therefore d = 2\sqrt{\frac{A}{\pi}}$

$\therefore d = .059 \text{ in}$

will use  $d = .575"$ ,  $\therefore$  Safety Factor = 6.4

$M_{max} = \frac{R_v L}{2} = \frac{(54.8)(2.0)}{2} = 54.8 \text{ ft}\cdot\text{lb}$

$Z_{req} = \frac{(54.8)(12)}{20,000} = .041 \text{ in}^3$

$\therefore$  safety factor = 1.2

3. 22" x 8" duct

6.75 ft/s air, .75 1/s<sup>2</sup>, 26 ft, 1.6

$W = 5.0 \text{ 1/s}^2 \text{ air}$

$R_v = \frac{WL}{2} = \frac{(5.0)(8)}{2} = 15.0 \text{ lb}$

$R_s = (15)(2.0)(15) = 47.3 \text{ lb}$


$R_b = \frac{47.3}{20,000} = .0024 \text{ in}^2$       $d = .055 \text{ in}$

$\therefore$  bolt safety factor = 6.8

$M_{max} = \frac{47.3(2)}{2} = 47.3 \text{ ft}\cdot\text{lb}$


$Z_{max} = \frac{47.3(12)}{20,000} = .028 \text{ in}^3$

$\therefore$  angle iron safety factor = 1.8



SAFETY RELATED DESIGN ANALYSIS  
 Sheet 30 of 51

B. Round Duct



1. 24" round duct and smaller  
 span = 8 ft, 7.8 1/5 ft run, 24 ft.  
 $W = 7.8 \frac{1}{5} \text{ ft run}$

$$R_v = \frac{7.8(9)}{2} = 35.2 \text{ lb}$$

$$R_s = 35.2(2.1)(1.5) = 98.3 \text{ lb}$$

$$A_b = \frac{98.3}{20,000} = .0049 \text{ in}^2; d_s = .079 \text{ in}$$

$\therefore$  bolt safety factor = 4.7

$$R_s = 98.3$$

Strap max. load = 280

$\therefore$  strap safety factor = 2.6

2. 28" round duct, 24 ft., 1 = 6 ft

$$W = 8.5 \frac{1}{5} \text{ ft run}$$

$$R_v = \frac{W L}{2} = \frac{(8.5)(6)}{2} = 25.5 \text{ lb}$$

$$R_s = (25.5)(2.1)(1.5) = 80.3 \text{ lb}$$

$$A_b = \frac{80.3}{20,000} = .0040 \text{ in}^2; d = .071 \text{ in}$$

$\therefore$  bolt safety factor = 5.3

Prepared By: 1st [Signature] Date 9/16/82

SAFETY RELATED DESIGN ANALYSIS

Sheet 31 of 51

allowing slip load = 260 lb.

∴ strap safety factor = 3.2

All horizontal duct run hangers are sufficient to sustain vertical seismic loading. It is assumed that all vertical duct runs will remain within the penetration boundaries after hanger failure, and will not cause a problem as far as damage to safety related equipment is concerned. All vertical and horizontal duct hangers as called out in spec. 75-5-02, are designed to SMACNA Standards, 1976 Edition, with extra safety factors included. It is assumed that any failure of a vertical duct hanger will not cause a problem with safety related equipment due to the fact that duct will be contained within the duct floor penetration boundaries.

XI Fire Protection System

The fire protection system per the BRCA will be designed and installed as called out in spec. 75-5-02 per NFPA Standard 120 and UL requirements. The Contractor was supplied with room volumes and required Halon concentration (5% within 10 sec. of detection for 20 min soaking time or not less than 5% concentration with a 50% reserve charge) for all areas to be protected. The Contractor (or Subcontractor) will then design and install a Halon system to meet the criteria of spec. 75-5-02. The concentration and soaking time specified should be more than sufficient to put out the average deep seated fire and/or provide enough response time to get a

Prepared By: /s/ [Signature] 9/8/82  
Date



PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
DESIGN ANALYSIS

CN 1461D  
BY M. Lombard  
PAGE B-32.1D

Form 344-22-4062

- ELECTRICAL
- MECHANICAL
- STRUCTURAL
- SAFETY RELATED
- NON-SAFETY RELATED

The use of beam clamps for attachment of the 3/4" rod for HVAC horizontal duct run hangers to the building is allowed per this CN reissue. This low loading attached directly to the beams will cause no structural problems. Reviewing hanger design on pages B-28 thru B-32 of the initial issue of CN-1461, it is seen that the maximum seismic load resisted by the 3/4" rod is 98.3 lb. Using beam clamps rated at 300 pound minimum load, this yields a minimum safety factor of 3.1, and is considered acceptable for this application. The 300 pound minimum rating for the beam clamps will be added to spec. 75-J-02 by this reissue, along with the allowance to use the beam clamps themselves.

PREPARED BY [Signature] 8/21/85  
SIGNATURE DATE

SAFETY RELATED DESIGN ANALYSIS  
Sheet 32 of 51.

Fire fighting crew into the area. All design is subject to PSC approval.

Fire dampers are to be installed everywhere that ductwork penetrates a wall or floor, and shall be of 3/4 in. fire rated construction. Closure control shall be by a link that will close manually by a local push button, by a 165°F thermal fire link, or by an electrically actuated solenoid. This will enable the fire detection system to close all necessary dampers to seal against Helon leakage in a discharge area.

Electrical portion of the fire detection and Helon discharge control system will be done per CN 1462 and Section 16000 of spec 75-5-02.

Proto-Power Management Corp. has performed a fire hazards analysis for Building 10 and found the fire protection to be in compliance with Branch Technical Position 9.5-1, and is included as pages B-55A thru B-69B. Also see p. B-70B.

XII Plumbing Work

XIII plumbing work for this CN is for the computer room HVAC units and will be done per the 75-5-02 specification guidelines.

Added by  
CN-1461A

Verification of seismic hangers for copper pipe:

2" line, W=216/ft, Rv=2016 (10 str. spacings)

$$R_s = 20(1.5 \times 2.1) = 6316$$

$$A_b = \frac{63}{20,000} = .00315 \text{ in}^2$$

$$d_b = \sqrt{\frac{2(.00315)}{\pi}} = .065 \text{ in} \text{ will use } d = .25 \text{ in}$$

∴ Safety Factor 3.97, piping hangers o.k.

Prepared By: /s/ [Signature] 9/15/82  
Date

PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
NUCLEAR PROJECT DEPARTMENT

SAFETY RELATED DESIGN ANALYSIS  
*Sheet 321 of 51*

Electrical   
Mechanical   
Structural

I. Seismic Analysis:

*All hangers See horizontal duct runs were checked to verify that they could sustain a vertical seismic load. See p. B-28 thru B-32.*

II. Stress Analysis:

*This was done by Stone & Webster.  
See CN-1460.*

III. Piping/Hanger Analysis:

*See p. B-28 thru B-32 See hanger analysis.*

IV. Hydraulic/Pneumatic Analysis:

*For duct system design, see p. B-24 thru B-26  
and p. B-34 thru B-52.*



SAFETY RELATED DESIGN ANALYSIS (continued)

Sheet 77.2 of 51

V. Thermal Analysis:

N/A

VI. Nuclear Analysis:

N/A

VII. Fire Protection Analysis:

See p. B-37, B-53 and spec. 75-J-2.2.

A fire hazards analysis was performed by Proto-Power, Corp. to review the fire protection for Building 10 per Branch Technical Position 95-1 and sound the proposed system to be in compliance

VIII. Environmental Analysis:

See pages B-55A thru B-69A.  
Also see p. B-70A for discussion of the analysis.

N/A

Added by CN-1461A

IX. Compatibility of Materials, Equipment and Processes:

N/A

SAFETY RELATED  
DESIGN ANALYSIS  
 Sheet 23 of 51

This analysis will calculate the airflow requirements for room 103 of the walkway structure. Only conduction will be considered due to the configuration of this room and the fact that the sun will never be able to shine directly onto the walls of the room. (The HVAC for this room will be supplied by the main building 10 Roo Drop unit.)

Added by CN-1461A

HVAC Loads:

1. Heating

A. Walls  $A = 2(10 \times 16.5) + 2(14 \times 16.5) = 800 \text{ ft}^2$   
 $\Delta T = 70 - 6.5 = 75$   $U = .105$  (3" insulation only)  
 $q = UA\Delta T = .105(800)(75)$   
 $q = 6300 \text{ Btu/h}$

B. Floor  $U = .44$  (8" concrete)  $\Delta T = 75$  (worst case)  $A = 10(14) = 140 \text{ ft}^2$   
 $q = .44(140)(75)$   
 $q = 4620 \text{ Btu/h}$

C. Ceiling  $U = .31$  (12" concrete - concave side)  
 $q = .31(140)(75)$   
 $q = 3260 \text{ Btu/h}$

$q_{\text{Total}} = 14,180 \text{ Btu/h}$  for heating

$q = 14,180 \text{ Btu/h} \left( \frac{1 \text{ W}}{3.412 \text{ Btu/h}} \right) = \frac{4160 \text{ W}}{4.2 \text{ kW}}$  OR  
 supplied by duct heater.

Revised by CN-1461A

2. Cooling

A. Walls  $\Delta T = 95 - 78 = 17^\circ \text{F}$   
 $q = .105(800)(17)$   
 $q = 1430 \text{ Btu/h}$

B. Floor  
 $q = .44(140)(17)$   
 $q = 1050 \text{ Btu/h}$

C. Ceiling  
 $q = .31(140)(17) = 740 \text{ Btu/h}$

D. People, 8 max.  
 $q_s = 8(240) = 1920$   
 $q_r = 8(510) = 4080$   
 $q = 6000 \text{ Btu/h}$

$q_{\text{Total}} = 9,220 \text{ Btu/h}$  for cooling

$Q = \frac{q}{1.08 \Delta T} = \frac{9220}{1.08(20)} = 427 \text{ cfm}$   
 use 450 cfm

Prepared By: [Signature] 10/20/82  
 Date

VERILIFE AIR DISTRIBUTION SYSTEM  
PAGE 1

05/23/92 U 2000

THESE ARE NO. ABBE1 LOGIC ERROR MESSAGES.  
REMOVE TEST COMMENT AND SUBMIT FINAL RUN.

READY  
LEAF1

LEAF1 LOGGED OFF ISD AT 13.44.36 ON JUNE 23, 1992  
LAST STEP COMPLETION CODE WAS USER 000

DEVS02A.13.47.28. JERKMAN. CONNECTED.

/FC1

DEVS02 13.55.06 KELESTI COMMAND COMPLETED

ISD ISD01/1710

LEAF1 LOGON IN PROGRESS AT 13.56.51 ON JUNE 23, 1992

WELCOME TO LACROSSE TSO

USE OF THESE FACILITIES IS LIMITED TO TRANE APPROVED ACTIVITY

WELCOME/IGNET OPERATORS NOTE

YOU MUST UNDERSTAND THE "TEST" PROCEDURE PAGE 4 POINT 6 AND PAGE

UNDERSTAND THESE POINTS, CALL JOHN WALTON. YOU ARE BILLED \$25 FOR  
NON-TEST INHS. NO CREDITS WILL BE GIVEN FROM LA CROSSE FOR YOUR  
ERRORS IN MAKING PRODUCTION RUNS WHEN YOU REALLY WANTED TO MAKE A  
TEST RUN.

CH 146  
BY *CB Land*  
PAGE 8-35  
FORM NO. 872-30-2650

IMPORTANT:

IF THE SALES ENGINEER DESIRES HELP IN OPTIMIZING THE DUCT SYSTEM  
AFTER THE INITIAL RUN IS MADE, CALL JOHN WALTON AT 787-3729.  
RELAY INFORMATION CONCERNING OVERSIZING VAV BOXES, RELAXING SPACE  
LIMITATIONS, LOWERING STATIC PRESSURES, ETC., THIS CAN BE A GREAT  
SELLING OPPORTUNITY BUT IT DOES MEAN AN ADDITIONAL \$25.00 RUN.

JOB TSDUR(TSD04197) EXECUTING

JOB TSDURV(JOB05217) ON OUTPUT QUEUE

JOB TSDVRT(JOB05240) ON OUTPUT QUEUE

JOB TSDVEY(JOB05485) ON OUTPUT QUEUE

JOB TSDVRT(JOB06741) ON OUTPUT QUEUE

JOB TSDVRT(JOB06972) ON OUTPUT QUEUE

JOB TSDVRT(JOB08435) ON OUTPUT QUEUE

READY

var:trng public,data

JOB TSDVRG SUBMITTED

READY

14.00.20 JOB 7014 IHAST165 TSDVRG ENDED AT LACROSSE CN(00)

30812008 Tsdvrg

(job07014) keep hold



CN 44  
BY *[Signature]*  
PAGE 8-37  
FORM NO. 875-50-2550

Blank lined page with horizontal ruling lines and a vertical margin line on the left side.



THE SOLE LIABILITY OF THE TRENE COMPANY IN FURNISHING THE VESTIBULE BOLT PROGRAM SHALL BE LIMITED TO  
REFUND OF THE PURCHASE PRICE OF THE PROGRAM SHOULD THERE BE ANY ERROR IN PROGRAM LOGS.

THE WARRANTIES AND LIABILITIES SET FORTH IN THE PRIOR PARAGRAPH IS IN LIEU OF ALL OTHER WARRANTIES AND  
LIABILITIES, WHETHER IN CONTRACT OR IN NEGLIGENCE, EXPRESS OR IMPLIED, IN LAW OR IN FACT, INCLUDING  
IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE IN NO EVENT SHALL THE  
TRENE COMPANY BE LIABLE FOR ANY INCIDENTAL OR CONSEQUENTIAL DAMAGES.



.....  
.....  
.....

.....  
.....  
.....

.....  
.....  
.....

.....  
.....  
.....

.....  
.....  
.....

.....  
.....  
.....

.....  
.....  
.....

.....  
.....  
.....

.....  
.....  
.....

.....  
.....  
.....

.....  
.....  
.....

.....  
.....  
.....

.....  
.....  
.....

.....  
.....  
.....





FAEE

2020

SPES AND STONOSTIC MESSAGES

UNIT CHARACTERISTICS WARD ON JUNE 1959 CONTAINS

FOR THE STUND UNIT TO BE ACESIBATE THE PROGRAM ASSUMES A 90-DEGREE

ATTENUATED ELONG TESTS BETWEEN THE PAM AND THE PERSY-REMOITY

OPERATIONS WOULD ON NO GUT HEAT PLEEF





UNIT	WEIGHT	LENGTH	DIAMETER	MARKING	DATE
1	5000	11.00	25	RESERVED	AC TUM
2	2000	15.00	25	RESERVED	RESERVED
3	4200	15.00	25	RESERVED	RESERVED
4	4200	17.00	25	RESERVED	RESERVED
5	2500	20.00	25	RESERVED	RESERVED
6	2500	20.00	25	RESERVED	RESERVED
7	2500	20.00	25	RESERVED	RESERVED
8	2500	20.00	25	RESERVED	RESERVED
9	1465	12.00	25	RESERVED	RESERVED
10	4200	20.00	25	RESERVED	RESERVED
11	4200	20.00	25	RESERVED	RESERVED
12	5000	11.00	25	RESERVED	RESERVED
13	5000	11.00	25	RESERVED	RESERVED





CN 1461

BY *Z. Campbell*

PAGE 8-18

FORM NO. 373-20-2850

NOTE THE DUCT WEIGHTS LISTED ARE NOT INCLUSIVE OF WASTE FACTOR

BASED ON THE WEIGHTS LISTED IN THE RECOMMENDATIONS

CHECK FOR THE WEIGHT LISTED AGAINST ACTUAL WEIGHT MEASUREMENT

FEET OF INSULATED TRUNK DUCTS

QUANTITY OF INSULATION IN TRUNK DUCTS

TRUNK CONNECTION MATERIAL SUMMARY

TRUNK JOINTS

FEET OF

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

INSULATION

PAGE 8

1-20-50

TRANSITION STATE SUMMARY

DEGREE

NUMBER

DIAMETER

500

100

100

100



WIREFRAME AIR-DISTRIBUTION-SYSTEM.....PAGE 8

INDEX.....

HIGHLIGHT MATERIALS-SUMMARY

HIGHLIGHT.....PAGE 9

INDEX.....PAGE 10

INDEX.....PAGE 12

INDEX.....PAGE 14

INDEX.....PAGE 16

INDEX.....PAGE 18

INDEX.....PAGE 20

INDEX.....PAGE 22

INDEX.....PAGE 24

INDEX.....PAGE 26

INDEX.....PAGE 28

INDEX.....PAGE 30

TOTAL

..... 500 ..... 1,200 ..... 2,000 ..... 3,500 ..... 4,000 ..... 5,000

WATER

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

WATER

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

ELECTRIC COIL MATERIAL SUMMARY

..... 400 ..... 1,200 ..... 2,000 ..... 3,000 ..... 4,000 ..... 5,000

NO. 6 STAGE

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

NO. 5 STAGE

..... 1,500 ..... 3,000 ..... 4,500 ..... 6,000 ..... 7,500 ..... 9,000

NO. 4 STAGE

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

CHECK VVV PREFERRED GAFALCO EBR AVAILABILITY OF DESIRED ELECTRIC COILS PER SPECIFIC NOX STAGES

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

..... 0 ..... 0 ..... 0 ..... 0 ..... 0 ..... 0

CHECK LIST OF DESIGN VERIFICATION QUESTIONS  
FOR DESIGN REVIEW METHOD

YES NO N/A

- () ( ) ( ) 1. Were the inputs correctly selected and incorporated into design?
- () ( ) ( ) 2. Are assumptions necessary to perform the design activity adequately described and reasonable? Where necessary, are the assumptions identified for subsequent re-verifications when the detailed design activities are completed?
- () ( ) ( ) 3. Are the appropriate quality and quality assurance requirements specified?
- () ( ) ( ) 4. Are the applicable codes, standards and regulatory requirements including issue and addenda properly identified and are their requirements for design met?
- () ( ) ( ) 5. Have applicable construction and operating experience been considered?
- () ( ) ( ) 6. Have the design interface requirements been satisfied?
- () ( ) ( ) 7. Was an appropriate design method used?
- () ( ) ( ) 8. Is the output reasonable compared to inputs?
- () ( ) ( ) 9. Are the specified parts, equipment, and processes suitable for the required application?
- () ( ) ( ) 10. Are the specified materials compatible with each other and the design environmental conditions to which the material will be exposed?
- () ( ) ( ) 11. Have adequate maintenance features and requirements been specified?
- () ( ) ( ) 12. Are accessibility and other design provisions adequate for performance of needed maintenance and repair?
- () ( ) ( ) 13. Has adequate accessibility been provided to perform the in-service inspection expected to be required during the plant life?
- ( ) ( ) () 14. Has the design properly considered radiation exposure to the public and plant personnel?
- () ( ) ( ) 15. Are the acceptance criteria incorporated in the design documents sufficient to allow verification that design requirements have been satisfactorily accomplished?

CHECK LIST OF DESIGN VERIFICATION QUESTIONS - Cont'd.

YES NO N/A

- ( ) ( ) (✓) 16. Have adequate pre-operational and subsequent periodic test requirements been appropriately specified?
- (✓) ( ) ( ) 17. Are adequate handling, storage, cleaning and shipping requirements specified?
- ( ) ( ) (✓) 18. Are adequate identification requirements specified?
- ( ) ( ) (✓) 19. Are requirements for record preparation review, approval, retention, etc., adequately specified?

Note: If the answer to any question is no, provide additional information and resolution below:

RESOLUTION OF DESIGN DEFICIENCIES

UNCOVERED DURING THE DESIGN VERIFICATION PROCESS

*There are no problems with the design method used in this CN.*

*M. L. Loh 9/20/82*

*M. L. Loh 12/14/82*

*M. L. Loh 4/20/83 (Reissue C)*

*M. L. Loh 8/29/83 (Reissue D)*

*M. L. Loh (reviewed changes to reissue D 9/6/83)*

*M. L. Loh (reviewed copper tubing support spacing calcs. reissue D 9/13/83)*

*Note: This analysis was performed before  
the Three Room Complex Addition was  
changed to Building 10.*

CN 1461A  
BY M. Lombard  
PAGE B-55A  
FORM NO. 372-30-2650

PROTO-POWER MANAGEMENT CORPORATION

581 POGUONNOCK ROAD  
GROTON, CONNECTICUT 06340  
(203) 448-6725

File: 7511434

November 19, 1982

Mr. J.R. Reesy  
Nuclear Design Department Manager  
Public Service Company of Colorado  
5909 East 38th Avenue  
Denver, Colorado 80207

Dear Jack:

This letter contains the results of Proto-Power Corporation's fire protection review of the Fort St. Vrain Three Room Complex Addition. This review was requested by telecon with PSC on November 3, 1982. The review was performed in accordance with Branch Technical Position 9.5-1, Appendix A and 10CFR50, Appendix R as it applies to Fort St. Vrain. The Fire Hazards Analysis performed to evaluate compliance with regulatory requirements is included as Attachment A. The Three Room Complex Addition meets the requirements of these documents except for two points: 1) separation of redundant cables; and 2) lack of emergency lighting.

1. Cables designated B1L1 and B2L2 serving inverter 1A and 1B respectively are located in both the south end ground floor room and the ground floor walkover room 101. This cable routing violates Section G of Appendix R to 10CFR50 which states "one train of systems necessary to achieve and maintain hot shutdown conditions from either the Control Room or the emergency control station(s) is free of fire damage". Furthermore, BTP 9.5-1, Appendix A (Paragraph 3.4.1.a in PSC's response to BTP 9.5-1) requires that redundant safety related systems be separated from each other so that both are not subject to damage from a single fire hazard. Based on the understanding that, as a minimum, inverter 1A or 1B is needed for plant shutdown, Proto-Power finds the presence of both B1L1 and B2L2 cables serving inverter 1A and 1B respectively in the same fire area to be in conflict with regulatory requirements. Appendix R to 10CFR50 requires that redundant cables be protected by a combination of one hour rated fire retardant (or barriers), and fire detection and suppression system. To meet these requirements, Proto-Power



Mr. J.R. Reesy

-2-

November 19, 1982

suggests wrapping one of the cable systems with a 1 hr. fire rated B&W Kaowool® blanket wrap currently being used by other utilities to meet this requirement. To meet the suppression system requirement, it could be demonstrated analytically that the in situ and transient combustibles in the two fire areas are too small (approximately 4 minutes) to be a fire hazard and therefore, don't warrant a fixed fire suppression system.

2. Fixed emergency lighting is not currently provided in the Three Room Complex Addition. BTP 9.5-1, Appendix A (Paragraph 3.4.5 in PSC's response to BTP 9.5-1) and Appendix R to 10CFR50 states that fixed emergency lighting is vital to safe shut-down and emergency response in the event of a fire. The absence of fixed emergency lighting violates regulatory requirements. Proto-Power suggests that fixed (battery pack) emergency lighting be provided for access and egress routes to and from the rooms within the Three Room Complex Addition.

Three additional points relating to fire protection are being suggested for your consideration, but are not required by either BTP 9.5-1 or Appendix R to 10CFR50.

- o The 1C battery room exhaust fan should be provided with loss-of-flow indication in the Control Room. The fire hazards analysis assumes the fan is operating to ensure that H<sub>2</sub> concentrations are maintained below 2% (by volume).
- o Pressure relief venting should be considered in the design of the Halon 1301 fire suppression systems to prevent overpressurizing the room during system discharge and, possibly destroying fire stops and door frames.
- o If redundant sets of safety related equipment are planned for the south end ground floor room and mezzanine, consideration should be given at this time for their separation which may include fire barriers (walls) and the location of detectors, fire suppression (Halon 1301) system, and ventilation ducts.

In addition, there is one item concerning channel independence that is an apparent conflict with your present PSAR commitments. Attachment B outlines our concern on this item. While this item

Mr. J.R. Reesy


-3-

November 19, 1982

appears to be a departure from your FSAR commitments, it is independent from BTP 9.5-1, Appendix A or Appendix R to 10CFR50. If you agree with our conclusion on this matter we can recommend to you alternative ways of correcting this concern.

The above information contains the results of our review of the Three Room Complex Addition to the requirements of BTP 9.5-1, Appendix A and 10CFR50, Appendix R. If you have any questions, please call me at (203) 446-9725.

Sincerely,



R.A. Schaufler  
Vice President

PDM:jmn  
Attachment

ATTACHMENT A

The Three Room Complex Addition (3RCA) has 4 floors of rooms and a mezzanine over the northern portion of the ground floor. In descending order, the floors contain a training room, equipment and office rooms, a computer room, and a ground level battery room and two converter rooms at Elev. 4791'0". The ground level rooms including the mezzanine contain safety related equipment. The equipment room (El. 4824'0") was analyzed as a safety related room because it is anticipated that safety related equipment may be installed in the future, but none has been designated at this time. All other rooms are considered non-safety related equipment areas. A two level walkover structure abuts the 3 RCA from the west wall. The walkover floors access the ground level and computer rooms. The two walkover floors designated R101 and R102 contain safety related cables and cable trays, however, no equipment is to be installed in the walkover structure. The rooms designated as safety related fire areas therefore are the three rooms on the ground level, the two walkover rooms and the equipment room at El. 4824'0". Each of these fire areas is enclosed by three hour fire rated walls.

Access doors and emergency exits separating the building's outer wall and internal fire walls are U.L. Class A fire rated steel doors. Electrical cable in trays, risers, and conduit, and ventilation ducts that penetrate the floors and walls of fire areas are equipped with fire stops and ventilation fire dampers respectively.

When evaluating the effects of the design basis fire, consideration has been given to safety related equipment which, on the basis of vertical, as well as horizontal proximity, could be involved in the fire. Similarly, any combustibles above or below the design basis fire area, and the effects of using hose water on safety related equipment in and below the design basis fire area, have also been considered.

Communication during a fire situation is maintained primarily by the station's public address (GAI-Tronic) system. The 3 RCA ventilation system provides for the removal of smoke and corrosive gasses during and following a fire situation.

Emergency lighting, as required by 10CFR50, Appendix R, and BTP 9.5-1, is not incorporated in the design of the Three Room Complex Addition, or the attached walkover structure. Appropriate action as outlined in the attached letter should be taken to ensure compliance with this guideline.

Ground Floor South, Including Mezzanine - El. 4791'0" and El. 4800'0"

Area Description

Located on the ground level are safety related instrumentation inverter 1B, one 120 volt distribution panel, one 25 KVA backup power transformer and associated cable and cable trays. Safety related cable trays, designated for bus two, loop two (B2L2) routing, are installed above the ground level section of this fire area. The mezzanine contains no safety related equipment at this time. Safety related cable trays, designated for bus one, loop one (B1L1) routing, are installed above the mezzanine. As presently designed, the location of unprotected raceways, B1L1 and B2L2 in the same fire area, is a violation of 10CFR50, Appendix R and BTP 9.5-1. Appropriate corrective action, as outlined in the attached letter, should be taken to ensure compliance with these guidelines.

Fire Area Boundary

The south end ground floor is open to the mezzanine which is over the north end ground floor and battery rooms. This area is bounded by three hour fire rated walls, that separate it from the north ground floor room which contains the other raceways necessary for safe shutdown and the 1C battery room.

Fire Load

The fire load in this area is very small consisting of small quantities of electrical cable insulation and paper waste in trash containers. The calculated fire load for this area is 4320 Btu/ft<sup>2</sup> ( $\approx$  3-1/4 min.). These combustibles are not of sufficient quantity to be considered a hazard to both of the safety related raceways that exist within this fire area.

Fire Protection Systems

Fire detection for this area is provided by an ionization type detector which alarms and annunciates in the Control Room. Primary fire suppression is provided by portable dry chemical extinguishers. Floor drains are not required as the floor mounted equipment is elevated by three inch channel, which elevates the equipment above the potential water level.

Design Basis Fire

The design basis fire assumes the complete combustion of paper waste in two fifty-five gallon drums and all the electrical cable insulation. Ignition is dependent on a transient source. As a result of the low fire load (4320 Btu/ft<sup>2</sup>), the separation of buses and the ability to achieve safe shutdown with equipment located in another separated fire area, the design basis fire will not affect the ability of the plant to achieve safe shutdown.

Ground Level North - Elev. 4791'0"

Area Description

Located in the north ground level room are safety related instrument inverters 1A and 1C, their associated distribution panels, backup power transformers, cable and cable trays. While this safety related equipment is redundant (for 2 out of 3 P.P.S. inputs), only inverter 1A or 1B, which is in the south ground floor room, is needed to obtain safe shutdown. The cable trays installed in this fire area are designated for B2L2 routing. Cabling for inverter 1C is run in conduit.

Fire Area Boundary

The fire area consists of concrete walls and ceiling that have three hour fire ratings.

Fire Load

The fire load in this area is 5360 Btu/ft<sup>2</sup> ( $\approx$  4 min.). It is attributable to the small quantity of electrical cable insulation and waste consisting of paper in trash containers.

Fire Protection System

Fire detection for this area is provided by an ionization type detector which alarms and annunciates in the Control Room. Primary fire suppression is provided by portable dry chemical extinguishers. Floor drains are not required as the floor mounted equipment is elevated by three inch channel, which elevates the equipment above the potential water level.

Design Basis Fire

The design basis fire assumes the complete combustion of the paper waste that could exist in two fifty-five gallon drums, and all the electrical cable insulation within this fire area. Ignition is dependent on a transient source. As a result of the low fire load (5360 Btu/ft<sup>2</sup>) and the ability to achieve safe shutdown with equipment located in another separated fire area, the design basis fire will not affect the ability of the plant to achieve safe shutdown.

Battery Room - Ele. 4791'0"

Area Description

The battery room contains safety related battery 1C.

### Fire Area

The fire area is enclosed in three hour rated fire walls and ceiling and utilizes Class A fire rated doors. There is an exhaust fan which vents the room atmosphere directly to the outdoors. The exhaust fan duct is equipped with a three-hour fire rated damper.

### Fire Load

The fire load in this area consists of electrical cable insulation, battery casing material, and loose paper in trash containers. The calculated fire load is 184,000 But/ft<sup>2</sup> (2.3 hrs.).

### Fire Protection Systems

Fire detection is provided by an ionization type detector which alarms and annunciates in the Control Room. Primary fire suppression is provided by portable dry chemical extinguishers.

### Design Basis Fire

The design basis fire assumes the complete combustion of the electrical cable insulation, battery casing material and paper waste in two fifty gallon drums. Ignition is dependent on a transient source. Since the battery is the only redundant safety related piece of equipment in this fire area and redundant safety related batteries are located in another separated fire area, the design basis fire will have no effect on the ability of the plant to achieve safe shutdown.

### Equipment Room - Elev. 4824'0"

#### Area Description

The equipment room is capable of containing safety related equipment but none has been designated as yet. Safety related cable trays are designated for B2L2 service. The ceilings have non-combustible one hour rated acoustical paneling suspended from them. The concrete walls have one hour fire rated non-combustible drywall coverings.

#### Fire Area Boundary

The fire area is enclosed in three hour rated fire walls and ceiling and Class A fire rated doors.

#### Fire Load

The fire load in this area is 5280 Btu/ft<sup>2</sup> (≈ 4 min.). It is based on electrical cable insulation and paper waste in trash containers.

Fire Protection System

Fire detection for this area is provided by an ionization type detector which alarms and annunciates in the Control Room. Primary fire suppression is provided by portable dry chemical extinguishers. Floor drains are not required as the floor mounted equipment is elevated by three inch channel, which elevates the equipment above the potential water level.

Design Basis Fire

The design basis fire for this area assumes the total combustion of the paper waste that could exist in two fifty-five gallon drums, and all electrical cable insulation in the fire area. Ignition is dependent on a transient source. As a result of the low fire load (5280 Btu/ft<sup>2</sup>), and the absence of any safety related equipment, the design basis fire will have no affect on the ability of the plant to achieve safe shutdown.

Walkover Room 101 - Elev. 4791'0"

Area Description

Room 101 contains safety related cable routing B1L1 as well as cable routed as B2L2 service. As presently designed, the location of unprotected raceways B1L1 and B2L2 in the same fire area is a violation of 10CFR50, Appendix R and BTP 9.5-1. Appropriate corrective action as outlined in the attached letter should be taken to ensure compliance with these guidelines.

Fire Area

The fire area is enclosed in three hour rated fire walls and ceiling and utilizes Class A fire rated doors.

Fire Load

The fire load in this area is very small consisting of small quantities of electrical cable insulation and paper waste in trash containers. The calculated fire load for this area is 10,400 Btu/ft<sup>2</sup> (8 min.). These combustibles are not of sufficient quantity to be a hazard to both of the safety related raceways that exist within this fire area.

Fire Protection System

Fire detection for this area is provided by an ionization type detector which alarms and annunciates in the Control Room. Primary fire suppression is provided by portable, dry chemical extinguishers.

### Design Basis Fire

The design basis fire assumes the complete combustion of paper waste contained in two fifty-five gallon drums, and all the electrical cable insulation within this fire area. Ignition is dependent on a transient source. As a result of the low fire load (10,400 Btu/ft<sup>2</sup>), the design basis fire will not affect the ability of the plant to achieve safe shutdown.

Walkover Room 102 - Elev. 4811'0"

### Area Description

Room 102 contains safety related cable and cable trays routed as BLL1.

### Fire Area

The fire area is enclosed in three hour rated fire walls and ceiling and utilizes Class A fire rated doors.

### Fire Load

The fire load is very small in this area and consists of small quantities of electrical cable insulation and paper waste in trash containers. The calculated fire load for this area is 9,600 Btu/ft<sup>2</sup> (7 min.).

### Fire Protection System

Fire detection for this area is provided by an ionization type detector which alarms and annunciates in the Control Room. Primary fire suppression is provided by portable, dry chemical extinguishers.

### Design Basis Fire

The design basis fire assumes complete combustion of the paper waste contained in two fifty-five gallon drums, and all the electrical cable insulation contained in the fire area. Ignition is dependent on a transient source. As a result of the low fire load (9,600 Btu/ft<sup>2</sup>) and the ability to achieve safe shutdown with system cables located in another separated fire area, the design basis fire will not affect the ability of the plant to achieve safe shutdown.



THREE ROOM COMPLEX ADDITION  
FORT ST. VRAIN

FIRE HAZARDS ANALYSIS SUMMARY

ITEM NO.	FIRE AREA LOCATION MAJOR EQUIPMENT	SAFETY RELATED	COMBUSTIBLE MATERIAL	QUANTITY	HEAT CONTENT (BTU/LB)	FIRE LOAD (BTU/FT <sup>2</sup> )	FIRE DETECTION	FIRE SUPPRESSION AVAILABLE	SEPARATION OF REDUNDANT S.R. EQUIPMENT
1	South Inverter Room Including Meszanine	Yes	Cable Insulation	3 ft <sup>3</sup>	12,000	4,320	Ionization Type	Dry Chemical	Separate Concrete Rooms & Cable Separation
2	North Inverter Room	Yes	Cable Insulation	.93 ft <sup>3</sup>	12,000	5,360			Separate Concrete Rooms & Cable Separation
3	Battery Room	Yes	Cable Insulation Battery Cell Cases	.15 ft <sup>3</sup> 12 ft <sup>3</sup>	12,000 18,000	186,000			Separate Concrete Rooms
4	South Computer Room	No	Cable Insulation	.88 ft <sup>3</sup>	12,000	6,400			
5	North Computer Room	No	Cable Insulation	.375 ft <sup>3</sup>	12,000	7,520			
6	Equipment Room	Yes	Cable Insulation	.3 ft <sup>3</sup>	12,000	5,280			No S.R. Equipment at present.
7	Office Room	No	Cable Insulation	.3 ft <sup>3</sup>	12,000	5,280			
8	Walkover Room 101	Yes	Cable Insulation	.3 ft <sup>3</sup>	12,000	10,400			Separate Concrete Room & Cable Separation
9	Walkover Room 102	Yes	Cable Insulation	.6 ft <sup>3</sup>	12,000	9,600			

ATTACHMENT B

The current design of the Three Room Complex Addition (3RCA) appears to conflict with current FSAR commitments in the specific area of the design for independence of the three logic channels. The conflict centers on the ability of a single event (i.e., a fire) to defeat the independence between the logic channels associated with Instrument Buses 1A and 1C. Specifically, the problem is the location of Inverter 1C and routing of cables associated with Inverter 1C in the same fire area as Inverter 1A and cables associated with Inverter 1A.

The bases for our concern are the FSAR commitments outlined below and as highlighted on the attached pages.

- a. Compliance with Design Criteria 20 (See Attachment B-1).
- b. Compliance with Design Criteria 21 (See Attachment B-2).
- c. Compliance with the Principles of Design outlined in Section 7.1.1.2 (See Attachments B-3 and B-4).

This apparent conflict is not an area of non-compliance with BTP 9.5-1, Appendix A or Appendix R to 10CFR50 since the remaining channel 1B can be utilized to achieve safe shutdown.

# ATTACHMENT B-1

CN 1461A  
BY M. Lombard  
PAGE B-66A  
FORM NO. 372-30-2650

FSAR UPDATE  
C.20-1

## CRITERION 20: PROTECTION SYSTEMS REDUNDANCY AND INDEPENDENCE (Category B)

"Redundancy and independence designed into protection systems shall be sufficient to assure that no single failure or removal from service of any component or channel of a system will result in loss of the protection function. The redundancy provided shall include, as a minimum, two channels of protection for each protection function to be served. Different principles shall be used where necessary to achieve true independence of redundant instrumentation components."

### DISCUSSION:

On the basis of the following information, it is concluded that Criterion 20 is satisfied.

In general, three independent sensing circuits are provided for each plant protective system input parameter. Exceptions for Loop Shutdown and Circulator trip exist as shown in Figures 7.1-1, 7.1-2, 7.1-3; however these do have two sensing circuits.

The basic logic system is two-out-of-three for the scram and steam/water dump circuitry. Independence between the three logic channels is maintained up to the final output stage where the two-out-of-three combination is made. This includes supply of power from three independent instrument power sources. The loop shutdown and circulator trip circuitry utilizes dual output stages arranged in a one-out-of-two configuration to ensure system reliability. Either output is energized to actuate the final control element(s). (The output logic should not be confused with the input sensing channels which are generally two-out-of-three as previously stated.) (Section 7.1.2.1).

Since the basic logic is two-out-of-three, or one-out-of-two for loop shutdown and circulator trip, it follows that the unsafe failure of either an input sensing channel or an entire logic channel will not result in loss of the protective function.

Features included in the design for independence are outlined in Section 7.1.1.2.

# ATTACHMENT B.2

CN 1461A

BY M. Lombard

PAGE B-67A

FORM NO. 372-30-2650

FSAR UPDATE  
C.21-1

## CRITERION 21: SINGLE FAILURE DEFINITION (Category B)

"Multiple failures resulting from a single event shall be treated as a single failure."

### DISCUSSION:

On the basis of the following information, it is concluded that Criterion 21 is satisfied.

Multiple failures resulting from a single event are treated as a single failure. Single events considered in the design for independence are outlined in Section 7.1.1.1. The environmental conditions for areas in the Fort St. Vrain plant are given in Section 7.1.1.4.

7.1.1.2

In addition the Proposed IEEE Guide to the Application of the Single Failure Criterion to Nuclear Power Plant Protection Systems, Fifth Draft, dated 9/30/68, has been used in the design of the Plant Protective System.

# ATTACHMENT B.3

CN 1461A  
BY M. Lombard  
PAGE B-68A  
FORM NO. 372-30-2650

FSAR UPDATE  
7.1-5

modules in the conducting or nonconducting mode, failure of power supplies, blockage or severance of process connections, and failures of transducers. The short circuits considered include those credible faults which affect multiple components, as may be illustrated by single inter-connecting lines on a schematic, and which may prevent system action. The basic logic system employs 2 of 3 redundancy for the sensing channels. The scram control is designed using hindrance logic, i.e., loss of power produces a scram. The accidental shutdown of both coolant loops must be avoided to provide the necessary core cooling. The associated circuitry is therefore deenergized during plant operation. Steam/water dump, loop isolation, and circulator trip circuitry are therefore designed using transmission logic, i.e., circuits are energized to produce protective action. Redundant output circuitry and final control elements are provided.

Quality of Components and Modules. The bulk of the electronics and circuitry (excluding preamplifiers when required) is located in the reactor plant protective system controlboard. A high degree of quality is maintained by rigid specifications and quality control. Components employed are of a high quality level and generally derated by at least 50%. Failure mode analysis has been made on critical circuitry. Wherever possible previously used circuitry, components, and modules have been employed minimizing the design of new circuitry. Solid-state circuitry is employed in conjunction with relays, utilizing the advantages of solid-state devices in low-level signal amplification and the advantages of relays for circuit isolation and for handling power. The procurement of all major plant systems is from reliable suppliers having previous experience in the design and construction of similar systems.

Channel Independence. In designing for channel independence, single events which are considered plausible include:

1. Shearing or blocking of process connections.
2. Rise in temperature, pressure, or humidity in the sensor, signal transmission, or readout area.
3. Vibration of process connections.
4. Severance, crushing, or shorting of wiring paths.
5. Fires in control areas.
6. Missiles.
7. Module removal.

# ATTACHMENT B.4

CN 1461A  
BY M. Lombard  
PAGE B-69A  
FORM NO. 372-30-2650

FSAR UPDATE  
7.1-6

In the design of the instrument system, the following means are employed to achieve channel independence:

1. The combining of redundant channels is made as close to the output portion of the systems as is practical. Hence, the use of the general logic scheme.
2. Channels are connected to the process system by physically separated instrument connections.
3. Redundant sensors are physically separated. For example, the neutron detectors and reactor pressure sensors are mounted in separate wells and PCRV penetrations spaced about the PCRV.
4. Wiring or cabling between redundant sensor locations and control room or control panel and on the controlboard are physically separated and mechanically protected where required.
5. Redundant power supplies are used to supply the various channels so that loss of a given power supply will not prevent system action or cause an unnecessary protective action.
6. Circuits are suitably fused and protected so that in the event of single grounds or shorts, the fault will be isolated and will not feed back into the system.
7. Circuits and components are used that, insofar as is practical, fail in a safe direction.
8. Sensor, protective apparatus, and readout components are physically located and protected to minimize possibility of accidental contact or damage. For example, the location of instruments within penetrations in the PCRV provides a considerable degree of protection from physical damage. The scram and other redundant plant protective system circuitry is located in separate vertical sections of controlboard separated by physical and thermal barriers.

Equipment Qualification. Various functional and calibration tests have been performed to ensure that the equipment is in conformance with the specification. This testing included:

1. Testing of components (such as plug-in assemblies).
2. Testing of assemblies (such as drawers or transmitters).
3. Point-to-point continuity and insulation resistance of wiring.

Accuracy drift tests on assemblies have been made.

Discussion of Fire Hazards Analysis

As per the preceding fire hazards analysis by Proto-Power Management Corp., the fire protection supplied by the planned detection and annunciation system and the installation of handheld dry chemical fire extinguishers meets the intent of Branch Technical Position 9.5-1. Therefore, per Branch Technical Position (BTP) 9.5-1, the procurement and installation of these items shall be covered by a QA program, which will bring the fire protection system into compliance with BTP 9.5-1.

In addition to the installation of the equipment discussed above, a Halon suppression system will also be installed in Building 10 in all areas except for the Training Room and the Office Area. This system is being installed for insurance purposes to provide extra protection in equipment areas of the building, and by no means is it being installed to meet BTP 9.5-1. Therefore, installation of this system will not be covered by a QA program, even though the Contractor will insure that all equipment is designed, purchased and installed per NFPA 12A and UL guidelines.

Unistrut Engineering Evaluation

The following pages contain an engineering evaluation on the use of P3300 Unistrut cast into concrete and used as a support for duct hangers and piping runs. Pages B-72D and B-73D contain the evaluation done by our Structural Dept. verifying the loading that the Unistrut would be rated for in the Building 10 situation, and also some recommended installation instructions. Pages B-74D thru B-77D contain the calculations verifying vertical duct run loads and the minimum safety factor involved when using Unistrut to support these duct runs.

The only type of loading not evaluated on p. B-72D and B-73D is when the Unistrut is loaded within two inches of the end of the insert. According to Unistrut engineering data, this <sup>loading</sup> would decrease the rating by a factor of two. This fact is addressed on page B-77D and this type of loading will be allowed only as absolutely necessary and as approved by the Engineer for the particular locations. The safety factors as given on p. B-76D do not take additional credit for the 3 to 1 safety factor included in the loading data given by Unistrut and used in the evaluation on p. B-72D.



CALCULATIONS FOR			CN <u>14610</u>
EQUIP. NO.	PROJ. NO.	CALC. NO.	BY <u>M. Campbell</u>
PREPARED BY	DATE	REF. DOCUMENTS:	PAGE <u>B-720</u>
REVIEWED BY	DATE	<u>Engineering Evaluation</u>	FORM NO. 372-30-2650
APPROVED BY	DATE		

UNISTRUT CONCRETE INSERTS

THE PURPOSE OF THIS MEMO IS TO OUTLINE THE STRUCTURAL DEPARTMENT'S VIEWS AND RECOMMENDATIONS ON USE OF GTE UNISTRUT P3300 SERIES CONTINUOUS CONCRETE INSERTS TO SUPPORT CLASS I / ~~CLASS I~~ ATTACHMENTS TO BUILDING 10. NON-CLASS I

TEST DATA (REF: DETROIT TESTING LABORATORY, INC. REPORT NO. 312178-D DATED 9/24/74) DOCUMENT THE INITIAL YIELD AND ULTIMATE CAPACITY OF SUBJECT CONCRETE INSERTS. DESIGN LOADS LISTED IN THE REPORT WERE EXCEEDED BY TEST RESULTS BY A MINIMUM FACTOR OF SAFETY OF 3. FOUR PULLOUT AND TWO SHEAR TESTS WERE CONDUCTED FOR VARIOUS LENGTHS OF UNISTRUT WITH THE CENTER OF GRAVITY OF LOAD AT THE MIDPOINT ALONG THE UNISTRUT LENGTH.

RECOMMENDED LOAD FOR THE INSERTS SHOWN IN THE UNISTRUT CATALOG NO. 9 IS 1500 LBS PER FOOT OF UNISTRUT LENGTH FOR PULLOUT TYPE LOADING; THIS VALUE IS BASED ON CONCRETE COMPRESSIVE STRENGTH OF 5000 PSI. FOR BUILDING 10 APPLICATIONS THE ALLOWABLE LOAD SHOULD BE REDUCED TO

$$1500 \text{ LBS/FT} \times \frac{3500 \text{ PSI}}{5000 \text{ PSI}} = 1050 \text{ LBS/FT (PULLOUT)}$$

ALLOWABLE LOAD FOR DIRECTION TRANSVERSE TO THE LONGITUDINAL AXIS (OTHER THAN PULLOUT) BASED ON UNISTRUT DESIGN LOAD DATA SHOULD BE

$$1260 \text{ LBS/FT} \times \frac{3500 \text{ PSI}}{5000 \text{ PSI}} = 880 \text{ LBS/FT (SHEAR)}$$

IN CONCLUSION, IT IS FELT THAT USE OF THE P3300 SERIES UNISTRUT CONCRETE INSERTS ARE ACCEPTABLE AS DESCRIBED HEREIN WITH THE FOLLOWING STIPULATIONS:

CALCULATIONS FOR			CN <u>1461D</u>
EQUIP. NO.	PROJ. NO.	CALC. NO.	BY <u>M. Lombard</u>
PREPARED BY	DATE	REF. DOCUMENTS:	PAGE <u>B-73D</u>
REVIEWED BY	DATE		FORM NO. 372-30-2650
APPROVED BY	DATE		

Recommended Installation Instructions


- 1) UNISTRUT L-SHAPED ANCHORS MUST NOT BE BENT IN ANY WAY FROM THEIR INTENDED ORIENTATION (AS DEPICTED IN UNISTRUT CATALOG) TO AVOID OBSTRUCTIONS SUCH AS REBAR. ENTIRE UNISTRUT SHALL BE RELOCATED AS NECESSARY TO CIRCUMVENT OBSTRUCTIONS. Unistrut should not interfere with rebar at any point.
- 2) UNISTRUT SHALL BE SURROUNDED BY CONCRETE TO WITHIN  $\frac{1}{16}$ " OF THE UNISTRUT'S EXPOSED SURFACE, and be installed per Unistrut recommended instructions.
- 3) RESULTANT OF APPLIED LOADS FROM ATTACHMENTS SHALL ACT AS CLOSE TO THE CENTER OF THE UNISTRUT LENGTH AS POSSIBLE. DETAILS SUCH AS UNISTRUT LENGTH, AND DIRECTION, LOCATION AND MAGNITUDE OF LOADS APPLIED TO BE REVIEWED AND APPROVED BY STRUCTURAL ENGINEERING, or by Mechanical Engineering. #11/1/83
- 4) A CLEAR DISTANCE OF 6 INCHES MINIMUM SHALL EXIST BETWEEN THE UNISTRUT AND:
  - A) EDGE OR DISCONTINUITY OF CONCRETE FOR LOADING TOWARD EDGE
  - B) ANY ANCHORING DEVICE (I.E., DRILLED IN PLACE CONCRETE ANCHOR BOLTS) RELYING ON MECHANICAL TRANSFER OF LOAD TO CONCRETE FOR RESISTANCE.

BY: J. O. Ten  
6/15/83

5. Unistrut should not be attached to within 2 inches of end of insert, unless absolutely necessary and approved by the Engineer. #12/9/1/83


Unistrut VER. Section For Duct Hanger Attachment

Assume that all duct hangers are of the following arrangement:



$F = \text{total weight of duct} \div 2$ , due to symmetry of duct hanger (see spec. 75-J-0.2, sec. 15000 for details) to be conservative, this total force will be assumed to act as shown.

This arrangement yields the following free body diagram:



$\sum M_A = 0, \text{ but } FL_1 + F_{Cx} L_1 = 0$   
 $F_{Cx} = -F \left( \frac{L_1}{L_1} \right) = -F$

and  $F_{Cy} = F_{Cx}$ , due to 45° angle  
 $F_{Cx}$  is bearing load transmitted into wall, and can be ignored in this analysis

$\sum M_C = 0, \text{ but } F_{Ax} L_1 - FL_1 = 0$   
 $F_{Ax} = F \left( \frac{L_1}{L_1} \right) = F$

$\sum F_y = 0 \rightarrow F_{Ay} = 0$  since  $F_{Cy} = -F$

These equations will be used to check the loading put on the Unistrut inserts.

$F_{Cy}$  = shear load to be resisted by Unistrut,  $F_{Ax}$  = pullout load to be resisted by Unistrut  
Rectangular Duct, 8 St. hanger spools, vertical run

1. 24" x 24" duct.  
 From SMACNA Guidelines { 8 St<sup>2</sup> duct / linear St. (8 St) = 64 St<sup>2</sup> duct, 18 St. run  
 2650. metal, .906 #/St<sup>2</sup>, (64 St<sup>2</sup>) (.906 #/St<sup>2</sup>) = 58.0 #/8 St run

Therefore, to be very conservative, assume  $F = \frac{58.0 \text{ lb.}}{2} = 29.0 \text{ lb.}$

$F_{Cx} = -F = -29.0 \text{ #}$ , bearing load transferred into wall, insignificant  
 $F_{Cy} = -F = -29.0 \text{ #}$ , shear loading for Unistrut to resist  
 $F_{Ax} = F = 29.0 \text{ #}$ , pullout " " " " " "

Checked by M 8/26/83

Made final 2/28/83

$$F = 140.0 \div 2 = 70.0$$

$$F_{c2} = -F = -70.0 \text{ lb, shear loading}$$

$$F_{A2} = F = 70.0 \text{ lb, pullout loading}$$

total weight of duct and insulation =  $129.5 + 10.5 = 140.0$  lb

$$145 \text{ ft}^2 \text{ duct / linear ft (85 ft)} = 112.5 \text{ ft}^2 \text{ duct / 85 ft run}$$

$$24 \text{ ga. metal, } 1.156 \text{ lb/ft}^2 \text{ (} 112.5 \text{ ft}^2 \text{)} = 129.5 \text{ lb duct / 85 ft run}$$

$$\text{insulation, } 112.5 \text{ ft}^2 \text{ (} 1.5 \text{ in} \times \frac{1}{12} \text{)} = 145 \text{ ft}^3 \text{ (} 7.5 \text{)} = 10.5 \text{ lb / 85 ft run}$$

4. 42" x 42" duct

$$F = 119.0 \div 2 = 59.5$$

$$F_{c2} = -F = -59.5 \text{ lb, shear loading}$$

$$F_{A2} = F = 59.5 \text{ lb, pullout loading}$$

total weight of duct and insulation =  $110.0 + 9.0 = 119.0$  lb / 85 ft run

$$125 \text{ ft}^2 \text{ / linear ft (85 ft)} = 96.5 \text{ ft}^2 \text{ duct / 85 ft run}$$

$$24 \text{ ga. metal, } 1.156 \text{ lb/ft}^2 \text{ (} 96.5 \text{ ft}^2 \text{)} = 110.0 \text{ lb / 85 ft run}$$

$$\text{insulation } 96.5 \text{ ft}^2 \text{ (} 1.5 \text{ in} \times \frac{1}{12} \text{)} = 125 \text{ ft}^3 \text{ (} 7.5 \text{)} = 9.0 \text{ lb}$$

3. 36" x 36" duct

$$F = 99.0 \div 2 = 49.5$$

$$F_{c2} = -F = -49.5 \text{ lb, bearing load transferred into wall, insignificant}$$

$$F_{c1} = -F = -49.5 \text{ lb, shear loading}$$

$$F_{A2} = F = 49.5 \text{ lb, pullout}$$

See University of Wisconsin for details

$$107.5 \text{ ft}^2 \text{ duct / linear ft (85 ft)} = 85.6 \text{ ft}^2 \text{ duct / 85 ft run}$$

$$24 \text{ ga. metal, } 1.156 \text{ lb/ft}^2 \text{ (} 85.6 \text{ ft}^2 \text{)} = 99.0 \text{ lb / 85 ft run}$$

2. 32" x 32" duct

Round Duct, 8 Ft. Length spacing, vertical run

1. 32" Round

22 ga.,  $12.6 \text{ lb/linear ft} (8 \text{ ft}) = 100.8 \text{ lb}/8 \text{ ft run}$   
 insulation, surface area  $= 2\pi r (8 \text{ ft}) = 2\pi (16 \text{ in}) (\frac{1.5 \text{ ft}}{12 \text{ in}}) (8 \text{ ft})$   
 $= 67.0 \text{ ft}^2$

Volume  $= 67.0 \text{ ft}^2 (1.5 \text{ in}) (\frac{1}{12}) = 8.4 \text{ ft}^3$

insulation weight  $= 8.4 \text{ ft}^3 (.75 \text{ lb/ft}^3) = 6.3 \text{ lb}/8 \text{ ft run}$

total weight of duct and insulation  $= 100.8 + 6.3 = 107.1 \text{ lb}/8 \text{ ft run}$

$F = 107.1 \text{ lb} / 2 = 53.6 \text{ lb}$

$F_{cy} = -F = -53.6 \text{ lb}$ , shear loading

$F_{Ax} = F = 53.6 \text{ lb}$ , pullout loading

2. 28" Round

22 ga.,  $11.0 \text{ lb/linear ft} (8 \text{ ft}) = 88 \text{ lb}/8 \text{ ft run}$   
 insulation, surface area  $= 2\pi r h = 2\pi (14) (\frac{1.5}{12}) (8 \text{ ft}) = 58.6 \text{ ft}^2$

Volume  $= 58.6 \text{ ft}^2 (1.5 \text{ in}) (\frac{1}{12}) = 7.3 \text{ ft}^3$

Weight  $= 7.3 \text{ ft}^3 (.75 \text{ lb/ft}^3) = 5.5 \text{ lb}/8 \text{ ft run}$

total weight of duct and insulation  $= 88 + 5.5 = 93.5 \text{ lb}/8 \text{ ft run}$

$F = 93.5 \text{ lb} / 2 = 46.8 \text{ lb}$

$F_{cy} = -F = -46.8 \text{ lb}$ , shear loading

$F_{Ax} = F = 46.8 \text{ lb}$ , pullout loading

3. 16" Round

24 ga.,  $5.1 \text{ lb/linear ft} (8 \text{ ft}) = 40.8 \text{ lb}/8 \text{ ft run}$   
 insulation, surface area  $= 2\pi r h = 2\pi (8) (\frac{1.5}{12}) (8) = 33.5 \text{ ft}^2$

Volume  $= 33.5 (1.5) (\frac{1}{12}) = 4.2 \text{ ft}^3$

Weight  $= 4.2 (.75) = 3.2 \text{ lb}/8 \text{ ft run}$

total weight of duct and insulation  $= 40.8 + 3.2 = 44.0 \text{ lb}/8 \text{ ft run}$

$F = 44.0 \text{ lb} / 2 = 22.0 \text{ lb}$

$F_{cy} = -F = -22.0 \text{ lb}$ , shear loading

$F_{Ax} = F = 22.0 \text{ lb}$ , pullout loading

*W. Lombard 5/24/53*

Tabulation of Hanger Forces:

<u>Duct Size and Type</u>	<u>Shear Loading</u>	<u>Pullout Loading</u>
24" x 24" Rectangular	29.0 <sup>#</sup>	29.0 <sup>#</sup>
32" x 32" "	49.5 <sup>#</sup>	49.5 <sup>#</sup>
36" x 36" "	59.5 <sup>#</sup>	59.5 <sup>#</sup>
42" x 42" "	70.0 <sup>#</sup>	70.0 <sup>#</sup>
32" Round	53.6 <sup>#</sup>	53.6 <sup>#</sup>
28" "	46.8 <sup>#</sup>	46.8 <sup>#</sup>
16" "	22.0 <sup>#</sup>	22.0 <sup>#</sup>

Per the attached Unistrut calculations on p. B-720 and B-730, the Unistrut is rated for 1050<sup>#</sup>/ft. pullout load and 880<sup>#</sup>/ft. shear load. Using the maximum loading from the table above, this would give a 12.6 to 1 safety factor in shear and a 15.0 to 1 safety factor for pullout loading, assuming that a one foot minimum piece of insert is used for each attachment point. If the insert is loaded within two inches of the end, the safety factor minimums drop to 6.3 to 1 in shear and 7.5 to 1 in pullout. These safety factors do not include the additional 3 to 1 safety factor put into the loading data by Unistrut, and are considered adequate for this application.

Due to the very low loading involved, Unistrut inserts can also be used to anchor refrigeration piping runs at 8 ft. spacings, and also drain and vent lines and water supply piping anchors at 10 ft. spacings or less per spec. 75-5-02:

1. Refrigeration piping, worst case, 4 7/8" line full of refrigerant, 8 ft. spacings, pipe - .5<sup>#</sup>/ft, refrigerant - .41<sup>#</sup>/ft, approximately 30<sup>#</sup>/hanger, safety factor = 29.3 to 1 (shear loading)
2. Drain and vent line, 2" copper, 2<sup>#</sup>/ft, 20<sup>#</sup>/hanger, safety factor = 44 to 1
3. Water supply line, pipe - .14<sup>#</sup>/ft, water - .29<sup>#</sup>/ft, 3.44<sup>#</sup>/8 ft. safety factor = 258 to 1 (shear loading)

W. Lambert 8/26/73

Additional Hanger Information

Sheet Metal and Air Conditioning Contractors National Association, Inc. (SMACNA) guidelines were used to size angle iron and duct fasteners for vertical duct runs. SMACNA recommends using 1" x 1/2" or 1 1/4" x 1 1/4" x 1/2" angle at 12 foot spacings for similar vertical duct hangers, therefore the use of 1" x 1 1/4" angle at 8 ft. spacings is considered very acceptable. The attachment of the vertical duct to the angle iron hanger was also designed using SMACNA guidelines per the following table:

<u>Duct size and type</u>	<u>Weight per 8 ft. section (Insulation included if app.)</u>	<u>Number of Fasteners</u>	<u>Safety Factor</u>
42" x 42" Rectangular	140.0 #	14	3.5
36" x 36" "	119.0 #	10	2.9
32" x 32" "	99.0 #	10	3.5
24" x 24" "	58.0 #	8	4.8
32" Round	107.1 #	8	2.6
28" "	93.5 #	6	2.2
16" "	44.0	4	3.2

*M. Lombard 8/26/73*

Additional Fire Protection Information

It is our intent that Fire hydrant #9 and the hose reels contained in the building that envelops the hydrant will provide back up fire protection for Building 10. The hose reels are long enough to reach the equipment areas inside the building through the east access doors, and the recent relocation of Fire hydrant #9 and its building make it more accessible for the Fire fighting crews.

MAL/jm 9/26/83



1/4" tube,  $d_o = .375$ ",  $d_i = .311$ ",  $w = .134$  #/ft, 4' long, simply supported, copper



Uniform load (See Mechanical Engineering Design, by Shigley)

$$M = \frac{wlx}{2} (l-x) \quad M_{max} \text{ at } x = l/2$$

$$M = \frac{w(l/2)}{2} (l - l/2) = \frac{wl}{4} \left(\frac{l}{2}\right)$$

$$M_{max} = \frac{wl^2}{8}$$

$Z =$  section modulus

$$Z = \frac{\pi}{32d_o} (d_o^4 - d_i^4)$$

$I =$  moment of inertia

$$I = \frac{\pi}{64} (d_o^4 - d_i^4)$$

weight of water in tube,

$$\text{Volume} = \pi R_o^2 h = \pi \left(\frac{.311}{2}\right)^2 (48)$$

$$= 3.65 \text{ in}^3 \left(\frac{1.54}{1728} \frac{\text{ft}^3}{\text{in}^3}\right) = .0021 \text{ ft}^3$$

$$\text{weight} = (.0021)(62.4 \frac{\text{lb}}{\text{ft}^3}) = .132 \text{ #}$$

$$w_{\text{water}} = \frac{.132 \text{ #}}{4 \text{ ft}} = .033 \text{ #/ft}$$

$$w_{\text{total}} = .033 + .134 = .167 \text{ #/ft}$$

$$M_{max} = \frac{wl^2}{8} = \frac{(.167 \frac{\text{#}}{\text{ft}})(4 \text{ ft})^2}{8} = .334 \text{ ft}\cdot\text{lb} \left(\frac{12 \text{ in}}{1 \text{ ft}}\right) = 4.01 \text{ in}\cdot\text{lb}$$

$$Z = \frac{\pi}{32d_o} (d_o^4 - d_i^4) = \frac{\pi}{32(.375)} (.375^4 - .311^4)$$

$$Z = .00273 \text{ in}^3$$

$$\sigma = \frac{M}{Z} = \frac{4.01 \text{ in}\cdot\text{lb}}{.00273 \text{ in}^3} = 1468.9 \text{ psi}$$

$$I = \frac{\pi}{64} (d_o^4 - d_i^4) = \frac{\pi}{64} (.375^4 - .311^4)$$

$$I = .000512 \text{ in}^4 \quad E = 15.6 \times 10^6 \text{ psi}$$

$\delta =$  deflection

$$\delta_{max} = \frac{5wl^4}{384EI} = \frac{5(.167 \frac{\text{#}}{\text{ft}})(\frac{1 \text{ ft}}{12 \text{ in}})^4 (48 \text{ in})^4}{384(15.6 \times 10^6 \text{ psi})(.000512 \text{ in}^4)}$$

$$\delta_{max} = .12 \text{ in}$$

1/8" tube,  $d_o = .625$ ,  $d_i = .527$ ,  $w = .344$  #/ft, 4 ft. long specimen, copper

weight of water in tube,

$$vol = \pi R_i^2 h = \pi \left(\frac{.527}{2}\right)^2 (48) = 10.5 \text{ in}^3 \left(\frac{1 \text{ ft}^3}{1728 \text{ in}^3}\right)$$

$$vol. = .0061 \text{ ft}^3$$

$$weight = (.0061)(62.4) = .381 \text{ #}$$

$$w = \frac{.381 \text{ #}}{4 \text{ ft}} = .095 \text{ #/ft}$$

$$w_{tot} = .095 + .344 = .439 \text{ #/ft}$$

$$M_{max} = \frac{w l^2}{8} = \frac{(.439 \text{ #/ft})(4 \text{ ft})^2}{8} = .88 \text{ ft} \cdot \text{lb} \left(\frac{12 \text{ in}}{1 \text{ ft}}\right) = 10.54 \text{ in} \cdot \text{lb}$$

$$Z = \frac{\pi (.625^4 - .527^4)}{32(.625)} = .012 \text{ in}^3$$

$$I = \frac{\pi (.625^4 - .527^4)}{64} = .0037 \text{ in}^4$$

$$\sigma_{max} = \frac{M_{max}}{Z} = \frac{10.54 \text{ in} \cdot \text{lb}}{.012 \text{ in}^3} = 878.3 \text{ psi}$$

$$\delta_{max} = \frac{5 w l^4}{384 E I} = \frac{5 (.439 \text{ #/ft}) \left(\frac{1 \text{ ft}}{12 \text{ in}}\right)^4 (48 \text{ in})^4}{384 (15.6 \times 10^6 \text{ psi}) (.0037 \text{ in}^4)} = .044 \text{ in}$$

3/8" tube,  $d_o = .750$ ,  $d_i = .652$ ,  $w = .418$  #/ft, 4' long specimen, copper  
 weight of water in tube

$$vol. = \pi R_i^2 h = \pi \left(\frac{.652}{2}\right)^2 (48 \text{ in}) = 16.03 \text{ in}^3 \left(\frac{1 \text{ ft}^3}{1728 \text{ in}^3}\right)$$

$$vol. = .0093 \text{ ft}^3$$

$$weight = (.0093 \text{ ft}^3)(62.4 \text{ #/ft}^3) = .58 \text{ #}$$

$$w = \frac{.58 \text{ #}}{4 \text{ ft}} = .15 \text{ #/ft}$$

$$w_{tot} = .418 + .15 = .57 \text{ #/ft} \left(\frac{1 \text{ ft}}{12 \text{ in}}\right) = .047 \text{ #/in}$$

$$M_{max} = \frac{w l^2}{8} = \frac{(.047 \text{ #/in})(48 \text{ in})^2}{8} = 13.5 \text{ in} \cdot \text{lb}$$

$$Z = \frac{\pi (.750^4 - .652^4)}{32(.750)} = .018 \text{ in}^3$$

$$\sigma = \frac{M}{Z} = \frac{13.5 \text{ in} \cdot \text{lb}}{.018 \text{ in}^3} = 750 \text{ psi}$$

$$I = \frac{\pi (.750^4 - .652^4)}{64} = .0067 \text{ in}^4$$

$$\delta_{max} = \frac{5 w l^4}{384 E I} = \frac{5 (.047 \text{ #/in})(48 \text{ in})^4}{384 (15.6 \times 10^6 \text{ psi}) (.0067 \text{ in}^4)} = .032 \text{ in}$$

3/4" tube,  $d_o = .875$ ,  $d_i = .745$ ,  $w = .641$  #/ft, 7 St. hanger spacing (84"), Copper

weight of water in tube

$$Vol = \pi R_i^2 h = \pi \left( \frac{.745}{2} \right)^2 (84) = 36.6 \text{ in}^3 \left( \frac{1.573}{128.0} \right)$$

$$Vol = .021 \text{ ft}^3$$

$$Weight = .021 \text{ ft}^3 (62.4 \text{ #/ft}^3) = 1.31 \text{ #}$$

$$w = \frac{1.31 \text{ #}}{7 \text{ ft}} = .19 \text{ #/ft}$$

$$w_{total} = .19 + .641 = .83 \frac{\text{#}}{\text{ft}} \left( \frac{1.573}{128.0} \right) = .0099 \text{ #/in}$$

$$\Delta_{max} = \frac{w L^4}{8} = \frac{(.0099 \text{ #/in})(84 \text{ in})^4}{8} = 60.86 \text{ in} \cdot \text{lb}$$

$$Z = \frac{\pi (.875^4 - .745^4)}{32 (.875)} = .031 \text{ in}^3$$

$$I = \frac{\pi (.875^4 - .745^4)}{64} = .014 \text{ in}^4$$

$$\sigma = \frac{M}{Z} = \frac{60.86 \text{ in} \cdot \text{lb}}{.031 \text{ in}^3} = 1963 \text{ psi}$$

$$\delta = \frac{5 w L^4}{384 EI} = \frac{5 (.0099 \text{ #/in})(84 \text{ in})^4}{384 (15.6 \times 10^6 \text{ psi})(.014 \text{ in}^4)} = .20 \text{ in}$$

The above analysis shows the maximum stress for 1/4", 1/2", 5/8" and 3/4" tubing with hanger spacing for horizontal runs as specified in work specification 75-J-02 will not exceed the 6000psi max. stress as given in ANSE R311-1990. Also by inspection the max. deflections are acceptable. All copper tube sizes in between these sizes above shall be acceptable for horizontal hanger spacing as shown in 75-J-02 per this analysis and engineering judgement, and guidelines given in ANSE R311-1990 (for 1" and over). Hanger failure will not affect safety related equipment since it will not be routed above such equipment.

M.A. J. 9/13/73



PUBLIC SERVICE COMPANY OF COLORADO

FORT ST. VRAIN NUCLEAR GENERATING STATION

CN TCR/SCR/PC/TR  
NO. 14628  
PAGE 7

SAFETY EVALUATION

**CATEGORY**

TYPE:  CN OVERALL     CN SUBMITTAL     SETPOINT CHANGE REPORT     TEST REQUEST  
 TEMPORARY CONFIGURATION REPORT     PROCEDURE CHANGE (FSAR)     OTHER

CLASSIFICATION: ARE THE SYSTEM(S) EQUIPMENT OR STRUCTURES INVOLVED, OR DOES THE ACTIVITY AFFECT:

CLASS I	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	ENGINEERED SAFEGUARD	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NO
SAFE SHUTDOWN	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NO	PLANT PROTECTIVE SYSTEM	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NO
SAFETY RELATED	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	SECURITY SYSTEM	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NO

REMARKS: This CN is Safety Related due to cable routing in the Safety Related Cable Tray System. Fire Protection for Building 10 must also be treated as Safety Related.

**EVALUATION**      USE ADDITIONAL SHEETS IF REQUIRED.

1 IS THE ACTIVITY IDENTIFIED IN THE FSAR OR TECH SPEC?  YES  NO  
LIST THE APPLICABLE SECTIONS REVIEWED. FSAR sections 1.2, 1.4, 1.6, 7.1.1.4, 7.4.1.8.2.4, 8.2.6, 9.12 Tech Specs sections 4.10.1, 4.10.2, 4.10.3, 4.10.4

2 DOES THE ACTIVITY REQUIRE THAT CHANGE(S) BE MADE TO THE FSAR OR TECH SPEC?  YES  NO  
LIST SECTIONS TO BE CHANGED AND THE CHANGES TO BE MADE. At the completion of the Building 10 addition, FSAR section 1.6 should be revised to reflect the new addition. Other items more specific will require FSAR update within Building 10 however they will be accomplished by other CN's.

3 DETERMINE WHETHER OR NOT THE ACTIVITY INVOLVED IS AN UNREVIEWED SAFETY QUESTION UTILIZING THE FOLLOWING GUIDELINES.

(A) HAS THE PROBABILITY OF OCCURRENCE OR THE CONSEQUENCES OF AN ACCIDENT OR MALFUNCTION OF EQUIPMENT IMPORTANT TO SAFETY PREVIOUSLY EVALUATED IN THE FSAR BEEN INCREASED?  YES  NO STATE BASIS: This CN only affects the Class I Safety Related Cable Tray system and Bldg 10 fire protection (treated as safety related) system which could have an effect on plant safety. Both are being constructed in accordance with current regulatory requirements, therefore the probability of occurrence or the consequences of an accident evaluated in the FSAR have not been increased.

(B) HAS THE POSSIBILITY OF AN ACCIDENT OR MALFUNCTION OF A DIFFERENT TYPE THAN ANY EVALUATED PREVIOUSLY IN THE FSAR BEEN CREATED?  YES  NO STATE BASIS: This CN has no effect on reactor plant functional operations. The items within the CN that are important to safety are in ~~not~~ being constructed in accordance with current requirements and therefore do not create the possibility of a new accident.

(C) HAS THE MARGIN OF SAFETY, AS DEFINED IN THE BASIS FOR ANY TECHNICAL SPECIFICATION OR IN THE FSAR BEEN REDUCED?  YES  NO STATE BASIS: No margin of safety ~~exists~~ is defined in the FSAR or Tech Specs concerning construction of Building 10 and therefore cannot be reduced. The margin of safety defined for tech specs associated with the three room control complex fire protection has not been reduced as its operation remains unchanged.

DOES THE ACTIVITY APPEAR TO: INVOLVE AN UNREVIEWED SAFETY QUESTION  YES  NO  
BE SAFETY SIGNIFICANT  YES  NO

BY: Mike Klauer      9/12/83      \*APPROVED: J.R. Johns      9-13-83  
(SIGNATURE)      (DATE)      (SIGNATURE)      (DATE)

\*REQUIRED ONLY FOR CHANGE NOTICE

PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
NUCLEAR PROJECT DEPARTMENT

- Electrical
- Mechanical
- Structural
- Safety Related
- Non Safety Related

DESIGN INPUT REQUIREMENTS

Sheet 1 of 1

1. Install Electrical portion of the Three Room Complex Addition  
And Walkover Structure.
2. Work to be completed in compliance with Specification 75-J-02  
and 45-S-14.
3. Work to be completed in accordance with drawings;

E-1945  
E-1946  
E-1947  
E-1948  
E-1949  
E-1950  
E-1951  
E-1952  
E-1953  
E-1954

Fire Protection System shall be installed per manufacturer's  
supplied drawings.

All other drawings shall be included in the Change Notice as  
sketches.

4. Relocate conduits, cables, grounding, etc., which will inhibit  
the construction of the Three Room Complex Addition.
5. Justify cable tray and hanger details for safety related equipment.

Prepared By: /s/ Keith B. Bond 9/27/82  
Date

Approved By: /s/ W.E. McHugh 9/28/82  
Date

REPLACE ENTIRE PAGE  
PER CN-1462

CN 1462 B

BY K. Bush

PAGE B2 B

FORM NO. 372-30-2650

PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VALEIN NUCLEAR GENERATING STATION  
NUCLEAR PROJECT DEPARTMENT

SAFETY RELATED DESIGN ANALYSIS

Sheet 1 of 19

Electrical

Mechanical

Structural

I. Seismic Analysis:

For detailed analysis of the Seismic Response Spectra generated for this building, see Seismic Book S2, Tab 2. All Safety Related, Class I Equipment shall be designed in accordance with the Response Spectra.

II. Stress Analysis:

For details of stress analysis, see seismic Book S2, tab 9.

Add per CN-1462 B

For Unistrut Inserts, see page B6.

III. Piping/Hanger Analysis:

Cable Tray Hanger Analysis is shown on sheets B5 thru B13 and B18 thru B21. All supports are designed in accordance with Seismic Book S2, Tab 9.

Cable Grip calculations on pages B18A thru B21A.

IV. Hydraulic/Pneumatic Analysis:

N/A



REPLACE ENTIRE  
PAGE PER CN-1462A

V. THERMAL ANALYSIS

All heat generated by Electrical Equipment (now or in the future) have been accounted for or estimated for in calculations in cooling Load. See Mechanical CN-1461 for HVAC calculations.

VI. NUCLEAR ANALYSIS

N/A

VII. FIRE PROTECTION ANALYSIS

A complete Fire Protection Review on Building 10, is attached on pages B3.1 thru B3.15. Emergency Lighting provides lighting for access to essential plant equipment required to shut down the plant, and for escape routes from the building. The system consists of fixed incandescent type fixtures powered by the station batteries. This lighting conforms to PSC response to BTP-9.5-1. Cable trays will be wrapped with a 1 hour fire rated blanket to meet BTP-9.5-1 requirements.

VIII. ENVIRONMENTAL ANALYSIS

All equipment installed is designed for the type of environment it is placed in.

IX. COMPATIBILITY OF MATERIALS, EQUIPMENT, AND PROCESSES

Fire Detection system is not tied into the Existing system. The New System is Compatible for use in Building 10. All geitronics, load centers, etc. will be compatible with plant operations.

PROTO-POWER MANAGEMENT CORPORATION

281 POQUONNOCK ROAD  
GROTON, CONNECTICUT 06340  
(203) 446-9725

File: 7511434

November 19, 1982

Mr. J.R. Reesy  
Nuclear Design Department Manager  
Public Service Company of Colorado  
5909 East 38th Avenue  
Denver, Colorado 80207

Dear Jack:

This letter contains the results of Proto-Power Corporation's fire protection review of the Fort St. Vrain Three Room Complex Addition. This review was requested by telecon with PSC on November 3, 1982. The review was performed in accordance with Branch Technical Position 9.5-1, Appendix A and 10CFR50, Appendix R as it applies to Fort St. Vrain. The Fire Hazards Analysis performed to evaluate compliance with regulatory requirements is included as Attachment A. The Three Room Complex Addition meets the requirements of these documents except for two points: 1) separation of redundant cables; and 2) lack of emergency lighting.

1. Cables designated B1L1 and B2L2 serving inverter 1A and 1B respectively are located in both the south end ground floor room and the ground floor walkover room 101. This cable routing violates Section G of Appendix R to 10CFR50 which states "one train of systems necessary to achieve and maintain hot shutdown conditions from either the Control Room or the emergency control station(s) is free of fire damage". Furthermore, BTP 9.5-1, Appendix A (Paragraph 3.4.1.a in PSC's response to BTP 9.5-1) requires that redundant safety related systems be separated from each other so that both are not subject to damage from a single fire hazard. Based on the understanding that, as a minimum, inverter 1A or 1B is needed for plant shutdown, Proto-Power finds the presence of both B1L1 and B2L2 cables serving inverter 1A and 1B respectively in the same fire area to be in conflict with regulatory requirements. Appendix R to 10CFR50 requires that redundant cables be protected by a combination of one hour rated fire retardant (or barriers), and fire detection and suppression system. To meet these requirements, Proto-Power



Mr. J.R. Reesy

-2-

November 19, 1982

suggests wrapping one of the cable systems with a 1 hr. fire rated B&W Kaowool® blanket wrap currently being used by other utilities to meet this requirement. To meet the suppression system requirement, it could be demonstrated analytically that the in situ and transient combustibles in the two fire areas are too small (approximately 4 minutes) to be a fire hazard and therefore, don't warrant a fixed fire suppression system.

2. Fixed emergency lighting is not currently provided in the Three Room Complex Addition. BTP 9.5-1, Appendix A (Paragraph 3.4.5 in PSC's response to BTP 9.5-1) and Appendix R to 10CFR50 states that fixed emergency lighting is vital to safe shut-down and emergency response in the event of a fire. The absence of fixed emergency lighting violates regulatory requirements. Proto-Power suggests that fixed (battery pack) emergency lighting be provided for access and egress routes to and from the rooms within the Three Room Complex Addition.

Three additional points relating to fire protection are being suggested for your consideration, but are not required by either BTP 9.5-1 or Appendix R to 10CFR50.

- o The IC battery room exhaust fan should be provided with loss-of-flow indication in the Control Room. The fire hazards analysis assumes the fan is operating to ensure that H<sub>2</sub> concentrations are maintained below 2% (by volume).
- o Pressure relief venting should be considered in the design of the Halon 1301 fire suppression systems to prevent overpressurizing the room during system discharge and, possibly destroying fire stops and door frames.
- o If redundant sets of safety related equipment are planned for the south end ground floor room and mezzanine, consideration should be given at this time for their separation which may include fire barriers (walls) and the location of detectors, fire suppression (Halon 1301) system, and ventilation ducts.

In addition, there is one item concerning channel independence that is an apparent conflict with your present FSAR commitments. Attachment B outlines our concern on this item. While this item

CN 1462  
BY K Bush  
PAGE B3.3A  
FORM NO. 372-30-2650

Mr. J.R. Reesy


-3-

November 19, 1982

appears to be a departure from your FSAR commitments, it is independent from BTP 9.5-1, Appendix A or Appendix R to 10CFR50. If you agree with our conclusion on this matter we can recommend to you alternative ways of correcting this concern.

The above information contains the results of our review of the Three Room Complex Addition to the requirements of BTP 9.5-1, Appendix A and 10CFR50, Appendix R. If you have any questions, please call me at (203) 446-9725.

Sincerely,



R.A. Schaufler  
Vice President

PDM:jmn  
Attachment

ATTACHMENT A

The Three Room Complex Addition (3RCA) has 4 floors of rooms and a mezzanine over the northern portion of the ground floor. In descending order, the floors contain a training room, equipment and office rooms, a computer room, and a ground level battery room and two converter rooms at Elev. 4791'0". The ground level rooms including the mezzanine contain safety related equipment. The equipment room (El. 4824'0") was analyzed as a safety related room because it is anticipated that safety related equipment may be installed in the future, but none has been designated at this time. All other rooms are considered non-safety related equipment areas. A two level walkover structure abuts the 3 RCA from the west wall. The walkover floors access the ground level and computer rooms. The two walkover floors designated R101 and R102 contain safety related cables and cable trays, however, no equipment is to be installed in the walkover structure. The rooms designated as safety related fire areas therefore are the three rooms on the ground level, the two walkover rooms and the equipment room at El. 4824'0". Each of these fire areas is enclosed by three hour fire rated walls.

Access doors and emergency exits separating the building's outer wall and internal fire walls are U.L. Class A fire rated steel doors. Electrical cable in trays, risers, and conduit, and ventilation ducts that penetrate the floors and walls of fire areas are equipped with fire stops and ventilation fire dampers respectively.

When evaluating the effects of the design basis fire, consideration has been given to safety related equipment which, on the basis of vertical, as well as horizontal proximity, could be involved in the fire. Similarly, any combustibles above or below the design basis fire area, and the effects of using hose water on safety related equipment in and below the design basis fire area, have also been considered.

Communication during a fire situation is maintained primarily by the station's public address (GAI-Tronic) system. The 3 RCA ventilation system provides for the removal of smoke and corrosive gasses during and following a fire situation.

Emergency lighting, as required by 10CFR50, Appendix R, and BTP 9.5-1, is not incorporated in the design of the Three Room Complex Addition, or the attached walkover structure. Appropriate action as outlined in the attached letter should be taken to ensure compliance with this guideline.

Ground Floor South, Including Mezzanine - El. 4791'0" and El. 4800'0"

Area Description

Located on the ground level are safety related instrumentation inverter 1B, one 120 volt distribution panel, one 25 KVA backup power transformer and associated cable and cable trays. Safety related cable trays, designated for bus two, loop two (B2L2) routing, are installed above the ground level section of this fire area. The mezzanine contains no safety related equipment at this time. Safety related cable trays, designated for bus one, loop one (B1L1) routing, are installed above the mezzanine. As presently designed, the location of unprotected raceways, B1L1 and B2L2 in the same fire area, is a violation of 10CFR50, Appendix R and BTP 9.5-1. Appropriate corrective action, as outlined in the attached letter, should be taken to ensure compliance with these guidelines.

Fire Area Boundary

The south end ground floor is open to the mezzanine which is over the north end ground floor and battery rooms. This area is bounded by three hour fire rated walls, that separate it from the north ground floor room which contains the other raceways necessary for safe shutdown and the 1C battery room.

Fire Load

The fire load in this area is very small consisting of small quantities of electrical cable insulation and paper waste in trash containers. The calculated fire load for this area is 4320 Btu/ft<sup>2</sup> ( $\approx$  3-1/4 min.). These combustibles are not of sufficient quantity to be considered a hazard to both of the safety related raceways that exist within this fire area.

Fire Protection Systems

Fire detection for this area is provided by an ionization type detector which alarms and annunciates in the Control Room. Primary fire suppression is provided by portable dry chemical extinguishers. Floor drains are not required as the floor mounted equipment is elevated by three inch channel, which elevates the equipment above the potential water level.

Design Basis Fire

The design basis fire assumes the complete combustion of paper waste in two fifty-five gallon drums and all the electrical cable insulation. Ignition is dependent on a transient source. As a result of the low fire load (4320 Btu/ft<sup>2</sup>), the separation of buses and the ability to achieve safe shutdown with equipment located in another separated fire area, the design basis fire will not affect the ability of the plant to achieve safe shutdown.

Ground Level North - Elev. 4791'0"

Area Description

Located in the north ground level room are safety related instrument inverters 1A and 1C, their associated distribution panels, backup power transformers, cable and cable trays. While this safety related equipment is redundant (for 2 out of 3 P.P.S. inputs), only inverter 1A or 1B, which is in the south ground floor room, is needed to obtain safe shutdown. The cable trays installed in this fire area are designated for B2L2 routing. Cabling for inverter 1C is run in conduit.

Fire Area Boundary

The fire area consists of concrete walls and ceiling that have three hour fire ratings.

Fire Load

The fire load in this area is 5360 Btu/ft<sup>2</sup> ( $\approx$  4 min.). It is attributable to the small quantity of electrical cable insulation and waste consisting of paper in trash containers.

Fire Protection System

Fire detection for this area is provided by an ionization type detector which alarms and annunciates in the Control Room. Primary fire suppression is provided by portable dry chemical extinguishers. Floor drains are not required as the floor mounted equipment is elevated by three inch channel, which elevates the equipment above the potential water level.

Design Basis Fire

The design basis fire assumes the complete combustion of the paper waste that could exist in two fifty-five gallon drums, and all the electrical cable insulation within this fire area. Ignition is dependent on a transient source. As a result of the low fire load (5360 Btu/ft<sup>2</sup>) and the ability to achieve safe shutdown with equipment located in another separated fire area, the design basis fire will not affect the ability of the plant to achieve safe shutdown.

Battery Room - Ele. 4791'0"

Area Description

The battery room contains safety related battery 1C.

### Fire Area

The fire area is enclosed in three hour rated fire walls and ceiling and utilizes Class A fire rated doors. There is an exhaust fan which vents the room atmosphere directly to the outdoors. The exhaust fan duct is equipped with a three-hour fire rated damper.

### Fire Load

The fire load in this area consists of electrical cable insulation, battery casing material, and loose paper in trash containers. The calculated fire load is 184,000 Btu/ft<sup>2</sup> (2.3 hrs.).

### Fire Protection Systems

Fire detection is provided by an ionization type detector which alarms and annunciates in the Control Room. Primary fire suppression is provided by portable dry chemical extinguishers.

### Design Basis Fire

The design basis fire assumes the complete combustion of the electrical cable insulation, battery casing material and paper waste in two fifty gallon drums. Ignition is dependent on a transient source. Since the battery is the only redundant safety related piece of equipment in this fire area and redundant safety related batteries are located in another separated fire area, the design basis fire will have no effect on the ability of the plant to achieve safe shutdown.

### Equipment Room - Elev. 4824'0"

#### Area Description

The equipment room is capable of containing safety related equipment but none has been designated as yet. Safety related cable trays are designated for B2L2 service. The ceilings have non-combustible one hour rated acoustical paneling suspended from them. The concrete walls have one hour fire rated non-combustible drywall coverings.

#### Fire Area Boundary

The fire area is enclosed in three hour rated fire walls and ceiling and Class A fire rated doors.

#### Fire Load

The fire load in this area is 5280 Btu/ft<sup>2</sup> (≈ 4 min.). It is based on electrical cable insulation and paper waste in trash containers.

#### Fire Protection System

Fire detection for this area is provided by an ionization type detector which alarms and annunciates in the Control Room. Primary fire suppression is provided by portable dry chemical extinguishers. Floor drains are not required as the floor mounted equipment is elevated by three inch channel, which elevates the equipment above the potential water level.

#### Design Basis Fire

The design basis fire for this area assumes the total combustion of the paper waste that could exist in two fifty-five gallon drums, and all electrical cable insulation in the fire area. Ignition is dependent on a transient source. As a result of the low fire load (5280 Btu/ft<sup>2</sup>), and the absence of any safety related equipment, the design basis fire will have no affect on the ability of the plant to achieve safe shutdown.

Walkover Room 101 - Elev. 4791'0"

#### Area Description

Room 101 contains safety related cable routing B1L1 as well as cable routed as B2L2 service. As presently designed, the location of unprotected raceways B1L1 and B2L2 in the same fire area is a violation of 10CFR50, Appendix R and BTP 9.5-1. Appropriate corrective action as outlined in the attached letter should be taken to ensure compliance with these guidelines.

#### Fire Area

The fire area is enclosed in three hour rated fire walls and ceiling and utilizes Class A fire rated doors.

#### Fire Load

The fire load in this area is very small consisting of small quantities of electrical cable insulation and paper waste in trash containers. The calculated fire load for this area is 10,400 Btu/ft<sup>2</sup> (8 min.). These combustibles are not of sufficient quantity to be a hazard to both of the safety related raceways that exist within this fire area.

#### Fire Protection System

Fire detection for this area is provided by an ionization type detector which alarms and annunciates in the Control Room. Primary fire suppression is provided by portable, dry chemical extinguishers.

Design Basis Fire

The design basis fire assumes the complete combustion of paper waste contained in two fifty-five gallon drums, and all the electrical cable insulation within this fire area. Ignition is dependent on a transient source. As a result of the low fire load (10,400 Btu/ft<sup>2</sup>), the design basis fire will not affect the ability of the plant to achieve safe shutdown.

Walkover Room 102 -- Elev. 4811'0"

Area Description

Room 102 contains safety related cable and cable trays routed as B111.

Fire Area

The fire area is enclosed in three hour rated fire walls and ceiling and utilizes Class A fire rated doors.

Fire Load

The fire load is very small in this area and consists of small quantities of electrical cable insulation and paper waste in trash containers. The calculated fire load for this area is 9,600 Btu/ft<sup>2</sup> (7 min.).

Fire Protection System

Fire detection for this area is provided by an ionization type detector which alarms and annunciates in the Control Room. Primary fire suppression is provided by portable, dry chemical extinguishers.

Design Basis Fire

The design basis fire assumes complete combustion of the paper waste contained in two fifty-five gallon drums, and all the electrical cable insulation contained in the fire area. Ignition is dependent on a transient source. As a result of the low fire load (9,600 Btu/ft<sup>2</sup>) and the ability to achieve safe shutdown with system cables located in another separated fire area, the design basis fire will not affect the ability of the plant to achieve safe shutdown.



THREE ROOM COMPLEX ADDITION  
FORT ST. VRAIN

FIRE HAZARD ANALYSIS SUMMARY

ITEM NO.	FIRE AREA LOCATION MAJOR EQUIPMENT	SAFETY RELATED	COMBUSTIBLE MATERIAL	QUANTITY	HEAT CONTENT (BTU/LB)	FIRE LOAD (BTU/FT <sup>2</sup> )	FIRE DETECTION	FIRE SUPPRESSION AVAILABLE	SEPARATION OF RECORDS/ S.R. EQUIPMENT HI
1	South Inverter Room Including Mainframe	Yes	Cable Insulation	3 ft <sup>3</sup>	12,000	4,320	Ionization Type	Dry Chemical	Separate Concrete Beams & Cable Separation
2	North Inverter Room	Yes	Cable Insulation	.93 ft <sup>3</sup>	12,000	5,360			Separate Concrete Beams & Cable Separation
3	Battery Room	Yes	Cable Insulation Battery Cell Cases	.15 ft <sup>3</sup> 13 ft <sup>3</sup>	12,000 18,000	184,000			Separate Concrete Beams
4	South Computer Room	No	Cable Insulation	.08 ft <sup>3</sup>	12,000	9,600			
5	North Computer Room	No	Cable Insulation	.375 ft <sup>3</sup>	12,000	7,320			
6	Equipment Room	Yes	Cable Insulation	.3 ft <sup>3</sup>	12,000	5,220			No S.R. Equipment at present.
7	Office Room	No	Cable Insulation	.3 ft <sup>3</sup>	12,000	5,280			
8	Walkover Room 101	Yes	Cable Insulation	.3 ft <sup>3</sup>	12,000	18,400			Separate Concrete Beams & Cable Separation
9	Walkover Room 102	Yes	Cable Insulation	.6 ft <sup>3</sup>	12,000	9,600			

CN 1462A  
BY K. Bush  
PAGE 133.10A  
FORM NO. 372-30-2650

ATTACHMENT B

The current design of the Three Room Complex Addition (3RCA) appears to conflict with current FSAR commitments in the specific area of the design for independence of the three logic channels. The conflict centers on the ability of a single event (i.e., a fire) to defeat the independence between the logic channels associated with Instrument Buses 1A and 1C. Specifically, the problem is the location of Inverter 1C and routing of cables associated with Inverter 1C in the same fire area as Inverter 1A and cables associated with Inverter 1A.

The bases for our concern are the FSAR commitments outlined below and as highlighted on the attached pages.

- a. Compliance with Design Criteria 20 (See Attachment B-1).
- b. Compliance with Design Criteria 21 (See Attachment B-2).
- c. Compliance with the Principles of Design outlined in Section 7.1.1.2 (See Attachments B-3 and B-4).

This apparent conflict is not an area of non-compliance with BTP 9.5-1, Appendix A or Appendix R to 10CFR50 since the remaining channel 1B can be utilized to achieve safe shutdown.

# ATTACHMENT B.1

CN 1462A  
BY K. Bush  
PAGE B3.12A  
FORM NO. 372-30-2650

FSAR UPDATE  
C.20-1

## CRITERION 20: PROTECTION SYSTEMS REDUNDANCY AND INDEPENDENCE (Category B)

"Redundancy and independence designed into protection systems shall be sufficient to assure that no single failure or removal from service of any component or channel of a system will result in loss of the protection function. The redundancy provided shall include, as a minimum, two channels of protection for each protection function to be served. Different principles shall be used where necessary to achieve true independence of redundant instrumentation components."

### DISCUSSION:

On the basis of the following information, it is concluded that Criterion 20 is satisfied.

In general, three independent sensing circuits are provided for each plant protective system input parameter. Exceptions for Loop Shutdown and Circulator trip exist as shown in Figures 7.1-1, 7.1-2, 7.1-3; however these do have two sensing circuits.

→ The basic logic system is two-out-of-three for the scram and steam/water dump circuitry. Independence between the three logic channels is maintained up to the final output stage where the two-out-of-three combination is made. This includes supply of power from three independent instrument power sources. The loop shutdown and circulator trip circuitry utilizes dual output stages arranged in a one-out-of-two configuration to ensure system reliability. Either output is energized to actuate the final control element(s). (The output logic should not be confused with the input sensing channels which are generally two-out-of-three as previously stated.) (Section 7.1.2.1).

Since the basic logic is two-out-of-three, or one-out-of-two for loop shutdown and circulator trip, it follows that the unsafe failure of either an input sensing channel or an entire logic channel will not result in loss of the protective function.

\* Features included in the design for independence are outlined in Section 7.1.1.2.

## ATTACHMENT B.2

CN 1962A  
BY K. Bush  
PAGE B3.13A  
FORM NO. 372-30-2650

FSAR UPDATE  
C.21-1

### CRITERION 21: SINGLE FAILURE DEFINITION (Category B)

"Multiple failures resulting from a single event shall be treated as a single failure."

#### DISCUSSION:

On the basis of the following information, it is concluded that Criterion 21 is satisfied.

Multiple failures resulting from a single event are treated as a single failure. Single events considered in the design for independence are outlined in Section 7.1.1.1. The environmental conditions for areas in the Fort St. Vrain plant are given in Section 7.1.1.4.

7.1.1.2

In addition the Proposed IEEE Guide to the Application of the Single Failure Criterion to Nuclear Power Plant Protection Systems, Fifth Draft, dated 9/30/68, has been used in the design of the Plant Protective System.

# ATTACHMENT B.3

CN 1962A  
BY K. Bush  
PAGE B3.19A  
FORM NO. 372-30-2650

FSAR UPDATE  
7.1-E

modules in the conducting or nonconducting mode, failure of power supplies, blockage or severance of process connections, and failures of transducers. The short circuits considered include those credible faults which affect multiple components, as may be illustrated by single interconnecting lines on a schematic, and which may prevent system action. The basic logic system employs 2 of 3 redundancy for the sensing channels. The scram control is designed using hindrance logic, i.e., loss of power produces a scram. The accidental shutdown of both coolant loops must be avoided to provide the necessary core cooling. The associated circuitry is therefore deenergized during plant operation. Steam/water dump, loop isolation, and circulator trip circuitry are therefore designed using transmission logic, i.e., circuits are energized to produce protective action. Redundant output circuitry and final control elements are provided.

Quality of Components and Modules. The bulk of the electronics and circuitry (excluding preamplifiers when required) is located in the reactor plant protective system controlboard. A high degree of quality is maintained by rigid specifications and quality control. Components employed are of a high quality level and generally derated by at least 50%. Failure mode analysis has been made on critical circuitry. Wherever possible previously used circuitry, components, and modules have been employed minimizing the design of new circuitry. Solid-state circuitry is employed in conjunction with relays, utilizing the advantages of solid-state devices in low-level signal amplification and the advantages of relays for circuit isolation and for handling power. The procurement of all major plant systems is from reliable suppliers having previous experience in the design and construction of similar systems.

Channel Independence. In designing for channel independence, single events which are considered plausible include:

1. Shearing or blocking of process connections.
2. Rise in temperature, pressure, or humidity in the sensor, signal transmission, or readout area.
3. Vibration of process connections.
4. Severance, crushing, or shorting of wiring paths.
5. Fires in control areas.
6. Missiles.
7. Module removal.

# ATTACHMENT B.4

CN 1462A  
BY K. Bush  
PAGE B3.15A  
FORM NO. 372-30-2650

FSAR UPDATE  
7.1-6

In the design of the instrument system, the following means are employed to achieve channel independence:

1. The combining of redundant channels is made as close to the output portion of the systems as is practical. Hence, the use of the general logic scheme.
2. Channels are connected to the process system by physically separated instrument connections.
3. Redundant sensors are physically separated. For example, the neutron detectors and reactor pressure sensors are mounted in separate wells and PCRV penetrations spaced about the PCRV.
4. Wiring or cabling between redundant sensor locations and control room or control panel and on the controlboard are physically separated and mechanically protected where required.
5. Redundant power supplies are used to supply the various channels so that loss of a given power supply will not prevent system action or cause an unnecessary protective action.
6. Circuits are suitably fused and protected so that in the event of single grounds or shorts, the fault will be isolated and will not feed back into the system.
7. Circuits and components are used that, insofar as is practical, fail in a safe direction.
8. Sensor, protective apparatus, and readout components are physically located and protected to minimize possibility of accidental contact or damage. For example, the location of instruments within penetrations in the PCRV provides a considerable degree of protection from physical damage. The scram and other redundant plant protective system circuitry is located in separate vertical sections of controlboard separated by physical and thermal barriers.

Equipment Qualification. Various functional and calibration tests have been performed to ensure that the equipment is in conformance with the specification. This testing included:

1. Testing of components (such as plug-in assemblies).
2. Testing of assemblies (such as drawers or transmitters).
3. Point-to-point continuity and insulation resistance of wiring.

Accuracy, drift tests on assemblies have been made.



PUBLIC SERVICE COMPANY OF COLORADO

FORT ST. VRAIN NUCLEAR GENERATING STATION  
SAFETY RELATED DESIGN ANALYSIS SHEET 3

CN 1462A

BY K. Bush

PAGE B4A

REPLACE ENTIRE PAGE  
PER CN-1462A

Form 344-22-4089

X. ACCESSIBILITY FOR IN-SERVICE INSPECTION, MAINTENANCE, AND REPAIR

All equipment is accessible for inservice inspection or maintenance from one or more sides at all times.

XI. SEPARATION AND SEGREGATION ANALYSIS

All cables trays are designated by bus, loop and service. Tray spacing for redundant cables of 2 ft horizontally and 3 ft vertically as stated by Reg Guide 1.75 and IEEE 389 are being met by the installation. These design criteria are being met due to only failure or faults internal to electrical equipment. Power cables under the computer room raised floor shall be in flexible conduit.

XII. ELECTRICAL ANALYSIS

Electrical Equipment will be powered by the Distribution System, secondary power shall be via the ACM. Computer Room HVAC South will feed from HVAC MCC (N-9262) with secondary of ACM and Distribution. All equipment is non-safety related and does not require a reliable electrical power source.

XIII. ACCIDENT ANALYSIS

No new accident or hazard shall be created by this CN. All equipment will meet the spectra response for its application.

PREPARED BY

K. Bush

3/3/83

DATE

# GTICES STRUDL

INFORMATION  
ONLY

CN 1462  
BY N. KNOX  
PAGE 34.1  
FORM NO. 372-30-2650

**"This was the perfect program for static analysis and design of dam spillway tainter gates. We made rapid and accurate analyses that led to weight-savings of several hundred pounds per gate, and that resulted in a real increase in the service life of the operating equipment for the gates."**



## What GTICES STRUDL\* is

GTICES STRUDL (Georgia Institute of Technology Integrated Civil Engineering System STRUctural Design Language), is an advanced system for analysis and design of simple, complex, and one-of-a-kind structures. It allows the engineer to specify a structural problem, perform a variety of analyses, reduce and combine results, and output printed or graphic information.

GTICES STRUDL provides a highly cost effective means for analyzing and designing framed structures and performing finite element analysis of plates, shells, and other continuous structures. The system also provides automatic structural topology generation and the processing of joint releases and eccentricities, elastic supports, and a variety of loading types.

GTICES STRUDL also offers a finite element dictionary, a library of high quality proprietary elements which represent a major improvement over competitive versions of STRUDL.

STRUDL is one of the most widely used and applied engineering software packages in the field, and GTICES STRUDL, as offered by BCS, is the most efficient and cost-effective version available.

## What GTICES STRUDL does

- Provides a highly user oriented, comprehensive, state-of-the-art, and integrated general purpose structural analysis and design information processing system for practical engineering use
- Provides more cost effective utilization of structural engineering computer time and engineering per-

sonnel, while generating less costly, more reliable design results

## GTICES STRUDL Capabilities

- Structural analysis. (2D, 3D, finite element)
- Steel member selection. (AISC specifications)
- Dynamic analysis. (natural frequency, response spectrum, time history)
- Buckling analysis
- Geometric non-linear analysis for frames
- Problem size independent

## GTICES STRUDL is easy to use

- Command structured input
- Batch or Interactive processing
- User-defined output
- Automatic computation of structural weight
- Automatic generation of structural topology
- Nondestructive SAVE/RESTORE capabilities
- Data base management features that work
- Extensive error checking capabilities

## GTICES STRUDL is used by

- Architectural/engineering firms
- Structural engineering consultants
- Manufacturing companies
- Construction and fabrication industries
- Research and development facilities
- Universities and educational centers
- Power and public utilities
- Military and government agencies



GTICES STRUDL aids analysis and design

INFORMATION ONLY

LOADING = 1      DL = .75(ILL) = .75(ILL)Z1

RESULTANT JOINT DISPLACEMENTS FROM JOINTS

JOINT	MEMBER	DISPLACEMENT			ROTATION		
		X DISP.	Y DISP.	Z DISP.	X ROT.	Y ROT.	Z ROT.
2	SLCBAL	-.0115	-.0025	-.0003	.0006	.0088	-.1491
3	SLCBAL	-.0172	-.0027	-.0001	.0004	-.0022	-.1513
9	SLCBAL	-.0172	-.0027	-.0001	-.0004	.0022	-.1513
8	SLCBAL	-.0115	-.0025	-.0003	-.0006	-.0088	-.1491
9	SLCBAL	-.0096	-.0018	-.0003	.0011	-.0252	-.1313
9	SLCBAL	-.1293	-.0023	-.0002	.0007	-.0130	-.1361
10	SLCBAL	-.1294	-.0024	-.0009	.0007	.0114	-.1399
11	SLCBAL	-.0979	-.0019	.0000	.0000	-.0000	-.1421
12	SLCBAL	-.1294	-.0024	-.0009	-.0007	-.0114	-.1399

GTICES STRUDL is a practical, totally user oriented system for the analysis and design of simple, complex, and one-of-a-kind structures. Output for the stiffness analysis consists, in part, of a tabulation of displacement values at each joint for each applied loading condition. STRUDL then selects members in compliance with AISC steel design codes. (1989 code shown, 1978 code available)

JOBID = NAVPAC      TITLE = R 12  
 STANDARD UNITS = INCH POUND RADIAN DEGREE R SECOND

\*\*\* NOTE: 1) PROVISION VALUES ARE GIVEN IN CODE UNITS SHOWN BELOW, WHEN APPLICABLE  
 2) PARAMETER VALUES ARE GIVEN IN STANDARD UNITS, WHEN APPLICABLE  
 3) WHEN CRITICAL IS SPECIFIED ONLY ACTUAL/ALLOWABLE RATIOS ARE GIVEN FOR PROVISIONS  
 4) MEMBERS WHICH DO NOT SATISFY ALL RELEVANT CODE PROVISIONS ARE MARKED BY TWO ASTERISKS (\*\*)  
 5) WHEN CRITICAL IS SPECIFIED PARAMETERS GIVEN ARE FOR MOST CRITICAL LOCATION

*Code criteria  
 Axial tension & bending members*

MEMBER CODE	PROFILE TABLE	RAJID SECTION	LOADING	CRITICAL NAME	PROVISION RATIO	PARAMETER NAME	VALUE	PARAMETER NAME	VALUE
1	W18X40	5.00	7	F21.6-2	.9239	PYLD	3.600E+04	KZ	1.150E+00
	STEELW	5.00	8	F21.6-2	.8813	KY	1.000E+00	CODETOL	1.000E+00
2	W10X25	40.00	5	F21.6-18	1.0021	PYLD	3.600E+04	KZ	1.150E+00
	STEELW	40.00	6	F21.6-2	.9278	KY	1.000E+00	CODETOL	1.000E+00

GTICES STRUDL summary of selected steel sections.

JOB ID = NAVPAC      JOB TITLE = R 12


ACTIVE UNITS = LENGTH INCH      HEIGHT FT      ANGLE DEG      TEMPERATURE DEG      TIME SEC

MEMBER PROPERTIES

MEMBER/SEC	TYPE	SECTION	AREA	PERIOD	AREA/C	IX/EC	IX/IEY	IX/IEZ	SY	SZ
1	W18X40	STEELW	11.600	5.656	4.294	.708	19.100	912.300	8.340	58.400
	W10X25	STEELW	17.100	6.218	3.453	1.009	6.200	1.000		
2	W10X25	STEELW	7.350	2.540	3.104	.373	13.700	133.000	4.760	10.500
	W10X25	STEELW	10.080	5.752	3.340	2.481	2.000	2.000		

*From AISC tables for wide flange sections*

The Engineer's Computer Service Company  
 Boeing Computer Services, a division of The Boeing Company, is well equipped to meet your engineering/scientific needs. Via the nationwide BCS communications network you can access our three MAINSTREAM time-sharing services for integrated interactive and batch processing on CDC CYBER and IBM hardware. We also offer a broad range of established applications plus full customizing service. More than 1000 BCS engineers and computing specialists are committed to serving you.




\*GTICES STRUDL is a proprietary product of Georgia Institute of Technology, Atlanta, GA.

FT. ST. URAIN 3RCA CABLE TRAY SEISMIC SUPP  
 CALCULATIONS.

SUPPORT SPACING = 6'-0" c.c.  
 CABLE TRAY WIDTH = 1.5'  
 CABLE TRAY WEIGHT = 55 psf  
 DESIGN LOAD =  $6 \times 1.5 \times 55 = 495 \#$

MAX HORIZ  $\ddot{x} = 3.4$   
 MAX VERT  $\ddot{G} = 1.1$   
 ELEV. 4835'-6"  
 W/ 2% DAMPING  
 FSU 3RCA  
 RESPONSE SPECTRA



CABLE TRAY HANGER

LOADS:  $P \& H = \text{MAX. } \ddot{G} \text{ FORCE} \times \text{DESIGN LOAD}$   
 $P = (1.1 + 1) 495 = 1039.5 \#$  USE 1040 #  
 $H = (3.4) 495 = 1683 \#$

ANALYSIS BY ED HICKS 9/28/82

Ed Hicks by Bob [Signature]

THIS PAGE INTENTIONALLY  
LEFT BLANK PER  
CN-1462 B

CN 1462 B  
BY K. Bush  
PAGE B5.2 B  
FORM NO. 372-30-2549

THIS PAGE INTENTIONALLY  
LEFT BLANK PER  
CN-1462 B

CN 1462 B  
BY K. Bush  
PAGE 35.3 B  
FORM NO. 372-30-2649

THIS PAGE INTENTIONALLY  
LEFT BLANK PER  
CN-1462 B

CALCULATIONS FOR			CN 1462 B
EQUIP. NO.			BY J. TESNER
PROJ. NO.			PAGE 86 B
CALC. NO.			FORM NO. 372-30-2650
PREPARED BY	DATE	REPLACE ENTIRE PAGE PER CN-1462B	
REVIEWED BY <i>Mark Muller</i>	DATE <i>8/16/83</i>		
APPROVED BY	DATE		

UNISTRUT CONCRETE INSERTS

THE PURPOSE OF THIS MEMO IS TO OUTLINE THE STRUCTURAL DEPARTMENT'S VIEWS AND RECOMMENDATIONS ON USE OF GTE UNISTRUT P3300 SERIES CONTINUOUS CONCRETE INSERTS TO SUPPORT CLASS I / NON CLASS I ATTACHMENTS TO BUILDING 10.

TEST DATA (REF: DETROIT TESTING LABORATORY, INC. REPORT NO. 312178-D DATED 9/24/74) DOCUMENT THE INITIAL YIELD AND ULTIMATE CAPACITY OF SUBJECT CONCRETE INSERTS. DESIGN LOADS LISTED IN THE REPORT WERE EXCEEDED BY TEST RESULTS BY A MINIMUM FACTOR OF SAFETY OF 3. FOUR PULLOUT AND TWO SHEAR TESTS WERE CONDUCTED FOR VARIOUS LENGTHS OF UNISTRUT WITH THE CENTER OF GRAVITY OF LOAD AT THE MIDPOINT ALONG THE UNISTRUT LENGTH.

RECOMMENDED LOAD FOR THE INSERTS SHOWN IN THE UNISTRUT CATALOG NO. 9 IS 1500 LBS PER FOOT OF UNISTRUT LENGTH FOR PULLOUT TYPE LOADING; THIS VALUE IS BASED ON CONCRETE COMPRESSIVE STRENGTH OF 5000 PSI. FOR BUILDING 10 APPLICATIONS THE ALLOWABLE LOAD SHOULD BE REDUCED TO

$$1500 \text{ LBS/FT} \times \frac{3500 \text{ PSI}}{5000 \text{ PSI}} = 1050 \text{ LBS/FT (PULLOUT)}$$

ALLOWABLE LOAD FOR DIRECTION TRANSVERSE TO THE LONGITUDINAL AXIS (OTHER THAN PULLOUT) BASED ON UNISTRUT DESIGN LOAD DATA SHOULD BE

$$1260 \text{ LBS/FT} \times \frac{3500 \text{ PSI}}{5000 \text{ PSI}} = 880 \text{ LBS/FT (SHEAR)}$$

IN CONCLUSION, IT IS FELT THAT USE OF THE P3300 SERIES UNISTRUT CONCRETE INSERTS ARE ACCEPTABLE AS DESCRIBED HEREIN WITH THE FOLLOWING STIPULATIONS: (SEE PAGE 99.4B)

CN 1462B  
BY K. Bush  
PAGE B7B  
FORM NO. 372-30-2649

THIS PAGE INTENTIONALLY  
LEFT BLANK PER  
CN-1462B

THIS PAGE INTENTIONALLY  
LEFT BLANK PER  
CN-1462 B



THIS PAGE INTENTIONALLY  
LEFT BLANK PER  
CN-1462 B

CN 1462 B  
BY K. Bush  
PAGE B10 B  
FORM NO. 372-30-2649

THIS PAGE INTENTIONALLY  
LEFT BLANK PER  
CN-1462 B

THIS PAGE INTENTIONALLY  
LEFT BLANK PER  
CN-1462 B

CN 1462 B  
BY K. Bush  
PAGE B12 B  
FORM NO. 372-30-2649

THIS PAGE INTENTIONALLY  
LEFT BLANK PER  
CN-1462 B

THIS PAGE INTENTIONALLY  
LEFT BLANK PER  
CN-1462 B

CALCULATIONS FOR		CN 1962B
<b>REPLACE ENTIRE PAGE</b>		BY J. TESNER
PREPARED BY PER CN-1962B	DATE	PAGE B14 B
REVIEWED BY	DATE	FORM NO. 372-30-2650
Mark Malina 8/16/83		

### CABLE TRAY SUPPORTS - GENERAL DESIGN NOTES

- 1) LOADS FROM TRAYS FOR SEISMIC AND DEAD WEIGHT CONDITIONS USED IN STRUCTURAL EVALUATION OF SUPPORTS (EXCEPT 10" X 14" BASE PLATE/ANCHOR BOLTS FOR 6x6 VERTICAL MEMBERS) WERE CALCULATED IN CN-1462 (PAGE B-5). THESE LOADS ARE BASED ON A SUPPORT SPACING OF 6 FT WITH TRAYS HOLDING THE MAXIMUM RECOMMENDED WEIGHT OF CABLES. A FACTOR OF 1.5 IS APPLIED TO THE PEAK HORIZONTAL AND VERTICAL SEISMIC DBE RESPONSE ACCELERATIONS (AND, CONSERVATIVELY, TO THE DEAD WEIGHT) TO ACCOUNT FOR CONTRIBUTION OF VARIOUS MODES OF VIBRATION.
  
- 2) SOME OVERALL DIMENSIONS FOR THE SUPPORTS WERE CHANGED FROM THOSE IN THE FOLLOWING ANALYSIS DUE TO CONSTRUCTION CONSIDERATIONS. FOR CHANGES IN HORIZONTAL CLEAR SPANS BETWEEN VERTICAL ANGLES THE FINAL DIMENSIONS SHOWN ON DRAWINGS REISSUED PER CN-1462B ARE LESS THAN OR EQUAL TO THOSE USED IN THE CALCULATIONS, THUS THE ANALYSIS PRODUCES CONSERVATIVE RESULTS. LENGTHS FOR VERTICAL MEMBERS, WHICH EXHIBIT A BENDING MODE UPON LATERAL LOAD APPLICATION, WERE SHORTENED WITH THE EXCEPTION BEING THE TYPE 1/TYPE 2 SUPPORTS. FOR THESE, THE DISTANCE FROM THE BOTTOM OF FLOOR SLAB DECKING TO THE UPPER TRAY WAS INCREASED 2 INCHES WHILE THE POSITION OF THE LOWER TRAY REMAINED UNCHANGED. THIS SLIGHT INCREASE IS ACCEPTABLE BY ENGINEERING JUDGEMENT.
  
- 3) IN CHECKING OF ANGLE-TO-ANGLE CONNECTION BOLTS, THE FOLLOWING OBSERVATIONS AND ASSUMPTIONS ARE MADE:
  - A) ALL SUPPORTS CARRY ONE 18 INCH WIDE TRAY OR TWO 9 INCH WIDE TRAYS PER LEVEL. SUPPORT TYPE 6 WAS CHANGED FROM A THREE 18 INCH TRAY TO A TWO 9 INCH TRAY SUPPORT BY ELECTRICAL ENGINEERING.

Add ENTIRE PAGE

CALC. NO.

CN 1462B

PREPARED BY PER CN-1462B

DATE

REF. DOCUMENTS:

BY J. TESNER

REVIEWED BY

DATE


PAGE 819.1

FORM NO. 372-30-2650

Mark Miller 8/16/93

B) ASSUME HORIZONTAL SEISMIC LOAD PER LEVEL IS ATTEMPTING TO SHEAR THE JOINT BOLTS AT EACH END OF THE HORIZONTAL ANGLE EQUALLY.

C) FOR VERTICAL LOAD, WORST CASE IS FOUND IN SUPPORT TYPE 4 SINCE TRAYS ARE STAGGERED AND ONE 18 INCH TRAY WILL BE MOUNTED CLOSE TO THE END OF THE HORIZONTAL L4x4x5/16 OH ON BOTH THE TOP AND BOTTOM LEVELS. ASSUME ENTIRE VERTICAL LOAD OF ONE 18 INCH TRAY IS SUPPORTED BY A SINGLE BOLT.



$$F_v = 1040 \text{ LBS}$$

$$F_h = \frac{1683}{2} = 842 \text{ LBS}$$

$$F_r = \sqrt{F_v^2 + F_h^2}$$

$$= \sqrt{(1040)^2 + (842)^2}$$

$$= 1338 \text{ LBS}$$

SHEAR STRESS BASED ON NOMINAL BOLT AREA -

GROSS  $A_g$  FOR  $\frac{1}{2}$ "  $\phi$  BOLT = 0.196 SQ IN

$$f_v = \frac{F_r}{A_g} = \frac{1338 \text{ LBS}}{0.196 \text{ SQ IN}} = 6827 \text{ PSI} < 21 \text{ KSI} \text{ * OK}$$

\* ALLOWABLE FOR BEARING TYPE CONNECTION, THREADS IN SHEAR PLANE, ASTM A325 BOLTS

BEARING ON ANGLE HOLE AND END TEAR-OUT WILL NOT GOVERN BY INSPECTION OF MATERIAL THICKNESS & EDGE DISTANCE

4) CHECK ANGLE UNBRACED LENGTHS [REF SDCC-011 ISSUE 6, SECT. 4.6]

$$\text{MAXIMUM UNBRACED LENGTH} = 76 b_f / \sqrt{F_y}$$

$$\text{FOR } L3 \times 3, l_b = 76(3) / \sqrt{36} = 38 \text{ IN.}; \text{ ACTUAL MAX. } 38 \text{ IN (TYPE 2)}$$

$$\text{FOR } L4 \times 4, l_b = 76(4) / \sqrt{36} = 51 \text{ IN.}; \text{ ACTUAL MAX. } 66 \text{ IN (TYPE 4)}$$

$$\text{FOR } L6 \times 6, l_b = 76(6) / \sqrt{36} = 76 \text{ IN.}; \text{ ACTUAL MAX. } 76 \text{ IN (TYPE 3)}$$

(CLEAR SPAN LENGTHS LISTED FOR ACTUAL SPANS)

CALCULATIONS FOR

Add ENTIRE PAGE

CALC. NO.

CN 1462B

PREPARED BY PER (N-1462B)

DATE

REF. DOCUMENTS:

BY J. TESNER

REVIEWED BY

DATE

PAGE B14.2 B

Mark Muller 8/16/93

FORM NO. 372-30-2650

FOR L4x4, TYPE 4, MAXIMUM MOMENT OCCURS WITH SINGLE 19 INCH TRAY AT CENTER OF SPAN (SPAN DIM. USED IS  $\bar{E}$  TO  $\bar{E}$  BOLTS)

$$M = \frac{PL}{4} = \frac{(1040 \text{ LBS})(73 \text{ IN})}{4} = 18980 \text{ IN-LBS}$$

PROPERTIES OF L4x4x5/16 CALCULATED ELSEWHERE IN THIS CN:

$$S_W = 2.09 \text{ IN}^3 \quad (\text{STRONG PRINCIPAL AXIS})$$

$$S_{Z \text{ MIN}} = 0.95 \text{ IN}^3 \quad \left. \begin{array}{l} \\ \\ \end{array} \right\} \text{WEAK PRINCIPAL AXIS}$$

$$S_{Z \text{ MAX}} = 1.20 \text{ IN}^3$$

STRESS AT ANGLE VERTEX -

$$\sigma_1 = \frac{0.707M}{S_{Z \text{ MIN}}} = \frac{(0.707)(18980 \text{ IN-LBS})}{0.95 \text{ IN}^3} = 14,125 \text{ PSI}$$

STRESS AT ANGLE LEG TIP -

$$\sigma_2 = 0.707M \left( \frac{1}{S_W} + \frac{1}{S_{Z \text{ MAX}}} \right)$$

$$= (0.707)(18980 \text{ IN-LBS}) \left( \frac{1}{2.09 \text{ IN}^3} + \frac{1}{1.20 \text{ IN}^3} \right) = 17,603 \text{ PSI}$$

EACH OF THESE FIGURES LIES FAR BELOW  $F_y = 36 \text{ KSI}$ , THE PERMISSIBLE BENDING STRESS FOR THE DW + OBE EARTHQUAKE LOAD COMBINATION PER THE FSAR. THEREFORE, LATERAL BUCKLING OF THE BEAM IS NOT A POSSIBLE FAILURE MODE.


FOR ALL OTHER SECTIONS, CALCULATED STRESSES ON FOLLOWING PAGES FOR ANGLES IN BENDING ARE LESS THAN 36 KSI, WHICH IS ACCEPTABLE.



CALCULATIONS FOR	ADD ENTIRE PAGE	CALC. NO.	CN 1462 B
PREPARED BY	PER CN-1462B DATE	REF. DOCUMENTS:	BY J. TESNER
REVIEWED BY	DATE		PAGE 819.3 B
	2 March Muller 8/18/83		FORM NO. 372-30-2650

CABLE TRAY SUPPORTS      GENERIC CALCULATIONS

HORIZONTAL MEMBERS - MAX. SPAN, MAX. LOAD - TYPE 6



3 TRAYS 18" EACH  
 TOTAL VERT. LOAD = (3)(1040)  
 = 3120 LBS  
 EQUIVALENT DIST. UNIF. LOAD  
 $W = 3120 \text{ LBS} / 6 \text{ FT}$   
 = 520 LBS/FT

$$M = \frac{wL^2}{8} = \frac{(520 \text{ LBS/FT})(6 \text{ FT})(72 \text{ IN})}{8}$$

$$= 28080 \text{ IN-LBS}$$

FROM PROPERTIES OF  $L4 \times 4 \times 5/16$ :

$$S_x = 2.09 \text{ IN}^3$$

$$S_z = 0.95 \text{ IN}^3$$

$$f_b = (0.707)(28080) \left( \frac{1}{2.09} + \frac{1}{0.95} \right) = 30,400 \text{ PSI} < 36 \text{ KSI}$$

(DBE LOAD CONDITION)

CHECK AXIAL COMPRESSION:

$$P = (3)(1683 \text{ LBS}) = 5049 \text{ LBS}$$

$$f_a = P/A = 5049 \text{ LBS} / 2.4 \text{ SQ IN} = 2104 \text{ PSI}$$

$$\frac{KL}{r} = \frac{(1)(72 \text{ IN})}{0.791} = 91 \quad F_a = 14.09 \text{ KSI}$$


$$f_a / F_a = \frac{2104}{14,090} = 0.15 \quad \text{COMBINED STRESSES OK}$$

SHEAR STRESS OK BY INSPECTION

→ USE  $L4 \times 4 \times 5/16$  FOR HORIZ. MEMBER, 6 FT SPAN

(TYPES 4 & 6 TRAYS)

CALCULATIONS FOR		CN <u>1462 B</u>
Add PAGE PER		CALC. NO.
PREPARED BY	CN-1462 B	DATE
REVIEWED BY	<u>Mark Muller</u>	DATE
		REF. DOCUMENTS:
		PAGE <u>814.4 B</u>
		FORM NO. 372-30-2650



FOR  $2 \times 4 \times 5/16$ :

$$I_x = I_y = 3.71 \text{ in}^4$$

$$r_z = 0.707 \text{ in}$$

$$A = 2.4 \text{ in}^2$$

$$r = \sqrt{r_z^2} \quad I = Ar^2$$

$$I_z = (2.4)(0.707)^2 = 1.50 \text{ in}^4$$

$$I_w = I_x + I_y - I_z$$

$$= (2)(3.71) - 1.50$$

$$= 5.92 \text{ in}^4$$

$$Cz_2 = (1.414)(1.12 \text{ in})$$

$$= 1.58 \text{ in}$$

$$Cz_1 = (4 \text{ in})(0.707) - 1.58 \text{ in}$$

$$= 1.25 \text{ in}$$

$$Cw = (4 \text{ in})(0.707)$$


$$= 2.83 \text{ in}$$

$$S_w = \frac{I_w}{Cw} = \frac{5.92}{2.83} = 2.09 \text{ in}^3$$

$$S_{z_{MN}} = \frac{I_z}{Cz_2} = \frac{1.50}{1.58} = 0.95 \text{ in}^3$$

CALCULATIONS FOR		CALC. NO.	CN 1462 B
PREPARED BY		REF. DOCUMENTS:	BY J. TESNER
REVIEWED BY			PAGE B14.5 B
Add PAGE PER CN-1462 B DATE 8/19/83			FORM NO. 372-30-2650

HORIZONTAL MEMBERS CHECK 4'-0 SPAN, 1 1/8" TRAY



$$M = \frac{PL}{4} = \frac{1040(48\text{IN})}{4} = 12480\text{IN-LBS}$$

REF: SDOCC-025 ISSUE 3 ATTACH. A  
TRAY L 3x3x1/4

$$f_b = MB = (12480\text{IN-LBS})(2.155) = 26,900\text{PSI} < 36\text{KSI}$$

AXIAL, SHEAR STRESS ACCEPTABLE BY INSPECTION

→ USE L 3x3x1/4 FOR HORIZ. MEMBER 4'-0 SPAN AND UNDER (TYPES 1, 2, 3, 5, 7 & 8)

VERTICAL MEMBERS

TYPE 1:  $M = (1/2)(1083\text{LBS})(0.5)(24\text{IN} + 44\text{IN}) = 23611\text{IN-LBS}$   
(9" TRAYS)

TYPE 2: SAME AS ABOVE  
(9" TRAYS)

TYPE 3:  $M = (1/2)(1083\text{LBS})(36\text{IN} + 54\text{IN} + 72\text{IN}) = 136,323\text{IN-LBS}$   
(13" TRAYS)

TYPE 4:  $M = (1/2)(1083\text{LBS})(36\text{IN} + 48\text{IN} + 66\text{IN}) = 106,005\text{IN-LBS}$   
(13" TRAYS)

TYPE 5:  $M = (1/2)(1083\text{LBS})(28\text{IN}) = 23562\text{IN-LBS}$   
(13" TRAY)

TYPE 6:  $M = (1/2)(1083\text{LBS})(3)(28\text{IN}) = 70686\text{IN-LBS}$   
(18" TRAYS)

TYPE 7:  $M = (1/2)(1083\text{LBS})(60\text{IN} + 78\text{IN} + 96\text{IN}) = 196,911\text{IN-LBS}$   
(18" TRAYS)

TYPE 8:  $M = (1/2)(1083\text{LBS})(24\text{IN}) = 20,196\text{IN-LBS}$

GROUP A: TYPES 1, 2, 5, 8

GROUP B: TYPES 3, 4, 7

GROUP C: TYPE 6

CALCULATIONS FOR		CN <u>K628</u>
Add PAGE PER		BY <u>J. TESNER</u>
PREPARED BY	<u>CN-1462 B</u>	REF. DOCUMENTS:
REVIEWED BY	<u>Mark Muller</u>	PAGE <u>814.6 8</u>
	<u>8/19/83</u>	FORM NO. 372-30-2650


FOR GROUP A USE  $L 4 \times 4 \times 5/16$  (PREVIOUS HOVRZ. MEMBER CALCS SHOW  $L 4 \times 4$  CAN HANDLE  $M = 23,030$  IN-LBS)

FOR GROUP C TRY  $L 6 \times 6 \times 3/16$  -  
 $S_z = 3.71$  IN<sup>3</sup> } FROM STAAD RUN  
 $S_w = 8.29$  IN<sup>3</sup> }

$$f_b = (0.707)(70686 \text{ IN-LBS}) \left( \frac{1}{3.71 \text{ IN}^3} + \frac{1}{8.29 \text{ IN}^3} \right) = 19,500 \text{ PSI} < 30 \text{ KSI}$$

(CONSERVATIVE) OK

FOR GROUP B TRY  $L 6 \times 6 \times 3/16$  -



$$A = 6.43 \text{ IN}^2$$

$$r_z = 1.18 \text{ IN}$$

$$I_x = I_y = 22.1 \text{ IN}^4$$

$$I_z = (2.43)(1.18)^2 = 3.95 \text{ IN}^4$$

$$I_w = I_x + I_y - I_z = (2)(22.1) - 3.95 = 35.25 \text{ IN}^4$$

$$CE_2 = (1.414)(1.71 \text{ IN}) = 2.42 \text{ IN}$$

$$CE_1 = (0.707)(0.707) = 2.42 \text{ IN}$$

$$= 1.822 \text{ IN}$$

MAX STRESS FOR  $M_z$  OCCURS AT A

$$CW = (0.707)(0.707) = 4.24 \text{ IN}$$

$$M_y = 196,911 \text{ IN-LBS}$$

$$M_z = M_w = (0.707)(196,911 \text{ IN-LBS}) = 139,216 \text{ IN-LBS}$$

$$s_{z \text{ MIN}} = \frac{I_z}{CE_2} = \frac{3.95 \text{ IN}^4}{2.42 \text{ IN}} = 3.70 \text{ IN}^3$$

$$s_{z \text{ MAX}} = \frac{I_z}{CE_1} = \frac{3.95 \text{ IN}^4}{1.82 \text{ IN}} = 4.92 \text{ IN}^3$$

$$s_w = \frac{I_w}{CW} = \frac{35.25 \text{ IN}^4}{4.24 \text{ IN}} = 8.31 \text{ IN}^3$$

CALCULATIONS FOR		CN <u>1462 B</u>
Add PAGE PER		BY <u>J. TESNER</u>
PREPARED BY <u>CN-1462 B</u>	DATE	REF. DOCUMENTS:
REVIEWED BY <u>G. Mack Mullin</u>	DATE <u>8/19/93</u>	PAGE <u>814.7 B</u>
		FORM NO. 372-30-2650

STRESS AT POINT A:

$$(f_c)_A = \frac{M_z}{S_{z\text{MIN}}} = \frac{139,216 \text{ IN-LBS}}{3.70 \text{ IN}^3} = 37,626 \text{ PSI N.G.}$$

STRESS AT POINTS B & C:

$$\begin{aligned} (f_c)_{B,C} &= \frac{M_z}{S_{z\text{MAX}}} + \frac{M_w}{S_w} = \frac{139,216 \text{ IN-LBS}}{4.92 \text{ IN}^3} + \frac{139,216 \text{ IN-LBS}}{3.31 \text{ IN}^3} \\ &= 28,296 \text{ PSI} + 16,753 \text{ PSI} \\ &= 45,049 \text{ PSI N.G.} \end{aligned}$$

TRAY TYPES 3 & 4:

$$M_y = 136,323 \text{ IN-LBS}$$

$$\begin{aligned} M_z = M_w &= (0.707)(136,323 \text{ IN-LBS}) \\ &= 96,380 \text{ IN-LBS} \end{aligned}$$

$$(f_c)_A = \frac{96380}{3.70} = 26,049 \text{ PSI} < 36 \text{ KSI OK}$$

$$(f_c)_{B,C} = \frac{96380}{4.92} + \frac{96380}{3.31} = 19,589 + 11,598 = 31,187 \text{ PSI} < 36 \text{ KSI OK}$$

AXIAL, SHEAR STRESS ACCEPTABLE BY INSPECTION

USE  $\angle 6 \times 6 \times 3/16$  FOR TYPE 3 & 4, ALSO FOR TYPE 7 BUT ADD DIAGONAL BRACES


SUPPORT TYPE	HORIZONTAL MEMBERS (QTY)	VERTICAL MEMBERS (QTY)	BRACING (YES/NO)
1	$\angle 3 \times 3 \times 1/4$ (2)	$\angle 4 \times 4 \times 3/8$ (2)	NO
2	$\angle 3 \times 3 \times 1/4$ (2)	$\angle 4 \times 4 \times 3/8$ (2)	NO
3	$\angle 3 \times 3 \times 1/4$ (3)	$\angle 6 \times 6 \times 3/16$ (2)	NO
4	$\angle 4 \times 4 \times 3/16$ (3)	$\angle 6 \times 6 \times 3/16$ (2)	NO
5	$\angle 3 \times 3 \times 1/4$ (1)	$\angle 4 \times 4 \times 3/16$ (2)	NO
6	$\angle 4 \times 4 \times 3/16$ (1)	$\angle 6 \times 6 \times 3/16$ (2)	NO
7	$\angle 3 \times 3 \times 1/4$ (3)	$\angle 6 \times 6 \times 3/16$ (2)	YES
8	$\angle 3 \times 3 \times 1/4$ (1)	$\angle 4 \times 4 \times 3/16$ (2)	NO

CABLE TRAY SUPPORTS - BASE PLATES

FOR  $4 \times 4 \times 5/16$ ,  $M = 28,611 \text{ IN-LBS}$   
 $P = \frac{1040}{2} = 520 \text{ LBS}$   
 $V = \frac{168^3}{2} = 340 \text{ LBS}$

TRY #  $8 \times 8 \times 5/8$

REF SDCC-025 ATTACH. A P. 2




$T_M = \frac{28,611 \text{ IN-LBS}}{(2 \text{ BOLTS})(7.5)(6.75 \text{ IN})} = 3179 \text{ LBS/BOLT}$

$T_P = \frac{520 \text{ LBS}}{4 \text{ BOLTS}} = 130 \text{ LBS/BOLT}$

$T_{TOTAL} = T_M + T_P = 3179 + 130 = 3309 \text{ LBS}$

TRY  $3/4$ " BOLTS



$r = \text{BEND INSIDE RADIUS} = 3d = (3)(0.75 \text{ IN}) = 2.25 \text{ IN}$   
 $s = \text{STRAIGHT EMBEDMENT (MIN.)} = 4.5 - 1.75 - 0.75 - 2.25 = -0.25 \text{ N.G.}$

SET TOP OF ANCHOR BOLTS IMMEDIATELY BELOW BOTTOM OF SLAB EDGE

$e = 4.5 - 1.25 - 0.75 - 2.25 = 0.25 \text{ IN}$

CALCULATIONS FOR		CN 1462 B	OF
PREPARED BY		BY J. TEINER	
REVIEWED BY		PAGE 819.9 B	
DATE		FORM NO. 372-30-2650	
Add PAGE PER CN-1462 B → Mark Muller 2/19/83		CALC. NO.	
		REF. DOCUMENTS:	

CHECK EFFECTIVE ANCHORAGE OF STANDARD HOOK IN TENSION

FOR #6 BAR (NOM. DIA. 3/4") ASSUME TOP BAR  $\ell_d = 450$  FOR  
 $f_y = 60,000$  PSI

$$f_n = \frac{\ell_d}{4} f_c' = 450 \sqrt{3500} = 26,622 \text{ PSI (REF ACI 318-77 SECTION 12.5.1)}$$

CORRECTING FOR SMOOTH BAR,  $f_y = 36,000$  PSI -

$$f_n' = \left(\frac{1}{2}\right) \left(\frac{36}{60}\right) (26,622 \text{ PSI}) = 7987 \text{ PSI}$$

PER THE ACI 1963 CODE, BOND STRESS TO DETERMINE EFFECTIVE ANCHORAGE OF EMBEDMENT LENGTHS FOR SMOOTH BARS IS EQUAL TO 1/2 OF THAT FOR DEFORMED BARS

ACTUAL TENSILE STRESS BASED ON NOMINAL BOLT DIA.

$$T = \frac{P}{A} = \frac{3309 \text{ LBS}}{\pi (0.75 \text{ IN})^2 / 4} = 7490 \text{ PSI} < 7987 \text{ PSI OK}$$

SHEAR STRESS ACCEPTABLE BY INSPECTION

CHECK BAR BEARING ON CONCRETE -

$$\text{ALLOWABLE STRESS} = 0.375 f_c' = 1312.5 \text{ PSI (AISC 1.5.5)}$$

$$\text{ACTUAL STRESS} = \frac{P}{A} = \frac{3309 \text{ LBS}}{(3 \text{ IN})(0.75 \text{ IN})} = 490 \text{ PSI OK}$$

PROJECTED AREA OF STRAIGHT PORTION OF BAR ON CONCRETE

CONCRETE CONE PULLOUT IS NOT A GOVERNING CONCERN SINCE CONCRETE IS CONFINED BY DECKING AND #4E IS WELL REINFORCED.

CHECK #6 ENDING -


$$M = (2)(3309 \text{ LBS})(1 \text{ IN}) = 6618 \text{ IN-LBS}$$

$$I = 50 \frac{\text{IN}^4}{6} = (3 \text{ IN})(0.625 \text{ IN})^3 / 6 = 0.521 \text{ IN}^4$$

$$f = \frac{M}{I} = \frac{6618 \text{ IN-LBS}}{0.521 \text{ IN}^4} = 12,707 \text{ PSI} < 36 \text{ KSI (4.5 } f_y) \text{ OK}$$

CALCULATIONS FOR		CALC. NO.	CN 1462 B	OF
PREPARED BY	<div style="border: 1px solid black; border-radius: 50%; padding: 5px; display: inline-block;">             Add PAGE PER           </div>	REF. DOCUMENTS:	BY J. TESNER	
REVIEWED BY	<div style="border: 1px solid black; border-radius: 50%; padding: 5px; display: inline-block;">             CN-1462 B           </div>		PAGE B-14.10 B	
	Mark Muller 2/19/83		FORM NO. 372-30-2650	

CHECK BASE WELD



$$S = \frac{(3.69)^2 ((4)(3.69) + 3.69)}{(6)((2)(3.69) + 3.69)}$$

$$= 3.78 \text{ IN}^2$$

[SEE SLOTTED DESIGN OF WELDED STRUCTURES]

$$L_w = (2)(3.69) = 7.38 \text{ IN}$$

$$f_{wres} \approx f_{wy} = \frac{28,611 \text{ IN-LBS}}{3.78 \text{ IN}^2} = \frac{520 \text{ LBS}}{7.38 \text{ IN}}$$

$$= 7640 \text{ LBS/IN}$$

ALLOWABLE STRESS - ACTUAL STRESS BASED ON AREA THROUGH WELD THROAT

WELD GOVERNS:  $(21 \text{ KSI})(4/3) = 28 \text{ LSI}$  (INCREASED 1/3 FOR DBE)  
 BASE METAL GOVERNS:  $[(0.4)(36 \text{ KSI})/0.707](4/3) = 27.2 \text{ LSI}$

$$t_w = \frac{f_{wres}}{(t)(0.707)} \quad t = \frac{7640 \text{ LBS/IN}}{(27,200 \text{ PSI})(0.707)} = 0.40 \text{ IN}$$

USE 1/4 IN. FILLET ALL AROUND - S WILL BE APPROX. DOUBLE SINCE C DISTANCE REMAINS ESSENTIALLY THE SAME AND I WILL MORE THAN DOUBLE.




EASE FLATES

FOR SUPPORTS WITH VERTICAL L6x6, ELEV. T.O.C. SLAB TO WHICH THEY ARE ATTACHED IS 4311'-0". ORIGINAL ANALYSIS BASED ON ARS AT 4335'-6". REDUCTION IN HORIZONTAL SEISMIC LOAD IS AS FOLLOWS:

PEAK HORIZ. g AT 4335'-6" (2% DAMPING) = 3.4 (CEE)  
 PEAK HORIZ. g AT 4311'-0" (5% DAMPING) = 1.4 (CEE)

$$M_{max} = (136,323 \text{ IN-LBS}) \left( \frac{1.4}{3.4} \right) = 56,133 \text{ IN-LBS}$$



$$T_m = \frac{56,133 \text{ IN-LBS}}{(3 \text{ BOLTS}) \left( \frac{7}{8} \right) (3.75 \text{ IN})}$$

$$= 3208 \text{ LBS/BOLT}$$

$$T(\text{DIRECT PULLOUT}) = (3 \text{ TRAYS}) (1040 \text{ LBS PER TRAY}) / (2) (6 \text{ BOLTS})$$

$$= 260 \text{ LBS/BOLT}$$

$$V = (3 \text{ TRAYS}) (1683 \text{ LBS/TRAY}) / (2) (6)$$

$$= 421 \text{ LBS/BOLT}$$

TENSION LOAD OF  
 $3208 + 260 = 3468 \text{ LBS}$   
 ACCEPTABLE FOR  $7/8" \phi$   
 L-BOLT PER CALCS FOR  
 BASE  $\#$  ON L4x4x5/16  
 SHEAR ACCEPTABLE BY INSPECTION

\* ACTUAL CABLE TRAY SUPPORTS ARE BOLTED STEEL STRUCTURES WITH RIGID BASE ATTACHMENTS. REG. GUIDE 1.01 ALLOWS USE OF 4% LAMINAR FOR WELDED STEEL AND 7/8 FOR BOLTED STEEL STRUCTURES WHEN CONSIDERING D.E.E LOADS. USE OF 5% DAMPING IS NEARLY 100%.

Add Page Per

PREPARED BY

CN-1462 B

DATE

REVIEWED BY

DATE

March Muller 8/18/83

CALC. NO.

REF. DOCUMENTS:

CN 1462 B

BY J. TESNER

OF

PAGE BK. 12 B

FORM NO. 372-30-2650

## CHECK WELD AT BASE -

FOR 6x6x $\frac{7}{16}$  ANGLE, WELD ON INSIDE LEGS:  
(SEE BELOW FOR CALCULATION OF WELD PROPERTIES)

$$S = 8.22 \text{ IN}^2 \quad L_w = 10.88 \text{ IN}$$

$$f_{wy} = \frac{1560 \text{ LBS}}{10.88 \text{ IN}} + \frac{56,133 \text{ IN-LBS}}{8.22 \text{ IN}^2} = 6972 \text{ LBS/IN}$$

SHEAR STRESS IS LOW,  $f_{wy}$  IS ESSENTIALLY RESULTANT

$$\sigma_w = \frac{6972 \text{ LBS/IN}}{(0.707)(0.375 \text{ IN})} = 26.3 \text{ KSI} < 27.2 \text{ KSI OK FOR } \frac{3}{8} \text{ FILLET}$$

SPECIFY  $\frac{7}{16}$ " FILLET FOR SAFETY MARGIN

## CHECK BASE PLATE -

$$M = (3 \text{ BOLTS})(3468 \text{ LBS/BOLT})(1 \text{ IN.})$$


$$= 10,404 \text{ IN-LBS}$$

$$S = (14 \text{ IN})(0.875 \text{ IN})^2/6 = 1.79 \text{ IN}^3$$

$$\sigma = \frac{M}{S} = \frac{10,404 \text{ IN-LBS}}{1.79 \text{ IN}^3} = 5824 \text{ PSI} < 50 \text{ KSI OK}$$

USE  $\frac{7}{8}$ " THICK PLATE FOR RIGIDITY

## CHECK WELD BETWEEN LxLxL AND PLATE



$$S_x (\text{POINT A}) = \frac{d^2(4b+d)}{6(2b+d)}$$

$$b = d = 5.44 \text{ IN (WELD ON INSIDE LEGS)}$$

$$S_x = \frac{(5.44)^2((4)(5.44) + 5.44)}{(6)((2)(5.44) + 5.44)}$$

$$= 8.22 \text{ IN}^2$$

$$L_w = (2)(5.44) = 10.88 \text{ IN.}$$

CN 1962A  
BY K. Bush  
PAGE B15A  
FORM NO. 372-10-2650

THIS PAGE INTENTIONALLY  
LEFT BLANK  
CN-1962A

CHECK LIST OF DESIGN VERIFICATION QUESTIONS  
FOR DESIGN REVIEW METHOD

YES NO N/A

- ( ) ( ) 1. Were the inputs correctly selected and incorporated into design?
- ( ) ( ) 2. Are assumptions necessary to perform the design activity adequately described and reasonable? Where necessary, are the assumptions identified for subsequent re-verifications when the detailed design activities are completed?
- ( ) ( ) 3. Are the appropriate quality and quality assurance requirements specified?
- ( ) ( ) 4. Are the applicable codes, standards and regulatory requirements including issue and addenda properly identified and are their requirements for design met?
- ( ) ( ) 5. Have applicable construction and operating experience been considered?
- ( ) ( ) 6. Have the design interface requirements been satisfied?
- ( ) ( ) 7. Was an appropriate design method used?
- ( ) ( ) 8. Is the output reasonable compared to inputs?
- ( ) ( ) 9. Are the specified parts, equipment, and processes suitable for the required application?
- ( ) ( ) 10. Are the specified materials compatible with each other and the design environmental conditions to which the material will be exposed?
- ( ) ( )  11. Have adequate maintenance features and requirements been specified?
- ( ) ( ) 12. Are accessibility and other design provisions adequate for performance of needed maintenance and repair?
- ( ) ( ) 13. Has adequate accessibility been provided to perform the in-service inspection expected to be required during the plant life?
- ( ) ( )  14. Has the design properly considered radiation exposure to the public and plant personnel?
- ( ) ( ) 15. Are the acceptance criteria incorporated in the design documents sufficient to allow verification that design requirements have been satisfactorily accomplished?

CHECK LIST OF DESIGN VERIFICATION QUESTIONS - Cont'd.

YES NO N/A

- ( ) ( ) (X) 16. Have adequate pre-operational and subsequent periodic test requirements been appropriately specified?
- (X) ( ) ( ) 17. Are adequate handling, storage, cleaning and shipping requirements specified?
- (X) ( ) ( ) 18. Are adequate identification requirements specified?
- (X) ( ) ( ) 19. Are requirements for record preparation review, approval, retention, etc., adequately specified?

Note: If the answer to any question is no, provide additional information and resolution below:

RESOLUTION OF DESIGN DEFICIENCIES

UNCOVERED DURING THE DESIGN VERIFICATION PROCESS

*No Deficiencies Found*  
*Dugan Bates*  
*10/1/82*



PUBLIC SERVICE COMPANY OF COLORADO

FORT ST. VRAIN NUCLEAR GENERATING STATION

CHECK LIST OF DESIGN VERIFICATION QUESTIONS FOR DESIGN REVIEW METHOD

CN 1462B  
B. ~~Kennell~~ Mullen  
PAGE 817.1

Form 344-22-4095

YES NO N/A

- 1. Were the inputs correctly selected and incorporated into design?
- 2. Are assumptions necessary to perform the design activity adequately described and reasonable? Where necessary, are the assumptions identified for subsequent re-verifications when the detailed design activities are completed?
- 3. Are the appropriate quality and quality assurance requirements specified?
- 4. Are the applicable codes, standards and regulatory requirements including issue and addenda properly identified and are their requirements for design met?
- 5. Have applicable construction and operating experience been considered?
- 6. Have the design interface requirements been satisfied?
- 7. Was an appropriate design method used?
- 8. Is the output reasonable compared to inputs?
- 9. Are the specified parts, equipment, and processes suitable for the required application?
- 10. Are the specified materials compatible with each other and the design environmental conditions to which the material will be exposed?
- 11. Have adequate maintenance features and requirements been specified?
- 12. Are accessibility and other design provisions adequate for performance of needed maintenance and repair?
- 13. Has adequate accessibility been provided to perform the in-service inspection expected to be required during the plant life?
- 14. Has the design properly considered radiation exposure to the public and plant personnel?
- 15. Are the acceptance criteria incorporated in the design documents sufficient to allow verification that design requirements have been satisfactorily accomplished?
- 16. Have adequate pre-operational and subsequent periodic test requirements been appropriately specified?
- 17. Are adequate handling, storage, cleaning and shipping requirements specified?
- 18. Are adequate identification requirements specified?
- 19. Are requirements for record preparation review, approval, retention, etc., adequately specified?

NOTE: If the answer to any question is no, provide additional information and resolution below:


RESOLUTION OF DESIGN DEFICIENCIES UNCOVERED DURING THE DESIGN VERIFICATION PROCESS

No deficiencies were found during the Electrical Review. Wayne Kennell 8/15/83 ~~at the time~~


No deficiencies were found in the structural review.

No deficiencies found during review of minor electrical changes  
Wayne Kennell  
8-26-83

Mark Mullen 8/18/83




PLAN  
MILD STEEL R




ELEVATION

CABLE SUPPORT FOR BUILDING 10  
FOR CABLES FROM EL 4791 TO  
4835 SUPPORT WILL BE  
MOUNTED TO WALL



DESIGN FOR CONCENTRATED LOAD AT END OF 3/4" x 7" bar



$M_{MAX} = PL = 235 \times 7 = 1645 \text{ in.}\#$   
 $M_{SEISMIC} = 1645 \times 1.0 \times 1.5 = 2467.5$

$S_m = \frac{1645}{22K} = .074 \text{ in}^3$

RECTANGLE AXIS OF MOMENT THROUGH CENTER

$S = \frac{bd^3}{6} = \frac{.75 \times 4^3}{6} = 8 \text{ in}^3$

$\Sigma R_1 = 3 \times 235 + 7 \times 235 + 11 \times 235 + 15 \times 235$   
 $\Sigma R_1 = 705 + 1645 + 2595 + 3525 = 8460$   
 $R_1 = 470 \#$   
 $R_1 \text{ Seismic } 470 \times 1 \times 1.5 = 705 \#$   
 $\Sigma M_1 = 3 \times 2468 \text{ in}\# + 7 \times 2468 \text{ in}\# + 11 \times 2468 \text{ in}\# + 15 \times 2468 \text{ in}\#$   
 $\Sigma M_1 = 7404 + 17276 + 27148 + 37020$   
 $\Sigma M_1 = 88848$   
 $M_1 = 4936 \text{ in}\#$



$$M = 4936$$

$$S_m = \frac{4936}{22K} \cdot 224 \text{ in}^3$$

RECTANGLE AXIS OF MOMENT THROUGH CENTER

$$S = \frac{bd^3}{6} = \frac{.5 \times 6^3}{6} = 18 \text{ in}^3$$

USE A RED HEAD CONC ANCHOR

MIN SIZE  $1/2'' \phi$  PULL OUT = 1700 > 705

SHEAR = 1344 > 705

CHECK NATURAL FREQUENCY OF SYSTEM

$$f = \frac{3.52}{2\pi} \sqrt{\frac{EIg}{W L^3}} \text{ cps, FOR CANTILEVER}$$

$$f = \frac{3.52}{2\pi} \sqrt{\frac{29 \times 10^6 \times 4 \times 386.4}{235 \times 7^3}} \text{ cps}$$

$f = 417 \text{ cps}$  THEREFORE SYSTEM IS RIGID  
 AND WILL MOVE THE SAME  
 AS THE BUILDING. NO  
 SEISMIC PROBLEMS.

$$\text{where: } I = \frac{1}{12} b h^3 = \frac{1}{12} (.75) 4^3 = 4 \text{ in.}^4$$

$$L = 7 \text{ m.}$$

$$W = 235 \text{ \#}$$

$$g = 386.4 \text{ in./sec.}^2$$

$$E = 29 \times 10^6 \text{ psi}$$

$$f = \text{NATURAL FREQ.}$$



PUBLIC SERVICE COMPANY OF COLORADO

FORT ST. VRAIN NUCLEAR GENERATING STATION

SAFETY EVALUATION

CN TCR / SCR / PC / TR NO. 1255 PAGE 2

CATEGORY TYPE: [X] CN OVERALL [ ] CN SUBMITTAL [ ] SETPOINT CHANGE REPORT [ ] TEST REQUEST [ ] TEMPORARY CONFIGURATION REPORT [ ] PROCEDURE CHANGE (FSAR) [ ] OTHER CLASSIFICATION: ARE THE SYSTEM(S) EQUIPMENT OR STRUCTURES INVOLVED, OR DOES THE ACTIVITY AFFECT: CLASS I [X] YES [ ] NO ENGINEERED SAFEGUARD [X] YES [ ] NO SAFE SHUTDOWN [X] YES [ ] NO PLANT PROTECTIVE SYSTEM [ ] YES [X] NO SAFETY RELATED [X] YES [ ] NO SECURITY SYSTEM [ ] YES [X] NO REMARKS

EVALUATION USE ADDITIONAL SHEETS IF REQUIRED:

1 IS THE ACTIVITY IDENTIFIED IN THE FSAR OR TECH SPEC? [X] YES [ ] NO LIST THE APPLICABLE SECTIONS REVIEWED. FSAR sections 7.4.3, 8.2.2.3, 8.2.2.4, 8.2.3.4, 8.2.3.5, 8.2.5.2 Tech Specs LCO 4.6, SR 5.6.2

2 DOES THE ACTIVITY REQUIRE THAT CHANGE(S) BE MADE TO THE FSAR OR TECH SPEC? [X] YES [ ] NO LIST SECTIONS TO BE CHANGED AND THE CHANGES TO BE MADE. Sections 7.4.3, 8.2.2.3 must be revised to indicate the new configuration. FSAR figure 8.2-13 must be revised; a possible but not mandatory example is shown on page 3 and 4 of this CN. Tech Spec LCO 4.6 must be revised; a possible but not mandatory revision is shown on page 5 of this CN

3 DETERMINE WHETHER OR NOT THE ACTIVITY INVOLVED IS AN UNREVIEWED SAFETY QUESTION UTILIZING THE FOLLOWING GUIDELINES. (A) HAS THE PROBABILITY OF OCCURRENCE OR THE CONSEQUENCES OF AN ACCIDENT OR MALFUNCTION OF EQUIPMENT IMPORTANT TO SAFETY PREVIOUSLY EVALUATED IN THE FSAR BEEN INCREASED? [ ] YES [X] NO STATE BASIS: CN 1255 provides an independent instrument power transformer to provide back-up power for each inverter (1A and 1B) which provides power to the non-interruptible buses 1A and 1B. Power is transferred from the preferred source to the alternate source via static transfer switches replacing manual transfer switches in the present configuration. The electrical power source for the new Instrument Power Transformers 1A-1 and 1B-1 is Essential 480V Swgr (see attached) (B) HAS THE POSSIBILITY OF AN ACCIDENT OR MALFUNCTION OF A DIFFERENT TYPE THAN ANY EVALUATED PREVIOUSLY IN THE FSAR BEEN CREATED? [ ] YES [X] NO STATE BASIS: Because the system functions as before to provide power to vital equipment only with increased reliability as described in 3(A), the possibility of a new accident or malfunction has not been created. (C) HAS THE MARGIN OF SAFETY, AS DEFINED IN THE BASIS FOR ANY TECHNICAL SPECIFICATION OR IN THE FSAR BEEN REDUCED? [ ] YES [X] NO STATE BASIS: Increasing the reliability and flexibility of the non-interruptible power supply system can only increase the system's margin of safety.

DOES THE ACTIVITY APPEAR TO: INVOLVE AN UNREVIEWED SAFETY QUESTION [ ] YES [X] NO BE SAFETY SIGNIFICANT [ ] YES [X] NO BY Michael O'Dew 6/10/83 APPROVED J.R. Johns 6-10-83

3 (A) (cont)

page 2.1

Bus 1 and Bus 3 respectively. The present electrical configuration allows backup power for Non-interruptible buses 1A and 1B to be provided from the same source. The inverters (1A and 1B) are also being upgraded from 14.5 KVA to 25 KVA which will prevent system overload and allow sufficient margin for future modifications. Interruptible Bus 3 will also be provided with a static transfer switch utilizing instrument transformers 1A and 1B for power sources. Each item changed within this CA adds to the reliability and flexibility of a vital electrical power system within FSU. Due to the increased reliability of this system, the probability of occurrence of the consequences of an accident or malfunction of equipment important to safety evaluated in the FSAR has not been increased.





Figure 8.2-13  
Electrical Single-Line Diagram  
Instrument Power and DC Power System

ADDITIONAL CHANGES TO THIS DWG  
COVERED IN CN-1332

FIGURE 8.2-13

F. SHAN UPDHITE  
8.2-69

CN 1255  
BY M. RIGSBY  
PAGE 4  
FORM NO. 372-30-2680



CN-1255

{ SEE CN-1932 FOR OTHER CHANGES SHOWN ON THIS DWG }

ELEC. SINGLE-LINE DIA. FIGURE 8.2-13  
INST-PWR. & DC PWR SYS

CN-1255

\*  
SEE BELOW

Backup electric power for the non-interruptible a-c instrument loads is provided by bus ties from Instrument Bus No. 3 to Instrument Buses 1 and 2 which are normally fed by the two Instrument Power Inverters. Bus No. 3 receives its power from redundant instrument transformers which are supplied from the essential 480 volt switchgear. (FSAR Section 8.2.2.3.)

A redundant source of electric power for the d-c instrument loads is available from a bus tie between the two d-c buses which allows one battery or a-c to d-c rectifier to supply both buses.

These backups and redundancies permit the temporary removal from service of an instrument power inverter, a battery, a d-c bus or an a-c to d-c rectifier.

A diesel fuel storage capacity of 50,000 gallons is provided. A supply of 20,000 gallons of diesel fuel is adequate to provide for operation of the standby generators for at least seven days under required loading conditions. This allows adequate time to obtain additional fuel and to make provisions to restore the standby source of power into the station.

\* ON INSTRUMENT BUSES 1 AND 2 IS SUPPLIED BY INDIVIDUAL 480-120/240V BACK-UP POWER TRANSFORMERS. THE NORMAL FEED TO THESE BUSES IS INDIVIDUAL INSTRUMENT POWER INVERTERS. THE 480-120/240V BACK-UP POWER TRANSFORMERS WILL BE SUPPLIED FROM ESSENTIAL 480V SWITCHGEAR.

CN-1255

PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
NUCLEAR PROJECT DEPARTMENT

Electrical   
Mechanical   
Structural   
Safety Related   
Non Safety Related

DESIGN INPUT REQUIREMENTS

Sheet 1 of 2

THIS CN IS A PORTION OF THE WORK INVOLVED WITH UPGRADING THE INTERRUPTIBLE AND NON-INTERRUPTIBLE INSTRUMENT BUSES. THE REMAINDER OF THIS PROJECT IS COVERED BY CN-1332 (400A(DC) OUTPUT RATT. CNG AND 15KVA INVERTER) AND CN-139 (RE-PLACEMENT AND UPGRADE OF BATTERIES 1A, 1B AND 1C).

THE PRIMARY FEEDS TO NON-INTERRUPTIBLE BUSES 1 AND 2 ARE THE 125V DC BUSES 1A AND 1B THROUGH INVERTERS 1A AND 1B. BACK-UP POWER TO BUSES 1 AND 2 IS SUPPLIED FROM 1A AND 1B (480-124208V) TRANSFORMERS. THESE TRANSFORMERS ARE RATED AT 45 KVA EACH. IN EACH CASE A MANUAL THROW-OVER SCHEME IS USED. PAST OPERATION HAS PROVEN THAT INSTRUMENT TRANSFORMERS 1A AND 1B ARE NOT SIZED PROPERLY TO HANDLE THE COLLECTED LOADS DURING AN UPSET CONDITION. INVERTERS 1A AND 1B ARE RATED AT 14.5 KVA AND ARE PRESENTLY LOADED TO CAPACITY.

THIS CN WILL REPLACE EXISTING INVERTERS 1A AND 1B (RATED AT 14.5 KVA) WITH NEW INVERTERS RATED AT 25 KVA TO PROVIDE FOR ADDITIONAL INSTRUMENT BUS LOADS AS NEEDED FOR PLANT MODIFICATIONS OR ADDITIONS. THE NEW INVERTERS WILL BE EQUIPPED WITH STATIC TRANSFER SWITCHES FOR AUTOMATIC THROW-OVER TO BACK-UP POWER SOURCES WHEN CONDITIONS DICTATE.

THE BACK-UP POWER SOURCES TO NON-INTERRUPTIBLE INSTRUMENT BUSES 1 AND 2 WILL BE REMOVED FROM INSTRUMENT POWER TRANSFORMERS 1A AND 1B AND NEW 25 KVA BACK-UP POWER TRANSFORMERS WILL BE INSTALLED FOR THIS PURPOSE. INTERRUPTIBLE BUS 3 WILL REMAIN TIED TO 1A AND 1B TRANSFORMERS.

Prepared By: /s/ M. RIGSEY 9/15/82  
Date

Approved By: /s/ Wendy 11-9-82  
Date



PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
NUCLEAR PROJECT DEPARTMENT

Electrical   
Mechanical   
Structural   
Safety Related   
Non Safety Related

DESIGN INPUT REQUIREMENTS

Sheet 2 of 2

THIS WILL ALLEVIATE THE OVERLOAD CONDITIONS FOUND PREVIOUSLY ON THESE TRANSFORMERS. IN ADDITION TO RELIEVING THE OVERLOAD PROBLEMS ASSOCIATED WITH THESE TRANSFORMERS A THREE PHASE STATIC TRANSFER SWITCH WILL BE INSTALLED TO MONITOR AND THROW-OVER AUTOMATICALLY FROM PREFERRED TO SECONDARY TRANSFORMER FEED TO INTERRUPTIBLE BUS 3.

THE NEW 25KVA BACK-UP POWER TRANSFORMERS TO BE INSTALLED AS BACK-UP POWER SOURCES WILL BE FED FROM ESSENTIAL 480V SWITCHGEAR.

ALL ELECTRICAL WORK WILL BE PERFORMED IN ACCORDANCE WITH SPEC. 1-N-2 AND FSJ STANDARDS.

A FLAMASTIC COATING WILL BE APPLIED TO ALL CABLES, WHERE APPLICABLE, PER SPEC 93-2-71.

THIS WORK HAS BEEN UNDERTAKEN BECAUSE OF COMMITMENTS MADE IN ANSWER TO IG BULLETIN 79-27.

Prepared By: /s/ M. RIGSBY 9/5/82  
Date

Approved By: /s/ W. M. ... 11-9-82  
Date



PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
SAFETY RELATED DESIGN ANALYSIS - SHEET 1

CN 1255  
BY M. RIGSBY  
PAGE B-2

Form 344-22-4063

- ELECTRICAL  
 MECHANICAL  
 STRUCTURAL

I. SEISMIC ANALYSIS

THE 25KVA INVERTERS, 25KVA BACK-UP POWER TRANSFORMERS, 3 PHASE STATIC TRANSFER SWITCH AND 120V DISTRIBUTION PANELS WILL BE SEISMICALLY QUALIFIED TO PSV STANDARD CURVES FOR BUILDING 10 AND THE 480V SWITCHGEAR ROOM.  
25KVA TRANSFORMER SEISMIC TEST REPORT # PEI-TR-B1-7, TAB 87 IN SEISMIC QUALIFICATION BOOK (SR-EQ-QR).  
25KVA INVERTER SEISMIC TEST REPORT # 10046, TAB 88 IN SEISMIC QUALIFICATION BOOK (SR-EQ-QR).  
120V DIST. PNL. AND STATIC TRANSFER SWITCH TEST REPORTS WILL BE ENTERED INTO THE SYSTEM ON A RE-ISSUE OF THIS CD.

II. STRESS ANALYSIS

N/A

III. PIPING/HANGER ANALYSIS

N/A

IV. HYDRAULIC/PNEUMATIC ANALYSIS

N/A

SAFETY RELATED DESIGN ANALYSIS (continued)  
Sheet 2 of 3

V. Thermal Analysis:

EQUIPMENT HAS BEEN DESIGNED TO OPERATE AT AN AMBIENT TEMPERATURE OF 120°F WHICH HAS BEEN CALCULATED AS "WORST CASE" WITH LOSS OF COOLING.

CABLE BEING INSTALLED IS CERTIFIED TO PASS THE IEEE 383 VERTICAL FLAME TEST.

VI. Nuclear Analysis:

N/A

VII. Fire Protection Analysis:

CABLE BEING INSTALLED IS CERTIFIED TO PASS THE IEEE 383 VERTICAL FLAME TEST AND WILL BE PROTECTED, WHERE REQUIRED, BY A PLASTIC COVERING PER FSV STANDARD PROCEDURES. A DIRT SHIELD WILL BE PROVIDED TO PROTECT INSTALLED EQUIPMENT FROM FIRE PROTECTION WATER SPRAY.

VIII. Environmental Analysis:

THE EQUIPMENT CABINETS AND THERMAL OPERATING CHARACTERISTICS MAKE THIS EQUIPMENT SUITABLE FOR INSTALLATION PER FSV STANDARDS.

TRANSFORMER QUALIFICATION - LETTER DTD 4/1/1983 - TABAS, SE-AC-QR  
INVERTER QUALIFICATION - LETTER DTD 4/1/1983 - TABAT, SE-AC-QR  
STATIC TRANSFER SWITCH - LETTER DTD 3/22/1983 - TABAU, SE-AC-QR  
120V DIST. PUL. QUALIFICATION WILL BE ENTERED INTO SYSTEM ON RE-ISSUE OF THIS CN.

IX. Compatibility of Materials, Equipment and Processes:

ALL MATERIAL SUPPLIED FOR THIS INSTALLATION WILL BE COMPATIBLE PER FSV STANDARDS.

SAFETY RELATED DESIGN ANALYSIS (continued)  
Sheet 3 of 3

X. Accessibility for In-Service Inspection, Maintenance and Repair:

120V Non-INT DIST. PNL IA-1, IB-1, INVERTER IA, 25KV AB.U. POWER TRANSF IA-1, INVERTER IB, AND 25KV AB.U. PWR. TRANSF IB-1 WILL BE INSTALLED ON THE GROUND FLOOR OF THE NEW 3 ROOM COMPLEX. THE 3 PHASE STATIC TRANSFER SWITCH WILL BE INSTALLED ON THE FLOOR OF THE EXISTING 420V SWITCH ROOM. SUFFICIENT CLEARANCES WILL BE PROVIDED FOR INSPECTION, MTC & REPAIR.

XI. Separation and Segregation Analysis:

SEPARATION/SEGREGATION CRITERIA WILL BE MET.

XII. Electrical Analysis:

THE ADDITIONAL CAPACITIES BEING PROVIDED WITH THE 25KV IA INVERTERS ALONG WITH THE BACK-UP POWER SOURCE AND FIELD LOAD RE-ARRANGEMENT WILL ADD TO THE SYSTEM STABILITIES AND PROVIDE FOR FUTURE GROWTH.  
ALL WORK WILL CONFORM TO SPEC. I-N-2

XIII. Accident Analysis:

NO NEW ACCIDENT MODES WILL BE IDENTIFIED BY IMPLEMENTATION OF THIS CN.

CHECK LIST OF DESIGN VERIFICATION QUESTIONS  
FOR DESIGN REVIEW METHOD

YES NO N/A

- () ( ) ( ) 1. Were the inputs correctly selected and incorporated into design?
- () ( ) ( ) 2. Are assumptions necessary to perform the design activity adequately described and reasonable? Where necessary, are the assumptions identified for subsequent re-verifications when the detailed design activities are completed?
- () ( ) ( ) 3. Are the appropriate quality and quality assurance requirements specified?
- () () ( ) 4. Are the applicable codes, standards and regulatory requirements including issue and addenda properly identified and are their requirements for design met?  
*WB 5/24/83* *Boh 6/25/83*
- () ( ) ( ) 5. Have applicable construction and operating experience been considered?
- () ( ) ( ) 6. Have the design interface requirements been satisfied?
- () ( ) ( ) 7. Was an appropriate design method used?
- () ( ) ( ) 8. Is the output reasonable compared to inputs?
- () ( ) ( ) 9. Are the specified parts, equipment, and processes suitable for the required application?
- () ( ) ( ) 10. Are the specified materials compatible with each other and the design environmental conditions to which the material will be exposed?
- () ( ) ( ) 11. Have adequate maintenance features and requirements been specified?
- () ( ) ( ) 12. Are accessibility and other design provisions adequate for performance of needed maintenance and repair?
- () ( ) ( ) 13. Has adequate accessibility been provided to perform the in-service inspection expected to be required during the plant life?
- ( ) ( ) () 14. Has the design properly considered radiation exposure to the public and plant personnel?
- () ( ) ( ) 15. Are the acceptance criteria incorporated in the design documents sufficient to allow verification that design requirements have been satisfactorily accomplished?

CHECK LIST OF DESIGN VERIFICATION QUESTIONS - Cont'd.

YES NO N/A

- ( ) ( ) (✓) 16. Have adequate pre-operational and subsequent periodic test requirements been appropriately specified?
- (✓) ( ) ( ) 17. Are adequate handling, storage, cleaning and shipping requirements specified?
- (✓) ( ) ( ) 18. Are adequate identification requirements specified?
- (✓) ( ) ( ) 19. Are requirements for record preparation review, approval, retention, etc., adequately specified?

Note: If the answer to any question is no, provide additional information and resolution below:

RESOLUTION OF DESIGN DEFICIENCIES

UNCOVERED DURING THE DESIGN VERIFICATION PROCESS

- 1.) Pgs. B1 thru B4; Additional design input information required to fully meet the intent of Eng. 1.
- 2.) Add Plamastic material to Bill of Materials.
- 3.) Pg. G40; Clarify cable change out with an additional dwg.
- 4.) Pg. G61; Clarify cable change out with an additional dwg.
- 5.) Pg. G51; Clarify cable change out with an additional dwg.
- 6.) Pg. G70; Clarify Cable change out with an additional dwg.
- 7.) Add Spec. 92-N-88 to D.U.L.

*R.A. Schindler* 5/18/83

All design deficiencies have been resolved satisfactorily.

*R.A. Schindler* 5/23/83

*RBS* 9/23/83



# PUBLIC SERVICE COMPANY OF COLORADO

FORT ST. VRAIN NUCLEAR GENERATING STATION

TCR / SCR / PC / TR

NO. 13328

PAGE 2

## SAFETY EVALUATION

### CATEGORY

TYPE:

- CN OVERALL     CN SUBMITTAL     SETPOINT CHANGE REPORT     TEST REQUEST  
 TEMPORARY CONFIGURATION REPORT     PROCEDURE CHANGE (FSAR)     OTHER

CLASSIFICATION: ARE THE SYSTEM(S) EQUIPMENT OR STRUCTURES INVOLVED, OR DOES THE ACTIVITY AFFECT:

- |                |   |                             |                         |                              |  |
|----------------|---|-----------------------------|-------------------------|------------------------------|--|
| CLASS I        | <input checked="" type="checkbox"/> YES | <input type="checkbox"/> NO | ENGINEERED SAFEGUARD    | <input type="checkbox"/> YES | <input checked="" type="checkbox"/> NO |
| SAFE SHUTDOWN  | <input checked="" type="checkbox"/> YES | <input type="checkbox"/> NO | PLANT PROTECTIVE SYSTEM | <input type="checkbox"/> YES | <input checked="" type="checkbox"/> NO |
| SAFETY RELATED | <input checked="" type="checkbox"/> YES | <input type="checkbox"/> NO | SECURITY SYSTEM         | <input type="checkbox"/> YES | <input checked="" type="checkbox"/> NO |

REMARKS

### EVALUATION

USE ADDITIONAL SHEETS IF REQUIRED.

1 IS THE ACTIVITY IDENTIFIED IN THE FSAR OR TECH SPEC?  YES  NO  
 LIST THE APPLICABLE SECTIONS REVIEWED. FSAR section 7.4.3, 8.2.2.3, 8.2.2.4, 8.2.3, 8.2.3.3, 8.2.3.4, 8.2.3.5, 8.2.5.1, 8.2.5.2, Figures 8.2-13, 8.2-14, reviewed tech specs section LCO 4.6

2 DOES THE ACTIVITY REQUIRE THAT CHANGE(S) BE MADE TO THE FSAR OR TECH SPEC?  YES  NO  
 LIST SECTIONS TO BE CHANGED AND THE CHANGES TO BE MADE. Figures 8.2-13 and 8.2-14 of the FSAR must be revised. A change of the tech specs is shown in CN-1255 and is related to this change. LCO 4.6 has several changes needed to: eliminate reference to PPS battery and battery charger/inverter; re-describe paragraph in basis for backup power to Bus 3; possibly describe additional flexibility with new system. FSAR Section 8.2.3.4 needs changed to eliminate reference to PPS battery.

3 DETERMINE WHETHER OR NOT THE ACTIVITY INVOLVED IS AN UNREVIEWED SAFETY QUESTION UTILIZING THE FOLLOWING GUIDELINES.

(A) HAS THE PROBABILITY OF OCCURRENCE OR THE CONSEQUENCES OF AN ACCIDENT OR MALFUNCTION OF EQUIPMENT IMPORTANT TO SAFETY PREVIOUSLY EVALUATED IN THE FSAR BEEN INCREASED?

YES  NO STATE BASIS: This change increases the capacity and reliability of the non-interruptible bus 3 system. It also increases the capacity of the 125 V DC system by upgrading battery charger I.D. An additional DC source has been made available to five Battery/Charger/Inverter IC configuration. By increasing the capacity and reliability and adding a dedicated backup supply from 480V Essential Bus #1 via Inst. Pur Transformer IC-1 and a static transfer switch, the overall integrity of the non-interruptible power supply system is improved.

(B) HAS THE POSSIBILITY OF AN ACCIDENT OR MALFUNCTION OF A DIFFERENT TYPE THAN ANY EVALUATED PREVIOUSLY IN THE FSAR BEEN CREATED?  YES  NO STATE BASIS:

The discussion above in item 3(A) concerning increased reliability and capacity also applies here. Since the system reliability and capacity has been enhanced by this modification, the possibility of a new accident or malfunction of equipment, as a result of a non-interruptible power supply failure has not been created.

(C) HAS THE MARGIN OF SAFETY, AS DEFINED IN THE BASIS FOR ANY TECHNICAL SPECIFICATION OR IN THE FSAR BEEN REDUCED?  YES  NO STATE BASIS:

Increasing the reliability and capacity of the non-interruptible power supply system increases it's margin of safety as defined in the basis for LCO 4.6. A change to LCO 4.6 is required with this CN.

DOES THE ACTIVITY APPEAR TO: INVOLVE AN UNREVIEWED SAFETY QUESTION  YES  NO  
 BE SAFETY SIGNIFICANT  YES  NO

BY Michael G. Lew (SIGNATURE)

9/28/83 (DATE)

\*APPROVED

J.R. Johns (SIGNATURE)

9-30-83 (DATE)


\*REQUIRED ONLY FOR CHANGE NOTICE

3(A) (continued) The probability of occurrence or the consequences of an accident or malfunction of equipment important to safety previously evaluated in the FSAR as a result of a non-interruptible power supply failure has been definitely reduced by this modification.



FSAR UPDATE  
8.2-69

CN 1332 B  
BY M. RIGSBY  
PAGE 3  
FORM NO. 372-30-2650



ELEC. SINGLE-LINE DIA.  
INST. PWR. & D.C. PWR SYS  
FIGURE 8.2-13



PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
DESIGN INPUT REQUIREMENTS

CN 1332 B

BY M. RIGSBY

PAGE B-1 B

Form 344-22-4060

SH. 1 OF 2

- ELECTRICAL
- MECHANICAL
- STRUCTURAL
- SAFETY RELATED
- NON-SAFETY RELATED

THIS CN IS A PORTION OF THE PROJECT TO UPGRADE THE INTERRUPTIBLE AND NON-INTERRUPTIBLE INSTRUMENT BUSES. THE REMAINDER OF THIS PROJECT IS COVERED BY CN-1255 (BACK-UP POWER TRANSFERS, 25KVA INVERTERS AND A 3 PHASE STATE TRANSFER SW.) AND CN-1391 (REPLACEMENT AND UPGRADE OF BATTERIES 1A, 1B AND 1C).

THE EXISTING BATT. CHG. 1D IS CONNECTED TO THE DC BUS TIE LINE AS A BACKUP SOURCE FOR 125V DC BUSES 1A AND 1B THROUGH BUS TIE AIR CIRCUIT BREAKERS. THE EXISTING 1D BATT. CHG. IS RATED AT 200A(DC) OUTPUT WHILE THE 1A AND 1B PRIMARY BATT. CHGS. ARE RATED AT 825A(DC) OUTPUT.

CN-1332 B

THE EXISTING 200A(DC) OUTPUT BATT. CHG. IS TO BE REPLACED WITH A 400A(DC) OUTPUT BATT. CHG. THE NEW 400A(DC) OUTPUT BATT. CHG. WILL ALSO BE TIED INTO THE NEW CONFIGURATION FOR INVERTER 1C (NON-INT. BUS 3) BY MEANS OF A SAFETY SWITCH DISCONNECT, FOR A BACK-UP SOURCE OF 125V DC. THE REPLACEMENT OF THE EXIST. 200A(DC) OUTPUT BATT. CHG. WITH A 400A(DC) OUTPUT BATT. CHG. WILL ENHANCE THE STABILITY OF THE SYSTEM AND IT BECOMES NECESSARY TO UTILIZE THE 1D BATT. CHG. AS THE PRIMARY DC SOURCE FOR BUSES 1A AND/OR 1B AND/OR INVERTER 1C (NON-INT BUS 3).

THE EXISTING NON-INTERRUPTIBLE INSTRUMENT BUS 3 IS NOT SIZED TO ACCEPT ANY ADDITIONAL LOAD. WITH THE CONTINUING PLANT MODIFICATIONS AND SUBSEQUENT ADDITIONAL LOADS FOR THE INSTRUMENT BUS SYSTEM IT HAS BECOME NECESSARY TO UPGRADE NON-INTERRUPTIBLE BUS 3. THIS CN WILL UTILIZE THE EXISTING 200A(DC) OUTPUT BATT. CHG. (1D), THAT IS BEING REPLACED, IN CONJUNCTION WITH A NEW 15KVA INVERTER TO PROVIDE ADDITIONAL CAPACITY AND STABILITY FOR THE #3 NON-INTERRUPTIBLE INSTRUMENT BUS. THE BATT. CHG. & INVERTER WILL BE THE PRIMARY FEED TO NON-INT BUS 3 WITH BACK-UP POWER BEING SUPPLIED FROM A NEW 480V - 120V INSTRUMENT POWER TRANSFORMER.

IEEE 38374 "TYPE TEST OF CLASS 1E ELECTRICAL CABLES, FIELD CABLES, AND CONNECTIONS FOR NUCLEAR POWER GENERATING STATIONS."

PREPARED BY

Murray Florsby  
SIGNATURE

2/15/83  
DATE

APPROVED BY

[Signature]  
SIGNATURE

9-12-83

DATE

CN 1332  
BY M. RISSBY  
PAGE B-1

PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
NUCLEAR PROJECT DEPARTMENT

Electrical   
Mechanical   
Structural   
Safety Related   
Non Safety Related

DESIGN INPUT REQUIREMENTS  
Sheet 2 of 2

ALL ELECTRICAL WORK WILL BE PERFORMED IN ACCORDANCE WITH SPEC. I-N-2 AND PSV STANDARDS.

A PLAMASTIC COATING WILL BE APPLIED TO ALL CABLES, WHERE APPLICABLE, PER SPEC. 93-I-71.

INVERTER AND BATTERY CHARGER HAVE BEEN SEISMICALLY AND ENVIRONMENTALLY QUALIFIED TO FIRST-CLASS CLASS 1B REQUIREMENTS.

Prepared By: /s/ Murray Rissby 9/15/82 Date  
Approved By: /s/ W.E. Nichols 11-2-82 Date



PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
SAFETY RELATED DESIGN ANALYSIS - SHEET 1

CN 1332B  
BY M. RIGSBY  
PAGE B-2B

Form 344-22-4063

- ELECTRICAL  
 MECHANICAL  
 STRUCTURAL

I. SEISMIC ANALYSIS

BATTERY CHG. (400A DC OUTPUT) IS VIA INVERTER, 480/120V BACK-UP INT. TRANSFORMER AND 120V DIST. ALL ARE SEISMICALLY QUALIFIED.

THE ADDITION OF 5 AUX. RELAYS AND 5 INDICATING LIGHTS TO THE 400A DC BATT. CHG. WILL HAVE NO EFFECT ON SEISMIC QUALIFICATION BECAUSE OF THE SMALL MASS INVOLVED.

FOR EVALUATION OF CONDUIT HANGERS EQUIPMENT MOUNTING AND ANCHORING AND THE RELOCATION OF THE 200A DC BATT. CHG FROM THE 430V SWR TO BUILDING 10 SEE P'S. B-3B THRU B-13B.

II. STRESS ANALYSIS

N/A

III. PIPING/HANGER ANALYSIS

N/A

IV. HYDRAULIC/PNEUMATIC ANALYSIS

N/A

SAFETY RELATED DESIGN ANALYSIS (continued)  
Sheet 2 of 3

V. Thermal Analysis:

EQUIPMENT HAS BEEN DESIGNED TO OPERATE AT AN AMBIENT TEMPERATURE OF 120°F WHICH HAS BEEN CALCULATED AS "WORST CASE" WITH LOSS OF COOLING. CABLE BEING INSTALLED IS CERTIFIED TO PASS THE IEEE 383 VERTICAL FLAME TEST.

VI. Nuclear Analysis:

N/A

VII. Fire Protection Analysis:

CABLE BEING INSTALLED IS CERTIFIED TO PASS THE IEEE 383 VERTICAL FLAME TEST AND WILL BE PROTECTED, WHERE REQUIRED, BY A FLAMASTIC COVERING PER FSV STANDARD PROCEDURES. A DRIP SHIELD WILL BE PROVIDED TO PROTECT INSTALLED EQUIPMENT.

VIII. Environmental Analysis:

THE EQUIPMENT CABINETS AND THERMAL OPERATING CHARACTERISTICS MAKE THIS EQUIPMENT SUITABLE FOR INSTALLATION PER FSV STANDARDS.

IX. Compatibility of Materials, Equipment and Processes:

ALL MATERIAL SUPPLIED FOR THIS INSTALLATION WILL BE COMPATIBLE PER FSV STANDARDS.



PUBLIC SERVICE COMPANY OF COLORADO  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 SAFETY RELATED DESIGN ANALYSIS - SHEET 3

CN 1332B  
 BY M. RIGSBY  
 PAGE B-4B

Form 344-22-4069

X. ACCESSIBILITY FOR IN-SERVICE INSPECTION, MAINTENANCE, AND REPAIR

THE BATT. CHG. (400A DC OUTPUT) WILL BE MOUNTED ON THE FLOOR AND ALONG THE SOUTH WALL IN THE EXISTING 480V SWGR. ROOM. THE IC CHARGER (200A DC OUTPUT), INVERTER AND ASSOCIATED EQUIP. WILL BE INSTALLED ON THE MEZE. OF BLDG. 10 (4800'-6"). (EQUIPMENT RE-LOCATED FROM 600FL. 6'LEV. 4791'-0' CN-1332B)

SUFFICIENT CLEARANCES HAVE BEEN PROVIDED FOR INSPECTION, MAINT. AND REPAIR.

XI. SEPARATION AND SEGREGATION ANALYSIS

SEPARATION/SEGREGATION CRITERIA WAS MET DURING ENGINEERING AND LAYOUT PHASE OF THIS PROJECT.

XII. ELECTRICAL ANALYSIS

SEE ATTACHED PG. 4.1B & 4.2B

XIII. ACCIDENT ANALYSIS

NO NEW ACCIDENT MODES ARE CREATED BY IMPLEMENTATION OF THIS CU.

PREPARED BY Murray Rigby 8/11/73  
 DATE

## XII. ELECTRICAL ANALYSIS

THE EXISTING 120V AC NON-INT BUS 3(IC) SYSTEM CONSISTS OF A 125V DC BATTERY RATED AT 320 AMP/HOUR, A 10KVA BATTERY CHARGER/INVERTER AND A 12 CIRCUIT, 120V AC (NON-INT) DISTRIBUTION PANEL (BUS 3).

THE POWER TIES TO THE 10KVA BATTERY CHARGER/INVERTER ARE A 3 PHASE, 208V AC FEED FROM INTERRUPTIBLE BUS 3 AND A DIRECT TIE TO THE 125V DC BATTERY. THE BATTERY CHARGER/INVERTER IS THE PRIMARY AC FEED TO THE 120V NON-INT BUS 3 WITH A BACK-UP FEED ALSO COMING FROM INTERRUPTIBLE BUS 3 TO NON-INT BUS 3. THE CIRCUIT BREAKERS ON NON-INT BUS 3 FROM THE BATTERY CHARGER/INVERTER AND FROM INTERRUPTIBLE BUS 3 ARE MECHANICALLY INTERLOCKED TO PREVENT BOTH AC POWER SOURCES FROM BEING TIED TO BUS 3 AT THE SAME TIME. THE BATTERY CHARGER/INVERTER FEED TO NON-INT BUS 3 IS A 50 AMP SERVICE, THE BACK-UP FEED FROM INTERRUPTIBLE BUS 3 IS A 30 AMP SERVICE.

THE RE-WORK OF THE NON-INT BUS 3(IC) SYSTEM INCREASES THE CAPACITY OF THIS SYSTEM BY APPROXIMATELY 50%. THIS INCREASE IS ACCOMPLISHED BY REPLACEMENT OF THE 10 KVA BATTERY CHARGER/INVERTER WITH A 15KVA INVERTER. THE 15 KVA INVERTER IS TO BE USED IN CONJUNCTION WITH THE EXISTING "ID" SWING BATTERY CHARGER (RATED AT 200A DC OUTPUT) WHICH IS BEING REPLACED WITH A 400A DC OUTPUT BATTERY CHARGER. IN ORDER TO TAKE ADVANTAGE OF THE ADDITIONAL INVERTER CAPACITY A 120V NON-INT DISTRIBUTION PANEL (IC-1) OF 24 CIRCUITS IS BEING ADDED IN BUILDING 10. IN ADDITION TO THE INCREASED CAPACITIES OUTLINED ABOVE THE IC BATTERY, RATED AT 320 AMP/HOUR, IS BEING REPLACED WITH AN 890 AMP/HOUR RATED BATTERY (CN-1391) WHICH IS APPROXIMATELY A 180% INCREASE IN BATTERY CAPABILITY. THIS INCREASE WILL PROVIDE FOR CONSIDERABLY LONGER DEPENDENCE ON THE BATTERY, IF THE SITUATION ARISES. THE NEW "ID" SWING BATTERY CHARGER (400 A DC OUTPUT) WILL ALSO BE TIED INTO THE NON-INT BUS 3(IC) SYSTEM AS AN ALTERNATE DC POWER SOURCE, THIS IS A BACK-UP SYSTEM THAT DOES NOT PRESENTLY EXIST.

THE PRIMARY AC FEED TO THE NEW 15KVA INVERTER WILL BE THROUGH THE 200A DC OUTPUT BATTERY CHARGER, WITH A DIRECT TIE TO THE 1C (890 AMP/HOUR) BATTERY. THE BATTERY CHARGER WILL BE FED FROM 480V L.C. SWITCHGEAR, BUS 2. THE BACK-UP AC POWER FEED TO THE INVERTER, IS THROUGH A 480-240/120V POWER TRANSFORMER (1C-1) FED FROM 480V L.C. SWITCHGEAR, BUS 1. THIS ARRANGEMENT WILL PUT 480V L.C. SWITCHGEAR BUSES 1 AND 2 IN THE INVERTER CABINET ON THE STATIC TRANSFER SWITCH. HOWEVER, THE AIR CIRCUIT BREAKER PROTECTION ON THESE CIRCUITS WILL PROVIDE THE NECESSARY BUS PROTECTION IN CASE OF A FAULT ON ONE OR THE OTHER OF THESE CIRCUITS.



CHECK LIST OF DESIGN VERIFICATION QUESTIONS - Cont'd.

YES NO N/A

- ( ) ( ) (✓) 16. Have adequate pre-operational and subsequent periodic test requirements been appropriately specified?
- (✓) ( ) ( ) 17. Are adequate handling, storage, cleaning and shipping requirements specified?
- (✓) ( ) ( ) 18. Are adequate identification requirements specified?
- (✓) ( ) ( ) 19. Are requirements for record preparation review, approval, retention, etc., adequately specified?

Note: If the answer to any question is no, provide additional information and resolution below:

RESOLUTION OF DESIGN DEFICIENCIES

UNCOVERED DURING THE DESIGN VERIFICATION PROCESS

No deficiencies found.  
Gregory S. Bates  
10/26/82

No deficiencies found. Change to  
Safety Evaluation Only.  
Gregory S. Bates  
4/12/83



PUBLIC SERVICE COMPANY OF COLORADO  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CHECK LIST OF DESIGN VERIFICATION QUESTIONS  
 FOR DESIGN REVIEW METHOD

CN 1332B  
 BY M. R. G. SBY  
 PAGE 3-7B

Form 344-22-4095

- | YES                                 | NO                       | N/A                                 |   |
|-------------------------------------|--------------------------|-------------------------------------|---|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 1. Were the inputs correctly selected and incorporated into design?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 2. Are assumptions necessary to perform the design activity adequately described and reasonable? Where necessary, are the assumptions identified for subsequent re-verifications when the detailed design activities are completed? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 3. Are the appropriate quality and quality assurance requirements specified?  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 4. Are the applicable codes, standards and regulatory requirements including issue and addenda properly identified and are their requirements for design met?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 5. Have applicable construction and operating experience been considered?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 6. Have the design interface requirements been satisfied?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 7. Was an appropriate design method used?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 8. Is the output reasonable compared to inputs?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 9. Are the specified parts, equipment, and processes suitable for the required application?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 10. Are the specified materials compatible with each other and the design environmental conditions to which the material will be exposed?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 11. Have adequate maintenance features and requirements been specified?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 12. Are accessibility and other design provisions adequate for performance of needed maintenance and repair?  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 13. Has adequate accessibility been provided to perform the in-service inspection expected to be required during the plant life?  |
| <input type="checkbox"/>            | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 14. Has the design properly considered radiation exposure to the public and plant personnel?  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 15. Are the acceptance criteria incorporated in the design documents sufficient to allow verification that design requirements have been satisfactorily accomplished?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 16. Have adequate pre-operational and subsequent periodic test requirements been appropriately specified?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 17. Are adequate handling, storage, cleaning and shipping requirements specified?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 18. Are adequate identification requirements specified?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 19. Are requirements for record preparation review, approval, retention, etc., adequately specified?  |

NOTE: If the answer to any question is no, provide additional information and resolution below:

RESOLUTION OF DESIGN DEFICIENCIES  
UNCOVERED DURING THE DESIGN VERIFICATION PROCESS

- ELECTRICAL DESIGN ANALYSIS INADEQUATE TO DETERMINE HOW MUCH THE 1C BUS CAPACITY WAS BEING INCREASED.  
 RESOLUTION: ELECTRICAL ANALYSIS ON P 2 B4, 1B AND 4.2B WAS ADDED
- THERMAL, ENVIRONMENTAL, AND COMPATIBILITY NOT SHOWN.  
 RESOLUTION: ANALYSIS SHOWN IN PREVIOUS REISSUES IS APPLICABLE TO WORK IN REISSUE 3.
- RESOLVED MINOR CHANGE NOTICE MECHANICS ERRORS.  
 WOTMAN D. McPHERSON 9/7/83

1-6-83

CN 1332 B  
BY M. RIGSBY  
PAGE 5-88  
FORM NO. 372-30-2650

TO: MURRAY RIGSBY

FROM: BOB GUNNERSON

SUBJ: BATTERY CHARGER TO BE MOUNTED  
ON MEZZ. IN BLOC 10 @ ELEV. 4800'-6";  
FSU

I CAN FIND NO PROBLEMS WITH  
THE BATTERY CHARGER BEING INSTALLED  
AT ELEV. 4800'-6" SINCE THE MAX  
G-FORCE IS 1.55 IN THE HORIZ.  
DIRECTION & 0.7 IN THE VERTICAL DIRECTION,  
ALL FOR 3% EQUIPMENT DAMPING.  
THE EQUIPMENT HAS BEEN QUALIFIED  
TO 2.0 G'S IN THE HORIZ. & VERT.  
DIRECTION PER SEISMIC CERT SHEET FOR  
EQ # N-9240.

ELECTRICAL EQUIPMENT MOUNTINGS

INFORMATION SUPPLIED BY ELECTRICAL ENGINEERING:

FLOOR MOUNTED { INVERTER IC N-9279 (DW APPROX. 1900 LBS)  
 BATTERY CHARGER IC N-9253 (DW APPROX. 2000 LBS)

FLOOR SLAB T.O.C. ELEV. 4800'-6"

WALL MOUNTED { BACK-UP PWR. TRANSF. IC N-9269 (DW = 380 LBS)  
 120V DIST. PNL. IC + N-92105 (DW = 65 LBS)  
 120V DC DISCONNECT SW. N-92117 (DW = 145 LBS)

N-9269, N-92105 MOUNTED TO WALL OVER MEZZ. FLOOR

USE ARS FOR ELEV. 4811'-0" (CONSERVATIVE)

N-92117 MOUNTED TO WALL IN EXISTING 480V ROOM

USE ARS FOR ELEV. 4811'-0" MAIN BUILDING

SEISMIC ARS DATA, DBE, DAMPING = 5%

REF. IEEE 344

1975, SECTION

3.5.3

EQUIPMENT NUMBER	BUILDING	ELEVATION	PEAK HORIZONTAL ACCELERATION, g's	PEAK VERTICAL ACCELERATION, g's
N-9279	10	4800'-6"	1.20	0.55
N-9253	10	4800'-6"		
N-9269	10	4811'-0"	1.40	0.60
N-92105	10	4811'-0"		
N-92117	TURBINE	4811'-0"	0.58*	0.28**

SOURCE FOR BUILDING 10: STONE & WEBSTER CALC. NO.


13569.04-SD-1, REV. 0, "AMPLIFIED RESPONSE SPECTRA FOR THREE ROOM COMPLEX ADDITION"

\* FROM SARGENT & LUNDY REPORT 8-11-1-1 (SAD-377), REV. 0, "GENERATION OF SEISMIC RESPONSE SPECTRA", PEAK VALUE FOR SLAB 2 ELEV. 4811'-0", 2% DAMPING (CONSV.)

\*\* VALUE IS 2/3 OF DBE HORIZONTAL GROUND MOTION AS DEFINED IN FSAR FOR 1% DAMPING (CONSV.)

FLOOR MOUNTED

N-9279



$P_{DW} = 1900 \text{ LBS}$

$P_{SEISH} = (1.5 \text{ STATIC COEFFICIENT}) \times (1900 \text{ LBS})(1.20g)$   
 $= 3420 \text{ LBS}$

$H = 39 \text{ INCHES}$  (ASSUME C.G. AT MID-HEIGHT OF MAIN CABINET)

$S = 27 \text{ IN MIN SPACING}$

$P_{SEISV} = (1.5 \text{ STATIC COEFFICIENT}) \times (1900 \text{ LBS})(0.55g)$   
 $= 1568 \text{ LBS}$

TENSION LOAD IN BOLTS -

PULLOUT IS NOT POSSIBLE SINCE  $P_{SEISV} < P_{DW}$ . NET MINIMUM DOWNWARD LOAD IS  $1900 - 1568 = 332 \text{ LBS}$ .

$$T_{OVERTURNING} = \frac{(3420 \text{ LBS})(39 \text{ IN}) - (332 \text{ LBS})(\frac{27 \text{ IN}}{2})}{(27 \text{ IN})(2 \text{ BOLTS})}$$

$$= 2387 \text{ LBS/BOLT}$$

$$V_{DIRECT} = \frac{3420 \text{ LBS}}{4 \text{ BOLTS}} = 855 \text{ LBS/BOLT}$$

USE  $\frac{3}{4}$ " DIA RED HEAD SELF-DRILLING A.B.

TENSION ALLOWABLE = 3240 LBS/BOLT

SHEAR ALLOWABLE = 3240 LBS/BOLT

(INTERACTION OK BY ENGINEERING JUDGEMENT)

$F_s = 5$   
 SDG-G11  
 ISSUE 6

ALSO USE  $\frac{3}{4}$ " DIA BOLTS FOR N-9253 DUE TO SIMILARITY AND CONSERVATISM IN ANALYSIS. MINIMUM SPACING IS 7 IN. FOR 100% CAPACITY - OK.

PREPARED BY J. TESNER


DATE 8/26/83

REF. DOCUMENTS:

REVIEWED BY Mark Phelan

DATE 9/26/83


HIGHEST LOAD ON BOLTS FOR WALL MOUNTED EQUIPMENT WILL OCCUR WITH N-9269. ASSUME C.G. APPROXIMATELY CENTERED INSIDE CABINET.



$$P_{DW} = 380 \text{ LBS}$$

$$P_{SEISV} = (1.5)(380 \text{ LBS})(0.6) = 342 \text{ LBS}$$

$$P_{SEISH} = (1.5)(380 \text{ LBS})(1.4) = 798 \text{ LBS}$$



$$F_x = 798 \text{ LBS}$$

$$F_y = 380 + 342 = 722 \text{ LBS}$$

$$F_z = 798 \text{ LBS}$$

$$M_x = (798 \text{ LBS}) \left( 9.5 + \frac{17.875}{2} - \frac{3}{2} \text{ IN} \right) = 114714 \text{ IN-LBS}$$

$$M_y = (798 \text{ LBS})(11 \text{ IN}) = 8778 \text{ IN-LBS}$$

$$M_z = (722 \text{ LBS})(11 \text{ IN}) = 7942 \text{ IN-LBS}$$

$$R = \sqrt{(11.75)^2 + (8.9375)^2} = 14.76 \text{ IN}$$

## CALCULATIONS FOR

CALC. NO.

CN 1332 B

PREPARED BY J. TESNER

DATE 8/26/83

REF. DOCUMENTS:

BY M. RIGSBY

REVIEWED BY Mark Mullin

DATE 4/26/83

PAGE B-12 B

FORM NO. 372-30-2650

NOTE THAT EFFECTS OF SEISMIC LOADING FOR X, Y & Z DIRECTIONS ARE CONSIDERED SIMULTANEOUSLY (CONSERVATIVE)

$$T_{TENSION} = \frac{F_x}{4 \text{ BOLTS}} = \frac{798 \text{ LBS}}{4} = 200 \text{ LBS/BOLT}$$

$$T_{MOMENT} = \frac{M_y}{(2 \text{ BOLTS})(13.5 \text{ IN})} + \frac{M_z}{(2 \text{ BOLTS})(17.875 \text{ IN})}$$

$$= \frac{8778 \text{ IN-LBS}}{(2)(13.5)} + \frac{7942 \text{ IN-LBS}}{(2)(17.875)} = 409 \text{ LBS/BOLT}$$

$$T_{TOTAL} = 200 + 409 = 609 \text{ LBS/BOLT}$$

$$V_{SHEAR} = \sqrt{\left(\frac{F_y}{4 \text{ BOLTS}}\right)^2 + \left(\frac{F_z}{4 \text{ BOLTS}}\right)^2}$$

$$= \sqrt{\left(\frac{722}{4}\right)^2 + \left(\frac{798}{4}\right)^2} = 269 \text{ LBS/BOLT}$$

$$V_{MAX} = \frac{M_x}{(4 \text{ BOLTS})(14.76 \text{ IN})} = \frac{1147 \text{ IN-LBS}}{(4)(14.76)} = 19 \text{ LBS/BOLT}$$

$$V_{TOTAL} \approx 269 + 19 = 288 \text{ LBS/BOLT}$$

3/8" DIA RED HEADS ACCEPTABLE BUT USE 1/2" DIA FOR ADDITIONAL MARGIN OF SAFETY.

FOR 1/2" DIA BOLTS =

FS = 5

TENSION ALLOWABLE = 1700 LBS/BOLT

SDCC-11

SHEAR ALLOWABLE = 1344 LBS/BOLT

ISSUE 6

(INTERACTION OK BY INSPECTION)

SWITCH N-92118 IS MOUNTED TO BLOCK WALL IN BUILDING 10 JUST BELOW ELEV. 4800'-6" AND IS SIMILAR TO N-92117 IN WEIGHT, OVERALL DIMENSIONS AND MOUNTING BOLT LOCATIONS. THEREFORE 1/2" DIA BOLTS WILL BE ACCEPTABLE FOR ALL WALL MOUNTED ELECTRICAL COMPONENTS LISTED.

### UNISTRUT SUPPORTS

ALL UNISTRUT SUPPORTS REVIEWED FOR THIS CN ARE ACCEPTABLE DUE TO SHORT SPANS AND LOW DISTRIBUTED CONDUIT WEIGHT, AND HIGH RATED LOADS ON UNISTRUT COMPONENTS FOR BEAM SPANS USED. BASE ATTACHMENTS (ANCHOR BOLTS/SHELLS, WELDS) AND THREADED RODS ARE ADEQUATE BY INSPECTION.

### BUILDING STRUCTURE EVALUATION

HEAVY EQUIPMENT ATTACHED DIRECTLY TO BUILDING 10/TURBINE BUILDING REINFORCED CONCRETE WALLS AND FLOOR SLAB, AND MASONRY BLOCK WALL ARE NOT OF THE MAGNITUDE REQUIRING STRESS CHECKS SINCE THE BUILDING STRUCTURE IS MASSIVE AND AMPLY REINFORCED IN PROPORTION TO THE LOADING. CONDUIT LOADINGS ARE INSIGNIFICANT AND THEIR AFFECTS ON THE MAIN BUILDING ARE NEGLIGIBLE.





# PUBLIC SERVICE COMPANY OF COLORADO

FORT ST. VRAIN NUCLEAR GENERATING STATION

CN/ TCR / SCR / PC / TR

NO. 1391

PAGE 2

## SAFETY EVALUATION

### CATEGORY

TYPE:

- CN OVERALL   
  CN SUBMITTAL   
  SETPOINT CHANGE REPORT   
  TEST REQUEST  
 TEMPORARY CONFIGURATION REPORT   
  PROCEDURE CHANGE (FSAR)   
  OTHER

CLASSIFICATION: ARE THE SYSTEM(S) EQUIPMENT OR STRUCTURES INVOLVED, OR DOES THE ACTIVITY AFFECT:

- |                |   |                             |                         |   |  |
|----------------|---|-----------------------------|-------------------------|---|--|
| CLASS I        | <input checked="" type="checkbox"/> YES | <input type="checkbox"/> NO | ENGINEERED SAFEGUARD    | <input checked="" type="checkbox"/> YES | <input type="checkbox"/> NO            |
| SAFE SHUTDOWN  | <input checked="" type="checkbox"/> YES | <input type="checkbox"/> NO | PLANT PROTECTIVE SYSTEM | <input checked="" type="checkbox"/> YES | <input type="checkbox"/> NO            |
| SAFETY RELATED | <input checked="" type="checkbox"/> YES | <input type="checkbox"/> NO | SECURITY SYSTEM         | <input type="checkbox"/> YES            | <input checked="" type="checkbox"/> NO |

REMARKS

### EVALUATION

USE ADDITIONAL SHEETS IF REQUIRED.

1 IS THE ACTIVITY IDENTIFIED IN THE FSAR OR TECH SPEC?  YES  NO

LIST THE APPLICABLE SECTIONS REVIEWED. FSAR sections 8.2.3, 8.2.2.4, 8.3, 8.2.3.9, 8.4; Criterion 24 and 39; Tech Spec's section SR 5.6.2 and 6.0 4.6.1.

2 DOES THE ACTIVITY REQUIRE THAT CHANGE(S) BE MADE TO THE FSAR OR TECH SPEC?  YES  NO

LIST SECTIONS TO BE CHANGED AND THE CHANGES TO BE MADE. Change FSAR section 8.2.3.9 to reflect the new Amp-Hour ratings of the batteries being installed with this CN. Page 3 indicates a suggested method for FSAR update.

3 DETERMINE WHETHER OR NOT THE ACTIVITY INVOLVED IS AN UNREVIEWED SAFETY QUESTION UTILIZING THE FOLLOWING GUIDELINES.

(A) HAS THE PROBABILITY OF OCCURRENCE OR THE CONSEQUENCES OF AN ACCIDENT OR MALFUNCTION OF EQUIPMENT IMPORTANT TO SAFETY PREVIOUSLY EVALUATED IN THE FSAR BEEN INCREASED?

YES  NO STATE BASIS: Replacement of existing batteries with batteries of greater capacity can not increase the probability of occurrence or the consequences of any accident or malfunction evaluated in the FSAR.

(B) HAS THE POSSIBILITY OF AN ACCIDENT OR MALFUNCTION OF A DIFFERENT TYPE THAN ANY EVALUATED PREVIOUSLY IN THE FSAR BEEN CREATED?  YES  NO STATE BASIS:

Since the only change to the DC system is replacing existing batteries with new batteries of increased capacity, no possibility of a new accident or malfunction has been created.

(C) HAS THE MARGIN OF SAFETY, AS DEFINED IN THE BASIS FOR ANY TECHNICAL SPECIFICATION OR IN THE FSAR BEEN REDUCED?  YES  NO STATE BASIS:

No margin of safety concerning battery capacity is defined. Since this modification is in the conservative direction, increased battery capacity should infer greater protection from overload and therefore less chance of DC system failure.

DOES THE ACTIVITY APPEAR TO: INVOLVE AN UNREVIEWED SAFETY QUESTION  YES  NO  
BE SAFETY SIGNIFICANT  YES  NO

BY Michael G Glawer  
(SIGNATURE)

7/19/83  
(DATE)

\*APPROVED

J R Johns  
(SIGNATURE)

7-19-83  
(DATE)

\*REQUIRED ONLY FOR CHANGE NOTICE

FSAR UPDATE  
8.2-13

two out of four engines was predicted to be .0000041, assuming no disconnect device failure.

Although the Fort St. Vrain installation is provided with a disconnect device rather than a clutch, the clutch experience on the fishing vessels indicated a failure probability of .0001 with a 99% confidence. By adding a clutch failure probability of .0001, the probability of failure to start 2 out of 4 diesel engines increased to .0000042 from .0000041. By assuming the clutch failure probability to be .001, the probability of failure to start 2 out of 4 diesel engines increased from .0000041 to .0000054.

In view of this very low probability of failure to start, it was concluded, on the basis of these data and analyses, that the Fort St. Vrain diesel-generator installation is highly reliable (probability of failure less than  $10^{-6}$ ).

To provide performance data on the actual nuclear plant equipment, a reliability demonstration test of the diesel generators at Fort St. Vrain was conducted in accordance with specifications accepted by the AEC/DRL staff. This series of 298 starting reliability tests required by the AEC, resulted in no actual failures to start, and showed that the reliability of these units exceeds 0.99 at a 95% confidence level. Details of the test are presented in Reference 1.

The Fort St. Vrain standby diesel generators are subjected to weekly surveillance tests as required by the Technical Specifications. In these tests, the diesel generator is required to start on command and reach rated speed within a specified time. In April 1980, the test performance records for the period of 1974 through 1979 were reviewed and evaluated. During that time, 549 starts were accomplished with no actual failures to start as defined in the original reliability test criteria. The results of the evaluation indicated that the reliability of the emergency diesels remained equivalent to that demonstrated by the test of Reference 1.

#### 8.2.3.4. DC Batteries

The ~~832~~ <sup>1680</sup> amp-hour station batteries provide separate and normally independent sources of power for essential DC-powered auxiliaries and services. Each battery is adequate to supply shutdown DC loads for not less than one hour following a loss of all AC power. During this outage period, either of the two standby generators may be started, or the reserve power supply may be restored, to ensure continuity of power to DC loads (and initiation of a recharge cycle to the batteries).

These two batteries also provide the source of power, through separate inverter sets, to two of the four AC instrument power buses. ~~320~~ <sup>890</sup> amp-hour PPS battery provides a source of power to one of the AC instrument power buses through a separate inverter set. This ensures continuity of power for these

PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
NUCLEAR PROJECT DEPARTMENT

Electrical   
Mechanical   
Structural   
Safety Related   
Non Safety Related

DESIGN INPUT REQUIREMENTS

Sheet 1 of 2

THE REPLACEMENT OF THE 1A-1B STATION BATTERIES AND THE 1C (PPS) BATTERY IS A PORTION OF THE SCHEDULED WORK TO UPGRADE THE INSTRUMENT POWER BUSES. THESE BATTERIES HAVE BEEN IN SERVICE FOR 12 YEARS AND ARE EXPERIENCING CELL FAILURES. [REDACTED]

[REDACTED] THE EXISTING 1A-1B STATION BATTERIES ARE RATED 832 AMP-HOUR, THE REPLACEMENT BATTERY IS RATED 1680 AMP-HOUR. THE EXISTING 1C (PPS) BATTERY IS RATED 320 AMP-HOUR, THE REPLACEMENT BATTERY IS RATED 890 AMP-HOUR. THE ADDITIONAL CAPACITY THAT IS BEING INSTALLED WILL PROVIDE FOR FUTURE PLANT REQUIREMENTS. THE UPGRADE OF THE BATTERIES WILL NOT ALTER ANY OF THE REDUNDANCY FEATURES OR OPERATING PHILOSOPHIES OF THE INSTRUMENT POWER BUS SYSTEM.

THE 1A-1B STATION BATTERY CELL REPLACEMENT WILL BE DONE UTILIZING THE EXISTING BATTERY ROOMS, BATTERY RACKS AND WIRING. THE 1C (PPS) BATTERY WILL BE RELOCATED TO THE BATTERY ROOM ON THE GROUND FLOOR OF BUILDING 10 AND INSTALLED ON A NEW BATTERY RACK. NEW WIRING WILL BE REQUIRED BECAUSE OF THE RELOCATION.

THE EXISTING 1C (PPS) BATTERY WILL BE RETAINED AND USED IN CONJUNCTION WITH THE EXISTING 1C BATTERY CHARGER/INVERTER IC AS A COMPUTER POWER SOURCE. THIS WORK WILL BE DONE IN A FUTURE CN.

Prepared By: /s/ MURRAY RIGSBY /s/ [Signature] 5-31-83  
Date Date

CN 1391  
BY M. RIGSBY  
PAGE B1.1

PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
NUCLEAR PROJECT DEPARTMENT

Electrical   
Mechanical   
Structural   
Safety Related   
Non Safety Related

DESIGN INPUT REQUIREMENTS

Sheet 2 of 2

THIS CN WILL ONLY BE CONCERNED WITH THE REPLACEMENT AND HOOK-UP OF THE 1A-1B STATION BATTERY CELLS AND THE INSTALLATION OF THE NEW 1C (PPS) BATTERY RACK AND BATTERY CELLS IN THE BATTERY ROOM OF BUILDING 10. THE NEW WIRING REQUIRED FOR THE 1C (PPS) BATTERY INSTALLATION WILL BE COVERED IN CN-1332.

Prepared By: /s/ MURRAY RIGSBY 3/24/83 Date  
Approved By: /s/ J. Bates 5-31-83 Date  
MS 9-16-83



PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
SAFETY RELATED DESIGN ANALYSIS - SHEET 1

CN 1391  
BY M. RIGSBY  
PAGE 52

Form 344-22-4063

ELECTRICAL  
 MECHANICAL  
 STRUCTURAL

I. SEISMIC ANALYSIS

THE 1A-1B STATION BATTERY CELLS (FC-21) ARE QUALIFIED PER WYLE LABORATORIES REPORT 43515-1 DTD. MAY 6, 1977, THE ORIGINAL QUALIFICATION ON THE EXISTING BATTERY RACKS IS STILL VALID.

THE 1C (PPS) BATTERY CELLS (SC-21) AND BATTERY BACK ARE QUALIFIED PER WYLE LABORATORIES REPORT 44478-2, DTD. MAY 24, 1980. THE USE OF 1/2" DIA. CONCRETE ANCHOR BOLTS IN LIEU OF 1/2" DIA. SAE GRADE 5 BOLTS (P. G-8 SHT. 1 OF 6) IS AN ACCEPTABLE ANCHORING METHOD FOR SEISMIC LOADING ON BATERIES (SEE CALCS ON PAGES B-2.3 & B-2.4). RACK LOADINGS HAVE NO SIGNIFICANT EFFECT ON BATTERY ROOM REINFORCED CONCRETE FLOOR.

II. STRESS ANALYSIS

N/A

III. PIPING/HANGER ANALYSIS

N/A

IV. HYDRAULIC/PNEUMATIC ANALYSIS

N/A



PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
SAFETY RELATED DESIGN ANALYSIS - SHEET 2

CN 1391  
BY M. Rigby  
PAGE B2.1

Form 344-22-4088

V. THERMAL ANALYSIS

REPLACEMENT BATTERY CELLS ARE CERTIFIED TO OPERATE SATISFACTORILY IN AN AMBIENT TEMPERATURE OF UP TO 120°F. (WORST CASE WITH LOSS OF A/C)

VI. NUCLEAR ANALYSIS

N/A

VII. FIRE PROTECTION ANALYSIS

STATION BATTERIES 1A-1B WILL REMAIN IN THE EXISTING BATTERY ROOMS THERE WILL BE NO CHANGE TO THE EXISTING FIRE PROTECTION STATUS.  
1C (PPS) BATTERY WILL BE RELOCATED TO THE BATTERY ROOM ON THE GROUND FLOOR OF BLDG. 10, ADEQUATE FIRE PROTECTION IS BEING INSTALLED IN THIS BUILDING.

VIII. ENVIRONMENTAL ANALYSIS

REPLACEMENT CELLS MEET ALL ENVIRONMENTAL CRITERIA AS OUTLINED IN SPEC. 92-N-56-2  
SEE PG. B2.5 FOR AIR CHANGE CALCULATIONS FOR BATTERY ROOMS/HYDROGEN OUTPUT.

IX. COMPATIBILITY OF MATERIALS, EQUIPMENT, AND PROCESSES

NO CONFLICT WITH STANDARDS.



PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
SAFETY RELATED DESIGN ANALYSIS - SHEET 3

CN 1391  
BY M. RIGSBY  
PAGE 32.2

Form 344-22-4069

X. ACCESSIBILITY FOR IN-SERVICE INSPECTION, MAINTENANCE, AND REPAIR

STATION BATTERY ROOMS 1A-1B WILL NOT BE ALTERED, ACCESSIBILITY WILL NOT CHANGE.  
1C (PPS) BATTERY ROOM IN BUILDING 10 WAS DESIGNED TO PROVIDE CENTER AISLE ACCESS.

XI. SEPARATION AND SEGREGATION ANALYSIS

EACH BATTERY (1A-1B-1C) LOCATED IN SEPARATE BATTERY ROOMS. NO CHANGES WILL BE MADE TO 1A-1B STATION BATTERY WIRING.  
1C (PPS) BATTERY WIRING WILL BE RUN IN CONDUIT.

XII. ELECTRICAL ANALYSIS

CAPACITY OF STA. BATT. 1A-1B WILL INCREASE FROM 832 AMP-HR TO 1680 AMP-HR.  
CAPACITY OF 1C (PPS) BATT. WILL INCREASE FROM 320 AMP-HR TO 890 AMP-HR.  
EXISTING DISCHARGE TESTS WILL NOT BE ALTERED, 1A-1B STA. BATT. TESTS WILL BE BASED ON 832 AMP-HR DISCHARGE, 1C (PPS) BATT. TEST WILL BE BASED ON 320 AMP-HR DISCHARGE.

\*

XIII. ACCIDENT ANALYSIS

NO NEW ACCIDENT MODES HAVE BEEN CREATED

↳ THE ADDITIONAL 1A-1B BATTERY CAPACITY WAS NOT PURCHASED AS A REQUIREMENT. THE CONCERN WAS TO PURCHASE A BATTERY THAT WOULD FIT THE EXISTING RACKS. ENGINEERING ADVANCEMENTS IN THE BATTERY FIELD ACCOUNT FOR THE ADDITIONAL CAPACITY IN COMPARABLE CELL DIMENSIONS.

PREPARED BY Murray Rigby 8/5/83  
DATE

CALCULATIONS FOR

PREPARED BY

DATE

REVIEWED BY

DATE

CALC. NO.

REF. DOCUMENTS:


CN 1391

BY TESNER

PAGE B-2.3

FORM NO. 372-30-2650

EVALUATE 1/2" DIA RED HEAD SELF-DRILLING ANCHORS FOR RACK



DW OF 60 CELLS AND BOTH RACKS  
= 12,800 LBS (REF. EXIDE RACK DWG)

EACH RACK IS 14'-0 LONG, THEREFORE  
 $DW = \frac{12,800 \text{ LBS}}{(14 \text{ FT/RACK})(2 \text{ RACKS})} = 457 \text{ LBS/FT}$

RACK FRAMES ARE ON 28.25" CENTERS  
DW FOR EACH FRAME IS  
 $(457 \text{ LBS/FT}) / \frac{28.25 \text{ FT}}{12} = 1076 \text{ LBS}$

REFER TO SWEC CALC "AMPLIFIED  
RESPONSE SPECTRA FOR 3 ROOM  
COMPLEX ADDITION" CALC. REV. 0,  
FIGS. 19, 20 & 21, DAMPING = 5%  
FOR BELOW VALUES (REG. GUIDE  
1.61 ALDWS 7% DAMPING FOR  
BOLTED STEEL STRUCTURES, 5%

RACK SECTIONAL VIEW

(DIMENSIONS APPROXIMATE - REFER  
TO RACK DWG P. G-9 AND P. G-5)

SEISMIC ACCCELERATIONS TO BE AMPLIFIED IS CONSERVATIVE)  
BY FACTOR OF 1.5 TO ACCOUNT FOR VARIOUS  
MODES OF VIBRATION

$g_v = 0.53$  PEAK VERTICAL ACCELERATION ELEV. 4791'

$g_H = 0.9$  PEAK HORIZONTAL ACCELERATION ELEV. 4791' (N-S, FIG. 19)

ASSUME TOTAL RACK LOAD IS ORIGINATING EQUALLY FROM THE  
ASSUMED C.G. OF BATERIES:

$$F_y(\text{MIN}) = (1/2)(1076 \text{ LBS})(1.0 - (1.5)(0.53)) = 110 \text{ LBS (ACTS DOWN)}$$

$$F_H = (1/2)(1076 \text{ LBS})(1.5)(0.9) = 726 \text{ LBS}$$

SUM MOMENTS ABOUT POINT A FOR OVERTURNING - ASSUME ONLY  
1 BOLT (AT B) RESISTS OVERTURNING:

$$(T_B)(35.6 \text{ IN.}) + (110 \text{ LBS})(8.9 \text{ IN.} + 26.7 \text{ IN.}) - (726 \text{ LBS})(20 \text{ IN.} + 16 \text{ IN.}) = 0$$

$$T_B = \frac{26136 - 39114 \text{ IN-LBS}}{35.6 \text{ IN.}} = 624 \text{ LBS TENSION}$$

$$V_B = (726 \text{ LBS})(2) / 2 \text{ BOLTS} = 404 \text{ LBS SHEAR}$$



CALCULATIONS FOR

CALC. NO.

CN 1391

PREPARED BY

DATE

REF. DOCUMENTS:

BY TESNER

REVIEWED BY

DATE

PAGE 8-2.4

FORM NO. 372-30-2650

ALLOWABLE LOADS FOR  $\frac{1}{2}$ "  $\phi$  RED HEAD SELF-DRILLING BOLT, FACTOR OF SAFETY = 5, ADJUSTED FOR CONCRETE STRENGTH  $f'_c = 3500$  PSI:

$$T_A = 1700 \text{ LBS}$$

$$V_A = 1344 \text{ LBS}$$

REF SDCC-011 ATTACHMENT K  
ISSUE 6

MINIMUM SPACING FOR 100% CAPACITY - 5 IN. OK

→  $\frac{1}{2}$ " DIA. ANCHORS ARE SATISFACTORY

PREPARED BY: J. TESNER

Battery Hydrogen Gas Output Calculation

(Ref. Exide Bulletin Section 58.00 Sh. 1 For Formula Eq. G7)

1. Existing Lead-Antimony Batteries (1A-1B Station Batteries)

890 Amp Hour

60 Cells

2.36 VPC charging (Eq. Chg.)

1344 Cu ft. (Battery Room)

$$60 \times \frac{890}{5.98} \times .700 \times 8.9 \times .016 = 598 \text{ Cu Ft H}_2 \text{ GAS/HR}$$

$$\frac{598}{13.4} = .446 \text{ Air Changes/HR (to keep H}_2 \text{ concentration less than 1\%)}$$

2. New Lead-Calcium Batteries (1A-1B Station Batteries)

1680 Amp Hour

60 Cells

2.42 VPC charging (Eq. Chg.)

1344 Cu ft. (Battery Room)

$$60 \times \frac{1680}{9.95} \times .058 \times 16.8 \times .016 = .935 \text{ Cu Ft. H}_2 \text{ GAS/HR}$$

$$\frac{.935}{13.4} = .070 \text{ Air Changes/HR (to keep H}_2 \text{ concentration less than 1\%)}$$

3. New Lead-Calcium Batteries (1C Battery, Bldg 10)

890 Amp Hour

60 Cells

2.42 VPC charging (Eq. Chg.)

1344 Cu. ft. (Battery Room)

$$60 \times \frac{890}{4.96} \times .058 \times 8.9 \times .016 = .496 \text{ Cu ft. H}_2 \text{ GAS/HR}$$

$$\frac{.496}{13.4} = .037 \text{ Air Changes/HR (to keep H}_2 \text{ concentration less than 1\%)}$$

The above indicates the existing 1A & 1B station Battery Rooms have had and will have sufficient ventilation for the new batteries.

The new Bldg. 10 Battery Room also provides adequate ventilation.



PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
CHECK LIST OF DESIGN VERIFICATION QUESTIONS  
FOR DESIGN REVIEW METHOD

CN 1391  
BY R. Schendorf  
PAGE 83

Form 344-22-4095

- | YES                                 | NO                       | N/A                                 |   |
|-------------------------------------|--------------------------|-------------------------------------|---|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 1. Were the inputs correctly selected and incorporated into design?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 2. Are assumptions necessary to perform the design activity adequately described and reasonable? Where necessary, are the assumptions identified for subsequent re-verifications when the detailed design activities are completed? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 3. Are the appropriate quality and quality assurance requirements specified?  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 4. Are the applicable codes, standards and regulatory requirements including issue and addenda properly identified and are their requirements for design met?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 5. Have applicable construction and operating experience been considered?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 6. Have the design interface requirements been satisfied?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 7. Was an appropriate design method used?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 8. Is the output reasonable compared to inputs?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 9. Are the specified parts, equipment, and processes suitable for the required application?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 10. Are the specified materials compatible with each other and the design environmental conditions to which the material will be exposed?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 11. Have adequate maintenance features and requirements been specified?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 12. Are accessibility and other design provisions adequate for performance of needed maintenance and repair?  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 13. Has adequate accessibility been provided to perform the in-service inspection expected to be required during the plant life?  |
| <input type="checkbox"/>            | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 14. Has the design properly considered radiation exposure to the public and plant personnel?  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 15. Are the acceptance criteria incorporated in the design documents sufficient to allow verification that design requirements have been satisfactorily accomplished?   |
| <input type="checkbox"/>            | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 16. Have adequate pre-operational and subsequent periodic test requirements been appropriately specified?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 17. Are adequate handling, storage, cleaning and shipping requirements specified?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 18. Are adequate identification requirements specified?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 19. Are requirements for record preparation review, approval, retention, etc., adequately specified?  |

NOTE: If the answer to any question is no, provide additional information and resolution below:

RESOLUTION OF DESIGN DEFICIENCIES  
UNCOVERED DURING THE DESIGN VERIFICATION PROCESS

*No design deficiencies found.*

*R.A. Schendorf* 5/25/83  
*RA* 9/16/83



# PUBLIC SERVICE COMPANY OF COLORADO

FORT ST. VRAIN NUCLEAR GENERATING STATION

CN/TCR/SCR/PC/TR

NO. 1781

PAGE 2

## SAFETY EVALUATION

### CATEGORY

TYPE:

- CN OVERALL   
  CN SUBMITTAL   
  SETPOINT CHANGE REPORT   
  TEST REQUEST  
 TEMPORARY CONFIGURATION REPORT   
  PROCEDURE CHANGE (FSAR)   
  OTHER

CLASSIFICATION: ARE THE SYSTEM(S) EQUIPMENT OR STRUCTURES INVOLVED, OR DOES THE ACTIVITY AFFECT:

- |                |   |  |                         |                              |  |
|----------------|---|--|-------------------------|------------------------------|--|
| CLASS I        | <input type="checkbox"/> YES            | <input checked="" type="checkbox"/> NO | ENGINEERED SAFEGUARD    | <input type="checkbox"/> YES | <input checked="" type="checkbox"/> NO |
| SAFE SHUTDOWN  | <input type="checkbox"/> YES            | <input checked="" type="checkbox"/> NO | PLANT PROTECTIVE SYSTEM | <input type="checkbox"/> YES | <input checked="" type="checkbox"/> NO |
| SAFETY RELATED | <input checked="" type="checkbox"/> YES | <input type="checkbox"/> NO            | SECURITY SYSTEM         | <input type="checkbox"/> YES | <input checked="" type="checkbox"/> NO |

REMARKS Fire Protection - treat as safety related

### EVALUATION

USE ADDITIONAL SHEETS IF REQUIRED.

1 IS THE ACTIVITY IDENTIFIED IN THE FSAR OR TECH SPEC?  YES  NO  
 LIST THE APPLICABLE SECTIONS REVIEWED. FSAR sections 1.6.7, 8.2.5, 8.2.7.1, 8.2.7.9, 8.2.7.5, 8.2.7.7, 9.12.5, 9.12.6, 14.1.4, Criterion 3 Tech Spec LCO 4.10 SR 5.10

2 DOES THE ACTIVITY REQUIRE THAT CHANGE(S) BE MADE TO THE FSAR OR TECH SPEC?  YES  NO  
 LIST SECTIONS TO BE CHANGED AND THE CHANGES TO BE MADE.

3 DETERMINE WHETHER OR NOT THE ACTIVITY INVOLVED IS AN UNREVIEWED SAFETY QUESTION UTILIZING THE FOLLOWING GUIDELINES.

(A) HAS THE PROBABILITY OF OCCURRENCE OR THE CONSEQUENCES OF AN ACCIDENT OR MALFUNCTION OF EQUIPMENT IMPORTANT TO SAFETY PREVIOUSLY EVALUATED IN THE FSAR BEEN INCREASED?  YES  NO STATE BASIS: Adding a one hour fire rated cable tray wrap to thermally isolate cables in a tray from the outside environment will decrease the probability of occurrence of electrical fires as described in the FSAR.

(B) HAS THE POSSIBILITY OF AN ACCIDENT OR MALFUNCTION OF A DIFFERENT TYPE THAN ANY EVALUATED PREVIOUSLY IN THE FSAR BEEN CREATED?  YES  NO STATE BASIS: The one hour fire blanket only isolates the cables within the tray from a possible thermal environment during a fire and cannot introduce the possibility of a new accident.

(C) HAS THE MARGIN OF SAFETY, AS DEFINED IN THE BASIS FOR ANY TECHNICAL SPECIFICATION OR IN THE FSAR BEEN REDUCED?  YES  NO STATE BASIS: No explicit margin of safety concerning a fire retardant cable tray wrap is given in the technical specifications or FSAR and therefore cannot be reduced. The overall plant margin of safety will be increased due to the increased reliability of the plant inverters.

DOES THE ACTIVITY APPEAR TO: INVOLVE AN UNREVIEWED SAFETY QUESTION  YES  NO  
 BE SAFETY SIGNIFICANT  YES  NO

BY Michael B. Leaver  
 (SIGNATURE)

3/23/84  
 (DATE)

\*APPROVED J.R. Johns  
 (SIGNATURE)

3-24-84  
 (DATE)

\*REQUIRED ONLY FOR CHANGE NOTICE



PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
DESIGN INPUT REQUIREMENTS

CN 1781  
BY M. MILLER  
PAGE 01

Form 344-22-4060

- ELECTRICAL
- MECHANICAL
- STRUCTURAL
- SAFETY RELATED
- NON-SAFETY RELATED

1. AN ANALYSIS OF BUILDING 10 BY PROTO-POWER, FOUND IN CN-1461, RECOMMENDS THAT A ONE-HOUR RATED FIRE RETARDENT BE ADDED TO A PORTION OF THE CABLE TRAY SYSTEM. THE EXACT LOCATIONS OF THE CABLE TRAYS CAN BE FOUND IN THE G-PACKAGE.
2. BTP 9.5-1, APPENDIX A REQUIRES THAT REDUNDANT SAFETY RELATED SYSTEMS BE SEPARATED FROM EACH OTHER SO THAT BOTH ARE NOT SUBJECT TO DAMAGE FROM A SINGLE FIRE HAZARD.
3. BOTH B1L1, AND B2L2 CABLES SERVE INVERTERS 1A AND 1B RESPECTIVELY IN THE SAME FIRE AREA IN BUILDING 10. AS A MINIMUM, INVERTER 1A OR 1B IS NEEDED FOR PLANT SHUTDOWN.
4. A ONE HOUR FIRE RATED CABLE TRAY WRAP MATERIAL WILL BE INSTALLED ON A PORTION OF CABLE TRAY IN BUILDING 10 AS RECOMMENDED BY PROTO-POWER IN CN-1461. THE HEMYC SYSTEM CONSISTS OF TWO BASIC COMPONENTS; A LIGHT WEIGHT METAL FRAMEWORK ATTACHED TO THE CABLE TRAY AND A FIREPROOF BLANKET THAT SURROUNDS THE FRAMEWORK.

PREPARED BY

SIGNATURE

Mark A. Miller 1/26/84

DATE

APPROVED BY

SIGNATURE

J. Bates

3/23/84

DATE



PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
SAFETY RELATED DESIGN ANALYSIS - SHEET 1

CN 1781  
BY M. MILLER  
PAGE 32

Form 344-22-4083

ELECTRICAL  
 MECHANICAL  
 STRUCTURAL

I. SEISMIC ANALYSIS

THE COMBINED WEIGHT OF THE BLANKET AND METAL FRAMEWORK TO THE CABLE TRAY SYSTEM IS CONSIDERED NEGLIGIBLE.

II. STRESS ANALYSIS

ADDITION WEIGHT TO THE CABLE TRAYS IS CONSIDERED NEGLIGIBLE.

III. PIPING/HANGER ANALYSIS

THE ADDITIONAL WEIGHT OF THE METAL FRAMEWORK TO THE CABLE TRAY SYSTEM IS CONSIDERED NEGLIGIBLE.

IV. HYDRAULIC/PNEUMATIC ANALYSIS

DOES NOT APPLY.



Form 344-22-4088

V. THERMAL ANALYSIS

THE WRAPPING WILL CONSIST OF A CERAMIC FIBER BLANKET (2300° WORKING TEMPERATURES) SEWN INTO AN ENVELOPE OF FIRE PROOF FABRIC (3400° F TEMPERATURE LIMIT ON EXPOSED SURFACES) USING A QUARTZ THREAD (3600° F TEMPERATURE LIMIT). THESE MATERIALS ARE ADEQUATE TO PROVIDE THE ONE-HOUR FIRE RATED PROTECTION. SEE ADDITIONAL SHEETS P. B4.1 & B4.2.

VI. NUCLEAR ANALYSIS

N/A

VII. FIRE PROTECTION ANALYSIS

CABLE TRAY PORTIONS WILL BE WRAPPED WITH A ONE-HOUR FIRE RATED BLANKET TO MEET REQUIREMENTS FOUND ON PAGE 131 OF THIS CN. CERTIFICATE OF CONFORMANCE FOR THE ONE HOUR FIRE RATING WILL BE SUPPLIED BY THE MANUFACTURER.

VIII. ENVIRONMENTAL ANALYSIS

THE BLANKET MATERIAL CONTAINS NO HAZARDOUS MATTER OR CHEMICALS, IS TOTALLY INERT AND DEVELOPS NO TOXIC OR DANGEROUS BY-PRODUCTS AT ANY TIME. IT CONTAINS NO ASBESTOS AND NO CURING TIME IS REQUIRED DURING INSTALLATION. THE BLANKET IS DESIGNED FOR THE TYPE OF ENVIRONMENT IT WILL BE INSTALLED IN.

IX. COMPATIBILITY OF MATERIALS, EQUIPMENT, AND PROCESSES

THE ENTIRE NEMVC SYSTEM IS COMPATIBLE WITH THE CABLE TRAYS IN BUILDING 10.



PUBLIC SERVICE COMPANY OF COLORADO  
FORT ST. VRAIN NUCLEAR GENERATING STATION  
SAFETY RELATED DESIGN ANALYSIS - SHEET 3

CN 1781  
BY M. MILLER  
PAGE 34

Form 344-22-4089

- X. ACCESSIBILITY FOR IN-SERVICE INSPECTION, MAINTENANCE, AND REPAIR  
SHOULD A BLANKET BE DAMAGED, REPAIR CAN BE DONE BY PLANT PERSONNEL WITH A MINIMUM OF TRAINING. NEW CABLE RUNS CAN BE INSTALLED BY REMOVING THE NECESSARY BLANKET, PLACING THE CABLE, AND RE-ATTACHING THE BLANKET. NO CUTTING, DRILLING, OR WELDING TO THE CABLE TRAY IS REQUIRED.
- XI. SEPARATION AND SEGREGATION ANALYSIS  
PREVIOUS SEPARATION AND SEGREGATION ANALYSIS FOR BUILDING 10 CABLE TRAYS WILL NOT BE AFFECTED BY ACTIVITIES PERFORMED IN THIS CN. SEPARATION AND SEGREGATION OF CABLES WILL BE SECURED BY THE ADDITION OF THE ONE HOUR FIRE RATED BLANKET.
- XII. ELECTRICAL ANALYSIS  
THE BLANKET WILL NOT AFFECT PERFORMANCE OF CABLES WITHIN THE CABLE TRAY.
- XIII. ACCIDENT ANALYSIS  
NO NEW ACCIDENTS OR HAZARDS WILL BE CREATED BY THIS CN. ALSO THE ADDITION OF THE ONE HOUR FIRE RATED BLANKET TO THE CABLE TRAY SYSTEM WILL REDUCE THE PROBABILITY OF AN ACCIDENT.

PREPARED BY Mark A. Miller 1/26/84  
DATE



THERMAL ANALYSIS

Wrapping a one-hour fire rated blanket around cable trays in Building 10 will trap heat being dissipated from the power cables, raising the ambient temperatures around the cables.

Table 1 shows data collected from B&B Insulation's Ampacity Test. Pages B4-3 thru B4-5 show the cable tray layout, thermocouples, and arrangement of cables in the trays. The objective of the cable tray ampacity test was to determine the maximum cable ampacity with a conductor temperature of 90°C with a tray wrapped with the blanket. (HEMYC Fire Protection System.) There are presently 4 circuits in Building 10 cable trays that are affected by the blankets:

			Actual Load Amps	WATTS/FT (I <sup>2</sup> R)	TOTAL WATTS/FT
ca. 5427	3/c #6	480V Feed to 1C XFMR	20	.20	.40
		For #6, R = .0005038 Ω/FT.			
ca. 141	3/c #6	480V Feed to 1A XFMR	0	0	0
ca. 1157	2-1/c 350	125VDC Inverter Input Feed	150	.85	1.70
		For 350 MCM, R = .0000378 Ω/FT.			
ca. 143	2-1/c 350	60VAC Inverter Output	125	.60	1.20
				TOTAL WATTS/FT = 3.30	

The total WATTS/FT for the four circuits is 3.30 watts/ft. The total heat dissipated during the B&B ampacity test was 63.83 watts/ft.

- Δ Only two conductors will be energized. One is spare.
- This is a backup cable to ca. 143.
- ★ Insulco/B&B's Final Report for Ampacity Test Cable Tray and Conduit Containing 600 Volt Power Cables Protected By A HEMYC FIRE WRAP.

### CONCLUSION

Page 2 of 2

The 3.32 WATTS/FT does not exceed the 63.83 WATTS/FT found from the B & B ampacity test. To ensure that 63.83 WATTS/FT are not exceeded, cable tray drawings will log each new cable and the additional WATTS/FT per cable.


TABLE 1  
CABLE TRAY RESULTS

<u>CABLE I.D.</u>	<u>CABLE TYPE</u>	<u>NUMBER OF CABLES IN TRAY</u>	<u>RESISTANCE Ω/FT.</u>	<u>TOTAL NUMBER OF CONDUCTORS</u>	<u>FSV</u>	<u>IPCEA (ICEA) @ 2.0 IN.</u>	<u>TESTED AMPACITIES</u>	<u>WATTS/FT. (I<sup>2</sup>R) per conductor</u>	<u>TOTAL WATTS (per FT.)</u>
	1/C 500 MCM		.0000266		277	320	400*	4.24	4.240
E	3-1/C 250 MCM	6	.0000529	18	179	176	199	2.10	37.800
	1/C #1/0		.00001250		102.6	78	88*	.097	.097
D	1/C #4	4	.0003163	4	56	33	36.9	.431	1.724
C	3/C #8	8	.0008013	24	31.6	22	19.8	.314	7.536
B	2/C #10	36	.0012750	72	23	14.28	8.1	.084	6.048
A	4/C #10	19	.0012750	76	23	14.0	8.1	.084	6.384
	<u>Totals</u>	<u>73</u>		<u>194</u>					

CN 1781  
BY M. MILLER  
PAGE B. 4. 3  
FORM NO. 373-30-2680

\*Graph Projection  
(See Figure 6)

63-83



UNISTRUT  
SUPPORT AT INTERVALS  
OF 6 - 0 FEET

FIGURE 1  
CABLE TRAY SUPPORT FOR TEST




FIGURE 2  
 CABLE TRAY WITH RANDOM LAY  
 USED IN THE TESTS

NOTES: The Cable Depth Is Two (2) Inches Using The Formula:

$$\frac{(N_1)(d_1)^2 + (N_2)(d_2)^2 \dots (N_r)(d_r)^2}{W}$$

THERMOCOUPLES




FIGURE 3  
THERMOCOUPLE LOCATIONS IN THE  
CABLE TRAY FOR TEST





FIGURE 4

ELECTRICAL CIRCUIT USED DURING TEST

46 7522

K-E LOGARITHMIC 3 P 5 CYCLES  
 NEWFEL & ESSER CO. MADE IN U.S.A.

CONDUCTORS CROSSSECTIONAL AREA IN SQUARE MM



▲ Test Readings  
 ● Projected

FIGURE 6  
 PROJECTIONS FOR AMPACITIES





PUBLIC SERVICE COMPANY OF COLORADO  
 FORT ST. VRAIN NUCLEAR GENERATING STATION  
 CHECK LIST OF DESIGN VERIFICATION QUESTIONS  
 FOR DESIGN REVIEW METHOD

CN 1721  
 BY WALLACE  
 PAGE 85

Form 344-22-4095

YES NO N/A

- |                                     |                          |                                     |   |
|-------------------------------------|--------------------------|-------------------------------------|---|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 1. Were the inputs correctly selected and incorporated into design?   |
| <input type="checkbox"/>            | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 2. Are assumptions necessary to perform the design activity adequately described and reasonable? Where necessary, are the assumptions identified for subsequent re-verifications when the detailed design activities are completed? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 3. Are the appropriate quality and quality assurance requirements specified?  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 4. Are the applicable codes, standards and regulatory requirements including issue and addenda properly identified and are their requirements for design met?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 5. Have applicable construction and operating experience been considered?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 6. Have the design interface requirements been satisfied?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 7. Was an appropriate design method used?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 8. Is the output reasonable compared to inputs?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 9. Are the specified parts, equipment, and processes suitable for the required application?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 10. Are the specified materials compatible with each other and the design environmental conditions to which the material will be exposed?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 11. Have adequate maintenance features and requirements been specified?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 12. Are accessibility and other design provisions adequate for performance of needed maintenance and repair?  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 13. Has adequate accessibility been provided to perform the in-service inspection expected to be required during the plant life?  |
| <input type="checkbox"/>            | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 14. Has the design properly considered radiation exposure to the public and plant personnel?  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 15. Are the acceptance criteria incorporated in the design documents sufficient to allow verification that design requirements have been satisfactorily accomplished?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 16. Have adequate pre-operational and subsequent periodic test requirements been appropriately specified?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 17. Are adequate handling, storage, cleaning and shipping requirements specified?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 18. Are adequate identification requirements specified?   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/>            | 19. Are requirements for record preparation review, approval, retention, etc., adequately specified?  |

NOTE: If the answer to any question is no, provide additional information and resolution below:

RESOLUTION OF DESIGN DEFICIENCIES  
UNCOVERED DURING THE DESIGN VERIFICATION PROCESS

1. BY WRAPPING THE BLANKETS AROUND POWER TRAYS IT WILL TRAP HEAT BEING DISCIPATED OFF OF POWER CABLES RAISING THE AMBIENT TEMPERATURES AROUND THE CABLES. HAS THE EFFECT OF THIS HEAT BUILD-UP BEEN ADDRESSED AND CABLES DERATED FOR THE RAISED AMBIENT TEMPERATURE? THERMO ANALYSIS HAS BEEN ADDRESSED SEE PAGES B4.1 AND B4.2

Daniel Wallace  
 2/2/84  
 DW  
 3/14/84