

NOV 2 1984

Docket No. 50-346

Toledo Edison Company  
ATTN: Mr. Richard P. Crouse  
Vice President  
Nuclear  
Edison Plaza  
300 Madison Avenue  
Toledo, OH 43652

Gentlemen:

Thank you for your letter dated October 22, 1984, informing us of the steps you have taken in response to our Immediate Action Letter (IAL) dated January 29, 1981. The IAL required that you establish a program to identify the source of water found in the electrical penetrations and to establish a testing program to verify the continued acceptability of the penetrations. Based on your letter and our observations, as documented in Inspection Report No. 346/84-23, dated October 5, 1984, we concur that the testing program, as required by the IAL, may be discontinued.

We consider your actions to be adequate and hereby close the IAL.

Sincerely,  
Original signed by  
A. Bert Davis  
  
James G. Keppler  
Regional Administrator

cc w/ltr dtd 10/22/84:  
T. D. Murray, Station  
Superintendent  
DMB/Document Control Desk (RIDS)  
Resident Inspector, RIII  
Harold W. Kohn, Ohio EPA  
James W. Harris, State of Ohio  
Robert H. Quillin, Ohio  
Department of Health

8411060357 841102  
PDR ADOCK 05000346  
Q PDR

AITS F03059284 ✓

RIII  
*R.M.*  
Mendez/lc  
10/30/84

RIII  
*Williams*  
Williams  
10/1/84

RIII  
*Jackiw*  
Jackiw  
11/1/84

RIII  
*Little*  
Little  
11/1/84

RIII  
*Spessard*  
Spessard  
11/1

RIII  
*Davis*  
Davis  
11/1

RIII  
*Keppler*  
Keppler  
11/1

11/1  
1E01