

Nuclear Construction Division Robinson Plaza, Building 2, Suite 210 Pittsburgh, PA 15205 2NRC-4-181 (412) 787-5141 (412) 923-1960 Telecopy (412) \$57-2629 November 1, 1984

United States Nuclear Regulatory Commission Washington, DC 20555

ATTENTION: Mr. George W. Knighton, Chief

Licensing Branch 3

Office of Nuclear Reactor Regulation

SUBJECT:

Beaver Valley Power Station - Unit No. 2

Docket No. 50-412

FSAR Separate Submittal for Environmental Qualification Report Environmental Qualification of Safety Related Mechanical

Equipment

Gentlemen:

Submitted for your review at this time are six (6) copies of the updated Environmental Qualification Program for Safety Related Mechanical Equipment. This is part of the Equipment Qualification Report transmitted to you this past June (2NRC-4-087, dated June 22, 1984). This program has been performed by Duquesne Light Company (DLC) in response to FSAR Questions 270.2 and 270.3 identified in FSAR Amendment 4 (2NRC-3-096, dated December 2, 1983).

The program as revised contains the following information:

- 1) Qualification methodology utilized
- 2) Detailed master listing of equipment included
- 3) Oualification results

It is understood that several items will be chosen by the Equipment Qualification Branch for detailed review. Extensive back-up documentation and additional information is available in conjunction with the program and will be transmitted to you for those items selected.

The evaluation's results are now complete and DLC has initiated steps to qualify that equipment that has been identified as not having the ability to withstand the postulated environments. Equipment items with the EQ status code of "I" denoted on this master list are included in this category. This generally indicates that a particular type and/or model number is not well suited for a specific area (i.e., containment) as opposed to the item lacking any substantial qualification levels.

8411060531 841101 PDR ADOCK 05000412 A PDR A048

United States Nuclear Regulatory Commission Mr. George W. Knighton, Chief Page 2

All requests for additional information should be coordinated through Mr. C. L. Hill who can be contacted at (412) 787-5141.

DUQUESNE LIGHT COMPANY

E. J. Woolever
Vice President

CLH/wjs Attachment

cc: Mr. B. K. Singh, Project Manager (w/a)
Mr. G. Walton, NRC Resident Inspector (w/a)

COMMONWEALTH OF PENNSYLVANIA)

SS:
COUNTY OF ALLEGHENY)

Notary Public

ANITA ELAINE REITER, NOTARY PUBLIC ROBINSON TOWNSHIP, ALLEGHENY COUNTY MY COMMISSION EXPIRES OCTOBER 20, 1986 United States Nuclear Regulatory Commission Mr. George W. Knighton, Chief Page 3

CLH/wjs NR/NRC/EQ/SRME Attachment

```
bcc: J. J. Carey (w/o attachment)
     W. T. Wardzinski "
     E. J. Woolever
     C. E. Ewing
     T. D. Jones
     J. A. Hultz
     R. E. Dougher
     E. F. Kurtz, Jr.
     J. H. Latshaw
                         - 11
     T. P. Noonan
     J. A. Rocco
     H. M. Siegel
     R. J. Swiderski
     G. L. Beatty
     E. T. Eilmann
     K. M. Holcomb
     J. Lee, Esq.
     R. E. Martin
     S. L. Pernick, Jr.
     T. J. Zoglmenn
     C. R. Bishop
     D. E. Burke (CEI)
     R. G. Schuerger (CEI) "
     W. T. Keller (NUTEC) "
     B. M. Miller (2) (OEC)"
     J. Silberg (SPPT)
     P. RaySircar (S&W)
     D. Chamberlain (S&W) "
     T. J. Lex (W)
      B. Lorenz (W)
     C. L. Hill
                   (w/attachment)
     NCD File
```