

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) H. B. Robinson Unit 2	DOCKET NUMBER (2) 0 5 0 0 0 0	PAGE (3) 1 OF 0 2
--	----------------------------------	----------------------

TITLE (4)  
Condensate Storage Tanks Level Transmitters

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
0 6	2 6	8 4	8 4	0 0 8	0 0	0 7	2 6	8 4			0 5 0 0 0 0
											0 5 0 0 0 0

OPERATING MODE (9) \_\_\_\_\_

POWER LEVEL (10) 0 0 1 0

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)

<input type="checkbox"/> 20.402(b)	<input type="checkbox"/> 20.408(a)	<input type="checkbox"/> 80.73(a)(2)(iv)	<input type="checkbox"/> 73.71(b)
<input type="checkbox"/> 20.408(a)(1)(i)	<input type="checkbox"/> 80.38(a)(1)	<input type="checkbox"/> 80.73(a)(2)(v)	<input type="checkbox"/> 73.71(a)
<input type="checkbox"/> 20.408(a)(1)(ii)	<input type="checkbox"/> 80.38(a)(2)	<input checked="" type="checkbox"/> 80.73(a)(2)(vi)	OTHER (Specify in Abstract below and in Text, NRC Form 365A)
<input type="checkbox"/> 20.408(a)(1)(iii)	<input type="checkbox"/> 80.73(a)(2)(i)	<input type="checkbox"/> 80.73(a)(2)(vii)(A)	
<input type="checkbox"/> 20.408(a)(1)(iv)	<input type="checkbox"/> 80.73(a)(2)(ii)	<input type="checkbox"/> 80.73(a)(2)(vii)(B)	
<input type="checkbox"/> 20.408(a)(1)(v)	<input type="checkbox"/> 80.73(a)(2)(iii)	<input type="checkbox"/> 80.73(a)(2)(ix)	

LICENSEE CONTACT FOR THIS LER (12)

NAME Carson L. Wright	TELEPHONE NUMBER
	AREA CODE: 8 1 0 3   3 1 8 3 - 4 5 2 4

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS
C	KIA	LIHT	F11810	N					

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE)  NO

EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

With the unit in a Steam Generator Replacement Outage and with the fuel in the Spent Fuel Pit, Condensate Storage Tank (CST) level transmitters, LT-1454A and B, were identified as out of calibration. The problem was identified by control board observation.

IE22  
1/1

tk  
8408060315 840726  
PDR ADOCK 05000261  
S PDR

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1)  H. B. Robinson, Unit 2	DOCKET NUMBER (2)  0 5 0 0 0 2 6 1	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
		8 4	0 0 8	0 0	0 2	OF	0 2

TEXT (If more space is required, use additional NRC Form 366A's) (17)

The Unit is in a Steam Generator Replacement Outage with the fuel in the Spent Fuel Pit. The Condensate Storage Tank (CST) level transmitters, LT-1454A and B, were identified as out of calibration in the non-conservative direction. "A" was out by 0.2%, and "B" was out by 7.575%. The operators identified the problem by control board observation.

Transmitter history does not reflect this type of drift. It is suspected that the drift was caused by physical jarring. There has been a significant amount of construction activity in the vicinity of these transmitters.

Both transmitters were recalibrated. The heavy construction activity is completed, and the area is now partially protected by a new building wall that limits access. Any potential damage that could occur would be observed by operations personnel as was the original incident when taking their shift logs. Both channels are compared once per shift for discrepancy, and the data is logged per procedure. No further action is considered necessary.

tk

# CP&L

Carolina Power & Light Company

H. B. ROBINSON STEAM ELECTRIC PLANT  
POST OFFICE BOX 790  
HARTSVILLE, SOUTH CAROLINA 29550

JUL 26 1984

Robinson File No: 13510C

Serial: RSEP/84-496


United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261  
LICENSE NO. DPR-23  
LICENSEE EVENT REPORT 84-008

Dear Sir:

In accordance with 10CFR50.73, the enclosed Licensee Event Report is submitted. This report fulfills the requirements for a written report within thirty (30) days of a reportable event and is in accordance with the format set forth in NUREG-1022, September, 1983.

Very truly yours,



R. E. Morgan  
General Manager  
H. B. Robinson SEG Plant

CLW/tk

Enclosure

cc: J. P. O'Reilly  
NRC Resident Inspector's Office  
INPO

IE22  
1/1