

JUL 26 1984

Docket Nos.: STN 50-482
and STN 50-483

Mr. D. F. Schnell
Vice President - Nuclear
Union Electric Company
P. O. Box 49
St. Louis, Missouri 63166

Mr. Glenn L. Koester
Vice President - Nuclear
Kansas Gas and Electric Company
P. O. Box 208
Wichita, Kansas 67201

Gentlemen:

Subject: Request for Additional Information Seismic and Dynamic
Qualification

As a result of its review of the information submitted in support of the
Callaway 100% Power Amendment, the staff has determined that additional
information is needed in the area of Seismic and Dynamic Qualification.
The specific information is contained in the enclosure.

In order to support the schedule for full power operation at the Callaway
Plant, your response should be received in this office by July 31, 1984.
This information has been previously discussed with members of your staff
and the SNUPPS staff.

If you require any additional assistance, please contact your project
manager.

Sincerely,

[Signature]
B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

Enclosure:
As stated

cc: See next page

CONFERENCES:

DL:LB#1	DL:LB#1 <i>Swor</i>	DL:LB#1 <i>[Signature]</i>
JHolonich:es	PO'Connor	BJYoungblood
7/26/84	7/26/84	7/26/84

DIST:

Docket File	VNoonan
NRC PDR	NRomey
Local PDR	
PRC System	
NSIC	
LB#1 Rdg	
MRUshbrook	
JHolonich	
PO'Connor	
OELD, Attorney	
ACRS 16	
EJordan	
NGrace	



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUL 26 1984

Docket Nos.: STN 50-482
and STN 50-483

Mr. D. F. Schnell
Vice President - Nuclear
Union Electric Company
P. O. Box 49
St. Louis, Missouri 63166

Mr. Glenn L. Koester
Vice President - Nuclear
Kansas Gas and Electric Company
P. O. Box 208
Wichita, Kansas 67201

Gentlemen:


Subject: Request for Additional Information Seismic and Dynamic
Qualification

As a result of its review of the information submitted in support of the Callaway 100% Power Amendment, the staff has determined that additional information is needed in the area of Seismic and Dynamic Qualification. The specific information is contained in the enclosure.

In order to support the schedule for full power operation at the Callaway Plant, your response should be received in this office by July 31, 1984. This information has been previously discussed with members of your staff and the SNUPPS staff.

If you require any additional assistance, please contact your project manager.

Sincerely,


B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

Enclosure:
As stated

cc: See next page

SNUPPS

Mr. D. F. Schnell
Vice President - Nuclear
Union Electric Company
P. O. Box 149
St. Louis, Missouri 63166

Mr. Glen L. Koester
Vice President - Nuclear
Kansas Gas and Electric Company
201 North Market Street
P. O. Box 208
Wichita, Kansas 67201

cc: Gerald Charnoff, Esq.
Thomas A. Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mayor Howard Steffen
Chamois, Missouri 65024

Jay Silberg, Esquire
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Kansas City Power & Light Company
ATTN: Mr. D. T. McPhee
Vice President - Production
1330 Baltimore Avenue
Kansas City, Missouri 64141

Mr. Donald W. Capone
Manager - Nuclear Engineering
Union Electric Company
P. O. Box 149
St. Louis, Missouri 63166

Mr. Nicholas A. Petrick
Executive Director, SNUPPS
5 Choke Cherry Road
Rockville, Maryland 20850

Ms. Mary Ellen Salava
Route 1, Box 56
Burlington, Kansas 66839

Mr. J. E. Birk
Assistant to the General Counsel
Union Electric Company
St. Louis, Missouri 63166

Eric A. Eisen, Esq.
Birch, Horton, Bittner & Moore
1140 Connecticut Avenue, N. W.
Washington, D. C. 20036

Mr. Howard Bundy
Resident Inspector/Wolf Creek NPS
c/o U. S. NRC
P. O. Box 311
Burlington, Kansas 66839

Ms. Wanda Christy
515 N. 1st Street
Burlington, Kansas 66839

Mr. Michael C. Keener
State Corporation Commission
State of Kansas
Fourth Floor, State Office Building
Topeka, Kansas 6612

Ms. Majorie Reilly
Energy Chairman of the League of
Women Voters of University City, MO
7065 Pershing Avenue
University City, Missouri 63130

Mr. John Neisler
U. S. Nuclear Regulatory Commission
Resident Inspectors Office
RR #1
Steedman, Missouri 65077

Mr. Fred Lukéy
Presiding Judge, Montgomery County
Rural Route
Rhineland, Missouri 65069

Terri Sculley, Director
Special Projects Division
Kansas Corporation Commission
State Office Building, 4th Floor
Topeka, Kansas 66612

Professor William H. Miller
Missouri Kansas Section, American
Nuclear Society
Department of Nuclear Engineering
1026 Engineering Building
University of Missouri
Columbia, Missouri 65211

cc: Robert G. Wright
Associate Judge, Eastern
District County Court
Callaway County, Missouri
Route #1
Fulton, Missouri

Lewis C. Green, Esq.
Green, Hennings & Henry
Attorney for Joint Intervenors
314 N. Broadway, Suite 1830
St. Louis, Missouri 63102

Mr. Earl Brown
School District Superintendent
P. O. Box 9
Kingdom City, Missouri 65262

Mr. Samuel J. Birk
R. R. #1, Box 243
Morrison, Missouri 65061

Mr. Harold Lottman
Presiding Judge, Dasconade County
Route 1
Owensville, Missouri 65066

A. Scott Cauger, Esq.
Assistant General Counsel for the
Missouri Public Service Comm.
P. O. Box 360
Jefferson City, Missouri 65101

Mr. John G. Reed
Route #1
Kingdom City, Missouri 65262

Mr. Dan I. Bolef, President
Kay Drey, Representative
Board of Directors Coalition
for the Environment
St. Louis Region
6267 Delmar Boulevard
University City, Missouri 63130

Mr. Donald Bollinger, Member
Missourians for Safe Energy
6267 Delmar Boulevard
University City, Missouri 63130

John H. Simpson, Esq.
Attorney for Intervenors
4350 Johnson Drive, Suite 120
Shawnee Mission, Kansas 66205

Mr. James G. Keppler
U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. John T. Collins
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza, Suite 1000
Arlington, Texas 76011

Mr. Joe Mulholland
Manager of Power Supply & Engineering
Kansas Electric Power Cooperative, Inc.
P. O. Box 4877
Gage Center Station
Topeka, Kansas 66604

C. Edward Peterson, Esq.
Legal Division
Kansas Corporation Commission
Fourth Floor
State Office Building
Topeka, Kansas 66612

Brian P. Cassidy, Regional Counsel
Federal Emergency Management Agency
Region I
J. W. McCormack POCH
Boston, Massachusetts 02109

ENCLOSURE
REQUEST FOR ADDITIONAL INFORMATION
CALLAWAY/WOLF CREEK

271.0 EQUIPMENT QUALIFICATION BRANCH (SEISMIC AND DYNAMIC QUALIFICATION)

271.19 By letter dated June 29, 1984 from N. Petrick (SNUPPS) to H. R. Denton (NRC), you stated that the acceptance criteria used by Westinghouse to seismically qualify post accident monitoring instrumentation is based on Regulatory Guide 1.97. The Regulatory Guide states, in part, "Instrumentation should continue to read within the required accuracy following, but not necessarily during, a safe shutdown earthquake." Seismic qualification tests of the Thermocouple/Core Cooling Monitoring System indicated that the instrumentation produced spurious signals during seismic excitation. Following seismic excitation the instrumentation returned to normal. Please provide appropriate indications that the plant operators will be instructed that the accident monitoring instruments are not to be relied upon during a seismic event.

Your response to this question is necessary to terminate JIO ESE 56A, "Core Cooling Monitoring System."