



# Nebraska Public Power District

COOPER NUCLEAR STATION  
P.O. BOX 96, BROWNVILLE, NEBRASKA 68321  
TELEPHONE (402)825-3811  
FAX (402)825-5211

NLS950208  
October 26, 1995

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Subject: Withdrawal of Relief Request RI-17, integrally Welded Shear Lugs on Piping  
Cooper Nuclear Station, Docket No. 50-298, License No. DPR-46

- References:
- 1) Letter (No. NLS950119) to USNRC Document Control Desk from John H. Mueller (NPPD) dated June 21, 1995, "Second Ten-Year Interval Inservice Inspection Relief Requests"
  - 2) Letter (No. NLS950139) to USNRC Document Control Desk from John H. Mueller (NPPD) dated July 14, 1995, "Second Ten-Year Interval Inservice Inspection Program"

Gentlemen:

Nebraska Public Power District (District) hereby withdraws Relief Request RI-17 for the Second Ten-Year Interval Inservice Inspection (ISI) program. At the time this relief request was submitted (Reference 1), the District anticipated examining a certain number of integrally welded shear lugs on piping that would require disassembly of the associated pipe clamp. Based on subsequent review of the examination data and Revision 4 of the Second Ten-Year Interval ISI program (Reference 2), the shear lugs that require disassembly of the associated support have been examined. Therefore, the proposed relief from ASME Section XI requirements is no longer needed for this interval.

If you have any questions or require additional information regarding this relief request, please call.

Sincerely,

John H. Mueller  
Site Manager

/dnm

9511010118 951026  
PDR ADOCK 03000298  
Q PDR

AOH

U. S. Nuclear Regulatory Commission  
October 26, 1995  
Page 2 of 7

cc: Regional Administrator  
USNRC Region IV  
Arlington, TX

NRC Resident Inspector  
Cooper Nuclear Station

NRC NRR Project Manager  
Rockville, MD

NPG Distribution

