



SCENARIO MANUAL
for

LIMERICK GENERATING STATION

Emergency Preparedness
Annual Exercise

(Radiological Scenario)

Scenario L53
October 24, 1995



**PECO
ENERGY**

SCENARIO MANUAL
for

LIMERICK GENERATING STATION

Emergency Preparedness
Annual Exercise

(Radiological Scenario)


Scenario L53
October 24, 1995

PECO ENERGY COMPANY
LIMERICK GENERATING STATION
1995 ANNUAL EXERCISE
SCENARIO CONFIDENTIALITY

This scenario manual which you have received is confidential and must remain in your possession or be kept under lock and key at all times. The scenario cannot be discussed with anyone who is not authorized to be scenario knowledgeable.

Any violation of this would invalidate the scenario for use in this Emergency Preparedness Exercise.

Your cooperation is greatly appreciated. Thank You.

A handwritten signature in cursive script, appearing to read "Rick Knaul".

Manager - Emergency Preparedness

**LIMERICK GENERATING STATION
EMERGENCY PREPAREDNESS ANNUAL EXERCISE
SCENARIO L53**

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1.0 INTRODUCTION	
1.1 Introduction / Mission	1.1-1
1.2 Schedule	1.2-1
1.3 Participants	1.3-1
2.0 OBJECTIVES	
2.1 PECO Energy Objectives	2.1-1
3.0 GUIDELINES AND INSTRUCTIONS	
3.1 Drill Guidelines and Conduct	3.1-1
3.2 Controller Instructions	3.2-1
3.3 Drill Communications	3.3-1
4.0 DRILL SCENARIO	
4.1 Initial Conditions	4.1-1
4.2 Scenario Abstract	4.2-1
4.3 Time Line	4.3-1
4.4 Event Summaries	4.4-1
4.5 Operational Data	4.5-1
4.6 Meteorological Data	4.6-1
5.0 REFERENCES	
5.1 Emergency Response Procedure Index	5.1-1
5.2 Reference Documents	5.2-1
6.0 IN-PLANT RADIOLOGICAL DATA	6.1.1
7.0 CHEMISTRY, RELEASE, DOSE DATA	7.1.1
8.0 MESSAGES	8.0-1

TABLE 6.1.1

RADIATION MONITORING SYSTEM DATA (T = 00:00) (15:00)

MONITOR KEY - FOR USE WITH TABLES 6.1.

Monitor	TITLE	Monitor	TITLE
1-RE-01	RCIC Pump Room--RX 177	2-RE-05	Aux. Bay Hallway--TB 200
1-RE-02	HPCI Pump Room--RX 177	2-RE-06	Iso Valve Compt.--RX 201
1-RE-03	Sump Compartment--RX 177	2-RE-07	Condensate Pmp Rm-TB 189
1-RE-04	CRD Pump Area--TB 200	2-RE-08	RHR Div I Compt--RX 201
1-RE-05	Aux. Bay Hallway--TB 200	2-RE-09	RHR Div II Compt--Rx 201
1-RE-06	Iso Valve Compt.--RX 201	2-RE-10	Steam Vent Area--RX 217
1-RE-07	Condensate Pmp Rm-TB 189	2-RE-11	RR Access Airlock-RX 217
1-RE-08	RHR Div I Compt--RX 201	2-RE-12	Hallway Cond. Fltr Demin
1-RE-09	RHR Div II Compt--Rx 201	2-RE-13	Condenser Area
1-RE-10	Steam Vent Area--RX 217	2-RE-14	Drywell--RX 253
1-RE-11	RR Access Airlock-RX 217	2-RE-15	CRDHCU Area East--RX 253
1-RE-12	Hallway Cond. Fltr Demin	2-RE-16	CRDHCU Area West--RX 253
1-RE-13	Condenser Area	2-RE-17	Neut Mon Sys Area-RX 253
1-RE-14	Drywell--RX 253	2-RE-18	Neut Mon Dr.Area--RX 253
1-RE-15	CRDHCU Area East--RX 253	2-RE-19	Turb Aux Bay Hallwy East
1-RE-16	CRDHCU Area West--RX 253	2-RE-20	Turb Aux Bay Hallwy West
1-RE-17	Neut Mon Sys Area-RX 253	2-RE-21	Rx Wtr Cleanup Pump Area
1-RE-18	Neut Mon Dr.Area--RX 253	2-RE-22	RWCU Heat Exchanger Area
1-RE-19	Turb Aux Bay Hallwy East	2-RE-23	SBLC System Area--RX 283
1-RE-20	Turb Aux Bay Hallwy West	2-RE-24	RWCU Instr. Rack Area
1-RE-21	Rx Wtr Cleanup Pump Area	2-RE-25	Turb Aux Bay--TB 269
1-RE-22	RWCU Heat Exchanger Area	2-RE-26	Turb Bldg Washdown Area
1-RE-23	SBLC System Area--RX 283	2-RE-27	RWCU Filter Area--RX 313
1-RE-24	RWCU Instr. Rack Area	2-RE-28	Exh. Flt. Area--TB 302
1-RE-25	Turb Aux Bay--TB 269	2-RE-29	D/W Head Laydown--RX 352
1-RE-26	Turb Bldg Washdown Area	2-RE-30	Dryer/Sep. Area--RX 352
1-RE-27	RWCU Filter Area--RX 313	2-RE-31	Spent Fuel Pool--RX 352
1-RE-28	Exh. Flt. Area--TB 302	2-RE-32	New Fuel Stor Vlt-RX 352
1-RE-29	D/W Head Laydown--RX 352	2-RE-33	Pool Plug Laydown-RX 352
1-RE-30	Dryer/Sep. Area--RX 352	2-RE-34	H2/O2 Anlyzr Area-CS 200
1-RE-31	Spent Fuel Pool--RX 352	2-RE-35	Gaseous RW Recmbner Hall
1-RE-32	New Fuel Stor Vlt-RX 352	0-RE-41	Sludge Disch. Mix PP RM
1-RE-33	Pool Plug Laydown-RX 352	0-RE-42	RW Hallway--RW 162
1-RE-34	H2/O2 Anlyzr Area-CS 200	0-RE-43	Cond. Stor. Disch. PP RM
1-RE-35	Gaseous RW Recmbner Hall	0-RE-44	Laundry Drain--RW 191
1-RE-36	Turb. Aux. Bay	0-RE-45	Floor Drn Fltr Hld PP RM
2-RE-01	RCIC Pump Room--RX 177	0-RE-46	Fuel Pool Fltr Hld PP RM
2-RE-02	HPCI Pump Room--RX 177	0-RE-47	Precoat Tnk&PP IJM-RW 191
2-RE-03	Sump Compartment--RX 177	0-RE-48	Remote Shutd Cntl Area
2-RE-04	CRD Pump Area--TB 200	0-RE-49	RW Cask Load Area

continued next column

continued next page

TABLE 6.1.1

RADIATION MONITORING SYSTEM DATA (T = 00:00) (15:00)

continued

MONITOR KEY - FOR USE WITH TABLES 6.1.

Monitor	TITLE	Monitor	TITLE
0-RE-50	RR Airlock--RX 217	SE160A	Mech Vac Pmp/Stm Seal (A)
0-RE-51	RW Hallway--RW 217	SE160B	Mech Vac Pmp/Stm Seal (B)
0-RE-52	Hot Maint Shop-Admin 217	SE-190	Prim Cont Leak Det @ 292
0-RE-53	TB RR Entrance	SE63-09	RW Discharge
0-RE-54	Hopper Comp.--RW 237	SE10-11	Serv Water - Cooling Twr
0-RE-55	RW Exh. Fan Area	SE13-11	Rx Encl Cooling Water
0-RE-56	CR--CS 269	RE42N6A	Main Steam Line (A)
0-RE-57	Turb. OP. Floor--TB 269	RE42N6B	Main Steam Line (B)
0-RE-58	Stnby Gas Trtmnt--CS 332	RE42N6C	Main Steam Line (C)
0-RE-60	N Stack Instr RM-RX 410	RE42N6D	Main Steam Line (D)
REX-025	(Local)Srce Str&Calib RM	RE285A1	S.Stack -Particulate (A)
RI-01	(Local)A Turb Encl Crane	RE285A2	S.Stack -Iodine (A)
RI-02	(Local)B Turb Encl Crane	RE285A3	S.Stack -Noble (A)
RI-101	(Local) Refuel Platform	RE285B1	S.Stack -Particulate (B)
RE41N6A	Main Steam Line (A)	RE285B2	S.Stack -Iodine (B)
RE41N6B	Main Steam Line (B)	RE285B3	S.Stack -Noble (B)
RE41N6C	Main Steam Line (C)	RE291A	Prim Cont Post-Loca (A)
RE41N6D	Main Steam Line (D)	RE291B	Prim Cont Post-Loca (B)
RE185A1	S.Stack -Particulate (A)	RE291C	Prim Cont Post-Loca (C)
RE185A2	S.Stack -Iodine (A)	RE291D	Prim Cont Post-Loca (D)
RE185A3	S.Stack -Noble (A)	REN20A	Rx Encl Exh Duct (A)
RE185B1	S.Stack -Particulate (B)	REN20B	Rx Encl Exh Duct (B)
RE185B2	S.Stack -Iodine (B)	REN20C	Rx Encl Exh Duct (C)
RE185B3	S.Stack -Noble (B)	REN20D	Rx Encl Exh Duct (D)
RE191A	Prim Cont Post-Loca (A)	REN21A	Refuel Area Exh Duct (A)
RE191B	Prim Cont Post-Loca (B)	REN21B	Refuel Area Exh Duct (B)
RE191C	Prim Cont Post-Loca (C)	REN21C	Refuel Area Exh Duct (C)
RE191D	Prim Cont Post-Loca (D)	REN21D	Refuel Area Exh Duct (D)
REN10A	Rx Encl Exh Duct (A)	SE17-23	Recombiner Comp. Exh.
REN10B	Rx Encl Exh Duct (B)	SE221C	RHR Service Water (C)
REN10C	Rx Encl Exh Duct (C)	SE221D	RHR Service Water (D)
REN10D	Rx Encl Exh Duct (D)	SE160A	Mech Vac Pmp/Stm Seal (A)
REN11A	Refuel Area Exh Duct (A)	SE160B	Mech Vac Pmp/Stm Seal (B)
REN11B	Refuel Area Exh Duct (B)	SE-190	Prim Cont Leak Det @ 292
REN11C	Refuel Area Exh Duct (C)	SE-290	Prim Cont Leak Det @ 292
REN11D	Refuel Area Exh Duct (D)	SE10-11	Serv Water - Cooling Twr
RR-609	RW Encl. Exhaust	SE13-11	Rx Encl Cooling Water
SE17-23	Recombiner Comp. Exh.	RE025A	Hot Shop Exhaust
SE121C	RHR Service Water (C)	RE025B	Hot Shop Iodine
SE121D	RHR Service Water (D)	RE68C-1	CR EM Fresh Air Duct (C)

continued next column

continued next page

TABLE 6.1.1

RADIATION MONITORING SYSTEM DATA (T = 00:00) (15:00)

continued

MONITOR KEY - FOR USE WITH TABLES 6.1.

Monitor	TITLE	Monitor	TITLE
RE68C-2	CR EM Fresh Air Duct (C)	RE007B2	CR Norm Air (B) Bkgd
RE68D-1	CR Em Fresh Air Duct (D)	RE007C1	CR Norm Air Supply (C)
RE68D-2	CR Em Fresh Air Duct (D)	RE007C2	CR Norm Air (C) Bkgd
RE76-4	N.Stack El.402	RE007D1	CR Norm Air Supply (D)
RE75-A1	N.Stack -Particulate (A)	RE007D2	CR Norm Air (D) Bkgd
RE75-A2	N.Stack -Iodine (A)	SE022A	RHR Service Water (A)
RE75-A3	N.Stack -Gas (A)	SE022B	RHR Service Water (B)
RE75-B1	N.Stack -Particulate (B)	RE26-16	Charcoal Offgas Effluent
RE75-B2	N.Stack -Iodine (B)	REN-04A	SJAE Disch Pipe to Recom
RE75-B3	N.Stack -Gas (B)	REN-04B	SJAE Disch Pipe to Recom
RE76-1	N.Stk -Widerange Gas (1)	REN-005	SJAE Disch Pipe to Recom
RE76-2	N.Stk -Widerange Gas (2)	PAS LC1	Pass Cntl Panel
RE76-3	N.Stk -Widerange Gas (3)	PAS LC2	Pass Cntl Panel
RE007A1	CR Norm Air Supply (A)	(2)-04A	SJAE Dsch Pp to Recom(2)
RE007A2	CR Norm Air (A) Bkgd	(2)-04B	SJAE Dsch Pp to Recom(2)
RE007B1	CR Norm Air Supply (B)	(2)-005	SJAE Dsch Pp to Recom(2)

TABLE 6.1.a

RADIATION MONITORING SYSTEM DATA (T = 00:00) (15:00)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.10	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.10	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.0	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	0.11	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	0.16	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.0	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.2	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	10.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	30.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	0.10	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	0.10	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.12	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	300.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	1000.	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	1.5	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	1.5	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	10.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	1.0	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	300.	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	300.	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	0.50	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	0.10	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	0.10	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	0.10	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	0.11	mR/hr	2-RE-29	1.0	mR/hr
1-RE-26	1.0	mR/hr	2-RE-30	1.0	mR/hr
1-RE-27	0.50	mR/hr	2-RE-31	1.0	mR/hr
1-RE-28	0.10	mR/hr	2-RE-32	0.10	mR/hr
1-RE-29	1.0	mR/hr	2-RE-33	1.0	mR/hr
1-RE-30	1.0	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.0	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.10	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.0	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	0.11	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.a

RADIATION MONITORING SYSTEM DATA (T = 00:00) (15:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.10	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	10.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.0	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	0.50	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	1.0	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.0	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	550.	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	600.	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	750.	mR/hr	RE291A	1.0	R/hr
RE41N6D	800.	mR/hr	RE291B	1.0	R/hr
RE185A1	3.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	5.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	3.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	5.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	2.8	R/hr	REN21A	0.50	mR/hr
RE191B	2.7	R/hr	REN21B	0.50	mR/hr
RE191C	2.7	R/hr	REN21C	0.50	mR/hr
RE191D	3.3	R/hr	REN21D	0.50	mR/hr
REN10A	0.10	mR/hr	SE17-23	10.	cpm
REN10B	0.10	mR/hr	SE221C	10.	cpm
REN10C	0.10	mR/hr	SE221D	10.	cpm
REN10D	0.10	mR/hr	SE160A	10.	cpm
REN11A	0.50	mR/hr	SE160B	10.	cpm
REN11B	0.50	mR/hr	SE-190	10.	cpm
REN11C	0.50	mR/hr	SE-290	10.	cpm
REN11D	0.50	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.a

RADIATION MONITORING SYSTEM DATA (T = 00:00) (15:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	57.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	1.E-12	uCi/cc	RE007D2	52.	cpm
RE75-A2	1.E-11	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	1.E-12	uCi/cc	RE26-16	10.	cpm
RE75-B2	1.E-11	uCi/cc	REN-04A	87.	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	87.	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	87.	mR/hr
RE76-2	2.2E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow			400284.	cfm	
South Stack Flow			268191.	cfm	
SGTS Flow			1.	cfm	

TABLE 6.1.b

RADIATION MONITORING SYSTEM DATA (T = 01:00) (16:00)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.10	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.10	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.0	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	0.11	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	0.15	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.0	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.1	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	10.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	30.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	0.10	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	0.10	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.11	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	300.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	1000.	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	1.5	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	1.5	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	10.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	1.0	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	300.	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	300.	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	0.50	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	0.10	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	0.10	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	0.10	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	0.11	mR/hr	2-RE-29	1.0	mR/hr
1-RE-26	1.0	mR/hr	2-RE-30	1.0	mR/hr
1-RE-27	0.50	mR/hr	2-RE-31	1.0	mR/hr
1-RE-28	0.10	mR/hr	2-RE-32	0.10	mR/hr
1-RE-29	1.0	mR/hr	2-RE-33	1.0	mR/hr
1-RE-30	1.0	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.0	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.10	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.0	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	0.11	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.b

RADIATION MONITORING SYSTEM DATA (T = 01:00) (16:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.10	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	10.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.0	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	0.50	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	1.0	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.0	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	550.	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	600.	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	750.	mR/hr	RE291A	1.0	R/hr
RE41N6D	800.	mR/hr	RE291B	1.0	R/hr
RE185A1	2.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	4.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	2.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	4.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	2.8	R/hr	REN21A	0.50	mR/hr
RE191B	2.7	R/hr	REN21B	0.50	mR/hr
RE191C	2.7	R/hr	REN21C	0.50	mR/hr
RE191D	3.3	R/hr	REN21D	0.50	mR/hr
REN10A	0.10	mR/hr	SE17-23	10.	cpm
REN10B	0.10	mR/hr	SE221C	10.	cpm
REN10C	0.10	mR/hr	SE221D	10.	cpm
REN10D	0.10	mR/hr	SE160A	10.	cpm
REN11A	0.50	mR/hr	SE160B	10.	cpm
REN11B	0.50	mR/hr	SE-190	10.	cpm
REN11C	0.50	mR/hr	SE-290	10.	cpm
REN11D	0.50	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SF121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.b

RADIATION MONITORING SYSTEM DATA (T = 01:00) (16:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	57.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	1.E-12	uCi/cc	RE007D2	52.	cpm
RE75-A2	1.E-11	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	1.E-12	uCi/cc	RE26-16	10.	cpm
RE75-B2	1.E-11	uCi/cc	REN-04A	85.	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	85.	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	85.	mR/hr
RE76-2	2.2E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow				400284.	cfm
South Stack Flow				268191.	cfm
SGTS Flow				1.	cfm

TABLE 6.1.c

RADIATION MONITORING SYSTEM DATA (T = 02:00) (17:00)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.10	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.10	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.0	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	0.11	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	0.14	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.0	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.1	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	10.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	30.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	0.10	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	0.10	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.11	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	300.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	1100.	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	1.5	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	1.5	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	10.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	1.0	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	300.	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	300.	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	0.50	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	0.10	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	0.10	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	0.10	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	0.11	mR/hr	2-RE-29	1.0	mR/hr
1-RE-26	1.0	mR/hr	2-RE-30	1.0	mR/hr
1-RE-27	0.50	mR/hr	2-RE-31	1.0	mR/hr
1-RE-28	0.10	mR/hr	2-RE-32	0.10	mR/hr
1-RE-29	1.0	mR/hr	2-RE-33	1.0	mR/hr
1-RE-30	1.0	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.0	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.10	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.0	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	0.11	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.c

RADIATION MONITORING SYSTEM DATA (T = 02:00) (17:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.10	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	10.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.0	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	0.50	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	1.0	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.0	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	550.	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	600.	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	750.	mR/hr	RE291A	1.0	R/hr
RE41N6D	800.	mR/hr	RE291B	1.0	R/hr
RE185A1	2.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	4.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	2.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	4.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	2.8	R/hr	REN21A	0.50	mR/hr
RE191B	2.7	R/hr	REN21B	0.50	mR/hr
RE191C	2.7	R/hr	REN21C	0.50	mR/hr
RE191D	3.3	R/hr	REN21D	0.50	mR/hr
REN10A	0.10	mR/hr	SE17-23	10.	cpm
REN10B	0.10	mR/hr	SE221C	10.	cpm
REN10C	0.10	mR/hr	SE221D	10.	cpm
REN10D	0.10	mR/hr	SE160A	10.	cpm
REN11A	0.50	mR/hr	SE160B	10.	cpm
REN11B	0.50	mR/hr	SE-190	10.	cpm
REN11C	0.50	mR/hr	SE-290	10.	cpm
REN11D	0.50	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.c

RADIATION MONITORING SYSTEM DATA (T = 02:00) (17:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	57.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	1.E-12	uCi/cc	RE007D2	52.	cpm
RE75-A2	1.E-11	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	1.E-12	uCi/cc	RE26-16	10.	cpm
RE75-B2	1.E-11	uCi/cc	REN-04A	85.	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	85.	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	85.	mR/hr
RE76-2	2.2E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow				400284.	cfm
South Stack Flow				268191.	cfm
SGTS Flow				1.	cfm

TABLE 6.1.d

RADIATION MONITORING SYSTEM DATA (T = 03:00) (18:00)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.10	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.10	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.0	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	0.11	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	0.14	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.0	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.1	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	10.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	30.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	0.10	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	0.10	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.11	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	300.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	1100.	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	1.5	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	1.5	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	10.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	1.0	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	300.	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	300.	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	0.50	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	0.10	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	0.10	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	0.10	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	0.11	mR/hr	2-RE-29	1.0	mR/hr
1-RE-26	1.0	mR/hr	2-RE-30	1.0	mR/hr
1-RE-27	0.50	mR/hr	2-RE-31	1.0	mR/hr
1-RE-28	0.10	mR/hr	2-RE-32	0.10	mR/hr
1-RE-29	1.0	mR/hr	2-RE-33	1.0	mR/hr
1-RE-30	1.0	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.0	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.10	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.0	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	0.11	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.d

RADIATION MONITORING SYSTEM DATA (T = 03:00) (18:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.10	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	10.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.0	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	0.50	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	1.0	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.0	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	550.	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	600.	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	750.	mR/hr	RE291A	1.0	R/hr
RE41N6D	800.	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	5.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	5.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	2.8	R/hr	REN21A	0.50	mR/hr
RE191B	2.7	R/hr	REN21B	0.50	mR/hr
RE191C	2.7	R/hr	REN21C	0.50	mR/hr
RE191D	3.3	R/hr	REN21D	0.50	mR/hr
REN10A	0.10	mR/hr	SE17-23	10.	cpm
REN10B	0.10	mR/hr	SE221C	10.	cpm
REN10C	0.10	mR/hr	SE221D	10.	cpm
REN10D	0.10	mR/hr	SE160A	10.	cpm
REN11A	0.50	mR/hr	SE160B	10.	cpm
REN11B	0.50	mR/hr	SE-190	10.	cpm
REN11C	0.50	mR/hr	SE-290	10.	cpm
REN11D	0.50	mR/hr	SE10-11	10.	cpm
RR-509	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.d

RADIATION MONITORING SYSTEM DATA (T = 03:00) (18:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
-----	-----	-----	-----	-----	-----
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	57.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	1.E-12	uCi/cc	RE007D2	52.	cpm
RE75-A2	1.E-11	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	1.E-12	uCi/cc	RE26-16	10.	cpm
RE75-B2	1.E-11	uCi/cc	REN-04A	85.	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	85.	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	85.	mR/hr
RE76-2	2.2E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr

North Stack Flow	400284.	cfm
South Stack Flow	268191.	cfm
SGTS Flow	1.	cfm

TABLE 6.1.e

RADIATION MONITORING SYSTEM DATA (T = 03:02) (18:02)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.10	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.10	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.0	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	0.11	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	0.14	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.0	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.1	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	10.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	30.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	0.10	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	0.10	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.11	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	280.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	1000.	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	1.5	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	1.5	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	10.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	1.0	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	290.	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	290.	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	0.50	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	0.10	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	0.10	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	0.10	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	0.11	mR/hr	2-RE-29	1.0	mR/hr
1-RE-26	1.0	mR/hr	2-RE-30	1.0	mR/hr
1-RE-27	0.50	mR/hr	2-RE-31	1.0	mR/hr
1-RE-28	0.10	mR/hr	2-RE-32	0.10	mR/hr
1-RE-29	1.0	mR/hr	2-RE-33	1.0	mR/hr
1-RE-30	1.0	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.0	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.10	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.0	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	0.11	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.e

RADIATION MONITORING SYSTEM DATA (T = 03:02) (18:02)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.10	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	10.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.0	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	0.50	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	1.0	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.0	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	520.	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	570.	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	710.	mR/hr	RE291A	1.0	R/hr
RE41N6D	750.	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	5.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	5.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	2.7	R/hr	REN21A	0.50	mR/hr
RE191B	2.6	R/hr	REN21B	0.50	mR/hr
RE191C	2.6	R/hr	REN21C	0.50	mR/hr
RE191D	3.2	R/hr	REN21D	0.50	mR/hr
REN10A	0.10	mR/hr	SE17-23	10.	cpm
REN10B	0.10	mR/hr	SE221C	10.	cpm
REN10C	0.10	mR/hr	SE221D	10.	cpm
REN10D	0.10	mR/hr	SE160A	10.	cpm
REN11A	0.50	mR/hr	SE160B	10.	cpm
REN11B	0.50	mR/hr	SE-190	10.	cpm
REN11C	0.50	mR/hr	SE-290	10.	cpm
REN11D	0.50	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.e

RADIATION MONITORING SYSTEM DATA (T = 03:02) (18:02)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	57.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	1.E-12	uCi/cc	RE007D2	52.	cpm
RE75-A2	1.E-11	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	1.E-12	uCi/cc	RE26-16	10.	cpm
RE75-B2	1.E-11	uCi/cc	REN-04A	85.	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	85.	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	85.	mR/hr
RE76-2	2.2E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr

North Stack Flow
South Stack Flow
SGTS Flow

400284. cfm
268191. cfm
1. cfm

TABLE 6.1.f

RADIATION MONITORING SYSTEM DATA (T = 03:04) (18:04)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.10	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.10	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.0	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	290.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	970.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.0	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.1	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	10.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	30.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	0.10	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	0.10	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.11	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	670.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	1.2E4	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	1.5	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	1.5	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	10.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	1.0	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	9.4E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	2.2E5	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	0.55	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	0.11	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	0.10	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	0.74	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	3000.	mR/hr	2-RE-29	1.0	mR/hr
1-RE-26	930.	mR/hr	2-RE-30	1.0	mR/hr
1-RE-27	0.50	mR/hr	2-RE-31	1.0	mR/hr
1-RE-28	1.4	mR/hr	2-RE-32	0.10	mR/hr
1-RE-29	1.0	mR/hr	2-RE-33	1.0	mR/hr
1-RE-30	1.0	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.0	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.10	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.0	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	1400.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.f

RADIATION MONITORING SYSTEM DATA (T = 03:04) (18:04)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.10	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	79.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.2	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	0.50	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	440.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.0	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	5.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	5.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	14.	R/hr	REN21A	0.50	mR/hr
RE191B	14.	R/hr	REN21B	0.50	mR/hr
RE191C	14.	R/hr	REN21C	0.50	mR/hr
RE191D	14.	R/hr	REN21D	0.50	mR/hr
REN10A	0.10	mR/hr	SE17-23	10.	cpm
REN10B	0.10	mR/hr	SE221C	10.	cpm
REN10C	0.10	mR/hr	SE221D	10.	cpm
REN10D	0.10	mR/hr	SE160A	980.	cpm
REN11A	0.50	mR/hr	SE160B	980.	cpm
REN11B	0.50	mR/hr	SE-190	10.	cpm
REN11C	0.50	mR/hr	SE-290	10.	cpm
REN11D	0.50	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.f

RADIATION MONITORING SYSTEM DATA (T = 03:04) (18:04)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
-----	-----	-----	-----	-----	-----
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	57.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	1.E-12	uCi/cc	RE007D2	52.	cpm
RE75-A2	1.E-11	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	1.E-12	uCi/cc	RE26-16	10.	cpm
RE75-B2	1.E-11	uCi/cc	REN-04A	OSH	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	OSH	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	OSH	mR/hr
RE76-2	2.2E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow			402786.	cfm	
South Stack Flow			0.	cfm	
SGTS Flow			2502.	cfm	

TABLE A.1.a

NEW RADIATION MONITOR SYSTEM ALARMS (T = 03:04) (18:04)

CRD Pump Area--TB 200	(1-RE-04)	HIGH
Aux. Bay Hallway--TB 200	(1-RE-05)	HIGH
Drywell--RX 253	(1-RE-14)	HIGH
Turb Aux Bay Hallwy East	(1-RE-19)	HIGH
Turb Aux Bay Hallwy West	(1-RE-20)	HIGH
Turb Aux Bay--TB 269	(1-RE-25)	HIGH
Turb Bldg Washdown Area	(1-RE-26)	HIGH
Turb. Aux. Bay	(1-RE-36)	HIGH
Main Steam Line (A)	(RE41N6A)	HIGH
Main Steam Line (A)	(RE41N6A)	HIHI
Main Steam Line (B)	(RE41N6B)	HIGH
Main Steam Line (B)	(RE41N6B)	HIHI
Main Steam Line (C)	(RE41N6C)	HIGH
Main Steam Line (C)	(RE41N6C)	HIHI
Main Steam Line (D)	(RE41N6D)	HIGH
Main Steam Line (D)	(RE41N6D)	HIHI
SJAE Disch Pipe to Recom	(REN-04A)	HIGH
SJAE Disch Pipe to Recom	(REN-04A)	HIHI
SJAE Disch Pipe to Recom	(REN-04B)	HIGH
SJAE Disch Pipe to Recom	(REN-04B)	HIHI
SJAE Disch Pipe to Recom	(REN-005)	HIGH
SJAE Disch Pipe to Recom	(REN-005)	HIHI

TABLE 6.1.g

RADIATION MONITORING SYSTEM DATA (T = 03:06) (18:06)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.11	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.11	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.0	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	180.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	620.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.0	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.1	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	15.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	30.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	0.23	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	0.12	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.11	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	480.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	3.0E4	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	1.5	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	1.7	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	10.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	1.0	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	6.0E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	1.4E5	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	0.63	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	0.13	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	0.12	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	1.6	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	1900.	mR/hr	2-RE-29	1.0	mR/hr
1-RE-26	600.	mR/hr	2-RE-30	1.0	mR/hr
1-RE-27	0.52	mR/hr	2-RE-31	1.0	mR/hr
1-RE-28	0.93	mR/hr	2-RE-32	0.10	mR/hr
1-RE-29	1.0	mR/hr	2-RE-33	1.0	mR/hr
1-RE-30	1.0	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.0	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.10	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.0	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	900.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.g

RADIATION MONITORING SYSTEM DATA (T = 03:06) (18:06)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-PE-50	0.10	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	50.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.2	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	0.50	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	280.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.0	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	5.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	5.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	31.	R/hr	REN21A	0.50	mR/hr
RE191B	31.	R/hr	REN21B	0.50	mR/hr
RE191C	31.	R/hr	REN21C	0.50	mR/hr
RE191D	32.	R/hr	REN21D	0.50	mR/hr
REN10A	0.10	mR/hr	SE17-23	10.	cpm
REN10B	0.10	mR/hr	SE221C	10.	cpm
REN10C	0.10	mR/hr	SE221D	10.	cpm
REN10D	0.10	mR/hr	SE160A	620.	cpm
REN11A	0.50	mR/hr	SE160B	620.	cpm
REN11B	0.50	mR/hr	SE-190	10.	cpm
REN11C	0.50	mR/hr	SE-290	10.	cpm
REN11D	0.50	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.g

RADIATION MONITORING SYSTEM DATA (T = 03:06) (18:06)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	57.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	1.E-12	uCi/cc	RE007D2	52.	cpm
RE75-A2	1.E-11	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	1.E-12	uCi/cc	RE26-16	10.	cpm
RE75-B2	1.E-11	uCi/cc	REN-04A	OSH	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	OSH	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	OSH	mR/hr
RE76-2	2.2E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow				402786.	cfm
South Stack Flow				0.	cfm
SGTS Flow				2502.	cfm

TABLE 6.1.h

RADIATION MONITORING SYSTEM DATA (T = 03:08) (18:08)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.15	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.12	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.0	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	180.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	610.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.0	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.1	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	32.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	31.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	0.74	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	0.14	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.11	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	440.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	4.2E4	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	1.5	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	2.5	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	10.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	1.0	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	6.0E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	1.4E5	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	0.72	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	0.16	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	0.15	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	2.6	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	1900.	mR/hr	2-RE-29	1.0	mR/hr
1-RE-26	590.	mR/hr	2-RE-30	1.0	mR/hr
1-RE-27	0.55	mR/hr	2-RE-31	1.0	mR/hr
1-RE-28	0.92	mR/hr	2-RE-32	0.10	mR/hr
1-RE-29	1.0	mR/hr	2-RE-33	1.0	mR/hr
1-RE-30	1.0	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.0	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.10	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.0	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	890.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.h

RADIATION MONITORING SYSTEM DATA (T = 03:08) (18:08)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.10	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	50.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.2	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	0.50	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	280.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.0	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	5.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	5.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	43.	R/hr	REN21A	0.50	mR/hr
RE191B	43.	R/hr	REN21B	0.50	mR/hr
RE191C	43.	R/hr	REN21C	0.50	mR/hr
RE191D	44.	R/hr	REN21D	0.50	mR/hr
REN10A	0.10	mR/hr	SE17-23	10.	cpm
REN10B	0.10	mR/hr	SE221C	10.	cpm
REN10C	0.10	mR/hr	SE221D	10.	cpm
REN10D	0.10	mR/hr	SE160A	620.	cpm
REN11A	0.50	mR/hr	SE160B	620.	cpm
REN11B	0.50	mR/hr	SE-190	10.	cpm
REN11C	0.50	mR/hr	SE-290	10.	cpm
REN11D	0.50	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.h

RADIATION MONITORING SYSTEM DATA (T = 03:08) (18:08)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	57.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	2.E-12	uCi/cc	RE007D2	52.	cpm
RE75-A2	7.E-11	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	2.E-12	uCi/cc	RE26-16	10.	cpm
RE75-B2	7.E-11	uCi/cc	REN-04A	OSH	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	OSH	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	OSH	mR/hr
RE76-2	2.2E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow				402786.	cfm
South Stack Flow				0.	cfm
JGTS Flow				2502.	cfm

TABLE 6.1.i

RADIATION MONITORING SYSTEM DATA (T = 03:10) (18:10)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.19	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.14	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.0	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	180.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	600.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.0	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.1	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	46.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	32.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	1.2	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	2.8	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.11	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	400.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	5.3E4	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	1.8	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	3.9	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	11.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	12.	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	5.9E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	1.4E5	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	0.83	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	0.20	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	0.19	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	27.	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	1900.	mR/hr	2-RE-29	1.0	mR/hr
1-RE-26	580.	mR/hr	2-RE-30	1.0	mR/hr
1-RE-27	53.	mR/hr	2-RE-31	1.0	mR/hr
1-RE-28	0.91	mR/hr	2-RE-32	0.10	mR/hr
1-RE-29	1.0	mR/hr	2-RE-33	1.0	mR/hr
1-RE-30	1.0	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.0	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.10	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.2	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	880.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.i

RADIATION MONITORING SYSTEM DATA (T = 03:10) (18:10)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.10	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	49.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.2	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	0.50	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	280.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.0	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	5.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	5.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	54.	R/hr	REN21A	0.50	mR/hr
RE191B	54.	R/hr	REN21B	0.50	mR/hr
RE191C	54.	R/hr	REN21C	0.50	mR/hr
RE191D	55.	R/hr	REN21D	0.50	mR/hr
REN10A	0.11	mR/hr	SE17-23	10.	cpm
REN10B	0.11	mR/hr	SE221C	10.	cpm
REN10C	0.11	mR/hr	SE221D	10.	cpm
REN10D	0.11	mR/hr	SE160A	610.	cpm
REN11A	0.50	mR/hr	SE160B	610.	cpm
REN11B	0.50	mR/hr	SE-190	10.	cpm
REN11C	0.50	mR/hr	SE-290	10.	cpm
REN11D	0.50	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.i

RADIATION MONITORING SYSTEM DATA (T = 03:10) (18:10)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
-----	-----	-----	-----	-----	-----
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	57.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	7.E-12	uCi/cc	RE007D2	52.	cpm
RE75-A2	2.E-10	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	7.E-12	uCi/cc	RE26-16	10.	cpm
RE75-B2	2.E-10	uCi/cc	REN-04A	OSH	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	OSH	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	OSH	mR/hr
RE76-2	2.2E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow				402812.	cfm
South Stack Flow				0.	cfm
SGTS Flow				2528.	cfm

TABLE A.1.b

NEW RADIATION MONITOR SYSTEM ALARMS (T = 03:10) (18:10)

RWCU Instr. Rack Area	(1-RE-24)	HIGH
RWCU Filter Area--RX 313	(1-RE-27)	HIGH
Prim Cont Post-Loca (A)	(RE191A)	HIGH
Prim Cont Post-Loca (B)	(RE191B)	HIGH
Prim Cont Post-Loca (C)	(RE191C)	HIGH
Prim Cont Post-Loca (D)	(RE191D)	HIGH

TABLE 6.1.j

RADIATION MONITORING SYSTEM DATA (T = 03:15) (18:15)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.31	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.22	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.1	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	170.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	580.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.1	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.1	mR/hr	2-RE-11	0.46	mR/hr
1-RE-08	93.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	35.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	2.7	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	4.5	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.11	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	300.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	7.5E4	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	2.1	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	6.5	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	11.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	18.	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	5.6E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	1.3E5	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	1.1	mR/hr	2-RE-25	0.13	mR/hr
1-RE-22	0.36	mR/hr	2-RE-26	0.83	mR/hr
1-RE-23	0.34	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	41.	mR/hr	2-RE-28	1.3	mR/hr
1-RE-25	1800.	mR/hr	2-RE-29	1.0	mR/hr
1-RE-26	560.	mR/hr	2-RE-30	1.0	mR/hr
1-RE-27	79.	mR/hr	2-RE-31	1.0	mR/hr
1-RE-28	8.1	mR/hr	2-RE-32	4.8	mR/hr
1-RE-29	1.0	mR/hr	2-RE-33	1.0	mR/hr
1-RE-30	1.0	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.1	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.20	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.4	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	840.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.j

RADIATION MONITORING SYSTEM DATA (T = 03:15) (18:15)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.12	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	47.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	4.3	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	1400.	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	3.9	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	270.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.6	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.0	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	4.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	4.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	76.	R/hr	REN21A	0.51	mR/hr
RE191B	76.	R/hr	REN21B	0.51	mR/hr
RE191C	76.	R/hr	REN21C	0.51	mR/hr
RE191D	76.	R/hr	REN21D	0.51	mR/hr
REN10A	0.12	mR/hr	SE17-23	10.	cpm
REN10B	0.12	mR/hr	SE221C	10.	cpm
REN10C	0.12	mR/hr	SE221D	10.	cpm
REN10D	0.12	mR/hr	SE160A	1300.	cpm
REN11A	0.51	mR/hr	SE160B	1300.	cpm
REN11B	0.51	mR/hr	SE-190	10.	cpm
REN11C	0.51	mR/hr	SE-290	10.	cpm
REN11D	0.51	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.j

RADIATION MONITORING SYSTEM DATA (T = 03:15) (18:15)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	1.6E6	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	2.8E-5	uCi/cc	RE007D2	52.	cpm
RE75-A2	OSH	uCi/cc	SE022A	10.	cpm
RE75-A3	8.6E-3	uCi/cc	SE022B	10.	cpm
RE75-B1	2.8E-5	uCi/cc	RE26-16	10.	cpm
RE75-B2	OSH	uCi/cc	REN-04A	OSH	mR/hr
RE75-B3	8.6E-3	uCi/cc	REN-04B	OSH	mR/hr
RE76-1	8.6E-3	uCi/cc	REN-005	OSH	mR/hr
RE76-2	8.6E-3	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
REC07A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow				402819.	cfm
South Stack Flow				0.	cfm
SGTS Flow				2535.	cfm

TABLE A.1.c

NEW RADIATION MONITOR SYSTEM ALARMS (T = 03:15) (18:15)

Stnby Gas Trtmnt--CS 332	(0-RE-58)	HIGH
N.Stack El.402	(RE76-4)	HIGH
N.Stack El.402	(RE76-4)	HIHI
N.Stack -Particulate (A)	(RE75-A1)	HIGH
N.Stack -Particulate (A)	(RE75-A1)	HIHI
N.Stack -Iodine (A)	(RE75-A2)	HIGH
N.Stack -Iodine (A)	(RE75-A2)	HIHI
N.Stack -Gas (A)	(RE75-A3)	HIGH
N.Stack -Gas (A)	(RE75-A3)	HIHI
N.Stack -Particulate (B)	(RE75-B1)	HIGH
N.Stack -Particulate (B)	(RE75-B1)	HIHI
N.Stack -Iodine (B)	(RE75-B2)	HIGH
N.Stack -Iodine (B)	(RE75-B2)	HIHI
N.Stack -Gas (B)	(RE75-B3)	HIGH
N.Stack -Gas (B)	(RE75-B3)	HIHI
N.Stk -Widerange Gas (2)	(RE76-2)	HIGH
N.Stk -Widerange Gas (2)	(RE76-2)	HIHI

TABLE 6.1.k

RADIATION MONITORING SYSTEM DATA (T = 03:20) (18:20)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.35	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.25	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.2	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	160.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	540.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.1	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.1	mR/hr	2-RE-11	0.46	mR/hr
1-RE-08	110.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	37.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	3.2	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	4.9	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.11	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	260.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	1.0E5	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	2.2	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	7.3	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	11.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	19.	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	5.3E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	1.2E5	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	1.3	mR/hr	2-RE-25	0.13	mR/hr
1-RE-22	0.42	mR/hr	2-RE-26	0.83	mR/hr
1-RE-23	0.40	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	45.	mR/hr	2-RE-28	1.3	mR/hr
1-RE-25	1700.	mR/hr	2-RE-29	1.0	mR/hr
1-RE-26	520.	mR/hr	2-RE-30	1.0	mR/hr
1-RE-27	85.	mR/hr	2-RE-31	1.0	mR/hr
1-RE-28	8.0	mR/hr	2-RE-32	4.8	mR/hr
1-RE-29	1.0	mR/hr	2-RE-33	1.0	mR/hr
1-RE-30	1.0	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.0	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.12	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.4	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	790.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.k

RADIATION MONITORING SYSTEM DATA (T = 03:20) (18:20)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.12	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	44.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	4.3	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	53.	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	3.9	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	250.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.6	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.0	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	4.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	4.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	100.	R/hr	REN21A	0.51	mR/hr
RE191B	100.	R/hr	REN21B	0.51	mR/hr
RE191C	100.	R/hr	REN21C	0.51	mR/hr
RE191D	100.	R/hr	REN21D	0.51	mR/hr
REN10A	0.12	mR/hr	SE17-23	10.	cpm
REN10B	0.12	mR/hr	SE221C	10.	cpm
REN10C	0.12	mR/hr	SE221D	10.	cpm
REN10D	0.12	mR/hr	SE160A	1300.	cpm
REN11A	0.52	mR/hr	SE160B	1300.	cpm
REN11B	0.52	mR/hr	SE-190	10.	cpm
REN11C	0.52	mR/hr	SE-290	10.	cpm
REN11D	0.52	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.k

RADIATION MONITORING SYSTEM DATA (T = 03:20) (18:20)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	68.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	5.E-11	uCi/cc	RE007D2	52.	cpm
RE75-A2	1.9E-9	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	5.E-11	uCi/cc	RE26-16	10.	cpm
RE75-B2	1.9E-9	uCi/cc	REN-04A	OSH	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	OSH	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	OSH	mR/hr
RE76-2	3.6E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow				402786.	cfm
South Stack Flow				0.	cfm
SGTS Flow				2502.	cfm

TABLE A.1.d

NEW RADIATION MONITOR SYSTEM ALARMS (T = 03:20) (18:20)

RHR Div I Compt--RX 201	(1-RE-08)	HIGH
Prim Cont Post-Loca (A)	(RE191A)	HIHI
Prim Cont Post-Loca (B)	(RE191B)	HIHI
Prim Cont Post-Loca (C)	(RE191C)	HIHI
Prim Cont Post-Loca (D)	(RE191D)	HIHI

TABLE 6.1.1

RADIATION MONITORING SYSTEM DATA (T = 03:30) (18:30)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.37	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.33	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.3	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	140.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	470.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.1	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.1	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	86.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	36.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	2.7	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	4.3	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.11	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	210.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	1.5E5	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	2.3	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	6.4	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	11.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	18.	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	4.6E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	1.1E5	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	1.6	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	0.59	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	0.56	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	45.	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	1500.	mR/hr	2-RE-29	1.0	mR/hr
1-RE-26	450.	mR/hr	2-RE-30	1.0	mR/hr
1-RE-27	77.	mR/hr	2-RE-31	1.0	mR/hr
1-RE-28	0.75	mR/hr	2-RE-32	0.10	mR/hr
1-RE-29	1.0	mR/hr	2-RE-33	1.0	mR/hr
1-RE-30	1.0	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.0	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.12	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.4	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	690.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.1

RADIATION MONITORING SYSTEM DATA (T = 03:30) (18:30)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.12	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	38.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.1	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	42.	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	220.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.0	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	4.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	4.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	150.	R/hr	REN21A	0.52	mR/hr
RE191B	150.	R/hr	REN21B	0.52	mR/hr
RE191C	150.	R/hr	REN21C	0.52	mR/hr
RE191D	150.	R/hr	REN21D	0.52	mR/hr
REN10A	0.12	mR/hr	SE17-23	10.	cpm
REN10B	0.12	mR/hr	SE221C	10.	cpm
REN10C	0.12	mR/hr	SE221D	10.	cpm
REN10D	0.12	mR/hr	SE160A	490.	cpm
REN11A	0.52	mR/hr	SE160B	490.	cpm
REN11B	0.52	mR/hr	SE-190	10.	cpm
REN11C	0.52	mR/hr	SE-290	10.	cpm
REN11D	0.52	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.1

RADIATION MONITORING SYSTEM DATA (T = 03:30) (18:30)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
-----	-----	-----	-----	-----	-----
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	57.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	6.E-11	uCi/cc	RE007D2	52.	cpm
RE75-A2	2.7E-9	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	6.E-11	uCi/cc	RE26-16	10.	cpm
RE75-B2	2.7E-9	uCi/cc	REN-04A	9.8E5	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	9.8E5	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	9.8E5	mR/hr
RE76-2	2.2E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow				402786.	cfm
South Stack Flow				0.	cfm
SGTS Flow				2502.	cfm

TABLE 6.1.m

RADIATION MONITORING SYSTEM DATA (T = 03:45) (18:45)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.35	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.35	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.3	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	120.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	410.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.1	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.1	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	65.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	34.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	2.1	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	3.8	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.11	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	180.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	1.9E5	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	2.3	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	5.4	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	11.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	16.	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	4.0E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	9.5E4	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	1.8	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	0.63	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	0.60	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	43.	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	1300.	mR/hr	2-RE-29	1.0	mR/hr
1-RE-26	400.	mR/hr	2-RE-30	1.0	mR/hr
1-RE-27	67.	mR/hr	2-RE-31	1.0	mR/hr
1-RE-28	0.68	mR/hr	2-RE-32	0.10	mR/hr
1-RE-29	1.0	mR/hr	2-RE-33	1.0	mR/hr
1-RE-30	1.0	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.0	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.14	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.3	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	600.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.m

RADIATION MONITORING SYSTEM DATA (T = 03:45) (18:45)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.13	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	34.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.1	mR/hr	RE42N6B	11.	mk/hr
0-RE-58	31.	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	190.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.0	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	4.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	4.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	190.	R/hr	REN21A	0.54	mR/hr
RE191B	190.	R/hr	REN21B	0.54	mR/hr
RE191C	190.	R/hr	REN21C	0.54	mR/hr
RE191D	190.	R/hr	REN21D	0.54	mR/hr
REN10A	0.12	mR/hr	SE17-23	10.	cpm
REN10B	0.12	mR/hr	SE221C	10.	cpm
REN10C	0.12	mR/hr	SE221D	10.	cpm
REN10D	0.12	mR/hr	SE160A	440.	cpm
REN11A	0.54	mR/hr	SE160B	440.	cpm
REN11B	0.54	mR/hr	SE-190	10.	cpm
REN11C	0.54	mR/hr	SE-290	10.	cpm
REN11D	0.54	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.m

RADIATION MONITORING SYSTEM DATA (T = 03:45) (18:45)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
-----	-----	-----	-----	-----	-----
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	57.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	6.E-11	uCi/cc	RE007D2	52.	cpm
RE75-A2	2.5E-9	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	6.E-11	uCi/cc	RE26-16	10.	cpm
RE75-B2	2.5E-9	uCi/cc	REN-04A	8.6E5	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	8.6E5	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	8.6E5	mR/hr
RE76-2	2.2E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow			402786.	cfm	
South Stack Flow			0.	cfm	
SGTS Flow			2502.	cfm	

TABLE 6.1.n

RADIATION MONITORING SYSTEM DATA (T = 04:00) (19:00)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.35	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.38	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.3	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	110.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	360.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.1	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.0	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	50.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	33.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	1.7	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	3.4	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.11	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	160.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	2.2E5	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	2.3	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	4.7	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	11.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	14.	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	3.5E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	8.4E4	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	1.9	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	0.71	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	0.67	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	41.	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	1100.	mR/hr	2-RE-29	1.1	mR/hr
1-RE-26	350.	mR/hr	2-RE-30	1.1	mR/hr
1-RE-27	58.	mR/hr	2-RE-31	1.1	mR/hr
1-RE-28	0.61	mR/hr	2-RE-32	0.10	mR/hr
1-RE-29	1.1	mR/hr	2-RE-33	1.1	mR/hr
1-RE-30	1.1	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.1	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.16	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.3	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	530.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.n

RADIATION MONITORING SYSTEM DATA (T = 04:00) (19:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.14	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	29.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.1	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	24.	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	170.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.1	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	4.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	4.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	220.	R/hr	REN21A	0.56	mR/hr
RE191B	220.	R/hr	REN21B	0.56	mR/hr
RE191C	220.	R/hr	REN21C	0.56	mR/hr
RE191D	220.	R/hr	REN21D	0.56	mR/hr
REN10A	0.12	mR/hr	SE17-23	10.	cpm
REN10B	0.12	mR/hr	SE221C	10.	cpm
REN10C	0.12	mR/hr	SE221D	10.	cpm
REN10D	0.12	mR/hr	SE160A	380.	cpm
REN11A	0.56	mR/hr	SE160B	380.	cpm
REN11B	0.56	mR/hr	SE-190	10.	cpm
REN11C	0.56	mR/hr	SE-290	10.	cpm
REN11D	0.56	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.n

RADIATION MONITORING SYSTEM DATA (T = 04:00) (19:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	57.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	5.E-11	uCi/cc	RE007D2	52.	cpm
RE75-A2	2.3E-9	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	5.E-11	uCi/cc	RE26-16	10.	cpm
RE75-B2	2.3E-9	uCi/cc	REN-04A	7.6E5	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	7.6E5	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	7.6E5	mR/hr
RE76-2	2.2E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr

North Stack Flow	402786.	cfm
South Stack Flow	0.	cfm
SGTS Flow	2502.	cfm

TABLE 6.1.0

RADIATION MONITORING SYSTEM DATA (T = 04:15) (19:15)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.35	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.39	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.3	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	95.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	320.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.1	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.0	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	43.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	33.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	1.5	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	3.1	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.11	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	140.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	2.4E5	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	2.3	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	4.8	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	11.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	12.	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	3.1E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	7.4E4	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	1.9	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	0.72	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	0.68	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	38.	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	990.	mR/hr	2-RE-29	1.1	mR/hr
1-RE-26	310.	mR/hr	2-RE-30	1.1	mR/hr
1-RE-27	51.	mR/hr	2-RE-31	1.1	mR/hr
1-RE-28	0.55	mR/hr	2-RE-32	0.10	mR/hr
1-RE-29	1.1	mR/hr	2-RE-33	1.1	mR/hr
1-RE-30	1.1	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.1	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.17	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.3	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	460.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.0

RADIATION MONITORING SYSTEM DATA (T = 04:15) (19:15)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.14	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	26.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.1	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	18.	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	150.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.1	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	4.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	4.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	240.	R/hr	REN21A	0.57	mR/hr
RE191B	240.	R/hr	REN21B	0.57	mR/hr
RE191C	240.	R/hr	REN21C	0.57	mR/hr
RE191D	240.	R/hr	REN21D	0.57	mR/hr
REN10A	0.12	mR/hr	SE17-23	10.	cpm
REN10B	0.12	mR/hr	SE221C	10.	cpm
REN10C	0.12	mR/hr	SE221D	10.	cpm
REN10D	0.12	mR/hr	SE160A	340.	cpm
REN11A	0.57	mR/hr	SE160B	340.	cpm
REN11B	0.57	mR/hr	SE-190	10.	cpm
REN11C	0.57	mR/hr	SE-290	10.	cpm
REN11D	0.57	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.0

RADIATION MONITORING SYSTEM DATA (T = 04:15) (19:15)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
-----	-----	-----	-----	-----	-----
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	57.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	3.E-11	uCi/cc	RE007D2	52.	cpm
RE75-A2	2.0E-9	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	3.E-11	uCi/cc	RE26-16	10.	cpm
RE75-B2	2.0E-9	uCi/cc	REN-04A	6.7E5	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	6.7E5	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	6.7E5	mR/hr
RE76-2	2.2E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow				402786.	cfm
South Stack Flow				0.	cfm
SGTS Flow				2502.	cfm

TABLE 6.1.p

RADIATION MONITORING SYSTEM DATA (T = 04:30) (19:30)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.32	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.36	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.3	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	83.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	280.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.1	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.0	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	38.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	32.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	1.3	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	2.8	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.10	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	120.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	2.5E5	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	2.2	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	4.3	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	11.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	11.	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	2.8E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	6.6E4	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	1.7	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	0.66	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	0.63	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	34.	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	870.	mR/hr	2-RE-29	1.1	mR/hr
1-RE-26	270.	mR/hr	2-RE-30	1.1	mR/hr
1-RE-27	45.	mR/hr	2-RE-31	1.1	mR/hr
1-RE-28	0.50	mR/hr	2-RE-32	0.10	mR/hr
1-RE-29	1.1	mR/hr	2-RE-33	1.1	mR/hr
1-RE-30	1.1	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.1	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.17	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.3	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	410.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.p

RADIATION MONITORING SYSTEM DATA (T = 04:30) (19:30)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.14	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	23.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.1	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	15.	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	130.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.1	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	3.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	3.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	250.	R/hr	REN21A	0.57	mR/hr
RE191B	250.	R/hr	REN21B	0.57	mR/hr
RE191C	250.	R/hr	REN21C	0.57	mR/hr
RE191D	250.	R/hr	REN21D	0.57	mR/hr
REN10A	0.12	mR/hr	SE17-23	10.	cpm
REN10B	0.12	mR/hr	SE221C	10.	cpm
REN10C	0.12	mR/hr	SE221D	10.	cpm
REN10D	0.12	mR/hr	SE160A	300.	cpm
REN11A	0.57	mR/hr	SE160B	300.	cpm
REN11B	0.57	mR/hr	SE-190	10.	cpm
REN11C	0.57	mR/hr	SE-290	10.	cpm
REN11D	0.57	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.p

RADIATION MONITORING SYSTEM DATA (T = 04:30) (19:30)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
-----	-----	-----	-----	-----	-----
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	57.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	2.E-11	uCi/cc	RE007D2	52.	cpm
RE75-A2	1.5E-9	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	2.E-11	uCi/cc	RE26-16	10.	cpm
RE75-B2	1.5E-9	uCi/cc	REN-04A	6.0E5	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	6.0E5	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	6.0E5	mR/hr
RE76-2	2.2E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow				402786.	cfm
South Stack Flow				0.	cfm
SGTS Flow				2502.	cfm

TABLE 6.1.q

RADIATION MONITORING SYSTEM DATA (T = 04:45) (19:45)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.31	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	0.35	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	2.3	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	74.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	250.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.1	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.0	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	34.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	32.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	1.2	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	2.5	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.10	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	110.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	2.6E5	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	2.2	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	4.0	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	11.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	9.9	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	2.5E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	6.0E4	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	1.6	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	0.63	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	0.61	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	30.	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	770.	mR/hr	2-RE-29	1.1	mR/hr
1-RE-26	240.	mR/hr	2-RE-30	1.1	mR/hr
1-RE-27	41.	mR/hr	2-RE-31	1.1	mR/hr
1-RE-28	0.45	mR/hr	2-RE-32	0.10	mR/hr
1-RE-29	1.1	mR/hr	2-RE-33	1.1	mR/hr
1-RE-30	1.1	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.1	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.17	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.2	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	360.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.q

RADIATION MONITORING SYSTEM DATA (T = 04:45) (19:45)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.14	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	20.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.1	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	12.	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	120.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.1	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	3.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	3.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	260.	R/hr	REN21A	0.56	mR/hr
RE191B	260.	R/hr	REN21B	0.56	mR/hr
RE191C	260.	R/hr	REN21C	0.56	mR/hr
RE191D	260.	R/hr	REN21D	0.56	mR/hr
REN10A	0.12	mR/hr	SE17-23	10.	cpm
REN10B	0.12	mR/hr	SE221C	10.	cpm
REN10C	0.12	mR/hr	SE221D	10.	cpm
REN10D	0.12	mR/hr	SE160A	260.	cpm
REN11A	0.56	mR/hr	SE160B	260.	cpm
REN11B	0.56	mR/hr	SE-190	10.	cpm
REN11C	0.56	mR/hr	SE-290	10.	cpm
REN11D	0.56	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.q

RADIATION MONITORING SYSTEM DATA (T = 04:45) (19:45)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
-----	-----	-----	-----	-----	-----
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	57.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	1.E-11	uCi/cc	RE007D2	52.	cpm
RE75-A2	1.2E-9	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	1.E-11	uCi/cc	RE26-16	10.	cpm
RE75-B2	1.2E-9	uCi/cc	REN-04A	5.4E5	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	5.4E5	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	5.4E5	mR/hr
RE76-2	2.2E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow				402786.	cfm
South Stack Flow				0.	cfm
SGTS Flow				2502.	cfm

TABLE 6.1.r

RADIATION MONITORING SYSTEM DATA (T = 05:00) (20:00)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	0.84	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	1.1	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	3.1	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	66.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	220.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	4.4	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.0	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	32.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	33.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	2.1	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	3.7	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.10	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	97.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	OSH	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	3.7	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	5.3	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	11.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	10.	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	2.3E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	5.4E4	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	3.0	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	2.2	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	2.2	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	28.	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	680.	mR/hr	2-RE-29	1.3	mR/hr
1-RE-26	210.	mR/hr	2-RE-30	1.3	mR/hr
1-RE-27	38.	mR/hr	2-RE-31	1.3	mR/hr
1-RE-28	0.41	mR/hr	2-RE-32	0.10	mR/hr
1-RE-29	1.3	mR/hr	2-RE-33	1.3	mR/hr
1-RE-30	1.3	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	1.3	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	0.39	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	1.4	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	320.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.r

RADIATION MONITORING SYSTEM DATA (T = 05:00) (20:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.21	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	18.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.1	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	10.	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	110.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	1.3	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	3.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	3.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	1.3E4	R/hr	REN21A	0.79	mR/hr
RE191B	1.3E4	R/hr	REN21B	0.79	mR/hr
RE191C	1.3E4	R/hr	REN21C	0.79	mR/hr
RE191D	1.3E4	R/hr	REN21D	0.79	mR/hr
REN10A	0.15	mR/hr	SE17-23	10.	cpm
REN10B	0.15	mR/hr	SE221C	10.	cpm
REN10C	0.15	mR/hr	SE221D	10.	cpm
REN10D	0.15	mR/hr	SE160A	230.	cpm
REN11A	0.79	mR/hr	SE160B	230.	cpm
REN11B	0.79	mR/hr	SE-190	10.	cpm
REN11C	0.79	mR/hr	SE-290	10.	cpm
REN11D	0.79	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.r

RADIATION MONITORING SYSTEM DATA (T = 05:00) (20:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
-----	-----	-----	-----	-----	-----
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	57.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	1.E-11	uCi/cc	RE007D2	52.	cpm
RE75-A2	7.5E-9	uCi/cc	SE022A	10.	cpm
RE75-A3	4.3E-7	uCi/cc	SE022B	10.	cpm
RE75-B1	1.E-11	uCi/cc	RE26-16	10.	cpm
RE75-B2	7.5E-9	uCi/cc	REN-04A	4.9E5	mR/hr
RE75-B3	3.9E-7	uCi/cc	REN-04B	4.9E5	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	4.9E5	mR/hr
RE76-2	2.2E-7	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow			402786.	cfm	
South Stack Flow			0.	cfm	
SGTS Flow			2502.	cfm	

TABLE A.1.e

NEW RADIATION MONITOR SYSTEM ALARMS (T = 05:00) (20:00)

Refuel Area Exh Duct (A)	(REN11A)	HIGH
Refuel Area Exh Duct (B)	(REN11B)	HIGH
Refuel Area Exh Duct (C)	(REN11C)	HIGH
Refuel Area Exh Duct (D)	(REN11D)	HIGH
Refuel Area Exh Duct (A)	(REN21A)	HIGH
Refuel Area Exh Duct (B)	(REN21B)	HIGH
Refuel Area Exh Duct (C)	(REN21C)	HIGH
Refuel Area Exh Duct (D)	(REN21D)	HIGH
N.Stack -Iodine (A)	(RE75-A2)	HIHI
N.Stack -Iodine (B)	(RE75-B2)	HIHI

TABLE 6.1.s

RADIATION MONITORING SYSTEM DATA (T = 05:30) (20:30)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	5.8	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	8.4	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	11.	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	53.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	180.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	7.6	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.0	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	37.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	42.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	12.	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	16.	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.10	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	79.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	OSH	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	18.	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	19.	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	15.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	19.	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	1.9E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	4.6E4	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	17.	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	17.	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	17.	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	33.	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	550.	mR/hr	2-RE-29	3.5	mR/hr
1-RE-26	170.	mR/hr	2-RE-30	3.5	mR/hr
1-RE-27	47.	mR/hr	2-RE-31	3.5	mR/hr
1-RE-28	0.35	mR/hr	2-RE-32	0.13	mR/hr
1-RE-29	3.5	mR/hr	2-RE-33	3.5	mR/hr
1-RE-30	3.5	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	3.5	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	2.6	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	3.6	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	260.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.s

RADIATION MONITORING SYSTEM DATA (T = 05:30) (20:30)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	0.94	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	15.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.0	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	9.9	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	88.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	3.5	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	3.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	3.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	1.3E4	R/hr	REN21A	3.0	mR/hr
RE191B	1.3E4	R/hr	REN21B	3.0	mR/hr
RE191C	1.3E4	R/hr	REN21C	3.0	mR/hr
RE191D	1.3E4	R/hr	PEN21D	3.0	mR/hr
REN10A	0.44	mR/hr	SE17-23	10.	cpm
REN10B	0.44	mR/hr	SE221C	10.	cpm
REN10C	0.44	mR/hr	SE221D	10.	cpm
REN10D	0.44	mR/hr	SE160A	190.	cpm
REN11A	3.0	mR/hr	SE160B	190.	cpm
REN11B	3.0	mR/hr	SE-190	10.	cpm
REN11C	3.0	mR/hr	SE-290	10.	cpm
REN11D	3.0	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.s

RADIATION MONITORING SYSTEM DATA (T = 05:30) (20:30)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	580.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	8.E-11	uCi/cc	RE007D2	52.	cpm
RE75-A2	9.2E-8	uCi/cc	SE022A	10.	cpm
RE75-A3	3.0E-6	uCi/cc	SE022B	10.	cpm
RE75-B1	8.E-11	uCi/cc	RE26-16	10.	cpm
RE75-B2	9.2E-8	uCi/cc	REN-04A	4.1E5	mR/hr
RE75-B3	3.0E-6	uCi/cc	REN-04B	4.1E5	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	4.1E5	mR/hr
RE76-2	3.0E-6	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow				402786.	cfm
South Stack Flow				0.	cfm
SGTS Flow				2502.	cfm

TABLE A.1.f

NEW RADIATION MONITOR SYSTEM ALARMS (T = 05:30) (20:30)

Sump Compartment--RX 177	(1-RE-03)	HIGH
CRDHCU Area West--RX 253	(1-RE-16)	HIGH
Refuel Area Exh Duct (A)	(REN11A)	HIHI
Refuel Area Exh Duct (B)	(REN11B)	HIHI
Refuel Area Exh Duct (C)	(REN11C)	HIHI
Refuel Area Exh Duct (D)	(REN11D)	HIHI
Refuel Area Exh Duct (A)	(REN21A)	HIHI
Refuel Area Exh Duct (B)	(REN21B)	HIHI
Refuel Area Exh Duct (C)	(REN21C)	HIHI
Refuel Area Exh Duct (D)	(REN21D)	HIHI

TABLE 6.1.t

RADIATION MONITORING SYSTEM DATA (T = 06:00) (21:00)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	8.4	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	12.	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	15.	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	45.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	150.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	9.2	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.0	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	39.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	47.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	17.	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	23.	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.10	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	66.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	OSH	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	25.	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	26.	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	17.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	23.	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	1.7E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	4.0E4	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	24.	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	24.	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	24.	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	35.	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	460.	mR/hr	2-RE-29	4.7	mR/hr
1-RE-26	150.	mR/hr	2-RE-30	4.7	mR/hr
1-RE-27	51.	mR/hr	2-RE-31	4.7	mR/hr
1-RE-28	0.31	mR/hr	2-RE-32	0.15	mR/hr
1-RE-29	4.7	mR/hr	2-RE-33	4.7	mR/hr
1-RE-30	4.7	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	4.7	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	3.8	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	4.8	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	220.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.t

RADIATION MONITORING SYSTEM DATA (T = 06:00) (21:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	1.3	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	12.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.0	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	11.	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	76.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
PI-101	4.7	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	3.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	3.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	1.1E4	R/hr	REN21A	4.2	mR/hr
RE191B	1.1E4	R/hr	REN21B	4.2	mR/hr
RE191C	1.1E4	R/hr	REN21C	4.2	mR/hr
RE191D	1.1E4	R/hr	REN21D	4.2	mR/hr
REN10A	0.59	mR/hr	SE17-23	10.	cpm
REN10B	0.59	mR/hr	SE221C	10.	cpm
REN10C	0.59	mR/hr	SE221D	10.	cpm
REN10D	0.59	mR/hr	SE160A	150.	cpm
REN11A	4.2	mR/hr	SE160B	150.	cpm
REN11B	4.2	mR/hr	SE-190	12.	cpm
REN11C	4.2	mR/hr	SE-290	10.	cpm
REN11D	4.2	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.t

RADIATION MONITORING SYSTEM DATA (T = 06:00) (21:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	1000.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	5.E-11	uCi/cc	RE007D2	52.	cpm
RE75-A2	7.0E-8	uCi/cc	SE022A	10.	cpm
RE75-A3	5.4E-6	uCi/cc	SE022B	10.	cpm
RE75-B1	5.E-11	uCi/cc	RE26-16	10.	cpm
RE75-B2	7.0E-8	uCi/cc	REN-04A	3.5E5	mR/hr
RE75-B3	5.4E-6	uCi/cc	REN-04B	3.5E5	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	3.5E5	mR/hr
RE76-2	5.4E-6	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow				402786.	cfm
South Stack Flow				0.	cfm
SGTS Flow				2502.	cfm

TABLE A.1.g

NEW RADIATION MONITOR SYSTEM ALARMS (T = 06:00) (21:00)

CRDHCU Area East--RX 253	(1-RE-15)	HIGH
Neut Mon Dr.Area--RX 253	(1-RE-18)	HIGH
Rx Wtr Cleanup Pump Area	(1-RE-21)	HIGH
RWCU Heat Exchanger Area	(1-RE-22)	HIGH
SBLC System Area--RX 283	(1-RE-23)	HIGH
Stnby Gas Trtmnt--CS 332	(0-RE-58)	HIGH
Rx Encl Exh Duct (A)	(REN10A)	HIGH
Rx Encl Exh Duct (B)	(REN10B)	HIGH
Rx Encl Exh Duct (C)	(REN10C)	HIGH
Rx Encl Exh Duct (D)	(REN10D)	HIGH
N.Stack -Gas (A)	(RE75-A3)	HIGH
N.Stack -Gas (B)	(RE75-B3)	HIGH
N.Stk -Widerange Gas (2)	(RE76-2)	HIGH

TABLE 6.1.u

RADIATION MONITORING SYSTEM DATA (T = 06:30) (21:30)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	10.	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	15.	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	18.	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	38.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	130.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	10.	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.0	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	41.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	50.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	20.	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	27.	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.10	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	56.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	OSH	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	30.	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	31.	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	18.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	26.	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	1.5E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	3.5E4	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	29.	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	29.	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	29.	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	36.	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	400.	mR/hr	2-RE-29	5.3	mR/hr
1-RE-26	120.	mR/hr	2-RE-30	5.3	mR/hr
1-RE-27	53.	mR/hr	2-RE-31	5.3	mR/hr
1-RE-28	0.28	mR/hr	2-RE-32	0.16	mR/hr
1-RE-29	5.3	mR/hr	2-RE-33	5.3	mR/hr
1-RE-30	5.3	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	5.3	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	4	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	4	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	190.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.u

RADIATION MONITORING SYSTEM DATA (T = 06:30) (21:30)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	1.5	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	11.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.0	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	12.	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	66.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	5.3	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	2.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	2.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	9700.	R/hr	REN21A	4.8	mR/hr
RE191B	9700.	R/hr	REN21B	4.8	mR/hr
RE191C	9700.	R/hr	REN21C	4.8	mR/hr
RE191D	9700.	R/hr	REN21D	4.8	mR/hr
REN10A	0.69	mR/hr	SE17-23	10.	cpm
REN10B	0.69	mR/hr	SE221C	10.	cpm
REN10C	0.69	mR/hr	SE221D	10.	cpm
REN10D	0.69	mR/hr	SE160A	130.	cpm
REN11A	4.8	mR/hr	SE160B	130.	cpm
REN11B	4.8	mR/hr	SE-190	15.	cpm
REN11C	4.8	mR/hr	SE-290	10.	cpm
REN11D	4.8	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.u

RADIATION MONITORING SYSTEM DATA (T = 06:30) (21:30)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
-----	-----	-----	-----	-----	-----
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	1400.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	2.E-11	uCi/cc	RE007D2	52.	cpm
RE75-A2	4.8E-8	uCi/cc	SE022A	10.	cpm
RE75-A3	7.4E-6	uCi/cc	SE022B	10.	cpm
RE75-B1	2.E-11	uCi/cc	RE26-16	10.	cpm
RE75-B2	4.8E-8	uCi/cc	REN-04A	3.1E5	mR/hr
RE75-B3	7.4E-6	uCi/cc	REN-04B	3.1E5	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	3.1E5	mR/hr
RE76-2	7.4E-6	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow				402786.	cfm
South Stack Flow				0.	cfm
SGTS Flow				2502.	cfm

LIMERICK GENERATING STATION
ANNUAL EXERCISE

SCENARIO L53
UNIT 1 REV 0

TABLE A.1.h

NEW RADIATION MONITOR SYSTEM ALARMS (T = 06:30) (21:30)

RR Access Airlock-RX 217 (1-RE-11) HIGH

TABLE 6.1.v

RADIATION MONITORING SYSTEM DATA (T = 07:00) (22:00)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	11.	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	16.	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	20.	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	33.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	110.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	11.	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.0	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	42.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	52.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	23.	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	30.	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.10	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	48.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	OSH	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	33.	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	34.	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	19.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	28.	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	1.4E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	3.2E4	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	32.	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	33.	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	33.	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	37.	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	340.	mR/hr	2-RE-29	5.8	mR/hr
1-RE-26	110.	mR/hr	2-RE-30	5.8	mR/hr
1-RE-27	54.	mR/hr	2-RE-31	5.8	mR/hr
1-RE-28	0.25	mR/hr	2-RE-32	0.16	mR/hr
1-RE-29	5.8	mR/hr	2-RE-33	5.8	mR/hr
1-RE-30	5.8	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	5.8	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	4.9	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	5.9	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	170.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.v

RADIATION MONITORING SYSTEM DATA (T = 07:00) (22:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	1.7	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	10.	cpm
0-RE-55	0.10	mR/hr	SE13-11	10.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.0	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	13.	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	59.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	5.8	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	2.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	2.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	8700.	R/hr	REN21A	5.3	mR/hr
RE191B	8700.	R/hr	REN21B	5.3	mR/hr
RE191C	8700.	R/hr	REN21C	5.3	mR/hr
RE191D	8700.	R/hr	REN21D	5.3	mR/hr
REN10A	0.76	mR/hr	SE17-23	10.	cpm
REN10B	0.76	mR/hr	SE221C	10.	cpm
REN10C	0.76	mR/hr	SE221D	10.	cpm
REN10D	0.76	mR/hr	SE160A	110.	cpm
REN11A	5.3	mR/hr	SE160B	110.	cpm
REN11B	5.3	mR/hr	SE-190	16.	cpm
REN11C	5.3	mR/hr	SE-290	10.	cpm
REN11D	5.3	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.v

RADIATION MONITORING SYSTEM DATA (T = 07:00) (22:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	1700.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	1.E-11	uCi/cc	RE007D2	52.	cpm
RE75-A2	3.7E-8	uCi/cc	SE022A	10.	cpm
RE75-A3	9.0E-6	uCi/cc	SE022B	10.	cpm
RE75-B1	1.E-11	uCi/cc	RE26-16	10.	cpm
RE75-B2	3.7E-8	uCi/cc	REN-04A	2.8E5	mR/hr
RE75-B3	9.0E-6	uCi/cc	REN-04B	2.8E5	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	2.8E5	mR/hr
RE76-2	9.0E-6	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow				402786.	cfm
South Stack Flow				0.	cfm
SGTS Flow				2502.	cfm

LIMERICK GENERATING STATION
ANNUAL EXERCISE

SCENARIO L53
UNIT 1 REV 0

TABLE A.1.i

NEW RADIATION MONITOR SYSTEM ALARMS (T = 07:00) (22:00)

HPCI Pump Room--RX 177 (1-RE-02) HIGH

TABLE 6.1.w

RADIATION MONITORING SYSTEM DATA (T = 08:00) (23:00)

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
1-RE-01	13.	mR/hr	2-RE-05	0.10	mR/hr
1-RE-02	19.	mR/hr	2-RE-06	0.10	mR/hr
1-RE-03	23.	mR/hr	2-RE-07	4.0	mR/hr
1-RE-04	26.	mR/hr	2-RE-08	10.	mR/hr
1-RE-05	89.	mR/hr	2-RE-09	10.	mR/hr
1-RE-06	12.	mR/hr	2-RE-10	20.	mR/hr
1-RE-07	1.0	mR/hr	2-RE-11	0.10	mR/hr
1-RE-08	43.	mR/hr	2-RE-12	0.10	mR/hr
1-RE-09	55.	mR/hr	2-RE-13	3.0	mR/hr
1-RE-10	26.	mR/hr	2-RE-14	30.	mR/hr
1-RE-11	34.	mR/hr	2-RE-15	1.5	mR/hr
1-RE-12	0.10	mR/hr	2-RE-16	1.5	mR/hr
1-RE-13	37.	mR/hr	2-RE-17	10.	mR/hr
1-RE-14	OSH	mR/hr	2-RE-18	0.50	mR/hr
1-RE-15	38.	mR/hr	2-RE-19	3.0	mR/hr
1-RE-16	39.	mR/hr	2-RE-20	3.0	mR/hr
1-RE-17	21.	mR/hr	2-RE-21	1.0	mR/hr
1-RE-18	31.	mR/hr	2-RE-22	0.10	mR/hr
1-RE-19	1.1E4	mR/hr	2-RE-23	0.10	mR/hr
1-RE-20	2.7E4	mR/hr	2-RE-24	1.0	mR/hr
1-RE-21	37.	mR/hr	2-RE-25	0.10	mR/hr
1-RE-22	38.	mR/hr	2-RE-26	0.10	mR/hr
1-RE-23	38.	mR/hr	2-RE-27	0.10	mR/hr
1-RE-24	37.	mR/hr	2-RE-28	0.10	mR/hr
1-RE-25	270.	mR/hr	2-RE-29	6.4	mR/hr
1-RE-26	84.	mR/hr	2-RE-30	6.4	mR/hr
1-RE-27	56.	mR/hr	2-RE-31	6.4	mR/hr
1-RE-28	0.22	mR/hr	2-RE-32	0.16	mR/hr
1-RE-29	6.4	mR/hr	2-RE-33	6.4	mR/hr
1-RE-30	6.4	mR/hr	2-RE-34	0.10	mR/hr
1-RE-31	6.4	mR/hr	2-RE-35	0.50	mR/hr
1-RE-32	5.5	mR/hr	0-RE-41	5.0	mR/hr
1-RE-33	6.5	mR/hr	0-RE-42	0.50	mR/hr
1-RE-34	0.10	mR/hr	0-RE-43	4.0	mR/hr
1-RE-35	0.50	mR/hr	0-RE-44	0.10	mR/hr
1-RE-36	130.	mR/hr	0-RE-45	2.5	mR/hr
2-RE-01	0.10	mR/hr	0-RE-46	2.0	mR/hr
2-RE-02	0.10	mR/hr	0-RE-47	1.0	mR/hr
2-RE-03	2.0	mR/hr	0-RE-48	0.10	mR/hr
2-RE-04	0.10	mR/hr	0-RE-49	2.0	mR/hr

continued next column

continued next page

TABLE 6.1.w

RADIATION MONITORING SYSTEM DATA (T = 08:00) (23:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
0-RE-50	1.9	mR/hr	SE160A	10.	cpm
0-RE-51	0.05	mR/hr	SE160B	10.	cpm
0-RE-52	0.01	mR/hr	SE-190	10.	cpm
0-RE-53	0.05	mR/hr	SE63-09	10.	cpm
0-RE-54	1.0	mR/hr	SE10-11	10.	cpm
0-RE-55	0.10	mR/hr	SE13-11	11.	cpm
0-RE-56	0.01	mR/hr	RE42N6A	9.7	mR/hr
0-RE-57	1.0	mR/hr	RE42N6B	11.	mR/hr
0-RE-58	16.	mR/hr	RE42N6C	8.4	mR/hr
0-RE-60	0.01	mR/hr	RE42N6D	11.	mR/hr
REX-025	0.10	mR/hr	RE285A1	1.E-12	uCi/cc
RI-01	48.	mR/hr	RE285A2	1.E-11	uCi/cc
RI-02	1.0	mR/hr	RE285A3	1.0E-7	uCi/cc
RI-101	6.4	mR/hr	RE285B1	1.E-12	uCi/cc
RE41N6A	OSH	mR/hr	RE285B2	1.E-11	uCi/cc
RE41N6B	OSH	mR/hr	RE285B3	1.0E-7	uCi/cc
RE41N6C	OSH	mR/hr	RE291A	1.0	R/hr
RE41N6D	OSH	mR/hr	RE291B	1.0	R/hr
RE185A1	1.E-12	uCi/cc	RE291C	1.0	R/hr
RE185A2	2.E-11	uCi/cc	RE291D	1.0	R/hr
RE185A3	1.0E-7	uCi/cc	REN20A	0.10	mR/hr
RE185B1	1.E-12	uCi/cc	REN20B	0.10	mR/hr
RE185B2	2.E-11	uCi/cc	REN20C	0.10	mR/hr
RE185B3	1.0E-7	uCi/cc	REN20D	0.10	mR/hr
RE191A	7300.	R/hr	REN21A	5.9	mR/hr
RE191B	7300.	R/hr	REN21B	5.9	mR/hr
RE191C	7300.	R/hr	REN21C	5.9	mR/hr
RE191D	7300.	R/hr	REN21D	5.9	mR/hr
REN10A	0.85	mR/hr	SE17-23	10.	cpm
REN10B	0.85	mR/hr	SE221C	10.	cpm
REN10C	0.85	mR/hr	SE221D	10.	cpm
REN10D	0.95	mR/hr	SE160A	80.	cpm
REN11A	5.9	mR/hr	SE160B	80.	cpm
REN11B	5.9	mR/hr	SE-190	19.	cpm
REN11C	5.9	mR/hr	SE-290	10.	cpm
REN11D	5.9	mR/hr	SE10-11	10.	cpm
RR-609	10.	cpm	SE13-11	10.	cpm
SE17-23	10.	cpm	RE025A	3.E-10	uCi/cc
SE121C	10.	cpm	RE025B	3.7E-9	uCi/cc
SE121D	10.	cpm	RE68C-1	1.8E-7	uCi/cc

continued next column

continued next page

TABLE 6.1.w

RADIATION MONITORING SYSTEM DATA (T = 08:00) (23:00)

continued

NOTE: 'OSH' = Offscale High

ALL MONITOR VALUES ARE 1 MINUTE AVERAGES

Monitor	value	units	Monitor	value	units
RE68C-2	41.	cpm	RE007B2	52.	cpm
RE68D-1	1.8E-7	uCi/cc	RE007C1	1.0E-6	uCi/cc
RE68D-2	41.	cpm	RE007C2	52.	cpm
RE76-4	2300.	uCi/s	RE007D1	1.0E-6	uCi/cc
RE75-A1	3.E-12	uCi/cc	RE007D2	52.	cpm
RE75-A2	2.9E-8	uCi/cc	SE022A	10.	cpm
RE75-A3	1.2E-5	uCi/cc	SE022B	10.	cpm
RE75-B1	3.E-12	uCi/cc	RE26-16	10.	cpm
RE75-B2	2.9E-8	uCi/cc	REN-04A	2.3E5	mR/hr
RE75-B3	1.2E-5	uCi/cc	REN-04B	2.3E5	mR/hr
RE76-1	1.0E-4	uCi/cc	REN-005	2.3E5	mR/hr
RE76-2	1.2E-5	uCi/cc	PAS LC1	1.0	mR/hr
RE76-3	0.1	uCi/cc	PAS LC2	1.0	mR/hr
RE007A1	1.0E-6	uCi/cc	(2)-04A	10.	mR/hr
RE007A2	52.	cpm	(2)-04B	10.	mR/hr
RE007B1	1.0E-6	uCi/cc	(2)-005	10.	mR/hr
North Stack Flow				402786.	cfm
South Stack Flow				0.	cfm
SGTS Flow				2502.	cfm

CONTROLLER INFORMATION FOR
USE WITH TABLES 6.2


Table 6.2, In-Plant Survey and Sampling Data, contains direct radiation reading information. This data is listed as values that may or may not be 'readable' by a particular instrument. Following is a list of radiation meters that are available, including the range of all scales of these instruments. Please provide data only applicable to the scale that the meter being used is set to. If not readable by that particular scale, report DATA as 'Offscale low' or 'Offscale high', as appropriate. ARM readings that are given for each elevation are the READOUTS on that particular elevation. The detectors are not necessarily on that elevation and may not reflect dose rates of the area where listed. In a case where no data is given for a particular area or elevation, data is ↑As Read↑

RO2	RO2A
0.2 - 50 mr/hr	2 - 50 mr/hr
2 - 50 mr/hr	20 - 500 mr/hr
20 - 500 mr/hr	200 - 5000 mr/hr
200 - 5000 mr/hr	2 - 50 r/hr

RO7	E520
(depends on which of three detectors is installed)	0.01 - 0.2 mR/hr
0 - 2 r/hr	0.1 - 2 mR/hr
0 - 200 r/hr	1 - 20 mR/hr
0 - 20000 r/hr	10 - 200 mR/hr
	100 - 2000 mR/hr

Johnson Xtender

50 - 1000	μR/hr
0.5 - 10	mR/hr
5 - 100	mR/hr
50 - 1000	mR/hr
0.5 - 10	R/hr
5 - 100	R/hr
10 - 1000	R/hr



Control Structure 217' Elevation

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Control Structure 217' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

Contamination and Airborne Survey Data at (T = 01:00) (16:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			



Control Structure 217' Elevation

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Control Structure 217' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

Radiation Survey Data at (T = 03:05) (18:05)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			



Control Structure 217' Elevation

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Control Structure 217' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

Contamination and Airborne Survey Data at (T = 03:30) (18:30)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:40) (18:40)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			



Control Structure 217' Elevation

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Control Structure 217' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:15) (19:15)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			



Control Structure 217' Elevation

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Control Structure 217' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

Radiation Survey Data at (T = 05:30) (20:30)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			



Control Structure 217' Elevation

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Control Structure 217' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			




EL. 350'



EL. 332'

△ ARM READOUT
● ARM DETECTOR



EL. 321'

CONTROL STRUCTURE EL. 321', 332', 350'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Control Structure 332' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 00:00) (15:00)

0-RE-58 0.50

Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 01:00) (16:00)

0-RE-58 0.50



EL. 350'



EL. 332'

△ ARM READOUT
● ARM DETECTOR



EL. 321'

CONTROL STRUCTURE EL. 321'; 332'; 350'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Control Structure 332' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 02:00) (17:00)

0-RE-58 0.50

Contamination and Airborne Survey Data at (T = 03:00) (18:00)



Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 03:00) (18:00)

0-RE-58 0.50



△ ARM READOUT
● ARM DETECTOR



CONTROL STRUCTURE EL 321, 332, 350

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Control Structure 332' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)




Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1						

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	51.	51.	B	53.	53.	C	120.	120.
D	16.	16.	E	370.	370.	F	130.	130.
G	190.	190.						

ARM Readings (mR/hr) at (T = 03:15) (18:15)

0-RE-58 0.50



CONTROL STRUCTURE EL 321', 332', 350'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Control Structure 332' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.4	0.4
D	3.1	3.1	E	0.8	0.8	F	2.6	2.6
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 03:25) (18:25)

0-RE-58 53.

Contamination and Airborne Survey Data at (T = 03:30) (18:30)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:40) (18:40)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.3	0.3
D	< 0.1	< 0.1	E	0.6	0.6	F	1.8	1.8
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 03:40) (18:40)

0-RE-58 34.




EL. 350'



EL. 332'

△ ARM READOUT
● ARM DETECTOR



EL. 321'

CONTROL STRUCTURE EL. 321', 332', 350'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Control Structure 332' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.2	0.2
D	< 0.1	< 0.1	E	0.4	0.4	F	1.2	1.2
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 04:00) (19:00)


0-RE-58 24.

Radiation Survey Data at (T = 04:15) (19:15)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.1	0.1
D	< 0.1	< 0.1	E	0.3	0.3	F	2.7	2.7
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 04:15) (19:15)

0-RE-58 18.




EL 350'



EL 332'

△ ARM READOUT
● ARM DETECTOR



EL 321'

CONTROL STRUCTURE EL. 321', 332', 350'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA

READINGS ABOVE NORMAL BACKGROUND

Control Structure 332' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	0.2	0.2	F	3.5	3.5
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 04:30) (19:30)



0-RE-58 15.

Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	0.2	0.2	F	3.7	3.7
G	< 0.1	< 0.1						


ARM Readings (mR/hr) at (T = 04:45) (19:45)

0-RE-58 12.



△ ARM READOUT

● ARM DETECTOR



CONTROL STRUCTURE EL. 321', 332', 350'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Control Structure 332' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	0.1	0.1	F	4.3	4.3
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 05:00) (20:00)


0-RE-58 10.

Radiation Survey Data at (T = 05:30) (20:30)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	0.1	0.1	F	32.	32.
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 05:30) (20:30)

0-RE-58 9.9




EL. 350'



EL. 332'

△ ARM READOUT
● ARM DETECTOR



EL. 321'

CONTROL STRUCTURE EL. 321', 332', 350'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Control Structure 332' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	0.2	0.2	F	65.	65.
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 06:00) (21:00)



0-RE-58 11.

Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	0.2	0.2	F	90.	90.
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 06:30) (21:30)

0-RE-58 12.



CONTROL STRUCTURE EL 321', 332', 350'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Control Structure 332' Elev.

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	0.2	0.2	F	110.	110.
G	0.1	0.1						

ARM Readings (mR/hr) at (T = 07:00) (22:00)

0-RE-58 13.

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	0.2	0.2	F	150.	150.
G	0.1	0.1						

ARM Readings (mR/hr) at (T = 08:00) (23:00)

0-RE-58 16.



REACTOR ENCLOSURE ROOF
410' ELEV.

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA

----- READINGS ABOVE NORMAL BACKGROUND -----

Reactor Enclosure Roof Elev. 410'

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 00:00) (15:00)

0-RE-60 0.01

 Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 01:00) (16:00)

0-RE-60 0.01



REACTOR ENCLOSURE ROOF
410' ELEV.

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Reactor Enclosure Roof Elev. 410'

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 02:00) (17:00)

0-RE-60 0.01

Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 03:00) (18:00)

0-RE-60 0.01



REACTOR ENCLOSURE ROOF
410' ELEV.

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Reactor Enclosure Roof Elev. 410'

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	0.2	0.2	E	< 0.1	< 0.1	F	< 0.1	< 0.1

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	2.8	2.8	B	2.6	2.6	C	3.0	3.0
D	4.1	4.1	E	3.6	3.6	F	3.8	3.8

ARM Readings (mR/hr) at (T = 03:15) (18:15)

0-RE-60 0.01



REACTOR ENCLOSURE ROOF
410' ELEV.

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA

----- READINGS ABOVE NORMAL BACKGROUND -----

Reactor Enclosure Roof Elev. 410'

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	2.8	2.8	B	2.6	2.6	C	3.0	3.0
D	4.6	4.6	E	3.7	3.7	F	3.8	3.8

ARM Readings (mR/hr) at (T = 03:25) (18:25)


0-RE-60 0.01

 Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.3	0.3
D	1.9	1.9	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 03:40) (18:40)

0-RE-60 0.01



REACTOR ENCLOSURE ROOF
410' ELEV.

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Reactor Enclosure Roof Elev. 410'

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.4	0.4
D	2.1	2.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:00) (19:00)


0-RE-60 0.01

 Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.4	0.4
D	2.2	2.2	E	0.1	0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:15) (19:15)

0-RE-60 0.01



REACTOR ENCLOSURE ROOF
410' ELEV.

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Reactor Enclosure Roof Elev. 410'

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.3	0.3
D	1.8	1.8	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:30) (19:30)


0-RE-60 0.01

Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.3	0.3
D	1.5	1.5	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:45) (19:45)

0-RE-60 0.01



REACTOR ENCLOSURE ROOF
410' ELEV.

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Reactor Enclosure Roof Elev. 410'

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.3	0.3
D	1.3	1.3	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 05:00) (20:00)


0-RE-60 0.01

 Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.2	0.2
D	1.0	1.0	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 05:30) (20:30)

0-RE-60 0.01



REACTOR ENCLOSURE ROOF
410' ELEV.

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Reactor Enclosure Roof Elev. 410'

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.2	0.2
D	0.8	0.8	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 06:00) (21:00)


0-RE-60 0.01

Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.2	0.2
D	0.7	0.7	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 06:30) (21:30)

0-RE-60 0.01



REACTOR ENCLOSURE ROOF
410' ELEV.

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Reactor Enclosure Roof Elev. 410'

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.2	0.2
D	0.6	0.6	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 07:00) (22:00)

0-RE-60 0.01

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.1	0.1
D	0.5	0.5	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 08:00) (23:00)

0-RE-60 0.01



TRUCK LOADING AREA

RADWASTE ELEVATION 217'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Radwaste Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 00:00) (15:00)

0-RE-49 2.0 0-RE-51 0.05

Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 01:00) (16:00)

0-RE-49 2.0 0-RE-51 0.05



RADWASTE ELEVATION 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Radwaste Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 02:00) (17:00)

0-RE-49 2.0 0-RE-51 0.05

Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:00) (18:00)

0-RE-49 2.0 0-RE-51 0.05



RADWASTE ELEVATION 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Radwaste Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:15) (18:15)

0-RE-49 2.0 0-RE-51 0.05



RADWASTE ELEVATION 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Radwaste Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:25) (18:25)


0-RE-49 2.0 0-RE-51 0.05

Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:40) (18:40)

0-RE-49 2.0 0-RE-51 0.05



TRUCK LOADING AREA

RADWASTE ELEVATION 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Radwaste Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 04:00) (19:00)


0-RE-49 2.0 0-RE-51 0.05

Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 04:15) (19:15)

0-RE-49 2.0 0-RE-51 0.05



RADWASTE ELEVATION 217'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA

----- READINGS ABOVE NORMAL BACKGROUND -----

Radwaste Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 04:30) (19:30)


0-RE-49 2.0 0-RE-51 0.05

 Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 04:45) (19:45)

0-RE-49 2.0 0-RE-51 0.05



TRUCK LOADING AREA

RADWASTE ELEVATION 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Radwaste Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 05:00) (20:00)


0-RE-49 2.0 0-RE-51 0.05

Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.2	0.2
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 05:30) (20:30)

0-RE-49 2.0 0-RE-51 0.05



RADWASTE ELEVATION 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Radwaste Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.2	0.2
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 06:00) (21:00)


0-RE-49 2.0 0-RE-51 0.05

Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.3	0.3
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 06:30) (21:30)

0-RE-49 2.0 0-RE-51 0.05



RADWASTE ELEVATION 217'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Radwaste Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.3	0.3
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 07:00) (22:00)

0-RE-49 2.0 0-RE-51 0.05

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.3	0.3
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 08:00) (23:00)

0-RE-49 2.0 0-RE-51 0.05



UNIT 1 REACTOR EL 177

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 177' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1	I	< 0.1	< 0.1
J	< 0.1	< 0.1	K	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 00:00) (15:00)

1-RE-01 0.10 1-RE-02 0.10 1-RE-03 2.0

Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1	I	< 0.1	< 0.1
J	< 0.1	< 0.1	K	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 01:00) (16:00)

1-RE-01 0.10 1-RE-02 0.10 1-RE-03 2.0



UNIT 1 REACTOR EL 177'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 177' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1	I	< 0.1	< 0.1
J	< 0.1	< 0.1	K	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 02:00) (17:00)

1-RE-01 0.10 1-RE-02 0.10 1-RE-03 2.0

Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1	I	< 0.1	< 0.1
J	< 0.1	< 0.1	K	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:00) (18:00)

1-RE-01 0.10 1-RE-02 0.10 1-RE-03 2.0



UNIT 1 REACTOR EL 177

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 177' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1	I	< 0.1	< 0.1
J	1.3	1.3	K	< 0.1	< 0.1			

Contamination and Airborne Survey Data at (T = 03:15) (18:15)


Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 11. cpm/100cm²
 Wall and Equipment Contamination: 1.1 cpm/100cm²
 Personnel Contamination Rate: 0.6 cpm/100cm² per minute

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	0.5	B	< 0.1	0.5	C	0.1	0.5
D	< 0.1	0.5	E	0.1	0.5	F	0.1	0.5
G	0.1	0.5	H	0.1	0.5	I	1.5	1.9
J	110.	110.	K	4.4	4.8			

ARM Readings (mR/hr) at (T = 03:15) (18:15)

1-RE-01 0.19 1-RE-02 0.14 1-RE-03 2.0



UNIT 1 REACTOR EL 177

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 177' Elev.

Contamination and Airborne Survey Data at (T = 03:15) (18:15)

Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 11. cpm/100cm²
 Wall and Equipment Contamination: 1.1 cpm/100cm²
 Personnel Contamination Rate: 0.6 cpm/100cm² per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.1	0.8	B	0.1	0.8	C	0.2	0.8
D	0.1	0.7	E	0.2	0.8	F	0.2	0.8
G	0.2	0.8	H	0.2	0.8	I	1.6	2.2
J	110.	110.	K	5.4	6.0			

ARM Readings (mR/hr) at (T = 03:25) (18:25)

1-RE-01 0.35 1-RE-02 0.25 1-RE-03 2.2

Contamination and Airborne Survey Data at (T = 03:30) (18:30)


Air Sample Contact Rate: 1.7E4 cpm/cf sample
 Floor Contamination: 66. cpm/100cm²
 Wall and Equipment Contamination: 6.6 cpm/100cm²
 Personnel Contamination Rate: 1.0 cpm/100cm² per minute

Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.2	1.1	B	0.2	1.1	C	0.2	1.1
D	0.2	1.1	E	0.2	1.1	F	0.2	1.1
G	0.2	1.1	H	0.3	1.2	I	1.2	2.1
J	80.	81.	K	3.9	4.8			

ARM Readings (mR/hr) at (T = 03:40) (18:40)

1-RE-01 0.35 1-RE-02 0.34 1-RE-03 2.3



UNIT 1 REACTOR EL 177

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 177' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: 1.5E4 cpm/cf sample
 Floor Contamination: 170. cpm/100cm²
 Wall and Equipment Contamination: 17. cpm/100cm²
 Personnel Contamination Rate: 0.8 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.2	1.4	B	0.2	1.4	C	0.3	1.5
D	0.2	1.4	E	0.2	1.5	F	0.3	1.5
G	0.3	1.5	H	0.3	1.5	I	0.9	2.1
J	53.	54.	K	2.8	4.0			

ARM Readings (mR/hr) at (T = 04:00) (19:00)

1-RE-01 0.35 1-RE-02 0.38 1-RE-03 2.3

Contamination and Airborne Survey Data at (T = 04:15) (19:15)


Air Sample Contact Rate: 1.3E4 cpm/cf sample
 Floor Contamination: 210. cpm/100cm²
 Wall and Equipment Contamination: 21. cpm/100cm²
 Personnel Contamination Rate: 0.7 cpm/100cm² per minute

Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.2	1.6	B	0.2	1.6	C	0.3	1.7
D	0.2	1.6	E	0.2	1.6	F	0.3	1.7
G	0.3	1.7	H	0.3	1.7	I	0.7	2.1
J	44.	45.	K	2.3	3.7			

ARM Readings (mR/hr) at (T = 04:15) (19:15)

1-RE-01 0.35 1-RE-02 0.39 1-RE-03 2.3



UNIT 1 REACTOR EL 177

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 177' Elev.

Contamination and Airborne Survey Data at (T = 04:30) (19:30)

Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 230. cpm/100cm²
 Wall and Equipment Contamination: 23. cpm/100cm²
 Personnel Contamination Rate: 0.5 cpm/100cm² per minute

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.2	1.5	B	0.2	1.5	C	0.3	1.6
D	0.2	1.5	E	0.2	1.6	F	0.3	1.6
G	0.3	1.6	H	0.3	1.7	I	0.6	2.0
J	37.	38.	K	2.0	3.4			

ARM Readings (mR/hr) at (T = 04:30) (19:30)

1-RE-01 0.32 1-RE-02 0.36 1-RE-03 2.3

Contamination and Airborne Survey Data at (T = 04:45) (19:45)


Air Sample Contact Rate: 7900. cpm/cf sample
 Floor Contamination: 240. cpm/100cm²
 Wall and Equipment Contamination: 24. cpm/100cm²
 Personnel Contamination Rate: 0.4 cpm/100cm² per minute

Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.2	1.6	B	0.2	1.6	C	0.3	1.6
D	0.2	1.5	E	0.2	1.6	F	0.3	1.6
G	0.3	1.6	H	0.3	1.7	I	0.6	1.9
J	32.	33.	K	1.7	3.1			

ARM Readings (mR/hr) at (T = 04:45) (19:45)

1-RE-01 0.31 1-RE-02 0.35 1-RE-03 2.3



UNIT 1 REACTOR EL 177

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 177' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: 18. mR/hr / cf sample
 Floor Contamination: 300. cpm/100cm2
 Wall and Equipment Contamination: 30. cpm/100cm2
 Personnel Contamination Rate: 4.6 cpm/100cm2 per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.7	5.7	B	0.7	5.7	C	1.0	6.0
D	0.7	5.7	E	0.8	5.8	F	1.0	6.0
G	1.0	6.0	H	1.1	6.1	I	1.1	6.0
J	29.	34.	K	2.6	7.6			

ARM Readings (mR/hr) at (T = 05:00) (20:00)

1-RE-01 0.84 1-RE-02 1.1 1-RE-03 3.1

Contamination and Airborne Survey Data at (T = 05:30) (20:30)


Air Sample Contact Rate: 100. mR/hr / cf sample
 Floor Contamination: 3000. cpm/100cm2
 Wall and Equipment Contamination: 300. cpm/100cm2
 Personnel Contamination Rate: 24. cpm/100cm2 per minute

Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	5.9	53.	B	5.9	53.	C	8.3	55.
D	5.7	53.	E	6.6	54.	F	8.3	55.
G	8.3	55.	H	9.2	56.	I	6.0	53.
J	32.	79.	K	12.	59.			

ARM Readings (mR/hr) at (T = 05:30) (20:30)

1-RE-01 5.8 1-RE-02 8.4 1-RE-03 11.



UNIT 1 REACTOR EL 177

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 177' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: 93. mR/hr / cf sample
 Floor Contamination: 5800. cpm/100cm²
 Wall and Equipment Contamination: 580. cpm/100cm²
 Personnel Contamination Rate: 19. cpm/100cm² per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	8.6	85.	B	8.6	85.	C	12.	89.
D	8.3	85.	E	9.6	86.	F	12.	89.
G	12.	89.	H	13.	90.	I	8.6	85.
J	34.	110.	K	17.	93.			

ARM Readings (mR/hr) at (T = 06:00) (21:00)

1-RE-01 8.4 1-RE-02 12. 1-RE-03 15.

Contamination and Airborne Survey Data at (T = 06:30) (21:30)


Air Sample Contact Rate: 79. mR/hr / cf sample
 Floor Contamination: 7600. cpm/100cm²
 Wall and Equipment Contamination: 760. cpm/100cm²
 Personnel Contamination Rate: 14. cpm/100cm² per minute

Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	10.	110.	B	10.	110.	C	14.	110.
D	10.	110.	E	11.	110.	F	14.	110.
G	14.	110.	H	16.	110.	I	10.	110.
J	35.	130.	K	20.	120.			

ARM Readings (mR/hr) at (T = 06:30) (21:30)

1-RE-01 10. 1-RE-02 15. 1-RE-03 18.



UNIT 1 REACTOR EL 177

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 177' Elev.

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: 71. mR/hr / cf sample
 Floor Contamination: 8700. cpm/100cm2
 Wall and Equipment Contamination: 870. cpm/100cm2
 Personnel Contamination Rate: 11. cpm/100cm2 per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	11.	130.	B	11.	130.	C	16.	130.
D	11.	130.	E	13.	130.	F	16.	130.
G	16.	130.	H	18.	130.	I	11.	130.
J	35.	150.	K	22.	140.			

ARM Readings (mR/hr) at (T = 07:00) (22:00)

1-RE-01 11. 1-RE-02 16. 1-RE-03 20.

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: 64. mR/hr / cf sample
 Floor Contamination: 1.0E4 cpm/100cm2
 Wall and Equipment Contamination: 1000. cpm/100cm2
 Personnel Contamination Rate: 9.5 cpm/100cm2 per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	13.	150.	B	13.	150.	C	19.	160.
D	13.	150.	E	15.	160.	F	19.	160.
G	19.	160.	H	21.	160.	I	13.	150.
J	36.	180.	K	25.	170.			

ARM Readings (mR/hr) at (T = 08:00) (23:00)

1-RE-01 13. 1-RE-02 19. 1-RE-03 23.



● ARM DETECTOR
 △ ARM READOUT

UNIT 1 REACTOR EL-201'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 201' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 00:00) (15:00)

1-RE-06 4.0 1-RE-08 10. 1-RE-09 30.

Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 01:00) (16:00)

1-RE-06 4.0 1-RE-08 10. 1-RE-09 30.



● ARM DETECTOR
△ ARM READOUT

UNIT 1 REACTOR EL 201'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 201' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 02:00) (17:00)

1-RE-06 4.0 1-RE-08 10. 1-RE-09 30.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 03:00) (18:00)

1-RE-06 4.0 1-RE-08 10. 1-RE-09 30.



● ARM DETECTOR
 △ ARM READOUT

UNIT 1 REACTOR EL 201'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 201' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	1.2	1.2
G	< 0.1	< 0.1						

Contamination and Airborne Survey Data at (T = 03:15) (18:15)


Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 11. cpm/100cm²
 Wall and Equipment Contamination: 1.1 cpm/100cm²
 Personnel Contamination Rate: 0.6 cpm/100cm² per minute

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.1	0.5	B	0.1	0.5	C	0.1	0.5
D	0.1	0.5	E	0.1	0.5	F	97.	97.
G	8.4	8.7						

ARM Readings (mR/hr) at (T = 03:15) (18:15)

1-RE-06 4.0 1-RE-08 46. 1-RE-09 32.



● ARM DETECTOR
 △ ARM READOUT

UNIT 1 REACTOR EL 201'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 201' Elev.

Contamination and Airborne Survey Data at (T = 03:15) (18:15)

Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 11. cpm/100cm2
 Wall and Equipment Contamination: 1.1 cpm/100cm2
 Personnel Contamination Rate: 0.6 cpm/100cm2 per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.2	0.8	B	0.2	0.8	C	0.2	0.8
D	0.2	0.8	E	0.2	0.8	F	100.	100.
G	10.	11.						

ARM Readings (mR/hr) at (T = 03:25) (18:25)

1-RE-06 4.1 1-RE-08 110. 1-RE-09 37.

Contamination and Airborne Survey Data at (T = 03:30) (18:30)


Air Sample Contact Rate: 1.7E4 cpm/cf sample
 Floor Contamination: 66. cpm/100cm2
 Wall and Equipment Contamination: 6.6 cpm/100cm2
 Personnel Contamination Rate: 1.0 cpm/100cm2 per minute

Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.3	1.2	B	0.3	1.2	C	0.3	1.2
D	0.3	1.2	E	0.3	1.2	F	71.	72.
G	7.2	8.1						

ARM Readings (mR/hr) at (T = 03:40) (18:40)

1-RE-06 4.1 1-RE-08 71. 1-RE-09 35.



● ARM DETECTOR
 △ ARM READOUT

UNIT 1 REACTOR EL. 201'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 201' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: 1.5E4 cpm/cf sample
 Floor Contamination: 170. cpm/100cm2
 Wall and Equipment Contamination: 17. cpm/100cm2
 Personnel Contamination Rate: 0.8 cpm/100cm2 per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.3	1.5	B	0.3	1.5	C	0.3	1.5
D	0.3	1.6	E	0.3	1.6	F	47.	48.
G	4.9	6.2						

ARM Readings (mR/hr) at (T = 04:00) (19:00)

1-RE-06 4.1 1-RE-08 50. 1-RE-09 33.

Contamination and Airborne Survey Data at (T = 04:15) (19:15)


Air Sample Contact Rate: 1.3E4 cpm/cf sample
 Floor Contamination: 210. cpm/100cm2
 Wall and Equipment Contamination: 21. cpm/100cm2
 Personnel Contamination Rate: 0.7 cpm/100cm2 per minute

Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.3	1.7	B	0.3	1.7	C	0.3	1.7
D	0.3	1.7	E	0.3	1.7	F	39.	40.
G	4.1	5.5						

ARM Readings (mR/hr) at (T = 04:15) (19:15)

1-RE-06 4.1 1-RE-08 43. 1-RE-09 33.



● ARM DETECTOR
 △ ARM READOUT

UNIT 1 REACTOR EL 201'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 201' Elev.

Contamination and Airborne Survey Data at (T = 04:30) (19:30)

Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 230. cpm/100cm2
 Wall and Equipment Contamination: 23. cpm/100cm2
 Personnel Contamination Rate: 0.5 cpm/100cm2 per minute

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.3	1.6	B	0.3	1.7	C	0.3	1.7
D	0.3	1.7	E	0.3	1.7	F	33.	34.
G	3.5	4.9						

ARM Readings (mR/hr) at (T = 04:30) (19:30)

1-RE-06 4.1 1-RE-08 38. 1-RE-09 32.

Contamination and Airborne Survey Data at (T = 04:45) (19:45)


Air Sample Contact Rate: 7900. cpm/cf sample
 Floor Contamination: 240. cpm/100cm2
 Wall and Equipment Contamination: 24. cpm/100cm2
 Personnel Contamination Rate: 0.4 cpm/100cm2 per minute

Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.3	1.6	B	0.3	1.6	C	0.3	1.7
D	0.3	1.7	E	0.3	1.7	F	28.	30.
G	3.0	4.4						

ARM Readings (mR/hr) at (T = 04:45) (19:45)

1-RE-06 4.1 1-RE-08 34. 1-RE-09 32.



● ARM DETECTOR
 △ ARM READOUT

UNIT 1 REACTOR EL 201'

§

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 201' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: 18. mR/hr / cf sample
 Floor Contamination: 300. cpm/100cm2
 Wall and Equipment Contamination: 30. cpm/100cm2
 Personnel Contamination Rate: 4.6 cpm/100cm2 per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.1	6.1	B	1.1	6.1	C	1.1	6.1
D	1.2	6.1	E	1.2	6.1	F	26.	31.
G	3.7	8.7						

ARM Readings (mR/hr) at (T = 05:00) (20:00)

1-RE-06 4.4 1-RE-08 32. 1-RE-09 33.

Contamination and Airborne Survey Data at (T = 05:30) (20:30)


Air Sample Contact Rate: 100. mR/hr / cf sample
 Floor Contamination: 3000. cpm/100cm2
 Wall and Equipment Contamination: 300. cpm/100cm2
 Personnel Contamination Rate: 24. cpm/100cm2 per minute

Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	9.2	56.	B	9.2	56.	C	9.2	56.
D	9.4	56.	E	9.4	56.	F	30.	77.
G	13.	60.						

ARM Readings (mR/hr) at (T = 05:30) (20:30)

1-RE-06 7.6 1-RE-08 37. 1-RE-09 42.



UNIT 1 REACTOR EL 201'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 201' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: 93. mR/hr / cf sample
 Floor Contamination: 5800. cpm/100cm2
 Wall and Equipment Contamination: 580. cpm/100cm2
 Personnel Contamination Rate: 19. cpm/100cm2 per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	13.	90.	B	13.	90.	C	13.	90.
D	14.	90.	E	14.	90.	F	32.	110.
G	18.	94.						

ARM Readings (mR/hr) at (T = 06:00) (21:00)

1-RE-06 9.2 1-RE-08 39. 1-RE-09 47.

Contamination and Airborne Survey Data at (T = 06:30) (21:30)


Air Sample Contact Rate: 79. mR/hr / cf sample
 Floor Contamination: 7600. cpm/100cm2
 Wall and Equipment Contamination: 760. cpm/100cm2
 Personnel Contamination Rate: 14. cpm/100cm2 per minute

Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	16.	110.	B	16.	110.	C	16.	110.
D	16.	110.	E	16.	110.	F	33.	130.
G	20.	120.						

ARM Readings (mR/hr) at (T = 06:30) (21:30)

1-RE-06 10. 1-RE-08 41. 1-RE-09 50.



● ARM DETECTOR
 △ ARM READOUT

UNIT 1 REACTOR EL 201'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 201' Elev.

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: 71. mR/hr / cf sample
 Floor Contamination: 8700. cpm/100cm²
 Wall and Equipment Contamination: 870. cpm/100cm²
 Personnel Contamination Rate: 11. cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	18.	130.	B	18.	130.	C	18.	130.
D	18.	130.	E	18.	130.	F	34.	150.
G	23.	140.						

ARM Readings (mR/hr) at (T = 07:00) (22:00)

1-RE-06 11. 1-RE-08 42. 1-RE-09 52.

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: 64. mR/hr / cf sample
 Floor Contamination: 1.0E4 cpm/100cm²
 Wall and Equipment Contamination: 1000. cpm/100cm²
 Personnel Contamination Rate: 9.5 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	21.	160.	B	21.	160.	C	21.	160.
D	21.	160.	E	21.	160.	F	35.	180.
G	26.	170.						

ARM Readings (mR/hr) at (T = 08:00) (23:00)

1-RE-06 12. 1-RE-08 43. 1-RE-09 55.



● ARM DETECTOR
△ ARM READOUT

UNIT 1 REACTOR EL. 217'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1	I	< 0.1	< 0.1
J	< 0.1	< 0.1	K	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 00:00) (15:00)

1-RE-10 0.10 1-RE-11 0.10 0-RF-50 0.10

Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1	I	< 0.1	< 0.1
J	< 0.1	< 0.1	K	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 01:00) (16:00)

1-RE-10 0.10 1-RE-11 0.10 0-RE-50 0.10



● ARM DETECTOR
△ ARM READOUT

UNIT 1 REACTOR EL 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1	I	< 0.1	< 0.1
J	< 0.1	< 0.1	K	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 02:00) (17:00)

1-RE-10 0.10 1-RE-11 0.10 0-RE-50 0.10

Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1	I	< 0.1	< 0.1
J	< 0.1	< 0.1	K	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:00) (18:00)

1-RE-10 0.10 1-RE-11 0.10 0-RE-50 0.10



● ARM DETECTOR
△ ARM READOUT

UNIT 1 REACTOR EL 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1	I	2.0	2.0
J	< 0.1	< 0.1	K	< 0.1	0.1			

Contamination and Airborne Survey Data at (T = 03:15) (18:15)


Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 11. cpm/100cm²
 Wall and Equipment Contamination: 1.1 cpm/100cm²
 Personnel Contamination Rate: 0.6 cpm/100cm² per minute

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.2	0.6	B	0.2	0.6	C	0.2	0.6
D	0.2	0.6	E	0.2	0.6	F	0.2	0.6
G	0.6	0.9	H	7.0	7.3	I	160.	160.
J	3.6	4.0	K	6.0	6.4			

ARM Readings (mR/hr) at (T = 03:15) (18:15)

1-RE-10 1.2 1-RE-11 2.8 0-RE-50 0.10



● ARM DETECTOR
△ ARM READOUT

UNIT 1 REACTOR EL 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 03:15) (18:15)

Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 11. cpm/100cm²
 Wall and Equipment Contamination: 1.1 cpm/100cm²
 Personnel Contamination Rate: 0.6 cpm/100cm² per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.3	0.9	B	0.3	0.9	C	0.3	0.9
D	0.3	1.0	E	0.4	1.0	F	0.4	1.0
G	0.7	1.3	H	8.3	9.0	I	160.	160.
J	4.0	4.6	K	6.3	6.9			

ARM Readings (mR/hr) at (T = 03:25) (18:25)

1-RE-10 3.2 1-RE-11 4.5 0-RE-50 0.10

Contamination and Airborne Survey Data at (T = 03:30) (18:30)


Air Sample Contact Rate: 1.7E4 cpm/cf sample
 Floor Contamination: 66. cpm/100cm²
 Wall and Equipment Contamination: 6.6 cpm/100cm²
 Personnel Contamination Rate: 1.0 cpm/100cm² per minute

Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.4	1.3	B	0.3	1.2	C	0.4	1.3
D	0.4	1.3	E	0.5	1.4	F	0.5	1.4
G	0.4	1.3	H	5.9	6.8	I	110.	120.
J	2.9	3.8	K	4.6	5.5			

ARM Readings (mR/hr) at (T = 03:40) (18:40)

1-RE-10 2.2 1-RE-11 3.9 0-RE-50 0.11



● ARM DETECTOR
 △ ARM READOUT

UNIT 1 REACTOR EL. 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: 1.5E4 cpm/cf sample
 Floor Contamination: 170. cpm/100cm²
 Wall and Equipment Contamination: 17. cpm/100cm²
 Personnel Contamination Rate: 0.8 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.5	1.7	B	0.4	1.6	C	0.5	1.7
D	0.5	1.7	E	0.5	1.8	F	0.5	1.8
G	0.5	1.7	H	4.1	5.4	I	76.	77.
J	2.1	3.3	K	3.2	4.5			

ARM Readings (mR/hr) at (T = 04:00) (19:00)

1-RE-10 1.7 1-RE-11 3.4 0-RE-50 0.12

Contamination and Airborne Survey Data at (T = 04:15) (19:15)


Air Sample Contact Rate: 1.3E4 cpm/cf sample
 Floor Contamination: 210. cpm/100cm²
 Wall and Equipment Contamination: 21. cpm/100cm²
 Personnel Contamination Rate: 0.7 cpm/100cm² per minute

Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.5	1.9	B	0.4	1.8	C	0.5	1.9
D	0.5	1.9	E	0.6	1.9	F	0.5	1.9
G	0.5	1.9	H	3.5	4.9	I	62.	64.
J	1.8	3.2	K	2.7	4.1			

ARM Readings (mR/hr) at (T = 04:15) (19:15)

1-RE-10 1.5 1-RE-11 3.1 0-RE-50 0.12



UNIT 1 REACTOR EL 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 04:30) (19:30)

Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 230. cpm/100cm²
 Wall and Equipment Contamination: 23. cpm/100cm²
 Personnel Contamination Rate: 0.5 cpm/100cm² per minute

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.5	1.8	B	0.4	1.7	C	0.5	1.8
D	0.5	1.8	E	0.5	1.9	F	0.5	1.9
G	0.5	1.8	H	3.0	4.3	I	53.	54.
J	1.6	2.9	K	2.3	3.7			

ARM Readings (mR/hr) at (T = 04:30) (19:30)

1-RE-10 1.3 1-RE-11 2.8 0-RE-50 0.12

Contamination and Airborne Survey Data at (T = 04:45) (19:45)


Air Sample Contact Rate: 7900. cpm/cf sample
 Floor Contamination: 240. cpm/100cm²
 Wall and Equipment Contamination: 24. cpm/100cm²
 Personnel Contamination Rate: 0.4 cpm/100cm² per minute

Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.4	1.8	B	0.4	1.7	C	0.4	1.8
D	0.4	1.8	E	0.5	1.9	F	0.5	1.9
G	0.4	1.8	H	2.6	4.0	I	45.	46.
J	1.4	2.7	K	2.0	3.4			

ARM Readings (mR/hr) at (T = 04:45) (19:45)

1-RE-10 1.2 1-RE-11 2.5 0-RE-50 0.12



UNIT 1 REACTOR EL 217

● ARM DETECTOR
△ ARM READOUT

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: 18. mR/hr / cf sample
 Floor Contamination: 300. cpm/100cm²
 Wall and Equipment Contamination: 30. cpm/100cm²
 Personnel Contamination Rate: 4.6 cpm/100cm² per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.8	6.8	B	1.5	6.5	C	1.8	6.8
D	1.8	6.8	E	2.0	6.9	F	2.0	6.9
G	1.8	6.8	H	3.7	8.7	I	41.	46.
J	2.3	7.3	K	2.9	7.9			

ARM Readings (mR/hr) at (T = 05:00) (20:00)

1-RE-10 2.1 1-RE-11 3.7 0-RE-50 0.19

Contamination and Airborne Survey Data at (T = 05:30) (20:30)


Air Sample Contact Rate: 100. mR/hr / cf sample
 Floor Contamination: 3000. cpm/100cm²
 Wall and Equipment Contamination: 300. cpm/100cm²
 Personnel Contamination Rate: 24. cpm/100cm² per minute

Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	15.	62.	B	12.	59.	C	15.	62.
D	15.	62.	E	16.	63.	F	16.	63.
G	15.	62.	H	16.	63.	I	43.	90.
J	12.	59.	K	13.	60.			

ARM Readings (mR/hr) at (T = 05:30) (20:30)

1-RE-10 12. 1-RE-11 16. 0-RE-50 0.92



UNIT 1 REACTOR EL. 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: 93. mR/hr / cf sample
 Floor Contamination: 5800. cpm/100cm²
 Wall and Equipment Contamination: 580. cpm/100cm²
 Personnel Contamination Rate: 19. cpm/100cm² per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	21.	98.	B	18.	94.	C	21.	98.
D	21.	98.	E	23.	100.	F	23.	100.
G	21.	98.	H	23.	99.	I	43.	120.
J	17.	94.	K	18.	94.			

ARM Readings (mR/hr) at (T = 06:00) (21:00)

1-RE-10 17. 1-RE-11 23. 0-RE-50 1.3

Contamination and Airborne Survey Data at (T = 06:30) (21:30)


Air Sample Contact Rate: 79. mR/hr / cf sample
 Floor Contamination: 7600. cpm/100cm²
 Wall and Equipment Contamination: 760. cpm/100cm²
 Personnel Contamination Rate: 14. cpm/100cm² per minute

Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	26.	120.	B	21.	120.	C	26.	120.
D	26.	120.	E	28.	130.	F	28.	130.
G	25.	120.	H	27.	120.	I	43.	140.
J	20.	120.	K	21.	120.			

ARM Readings (mR/hr) at (T = 06:30) (21:30)

1-RE-10 20. 1-RE-11 27. 0-RE-50 1.5



● ARM DETECTOR
△ ARM READOUT

UNIT 1 REACTOR EL. 217'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: 71. mR/hr / cf sample
 Floor Contamination: 8700. cpm/100cm²
 Wall and Equipment Contamination: 870. cpm/100cm²
 Personnel Contamination Rate: 11. cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	29.	140.	B	24.	140.	C	29.	140.
D	29.	140.	E	31.	150.	F	31.	150.
G	29.	140.	H	30.	140.	I	43.	160.
J	23.	140.	K	23.	140.			

ARM Readings (mR/hr) at (T = 07:00) (22:00)

1-RE-10 23. 1-RE-11 30. 0-RE-50 1.7

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: 64. mR/hr / cf sample
 Floor Contamination: 1.0E4 cpm/100cm²
 Wall and Equipment Contamination: 1000. cpm/100cm²
 Personnel Contamination Rate: 9.5 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	33.	170.	B	27.	170.	C	33.	170.
D	33.	170.	E	36.	180.	F	36.	180.
G	33.	170.	H	34.	180.	I	44.	190.
J	26.	170.	K	26.	170.			

ARM Readings (mR/hr) at (T = 08:00) (23:00)

1-RE-10 26. 1-RE-11 34. 0-RE-50 1.9



UNIT 1 REACTOR EL. 253

△ ARM READOUT
● ARM DETECTOR

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 00:00) (15:00)

1-RE-14	1000.	1-RE-15	1.5	1-RE-16	1.5
1-RE-17	10.	1-RE-18	1.0		

Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 01:00) (16:00)

1-RE-14	1000.	1-RE-15	1.5	1-RE-16	1.5
1-RE-17	10.	1-RE-18	1.0		



△ ARM READOUT
● ARM DETECTOR

UNIT 1 REACTOR EL. 253

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 02:00) (17:00)

1-RE-14	1100.	1-RE-15	1.5	1-RE-16	1.5
1-RE-17	10.	1-RE-18	1.0		

Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:00) (18:00)

1-RE-14	1100.	1-RE-15	1.5	1-RE-16	1.5
1-RE-17	10.	1-RE-18	1.0		



△ ARM READOUT
● ARM DETECTOR

UNIT 1 REACTOR EL. 253

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1			

Contamination and Airborne Survey Data at (T = 03:15) (18:15)


Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 11. cpm/100cm²
 Wall and Equipment Contamination: 1.1 cpm/100cm²
 Personnel Contamination Rate: 0.6 cpm/100cm² per minute

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	3.0	3.4	B	5.3	5.7	C	3.1	3.4
D	5.7	6.1	E	4.4	4.8	F	0.5	0.9
G	1.0	1.4	H	14.	15.			

ARM Readings (mR/hr) at (T = 03:15) (18:15)

1-RE-14 5.3E4 1-RE-15 1.8 1-RE-16 3.9
 1-RE-17 11. 1-RE-18 12.



△ ARM READOUT
● ARM DETECTOR

UNIT 1 REACTOR EL. 253

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 03:15) (18:15)

Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 11. cpm/100cm2
 Wall and Equipment Contamination: 1.1 cpm/100cm2
 Personnel Contamination Rate: 0.6 cpm/100cm2 per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	3.2	3.9	B	5.6	6.2	C	3.3	3.9
D	6.0	6.6	E	4.7	5.3	F	0.6	1.2
G	1.1	1.8	H	15.	15.			

ARM Readings (mR/hr) at (T = 03:25) (18:25)

1-RE-14 1.0E5 1-RE-15 2.2 1-RE-16 7.3
 1-RE-17 11. 1-RE-18 19.

Contamination and Airborne Survey Data at (T = 03:30) (18:30)


Air Sample Contact Rate: 1.7E4 cpm/cf sample
 Floor Contamination: 66. cpm/100cm2
 Wall and Equipment Contamination: 6.6 cpm/100cm2
 Personnel Contamination Rate: 1.0 cpm/100cm2 per minute

Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	2.8	3.7	B	4.9	5.8	C	2.7	3.6
D	4.4	5.3	E	3.5	4.4	F	0.7	1.6
G	1.1	2.0	H	13.	14.			

ARM Readings (mR/hr) at (T = 03:40) (18:40)

1-RE-14 1.8E5 1-RE-15 2.3 1-RE-16 5.7
 1-RE-17 11. 1-RE-18 16.



△ ARM READOUT
● ARM DETECTOR

UNIT 1 REACTOR EL. 253

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: 1.5E4 cpm/cf sample
 Floor Contamination: 170. cpm/100cm2
 Wall and Equipment Contamination: 17. cpm/100cm2
 Personnel Contamination Rate: 0.8 cpm/100cm2 per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	2.4	3.6	B	4.1	5.4	C	2.2	3.4
D	3.2	4.4	E	2.6	3.8	F	0.7	2.0
G	1.1	2.4	H	11.	12.			

ARM Readings (mR/hr) at (T = 04:00) (19:00)

1-RE-14 2.2E5 1-RE-15 2.3 1-RE-16 4.7
 1-RE-17 11. 1-RE-18 14.

Contamination and Airborne Survey Data at (T = 04:15) (19:15)


Air Sample Contact Rate: 1.3E4 cpm/cf sample
 Floor Contamination: 210. cpm/100cm2
 Wall and Equipment Contamination: 21. cpm/100cm2
 Personnel Contamination Rate: 0.7 cpm/100cm2 per minute

Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	3.2	4.6	B	4.1	5.5	C	4.5	5.8
D	2.9	4.2	E	2.3	3.7	F	0.7	2.1
G	1.1	2.4	H	9.6	11.			

ARM Readings (mR/hr) at (T = 04:15) (19:15)

1-RE-14 2.4E5 1-RE-15 2.3 1-RE-16 4.8
 1-RE-17 11. 1-RE-18 12.



△ ARM READOUT
● ARM DETECTOR

UNIT 1 REACTOR EL. 253

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 253' Flev.

Contamination and Airborne Survey Data at (T = 04:30) (19:30)

Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 230. cpm/100cm2
 Wall and Equipment Contamination: 23. cpm/100cm2
 Personnel Contamination Rate: 0.5 cpm/100cm2 per minute

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	2.8	4.2	B	3.7	5.0	C	3.8	5.2
D	2.5	3.8	E	2.0	3.4	F	0.7	2.0
G	1.0	2.3	H	8.6	9.9			

ARM Readings (mR/hr) at (T = 04:30) (19:30)

1-RE-14 2.5E5 1-RE-15 2.2 1-RE-16 4.3
 1-RE-17 11. 1-RE-18 11.

Contamination and Airborne Survey Data at (T = 04:45) (19:45)


Air Sample Contact Rate: 7900. cpm/cf sample
 Floor Contamination: 240. cpm/100cm2
 Wall and Equipment Contamination: 24. cpm/100cm2
 Personnel Contamination Rate: 0.4 cpm/100cm2 per minute

Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	2.5	3.9	B	3.3	4.6	C	3.4	4.7
D	2.2	3.5	E	1.8	3.1	F	0.6	2.0
G	0.9	2.3	H	7.7	9.1			

ARM Readings (mR/hr) at (T = 04:45) (19:45)

1-RE-14 2.6E5 1-RE-15 2.2 1-RE-16 4.0
 1-RE-17 11. 1-RE-18 9.9



△ ARM READOUT
● ARM DETECTOR

UNIT 1 REACTOR EL. 253

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: 18. mR/hr / cf sample
 Floor Contamination: 300. cpm/100cm2
 Wall and Equipment Contamination: 30. cpm/100cm2
 Personnel Contamination Rate: 4.6 cpm/100cm2 per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	3.8	8.8	B	4.1	9.1	C	4.5	9.5
D	3.5	8.5	E	3.3	8.2	F	2.1	7.1
G	2.5	7.5	H	8.5	13.			

ARM Readings (mR/hr) at (T = 05:00) (20:00)

1-RE-14 OSH 1-RE-15 3.7 1-RE-16 5.3
 1-RE-17 11. 1-RE-18 10.

Contamination and Airborne Survey Data at (T = 05:30) (20:30)


Air Sample Contact Rate: 100. mR/hr / cf sample
 Floor Contamination: 3000. cpm/100cm2
 Wall and Equipment Contamination: 300. cpm/100cm2
 Personnel Contamination Rate: 24. cpm/100cm2 per minute

Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	18.	65.	B	14.	61.	C	18.	65.
D	17.	64.	E	18.	65.	F	16.	63.
G	18.	65.	H	22.	69.			

ARM Readings (mR/hr) at (T = 05:30) (20:30)

1-RE-14 OSH 1-RE-15 18. 1-RE-16 19.
 1-RE-17 15. 1-RE-18 19.



△ ARM READOUT
● ARM DETECTOR

UNIT 1 REACTOR EL. 253

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: 93. mR/hr / cf sample
 Floor Contamination: 5800. cpm/100cm2
 Wall and Equipment Contamination: 580. cpm/100cm2
 Personnel Contamination Rate: 19. cpm/100cm2 per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	25.	100.	B	19.	96.	C	25.	100.
D	25.	100.	E	26.	100.	F	24.	100.
G	26.	100.	H	28.	100.			

ARM Readings (mR/hr) at (T = 06:00) (21:00)

1-RE-14 OSH 1-RE-15 25. 1-RE-16 26.
 1-RE-17 17. 1-RE-18 23.

Contamination and Airborne Survey Data at (T = 06:30) (21:30)


Air Sample Contact Rate: 79. mR/hr / cf sample
 Floor Contamination: 7600. cpm/100cm2
 Wall and Equipment Contamination: 760. cpm/100cm2
 Personnel Contamination Rate: 14. cpm/100cm2 per minute

Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	30.	130.	B	22.	120.	C	30.	130.
D	29.	130.	E	31.	130.	F	28.	130.
G	31.	130.	H	32.	130.			

ARM Readings (mR/hr) at (T = 06:30) (21:30)

1-RE-14 OSH 1-RE-15 30. 1-RE-16 31.
 1-RE-17 18. 1-RE-18 26.



△ ARM READOUT
● ARM DETECTOR

UNIT 1 REACTOR EL 253

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: 71. mR/hr / cf sample
 Floor Contamination: 8700. cpm/100cm²
 Wall and Equipment Contamination: 870. cpm/100cm²
 Personnel Contamination Rate: 11. cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	33.	150.	B	25.	140.	C	33.	150.
D	33.	150.	E	35.	150.	F	32.	150.
G	34.	150.	H	35.	150.			

ARM Readings (mR/hr) at (T = 07:00) (22:00)

1-RE-14 OSH 1-RE-15 33. 1-RE-16 34.
 1-RE-17 19. 1-RE-18 28.

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: 64. mR/hr / cf sample
 Floor Contamination: 1.0E4 cpm/100cm²
 Wall and Equipment Contamination: 1000. cpm/100cm²
 Personnel Contamination Rate: 9.5 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	37.	180.	B	28.	170.	C	38.	180.
D	37.	180.	E	40.	180.	F	36.	180.
G	40.	180.	H	39.	180.			

ARM Readings (mR/hr) at (T = 08:00) (23:00)

1-RE-14 OSH 1-RE-15 38. 1-RE-16 39.
 1-RE-17 21. 1-RE-18 31.



UNIT 1 REACTOR EL. 283'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA

----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 283' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 00:00) (15:00)

1-RE-21 0.50 1-RE-22 0.10 1-RE-23 0.10
 1-RE-24 0.10

 Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 01:00) (16:00)

1-RE-21 0.50 1-RE-22 0.10 1-RE-23 0.10
 1-RE-24 0.10



UNIT 1 REACTOR EL. 283'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA

----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 283' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 02:00) (17:00)

1-RE-21 0.50 1-RE-22 0.10 1-RE-23 0.10
 1-RE-24 0.10

 Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 03:00) (18:00)

1-RE-21 0.50 1-RE-22 0.10 1-RE-23 0.10
 1-RE-24 0.10



UNIT 1 REACTOR EL. 283'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 283' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	0.4	0.4	C	1.6	1.6
D	0.2	0.2	E	0.6	0.6	F	< 0.1	< 0.1

Contamination and Airborne Survey Data at (T = 03:15) (18:15)


Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 11. cpm/100cm²
 Wall and Equipment Contamination: 1.1 cpm/100cm²
 Personnel Contamination Rate: 0.6 cpm/100cm² per minute

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.8	1.2	B	11.	11.	C	10.	11.
D	9.0	9.4	E	7.3	7.6	F	0.2	0.6

ARM Readings (mR/hr) at (T = 03:15) (18:15)

1-RE-21 0.83 1-RE-22 0.20 1-RE-23 0.19
 1-RE-24 27.



UNIT 1 REACTOR EL. 283'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 283' Elev.

Contamination and Airborne Survey Data at (T = 03:15) (18:15)

Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 11. cpm/100cm²
 Wall and Equipment Contamination: 1.1 cpm/100cm²
 Personnel Contamination Rate: 0.6 cpm/100cm² per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.0	1.6	B	12.	13.	C	16.	16.
D	9.6	10.	E	9.1	9.7	F	0.4	1.0

ARM Readings (mR/hr) at (T = 03:25) (18:25)

1-RE-21 1.3 1-RE-22 0.42 1-RE-23 0.40
 1-RE-24 45.

 Contamination and Airborne Survey Data at (T = 03:30) (18:30)


Air Sample Contact Rate: 1.7E4 cpm/cf sample
 Floor Contamination: 66. cpm/100cm²
 Wall and Equipment Contamination: 6.6 cpm/100cm²
 Personnel Contamination Rate: 1.0 cpm/100cm² per minute

Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.8	1.7	B	12.	13.	C	21.	22.
D	7.4	8.3	E	9.4	10.	F	0.5	1.4

ARM Readings (mR/hr) at (T = 03:40) (18:40)

1-RE-21 1.8 1-RE-22 0.61 1-RE-23 0.58
 1-RE-24 43.



UNIT 1 REACTOR EL. 283'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 283' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: 1.5E4 cpm/cf sample
 Floor Contamination: 170. cpm/100cm²
 Wall and Equipment Contamination: 17. cpm/100cm²
 Personnel Contamination Rate: 0.8 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.7	1.9	B	12.	13.	C	25.	26.
D	5.6	6.8	E	9.2	10.	F	0.5	1.8

ARM Readings (mR/hr) at (T = 04:00) (19:00)

1-RE-21 1.9 1-RE-22 0.71 1-RE-23 0.67
 1-RE-24 41.

Contamination and Airborne Survey Data at (T = 04:15) (19:15)


Air Sample Contact Rate: 1.3E4 cpm/cf sample
 Floor Contamination: 210. cpm/100cm²
 Wall and Equipment Contamination: 21. cpm/100cm²
 Personnel Contamination Rate: 0.7 cpm/100cm² per minute

Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.6	2.0	B	11.	13.	C	26.	27.
D	5.3	6.6	E	10.	12.	F	0.7	2.0

ARM Readings (mR/hr) at (T = 04:15) (19:15)

1-RE-21 1.9 1-RE-22 0.72 1-RE-23 0.68
 1-RE-24 38.



UNIT 1 REACTOR EL. 283'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 283' Elev.

Contamination and Airborne Survey Data at (T = 04:30) (19:30)

Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 230. cpm/100cm²
 Wall and Equipment Contamination: 23. cpm/100cm²
 Personnel Contamination Rate: 0.5 cpm/100cm² per minute

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.6	1.9	B	10.	11.	C	23.	24.
D	4.5	5.9	E	8.6	10.	F	0.6	2.0

ARM Readings (mR/hr) at (T = 04:30) (19:30)

1-RE-21 1.7 1-RE-22 0.66 1-RE-23 0.6²
 1-RE-24 34.

Contamination and Airborne Survey Data at (T = 04:45) (19:45)


Air Sample Contact Rate: 7900. cpm/cf sample
 Floor Contamination: 240. cpm/100cm²
 Wall and Equipment Contamination: 24. cpm/100cm²
 Personnel Contamination Rate: 0.4 cpm/100cm² per minute

Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.5	1.9	B	8.8	10.	C	20.	21.
D	3.9	5.3	E	7.3	8.7	F	0.6	1.9

ARM Readings (mR/hr) at (T = 04:45) (19:45)

1-RE-21 1.6 1-RE-22 0.63 1-RE-23 0.61
 1-RE-24 30.



UNIT 1 REACTOR EL. 283'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 283' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: 18. mR/hr / cf sample
 Floor Contamination: 300. cpm/100cm2
 Wall and Equipment Contamination: 30. cpm/100cm2
 Personnel Contamination Rate: 4.6 cpm/100cm2 per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.5	6.5	B	8.9	14.	C	19.	24.
D	5.1	10.	E	7.9	13.	F	2.0	7.0

ARM Readings (mR/hr) at (T = 05:00) (20:00)

1-RE-21 3.0 1-RE-22 2.2 1-RE-23 2.2
 1-RE-24 28.

 Contamination and Airborne Survey Data at (T = 05:30) (20:30)


Air Sample Contact Rate: 100. mR/hr / cf sample
 Floor Contamination: 3000. cpm/100cm2
 Wall and Equipment Contamination: 300. cpm/100cm2
 Personnel Contamination Rate: 24. cpm/100cm2 per minute

Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	11.	58.	B	17.	64.	C	31.	78.
D	19.	66.	E	21.	68.	F	16.	63.

ARM Readings (mR/hr) at (T = 05:30) (20:30)

1-RE-21 17. 1-RE-22 17. 1-RE-23 17.
 1-RE-24 33.



UNIT 1 REACTOR EL. 283'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 283' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: 93. mR/hr / cf sample
 Floor Contamination: 5800. cpm/100cm2
 Wall and Equipment Contamination: 580. cpm/100cm2
 Personnel Contamination Rate: 19. cpm/100cm2 per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	16.	93.	B	21.	98.	C	36.	110.
D	26.	100.	E	28.	100.	F	23.	100.

ARM Readings (mR/hr) at (T = 06:00) (21:00)

1-RE-21 24. 1-RE-22 24. 1-RE-23 24.
 1-RE-24 35.

Contamination and Airborne Survey Data at (T = 06:30) (21:30)


Air Sample Contact Rate: 79. mR/hr / cf sample
 Floor Contamination: 7600. cpm/100cm2
 Wall and Equipment Contamination: 760. cpm/100cm2
 Personnel Contamination Rate: 14. cpm/100cm2 per minute

Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	19.	120.	B	24.	120.	C	39.	140.
D	31.	130.	E	32.	130.	F	28.	130.

ARM Readings (mR/hr) at (T = 06:30) (21:30)

1-RE-21 29. 1-RE-22 29. 1-RE-23 29.
 1-RE-24 36.



UNIT 1 REACTOR EL. 283'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 283' Elev.

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: 71. mR/hr / cf sample
 Floor Contamination: 8700. cpm/100cm²
 Wall and Equipment Contamination: 870. cpm/100cm²
 Personnel Contamination Rate: 11. cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	21.	140.	B	26.	140.	C	42.	160.
D	34.	150.	E	36.	150.	F	31.	150.

ARM Readings (mR/hr) at (T = 07:00) (22:00)

1-RE-21 32. 1-RE-22 33. 1-RE-23 33.
 1-RE-24 37.

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: 64. mR/hr / cf sample
 Floor Contamination: 1.0E4 cpm/100cm²
 Wall and Equipment Contamination: 1000. cpm/100cm²
 Personnel Contamination Rate: 9.5 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	25.	170.	B	28.	170.	C	45.	190.
D	39.	180.	E	40.	180.	F	36.	180.

ARM Readings (mR/hr) at (T = 08:00) (23:00)

1-RE-21 37. 1-RE-22 38. 1-RE-23 38.
 1-RE-24 37.



UNIT 1 REACTOR EL. 313'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 313' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 00:00) (15:00)

1-RE-27 0.50

Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 01:00) (16:00)

1-RE-27 0.50



UNIT 1 REACTOR EL. 313

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 313' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 02:00) (17:00)

1-RE-27 0.50

Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 03:00) (18:00)

1-RE-27 0.50



UNIT 1 REACTOR EL. 313'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 313' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: 0.5 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	1.3	1.3	E	30.	30.	F	0.1	0.2
G	< 0.1	< 0.1						

Contamination and Airborne Survey Data at (T = 03:15) (18:15)


Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 11. cpm/100cm²
 Wall and Equipment Contamination: 1.1 cpm/100cm²
 Personnel Contamination Rate: 0.6 cpm/100cm² per minute

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.0	1.4	B	0.7	1.1	C	0.4	0.8
D	44.	45.	E	200.	200.	F	1.0	1.4
G	0.4	0.7						

ARM Readings (mR/hr) at (T = 03:15) (18:15)

1-RE-27 53.



UNIT 1 REACTOR EL 313'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 313' Elev.

Contamination and Airborne Survey Data at (T = 03:15) (18:15)

Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 11. cpm/100cm2
 Wall and Equipment Contamination: 1.1 cpm/100cm2
 Personnel Contamination Rate: 0.6 cpm/100cm2 per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.2	1.8	B	0.8	1.5	C	0.5	1.2
D	50.	50.	E	300.	300.	F	1.5	2.2
G	0.6	1.2						

ARM Readings (mR/hr) at (T = 03:25) (18:25)

1-RE-27 85.

Contamination and Airborne Survey Data at (T = 03:30) (18:30)


Air Sample Contact Rate: 1.7E4 cpm/cf sample
 Floor Contamination: 66. cpm/100cm2
 Wall and Equipment Contamination: 6.6 cpm/100cm2
 Personnel Contamination Rate: 1.0 cpm/100cm2 per minute

Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.2	2.1	B	0.9	1.8	C	0.6	1.5
D	49.	50.	E	400.	400.	F	2.0	2.9
G	0.7	1.6						

ARM Readings (mR/hr) at (T = 03:40) (18:40)

1-RE-27 70.



UNIT 1 REACTOR EL. 313'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA

----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 313' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: 1.5E4 cpm/cf sample
 Floor Contamination: 170. cpm/100cm²
 Wall and Equipment Contamination: 17. cpm/100cm²
 Personnel Contamination Rate: 0.8 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.2	2.4	B	0.9	2.1	C	0.7	1.9
D	47.	48.	E	470.	470.	F	2.4	3.6
G	0.8	2.1						

ARM Readings (mR/hr) at (T = 04:00) (19:00)

1-RE-27 58.

 Contamination and Airborne Survey Data at (T = 04:15) (19:15)


Air Sample Contact Rate: 1.3E4 cpm/cf sample
 Floor Contamination: 210. cpm/100cm²
 Wall and Equipment Contamination: 21. cpm/100cm²
 Personnel Contamination Rate: 0.7 cpm/100cm² per minute

Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.1	2.5	B	1.0	2.3	C	0.7	2.0
D	45.	46.	E	490.	500.	F	2.5	3.8
G	0.9	2.2						

ARM Readings (mR/hr) at (T = 04:15) (19:15)

1-RE-27 51.



UNIT 1 REACTOR EL. 313'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 313' Elev.

Contamination and Airborne Survey Data at (T = 04:30) (19:30)

Air Sample Contact Rate: 1.0E4 cpm/cf sample
 Floor Contamination: 230. cpm/100cm²
 Wall and Equipment Contamination: 23. cpm/100cm²
 Personnel Contamination Rate: 0.5 cpm/100cm² per minute

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.0	2.3	B	0.9	2.2	C	0.6	2.0
D	39.	41.	E	430.	430.	F	2.1	3.5
G	0.8	2.1						

ARM Readings (mR/hr) at (T = 04:30) (19:30)

1-RE-27 45.

Contamination and Airborne Survey Data at (T = 04:45) (19:45)


Air Sample Contact Rate: 7900. cpm/cf sample
 Floor Contamination: 240. cpm/100cm²
 Wall and Equipment Contamination: 24. cpm/100cm²
 Personnel Contamination Rate: 0.4 cpm/100cm² per minute

Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.9	2.3	B	0.8	2.2	C	0.6	1.9
D	35.	36.	E	380.	380.	F	1.9	3.3
G	0.7	2.1						

ARM Readings (mR/hr) at (T = 04:45) (19:45)

1-RE-27 41.



UNIT 1 REACTOR EL. 313'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 313' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: 18. mR/hr / cf sample
 Floor Contamination: 300. cpm/100cm²
 Wall and Equipment Contamination: 30. cpm/100cm²
 Personnel Contamination Rate: 4.6 cpm/100cm² per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	2.4	7.4	B	2.2	7.2	C	2.0	7.0
D	33.	38.	E	340.	340.	F	3.3	8.2
G	2.2	7.2						

ARM Readings (mR/hr) at (T = 05:00) (20:00)

1-RE-27 38.

Contamination and Airborne Survey Data at (T = 05:30) (20:30)


Air Sample Contact Rate: 100. mR/hr / cf sample
 Floor Contamination: 3000. cpm/100cm²
 Wall and Equipment Contamination: 300. cpm/100cm²
 Personnel Contamination Rate: 24. cpm/100cm² per minute

Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	17.	64.	B	16.	63.	C	16.	63.
D	42.	89.	E	290.	340.	F	18.	65.
G	17.	64.						

ARM Readings (mR/hr) at (T = 05:30) (20:30)

1-RE-27 47.



UNIT 1 REACTOR EL 313'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 313' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: 93. mR/hr / cf sample
 Floor Contamination: 5800. cpm/100cm2
 Wall and Equipment Contamination: 580. cpm/100cm2
 Personnel Contamination Rate: 19. cpm/100cm2 per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	25.	100.	B	23.	100.	C	23.	100.
D	45.	120.	E	260.	330.	F	25.	100.
G	25.	100.						

ARM Readings (mR/hr) at (T = 06:00) (21:00)

1-RE-27 51.

Contamination and Airborne Survey Data at (T = 06:30) (21:30)


Air Sample Contact Rate: 79. mR/hr / cf sample
 Floor Contamination: 7600. cpm/100cm2
 Wall and Equipment Contamination: 760. cpm/100cm2
 Personnel Contamination Rate: 14. cpm/100cm2 per minute

Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	30.	130.	B	28.	130.	C	28.	130.
D	47.	150.	E	230.	330.	F	30.	130.
G	29.	130.						

ARM Readings (mR/hr) at (T = 06:30) (21:30)

1-RE-27 53.



UNIT 1 REACTOR EL. 313'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 313' Elev.

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: 71. mR/hr / cf sample
 Floor Contamination: 8700. cpm/100cm²
 Wall and Equipment Contamination: 870. cpm/100cm²
 Personnel Contamination Rate: 11. cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	33.	150.	B	31.	150.	C	31.	150.
D	49.	160.	E	220.	330.	F	34.	150.
G	33.	150.						

ARM Readings (mR/hr) at (T = 07:00) (22:00)

1-RE-27 54.

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: 64. mR/hr / cf sample
 Floor Contamination: 1.0E4 cpm/100cm²
 Wall and Equipment Contamination: 1000. cpm/100cm²
 Personnel Contamination Rate: 9.5 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	38.	180.	B	36.	180.	C	36.	180.
D	51.	190.	E	190.	330.	F	38.	180.
G	38.	180.						

ARM Readings (mR/hr) at (T = 08:00) (23:00)

1-RE-27 56.



UNIT 1 REACTOR EL. 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 00:00) (15:00)

1-RE-29	1.0	1-RE-30	1.0	1-RE-31	1.0
1-RE-32	0.10	1-RE-33	1.0		

Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 01:00) (16:00)

1-RE-29	1.0	1-RE-30	1.0	1-RE-31	1.0
1-RE-32	0.10	1-RE-33	1.0		



UNIT 1 REACTOR EL. 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 02:00) (17:00)

1-RE-29	1.0	1-RE-30	1.0	1-RE-31	1.0
1-RE-32	0.10	1-RE-33	1.0		

Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:00) (18:00)

1-RE-29	1.0	1-RE-30	1.0	1-RE-31	1.0
1-RE-32	0.10	1-RE-33	1.0		



UNIT 1 REACTOR EL. 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	87.	87.	B	280.	280.	C	0.1	0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:15) (18:15)

1-RE-29	1.0	1-RE-30	1.0	1-RE-31	1.0
1-RE-32	0.10	1-RE-33	1.2		



UNIT 1 REACTOR EL. 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	89.	89.	B	290.	290.	C	0.1	0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:25) (18:25)


1-RE-29	1.0	1-RE-30	1.0	1-RE-31	1.0
1-RE-32	0.11	1-RE-33	1.4		

Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	77.	77.	B	250.	250.	C	0.2	0.2
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:40) (18:40)

1-RE-29	1.0	1-RE-30	1.0	1-RE-31	1.0
1-RE-32	0.13	1-RE-33	1.3		



UNIT 1 REACTOR EL 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: 1100. cpm/cf sample
 Floor Contamination: 6.2 cpm/100cm²
 Wall and Equipment Contamination: 0.6 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	64.	64.	B	210.	210.	C	0.2	0.3
D	< 0.1	0.2	E	< 0.1	0.1			

ARM Readings (mR/hr) at (T = 04:00) (19:00)


1-RE-29	1.1	1-RE-30	1.1	1-RE-31	1.1
1-RE-32	0.16	1-RE-33	1.3		

Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	56.	56.	B	180.	180.	C	0.2	0.3
D	< 0.1	0.2	E	< 0.1	0.2			

ARM Readings (mR/hr) at (T = 04:15) (19:15)

1-RE-29	1.1	1-RE-30	1.1	1-RE-31	1.1
1-RE-32	0.17	1-RE-33	1.3		



UNIT 1 REACTOR EL 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: 1100. cpm/cf sample
 Floor Contamination: 6.2 cpm/100cm²
 Wall and Equipment Contamination: 0.6 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	50.	50.	B	160.	160.	C	0.2	0.3
D	< 0.1	0.2	E	< 0.1	0.2			

ARM Readings (mR/hr) at (T = 04:30) (19:30)


1-RE-29	1.1	1-RE-30	1.1	1-RE-31	1.1
1-RE-32	0.17	1-RE-33	1.3		

Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	44.	45.	B	140.	140.	C	0.2	0.3
D	< 0.1	0.2	E	< 0.1	0.2			

ARM Readings (mR/hr) at (T = 04:45) (19:45)

1-RE-29	1.1	1-RE-30	1.1	1-RE-31	1.1
1-RE-32	0.16	1-RE-33	1.2		



UNIT 1 REACTOR EL. 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: 4900. cpm/cf sample
 Floor Contamination: 22. cpm/100cm²
 Wall and Equipment Contamination: 2.2 cpm/100cm²
 Personnel Contamination Rate: 0.4 cpm/100cm² per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	40.	41.	B	130.	130.	C	6.6	7.0
D	0.8	1.2	E	0.3	0.7			

ARM Readings (mR/hr) at (T = 05:00) (20:00)


1-RE-29	1.3	1-RE-30	1.3	1-RE-31	1.3
1-RE-32	0.39	1-RE-33	1.4		

 Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	34.	38.	B	110.	110.	C	9.7	14.
D	3.1	7.3	E	2.5	6.6			

ARM Readings (mR/hr) at (T = 05:30) (20:30)

1-RE-29	3.5	1-RE-30	3.5	1-RE-31	3.5
1-RE-32	2.6	1-RE-33	3.6		



UNIT 1 REACTOR EL. 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: 3.7E4 cpm/cf sample
 Floor Contamination: 690. cpm/100cm2
 Wall and Equipment Contamination: 69. cpm/100cm2
 Personnel Contamination Rate: 2.8 cpm/100cm2 per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	30.	37.	B	94.	100.	C	9.5	16.
D	4.2	11.	E	3.7	10.			

ARM Readings (mR/hr) at (T = 06:00) (21:00)


1-RE-29	4.7	1-RE-30	4.7	1-RE-31	4.7
1-RE-32	3.8	1-RE-33	4.8		

Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	27.	35.	B	84.	92.	C	9.3	18.
D	4.8	13.	E	4.3	13.			

ARM Readings (mR/hr) at (T = 06:30) (21:30)

1-RE-29	5.3	1-RE-30	5.3	1-RE-31	5.3
1-RE-32	4.4	1-RE-33	5.4		



UNIT 1 REACTOR EL. 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: 3.1E4 cpm/cf sample
 Floor Contamination: 1200. cpm/100cm²
 Wall and Equipment Contamination: 120. cpm/100cm²
 Personnel Contamination Rate: 1.9 cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	24.	34.	B	75.	85.	C	9.0	19.
D	5.2	15.	E	4.8	15.			

ARM Readings (mR/hr) at (T = 07:00) (22:00)

1-RE-29	5.8	1-RE-30	5.8	1-RE-31	5.8
1-RE-32	4.9	1-RE-33	5.9		

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: 2.6E4 cpm/cf sample
 Floor Contamination: 1500. cpm/100cm²
 Wall and Equipment Contamination: 150. cpm/100cm²
 Personnel Contamination Rate: 1.3 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	21.	33.	B	63.	76.	C	8.6	21.
D	5.7	18.	E	5.4	18.			

ARM Readings (mR/hr) at (T = 08:00) (23:00)

1-RE-29	6.4	1-RE-30	6.4	1-RE-31	6.4
1-RE-32	5.5	1-RE-33	6.5		



UNIT 1 TURBINE EL. 200'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 200' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.2	0.2
D	0.7	0.7						

ARM Readings (mR/hr) at (T = 00:00) (15:00)

1-RE-04 0.11 1-RE-05 0.16

Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	0.2	0.2						

ARM Readings (mR/hr) at (T = 01:00) (16:00)

1-RE-04 0.11 1-RE-05 0.15



● ARM DETECTOR
 △ ARM READOUT

UNIT 1 TURBINE EL. 200'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 200' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 02:00) (17:00)

1-RE-04 0.11 1-RE-05 0.14

Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1						

ARM Readings (mR/hr) at (T = 03:00) (18:00)

1-RE-04 0.11 1-RE-05 0.14



UNIT 1 TURBINE EL. 200'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 200' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	16.	16.	B	720.	720.	C	100.	100.
D	210.	210.						

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	9.7	9.7	B	450.	450.	C	63.	63.
D	130.	130.						

ARM Readings (mR/hr) at (T = 03:15) (18:15)

1-RE-04 180. 1-RE-05 600.



UNIT 1 TURBINE EL. 200'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 200' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	8.5	8.5	B	390.	390.	C	55.	55.
D	110.	110.						

ARM Readings (mR/hr) at (T = 03:25) (18:25)

1-RE-04 160. 1-RE-05 540.

Contamination and Airborne Survey Data at (T = 03:30) (18:30)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	7.3	7.3	B	340.	340.	C	48.	48.
D	96.	96.						

ARM Readings (mR/hr) at (T = 03:40) (18:40)

1-RE-04 130. 1-RE-05 430.



ARM 04
□

ARM 05
□

● ARM DETECTOR
△ ARM READOUT

UNIT 1 TURBINE EL. 200'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 200' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	6.2	6.2	B	280.	280.	C	40.	40.
D	81.	81.						

ARM Readings (mR/hr) at (T = 04:00) (19:00)


1-RE-04 110. 1-RE-05 360.

 Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	5.4	5.4	B	250.	250.	C	35.	35.
D	71.	71.						

ARM Readings (mR/hr) at (T = 04:15) (19:15)

1-RE-04 95. 1-RE-05 320.



UNIT 1 TURBINE EL. 200'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 200' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	4.7	4.7	B	220.	220.	C	31.	31.
D	62.	62.						

ARM Readings (mR/hr) at (T = 04:30) (19:30)


1-RE-04 83. 1-RE-05 280.

Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	4.2	4.2	B	190.	190.	C	27.	27.
D	55.	55.						

ARM Readings (mR/hr) at (T = 04:45) (19:45)

1-RE-04 74. 1-RE-05 250.



UNIT 1 TURBINE EL. 200'

- ARM DETECTOR
- △ ARM READOUT

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 200' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	3.7	3.7	B	170.	170.	C	24.	24.
D	49.	49.						

ARM Readings (mR/hr) at (T = 05:00) (20:00)


1-RE-04 66. 1-RE-05 220.

Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	3.0	3.0	B	140.	140.	C	20.	20.
D	40.	40.						

ARM Readings (mR/hr) at (T = 05:30) (20:30)

1-RE-04 53. 1-RE-05 180.



- ARM DETECTOR
- △ ARM READOUT

UNIT 1 TURBINE EL. 200'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 200' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	2.4	2.4	B	120.	120.	C	16.	16.
D	34.	34.						

ARM Readings (mR/hr) at (T = 06:00) (21:00)


1-RE-04 45. 1-RE-05 150.

Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	2.1	2.1	B	100.	100.	C	14.	14.
D	29.	29.						

ARM Readings (mR/hr) at (T = 06:30) (21:30)

1-RE-04 38. 1-RE-05 130.



UNIT 1 TURBINE EL. 200'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 200' Elev.

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.8	1.8	B	87.	87.	C	12.	12.
D	25.	25.						

ARM Readings (mR/hr) at (T = 07:00) (22:00)

1-RE-04 33. 1-RE-05 110.

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.3	1.3	B	68.	68.	C	9.4	9.4
D	20.	20.						

ARM Readings (mR/hr) at (T = 08:00) (23:00)

1-RE-04 26. 1-RE-05 89.



UNIT 1 TURBINE EL. 217'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	0.1	0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 00:00) (15:00)

1-RE-07	1.2	1-RE-12	0.12	1-RE-13	300.
1-RE-36	0.11	0-RE-53	0.05		

Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 01:00) (16:00)

1-RE-07	1.1	1-RE-12	0.11	1-RE-13	300.
1-RE-36	0.11	0-RE-53	0.05		



UNIT 1 TURBINE EL. 217'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 02:00) (17:00)

1-RE-07 1.1 1-RE-12 0.11 1-RE-13 300.
 1-RE-36 0.11 0-RE-53 0.05

Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 03:00) (18:00)

1-RE-07 1.1 1-RE-12 0.11 1-RE-13 300.
 1-RE-36 0.11 0-RE-53 0.



UNIT 1 TURBINE EL. 217'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	3.6	3.6	B	1.1	1.1	C	770.	770.
D	73.	73.	E	190.	190.	F	< 0.1	< 0.1

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	2.3	2.3	B	0.7	0.7	C	480.	480.
D	46.	46.	E	120.	120.	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 03:15) (18:15)

1-RE-07	1.1	1-RE-12	0.11	1-RE-13	400.
1-RE-36	880.	0-RE-53	0.05		



UNIT 1 TURBINE EL. 217'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	2.0	2.0	B	0.6	0.6	C	420.	420.
D	40.	40.	E	100.	100.	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 03:25) (18:25)

1-RE-07	1.1	1-RE-12	0.11	1-RE-13	260.
1-RE-36	790.	0-RE-53	0.05		

Contamination and Airborne Survey Data at (T = 03:30) (18:30)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.7	1.7	B	0.5	0.5	C	360.	360.
D	35.	35.	E	90.	90.	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 03:40) (18:40)

1-RE-07	1.1	1-RE-12	0.11	1-RE-13	190.
1-RE-36	630.	0-RE-53	0.05		



UNIT 1 TURBINE EL. 217'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.5	1.5	B	0.5	0.5	C	300.	300.
D	29.	29.	E	75.	75.	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:00) (19:00)


1-RE-07	1.0	1-RE-12	0.11	1-RE-13	160.
1-RE-36	530.	0-RE-53	0.05		

Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.3	1.3	B	0.4	0.4	C	260.	260.
D	25.	25.	E	66.	66.	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:15) (19:15)

1-RE-07	1.0	1-RE-12	0.11	1-RE-13	140.
1-RE-36	460.	0-RE-53	0.05		



UNIT 1 TURBINE EL. 217'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.1	1.1	B	0.3	0.3	C	230.	230.
D	22.	22.	E	58.	58.	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:30) (19:30)


1-RE-07 1.0 1-RE-12 0.10 1-RE-13 120.
 1-RE-36 410. 0-RE-53 0.05

 Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1.0	1.0	B	0.3	0.3	C	200.	200.
D	20.	20.	E	52.	52.	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:45) (19:45)

1-RE-07 1.0 1-RE-12 0.10 1-RE-13 110.
 1-RE-36 360. 0-RE-53 0.05



UNIT 1 TURBINE EL. 217'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.9	0.9	B	0.3	0.3	C	180.	180.
D	17.	17.	E	46.	46.	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 05:00) (20:00)


1-RE-07	1.0	1-RE-12	0.10	1-RE-13	97.
1-RE-36	320.	0-RE-53	0.05		

Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.7	0.7	B	0.2	0.2	C	150.	150.
D	14.	14.	E	38.	38.	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 05:30) (20:30)

1-RE-07	1.0	1-RE-12	0.10	1-RE-13	79.
1-RE-36	260.	0-RE-53	0.05		



UNIT 1 TURBINE EL. 217'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.6	0.6	B	0.2	0.2	C	130.	130.
D	12.	12.	E	32.	32.	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 06:00) (21:00)


1-RE-07	1.0	1-RE-12	0.10	1-RE-13	66.
1-RE-36	220.	0-RE-53	0.05		

Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.5	0.5	B	0.2	0.2	C	110.	110.
D	9.8	9.8	E	27.	27.	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 06:30) (21:30)

1-RE-07	1.0	1-RE-12	0.10	1-RE-13	56.
1-RE-36	190.	0-RE-53	0.05		



UNIT 1 TURBINE EL. 217'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.4	0.4	B	0.1	0.1	C	94.	94.
D	8.4	8.4	E	24.	24.	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 07:00) (22:00)

1-RE-07	1.0	1-RE-12	0.10	1-RE-13	48.
1-RE-36	170.	0-RE-53	0.05		

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.3	0.3	B	< 0.1	< 0.1	C	74.	74.
D	6.4	6.4	E	19.	19.	F	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 08:00) (23:00)

1-RE-07	1.0	1-RE-12	0.10	1-RE-13	37.
1-RE-36	130.	0-RE-53	0.05		



△ ARM READOUT
● ARM DETECTOR

UNIT 1 TURBINE EL.239'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 239' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 00:00) (15:00)

1-RE-19 300. 1-RE-20 300.

Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 01:00) (16:00)

1-RE-19 300. 1-RE-20 300.



△ ARM READOUT
● ARM DETECTOR

UNIT 1 TURBINE EL. 239'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 239' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
---	-----	-----	---	-----	-----	---	-----	-----
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 02:00) (17:00)

1-RE-19 300. 1-RE-20 300.

 Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
---	-----	-----	---	-----	-----	---	-----	-----
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 03:00) (18:00)

1-RE-19 300. 1-RE-20 300.



△ ARM READOUT
● ARM DETECTOR

UNIT 1 TURBINE EL. 239'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 239' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (15:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	110.	110.	C	4.2	4.2

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	71.	71.	C	2.7	2.7

ARM Readings (mR/hr) at (T = 03:15) (18:15)


1-RE-19 5.9E4 1-RE-20 1.4E5

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	62.	62.	C	2.4	2.4

ARM Readings (mR/hr) at (T = 03:25) (18:25)

1-RE-19 5.3E4 1-RE-20 1.2E5



△ ARM READOUT
● ARM DETECTOR

UNIT 1 TURBINE EL. 239'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 239' Elev.

Contamination and Airborne Survey Data at (T = 03:30) (18:30)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	53.	53.	C	2.0	2.0

ARM Readings (mR/hr) at (T = 03:40) (18:40)

1-RE-19 4.2E4 1-RE-20 1.0E5

Contamination and Airborne Survey Data at (T = 04:00) (19:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	45.	45.	C	1.7	1.7

ARM Readings (mR/hr) at (T = 04:00) (19:00)

1-RE-19 3.5E4 1-RE-20 8.4E4



- △ ARM READOUT
- ARM DETECTOR

UNIT 1 TURBINE EL. 239'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 239' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	40.	40.	C	1.5	1.5

ARM Readings (mR/hr) at (T = 04:15) (19:15)


1-RE-19 3.1E4 1-RE-20 7.4E4

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	36.	36.	C	1.3	1.3

ARM Readings (mR/hr) at (T = 04:30) (19:30)

1-RE-19 2.8E4 1-RE-20 6.6E4



Δ ARM READOUT
 ● ARM DETECTOR

UNIT 1 TURBINE EL.239'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 239' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	33.	33.	C	1.2	1.2

ARM Readings (mR/hr) at (T = 04:45) (19:45)

1-RE-19 2.5E4 1-RE-20 6.0E4

Contamination and Airborne Survey Data at (T = 05:00) (20:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	30.	30.	C	1.0	1.0

ARM Readings (mR/hr) at (T = 05:00) (20:00)

1-RE-19 2.3E4 1-RE-20 5.4E4



- △ ARM READOUT
- ARM DETECTOR

UNIT 1 TURBINE EL. 239'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 239' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	25.	25.	C	0.8	0.8

ARM Readings (mR/hr) at (T = 05:30) (20:30)

1-RE-19 1.9E4 1-RE-20 4.6E4

Contamination and Airborne Survey Data at (T = 06:00) (21:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	22.	22.	C	0.7	0.7

ARM Readings (mR/hr) at (T = 06:00) (21:00)

1-RE-19 1.7E4 1-RE-20 4.0E4



- △ ARM READOUT
- ARM DETECTOR

UNIT 1 TURBINE EL. 239'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 239' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	20.	20.	C	0.6	0.6

ARM Readings (mR/hr) at (T = 06:30) (21:30)

1-RE-19 1.5E4 1-RE-20 3.5E4

Contamination and Airborne Survey Data at (T = 07:00) (22:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	18.	18.	C	0.5	0.5

ARM Readings (mR/hr) at (T = 07:00) (22:00)

1-RE-19 1.4E4 1-RE-20 3.2E4



△ ARM READOUT
● ARM DETECTOR

UNIT 1 TURBINE EL. 239'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
READINGS ABOVE NORMAL BACKGROUND

Unit 1 Turbine Enclosure 239' Elev.

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
---	-----	-----	---	-----	-----	---	-----	-----
A	< 0.1	< 0.1	B	16.	16.	C	0.4	0.4

ARM Readings (mR/hr) at (T = 08:00) (23:00)

1-RE-19 1.1E4 1-RE-20 2.7E4



UNIT 1 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1	I	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 00:00) (15:00)

1-RE-25 0.11 1-RE-26 1.0 0-RE-57 1.0

Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1	I	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 01:00) (16:00)

1-RE-25 0.11 1-RE-26 1.0 0-RE-57 1.0



UNIT 1 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	F	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1	I	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 02:00) (17:00)

1-RE-25 0.11 1-RE-26 1.0 0-RE-57 1.0

Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1	F	< 0.1	< 0.1
G	< 0.1	< 0.1	H	< 0.1	< 0.1	I	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 03:00) (18:00)

1-RE-25 0.11 1-RE-26 1.0 0-RE-57 1.0



UNIT 1 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA

----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1800.	1800.	B	690.	690.	C	2700.	2700.
D	2000.	2000.	E	18.	18.	F	< 0.1	< 0.1
G	2400.	2400.	H	36.	36.	I	< 0.1	< 0.1

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	1100.	1100.	B	430.	430.	C	1700.	1700.
D	1300.	1300.	E	11.	11.	F	< 0.1	< 0.1
G	1500.	1500.	H	22.	22.	I	1.3	1.3

ARM Readings (mR/hr) at (T = 03:15) (18:15)

1-RE-25 1900. 1-RE-26 580. 0-RE-57 1.2



UNIT 1 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	960.	960.	B	370.	370.	C	1500.	1500.
D	1100.	1100.	E	9.9	9.9	F	< 0.1	< 0.1
G	1300.	1300.	H	20.	20.	I	1.3	1.3

ARM Readings (mR/hr) at (T = 03:25) (18:25)

1-RE-25 1700. 1-RE-26 520. 0-RE-57 1.1

Contamination and Airborne Survey Data at (T = 03:30) (18:30)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	820.	820.	B	320.	320.	C	1300.	1300.
D	950.	950.	E	8.6	8.6	F	< 0.1	< 0.1
G	1100.	1100.	H	17.	17.	I	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 03:40) (18:40)

1-RE-25 1300. 1-RE-26 420. 0-RE-57 1.1



UNIT 1 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	690.	690.	B	270.	270.	C	1100.	1100.
D	790.	790.	E	7.2	7.2	F	< 0.1	< 0.1
G	940.	940.	H	14.	14.	I	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:00) (19:00)


1-RE-25 1100. 1-RE-26 350. 0-RE-57 1.1

Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	600.	600.	B	230.	230.	C	920.	920.
D	690.	690.	E	6.3	6.3	F	< 0.1	< 0.1
G	820.	820.	H	12.	12.	I	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:15) (19:15)

1-RE-25 990. 1-RE-26 310. 0-RE-57 1.1



UNIT 1 TURBINE EL. 269'



TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA

----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	530.	530.	B	210.	210.	C	810.	810.
D	610.	610.	E	5.6	5.6	F	< 0.1	< 0.1
G	720.	720.	H	11.	11.	I	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:30) (19:30)


1-RE-25 870. 1-RE-26 270. 0-RE-57 1.1

Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	470.	470.	B	180.	180.	C	720.	720.
D	540.	540.	E	4.9	4.9	F	< 0.1	< 0.1
G	640.	640.	H	9.6	9.6	I	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:45) (19:45)

1-RE-25 770. 1-RE-26 240. 0-RE-57 1.1



UNIT 1 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA

----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	420.	420.	B	160.	160.	C	640.	640.
D	480.	480.	E	4.4	4.4	F	< 0.1	< 0.1
G	570.	570.	H	8.5	8.5	I	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 05:00) (20:00)


1-RE-25 680. 1-RE-26 210. 0-RE-57 1.1

Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	340.	340.	B	130.	130.	C	520.	520.
D	390.	390.	E	3.6	3.6	F	0.2	0.2
G	460.	460.	H	6.9	6.9	I	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 05:30) (20:30)

1-RE-25 550. 1-RE-26 170. 0-RE-57 1.0



UNIT 1 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm2
 Wall and Equipment Contamination: < 0.1 cpm/100cm2
 Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	280.	280.	B	110.	110.	C	440.	440.
D	320.	320.	E	3.0	3.0	F	0.2	0.2
G	390.	390.	H	5.7	5.7	I	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 06:00) (21:00)


1-RE-25 460. 1-RE-26 150. 0-RE-57 1.0

Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	240.	240.	B	94.	94.	C	370.	370.
D	280.	280.	E	2.5	2.5	F	0.3	0.3
G	330.	330.	H	4.8	4.8	I	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 06:30) (21:30)

1-RE-25 400. 1-RE-26 120. 0-RE-57 1.0



UNIT 1 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 1 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	210.	210.	B	81.	81.	C	320.	320.
D	240.	240.	E	2.2	2.2	F	0.3	0.3
G	290.	290.	H	4.1	4.1	I	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 07:00) (22:00)

1-RE-25 340. 1-RE-26 110. 0-RE-57 1.0

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	160.	160.	B	63.	63.	C	250.	250.
D	190.	190.	E	1.6	1.6	F	0.3	0.3
G	230.	230.	H	3.1	3.1	I	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 08:00) (23:00)

1-RE-25 270. 1-RE-26 84. 0-RE-57 1.0



- △ ARM READOUT
- ARM DETECTOR

UNIT 2 REACTOR EL. 253'



TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 00:00) (15:00)

2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		

Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 01:00) (16:00)

2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		



△ ARM READOUT
● ARM DETECTOR

UNIT 2 REACTOR EL. 253'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 02:00) (17:00)

2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		

Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:00) (18:00)

2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		



- △ ARM READOUT
- ARM DETECTOR

UNIT 2 REACTOR EL. 253'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:15) (18:15)

2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		



△ ARM READOUT
 ● ARM DETECTOR

UNIT 2 REACTOR EL. 253'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:25) (18:25)


2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		

Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	0.1			

ARM Readings (mR/hr) at (T = 03:40) (18:40)

2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		



- △ ARM READOUT
- ARM DETECTOR

UNIT 2 REACTOR EL. 253'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	0.2			

ARM Readings (mR/hr) at (T = 04:00) (19:00)


2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		

Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	0.2			

ARM Readings (mR/hr) at (T = 04:15) (19:15)

2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		



- △ ARM READOUT
- ARM DETECTOR

UNIT 2 REACTOR EL. 253'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	0.2			

ARM Readings (mR/hr) at (T = 04:30) (19:30)


2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		

 Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	0.2			

ARM Readings (mR/hr) at (T = 04:45) (19:45)

2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		



△ ARM READOUT
 ● ARM DETECTOR

UNIT 2 REACTOR EL. 253'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	0.3	0.7			

ARM Readings (mR/hr) at (T = 05:00) (20:00)


2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		

Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	0.6	0.6	E	2.7	6.9			

ARM Readings (mR/hr) at (T = 05:30) (20:30)

2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		



- △ ARM READOUT
- ARM DETECTOR

UNIT 2 REACTOR EL. 253'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	0.8	0.8	E	4.0	11.			

ARM Readings (mR/hr) at (T = 06:00) (21:00)


2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		

 Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	1.0	1.0	E	4.8	13.			

ARM Readings (mR/hr) at (T = 06:30) (21:30)

2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		



- △ ARM READOUT
- ARM DETECTOR

UNIT 2 REACTOR EL. 253'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 253' Elev.

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	1.1	1.1	E	5.3	15.			

ARM Readings (mR/hr) at (T = 07:00) (22:00)

2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	1.3	1.3	E	6.1	19.			

ARM Readings (mR/hr) at (T = 08:00) (23:00)

2-RE-14	30.	2-RE-15	1.5	2-RE-16	1.5
2-RE-17	10.	2-RE-18	0.50		



UNIT 2 REACTOR EL. 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
READINGS ABOVE NORMAL BACKGROUND

Unit 2 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 00:00) (15:00)

2-RE-29	1.0	2-RE-30	1.0	2-RE-31	1.0
2-RE-32	0.10	2-RE-33	1.0		

Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 01:00) (16:00)

2-RE-29	1.0	2-RE-30	1.0	2-RE-31	1.0
2-RE-32	0.10	2-RE-33	1.0		



UNIT 2 REACTOR EL. 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 02:00) (17:00)

2-RE-29	1.0	2-RE-30	1.0	2-RE-31	1.0
2-RE-32	0.10	2-RE-33	1.0		

Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:00) (18:00)

2-RE-29	1.0	2-RE-30	1.0	2-RE-31	1.0
2-RE-32	0.10	2-RE-33	1.0		



UNIT 2 REACTOR EL. 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:15) (18:15)

2-RE-29	1.0	2-RE-30	1.0	2-RE-31	1.0
2-RE-32	0.10	2-RE-33	1.0		



UNIT 2 REACTOR EL. 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:25) (18:25)


2-RE-29	1.0	2-RE-30	1.0	2-RE-31	1.0
2-RE-32	0.10	2-RE-33	1.0		

Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1
D	< 0.1	< 0.1	E	< 0.1	< 0.1			

ARM Readings (mR/hr) at (T = 03:40) (18:40)

2-RE-29	1.0	2-RE-30	1.0	2-RE-31	1.0
2-RE-32	0.10	2-RE-33	1.0		



UNIT 2 REACTOR EL. 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: 1100. cpm/cf sample
 Floor Contamination: 6.2 cpm/100cm²
 Wall and Equipment Contamination: 0.6 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	0.1
D	< 0.1	0.1	E	< 0.1	0.1			

ARM Readings (mR/hr) at (T = 04:00) (19:00)


2-RE-29 1.1 2-RE-30 1.1 2-RE-31 1.1
 2-RE-32 0.10 2-RE-33 1.1

 Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	0.1	B	< 0.1	0.1	C	< 0.1	0.2
D	< 0.1	0.2	E	< 0.1	0.2			

ARM Readings (mR/hr) at (T = 04:15) (19:15)

2-RE-29 1.1 2-RE-30 1.1 2-RE-31 1.1
 2-RE-32 0.10 2-RE-33 1.1



UNIT 2 REACTOR EL. 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: 1100. cpm/cf sample
 Floor Contamination: 6.2 cpm/100cm²
 Wall and Equipment Contamination: 0.6 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	0.1	B	< 0.1	0.1	C	< 0.1	0.2
D	< 0.1	0.2	E	< 0.1	0.2			

ARM Readings (mR/hr) at (T = 04:30) (19:30)


2-RE-29	1.1	2-RE-30	1.1	2-RE-31	1.1
2-RE-32	0.10	2-RE-33	1.1		

 Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	0.1	B	< 0.1	0.1	C	< 0.1	0.2
D	< 0.1	0.2	E	< 0.1	0.2			

ARM Readings (mR/hr) at (T = 04:45) (19:45)

2-RE-29	1.1	2-RE-30	1.1	2-RE-31	1.1
2-RE-32	0.10	2-RE-33	1.1		



UNIT 2 REACTOR EL. 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: 4900. cpm/cf sample
 Floor Contamination: 22. cpm/100cm²
 Wall and Equipment Contamination: 2.2 cpm/100cm²
 Personnel Contamination Rate: 0.4 cpm/100cm² per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	0.5	B	< 0.1	0.5	C	0.3	0.7
D	0.3	0.7	E	0.3	0.7			

ARM Readings (mR/hr) at (T = 05:00) (20:00)


2-RE-29 1.3 2-RE-30 1.3 2-RE-31 1.3
 2-RE-32 0.10 2-RE-33 1.3

Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.4	4.5	B	0.4	4.5	C	2.5	6.6
D	2.5	6.6	E	2.5	6.6			

ARM Readings (mR/hr) at (T = 05:30) (20:30)

2-RE-29 3.5 2-RE-30 3.5 2-RE-31 3.5
 2-RE-32 0.13 2-RE-33 3.5



UNIT 2 REACTOR EL. 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: 3.7E4 cpm/cf sample
 Floor Contamination: 690. cpm/100cm2
 Wall and Equipment Contamination: 69. cpm/100cm2
 Personnel Contamination Rate: 2.8 cpm/100cm2 per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.6	7.3	B	0.6	7.3	C	3.7	10.
D	3.7	10.	E	3.7	10.			

ARM Readings (mR/hr) at (T = 06:00) (21:00)


2-RE-29	4.7	2-RE-30	4.7	2-RE-31	4.7
2-RE-32	0.15	2-RE-33	4.7		

 Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.7	9.3	B	0.7	9.3	C	4.3	13.
D	4.3	13.	E	4.3	13.			

ARM Readings (mR/hr) at (T = 06:30) (21:30)

2-RE-29	5.3	2-RE-30	5.3	2-RE-31	5.3
2-RE-32	0.16	2-RE-33	5.3		



UNIT 2 REACTOR EL. 352'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA

----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Reactor Enclosure 352' Elev.

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: 3.1E4 cpm/cf sample
 Floor Contamination: 1200. cpm/100cm2
 Wall and Equipment Contamination: 120. cpm/100cm2
 Personnel Contamination Rate: 1.9 cpm/100cm2 per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.8	11.	B	0.8	11.	C	4.8	15.
D	4.8	15.	E	4.8	15.			

ARM Readings (mR/hr) at (T = 07:00) (22:00)

2-RE-29	5.8	2-RE-30	5.8	2-RE-31	5.8
2-RE-32	0.16	2-RE-33	5.8		

 Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: 2.6E4 cpm/cf sample
 Floor Contamination: 1500. cpm/100cm2
 Wall and Equipment Contamination: 150. cpm/100cm2
 Personnel Contamination Rate: 1.3 cpm/100cm2 per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	0.9	13.	B	0.9	13.	C	5.4	18.
D	5.4	18.	E	5.4	18.			

ARM Readings (mR/hr) at (T = 08:00) (23:00)

2-RE-29	6.4	2-RE-30	6.4	2-RE-31	6.4
2-RE-32	0.16	2-RE-33	6.4		



UNIT 2 TURBINE EL. 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 00:00) (15:00)

2-RE-07	4.0	2-RE-12	0.10	2-RE-13	3.0
0-RE-53	0.05				

Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 01:00) (16:00)

2-RE-07	4.0	2-RE-12	0.10	2-RE-13	3.0
0-RE-53	0.05				



ARM 12

UNIT 2 TURBINE EL. 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 02:00) (17:00)

2-RE-07	4.0	2-RE-12	0.10	2-RE-13	3.0
0-RE-53	0.05				

Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 03:00) (18:00)

2-RE-07	4.0	2-RE-12	0.10	2-RE-13	3.0
0-RE-53	0.05				



UNIT 2 TURBINE EL. 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)


Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
---	-----	-----	---	-----	-----	---	-----	-----
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
---	-----	-----	---	-----	-----	---	-----	-----
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 03:15) (18:15)

2-RE-07 4.0 2-RE-12 0.10 2-RE-13 3.0
 0-RE-53 0.05



UNIT 2 TURBINE EL. 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 03:25) (18:25)

2-RE-07 4.0 2-RE-12 0.10 2-RE-13 3.0
 0-RE-53 0.05

Contamination and Airborne Survey Data at (T = 03:30) (18:30)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 03:40) (18:40)

2-RE-07 4.0 2-RE-12 0.10 2-RE-13 3.0
 0-RE-53 0.05



UNIT 2 TURBINE EL. 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
---	-----	-----	---	-----	-----	---	-----	-----
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:00) (19:00)


2-RE-07	4.0	2-RE-12	0.10	2-RE-13	3.0
0-RE-53	0.05				

 Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
---	-----	-----	---	-----	-----	---	-----	-----
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:15) (19:15)

2-RE-07	4.0	2-RE-12	0.10	2-RE-13	3.0
0-RE-53	0.05				



UNIT 2 TURBINE EL. 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:30) (19:30)


2-RE-07	4.0	2-RE-12	0.10	2-RE-13	3.0
0-RE-53	0.05				

Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:45) (19:45)

2-RE-07	4.0	2-RE-12	0.10	2-RE-13	3.0
0-RE-53	0.05				



UNIT 2 TURBINE EL. 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
---	-----	-----	---	-----	-----	---	-----	-----
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 05:00) (20:00)


2-RE-07	4.0	2-RE-12	0.10	2-RE-13	3.0
0-RE-53	0.05				

 Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
---	-----	-----	---	-----	-----	---	-----	-----
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 05:30) (20:30)

2-RE-07	4.0	2-RE-12	0.10	2-RE-13	3.0
0-RE-53	0.05				



UNIT 2 TURBINE EL. 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 06:00) (21:00)


2-RE-07 4.0 2-RE-12 0.10 2-RE-13 3.0
 0-RE-53 0.05

 Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 06:30) (21:30)

2-RE-07 4.0 2-RE-12 0.10 2-RE-13 3.0
 0-RE-53 0.05



UNIT 2 TURBINE EL. 217

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 217' Elev.

Contamination and Airborne Survey Data at (T = 07:00) (22:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 07:00) (22:00)

2-RE-07	4.0	2-RE-12	0.10	2-RE-13	3.0
0-RE-53	0.05				

Contamination and Airborne Survey Data at (T = 08:00) (23:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 08:00) (23:00)

2-RE-07	4.0	2-RE-12	0.10	2-RE-13	3.0
0-RE-53	0.05				



UNIT 2 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 00:00) (15:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 00:00) (15:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 00:00) (15:00)

2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.0

Contamination and Airborne Survey Data at (T = 01:00) (16:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 01:00) (16:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 01:00) (16:00)

2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.0



UNIT 2 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 02:00) (17:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 02:00) (17:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
---	-----	-----	---	-----	-----	---	-----	-----
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 02:00) (17:00)

2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.0

Contamination and Airborne Survey Data at (T = 03:00) (18:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:00) (18:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
---	-----	-----	---	-----	-----	---	-----	-----
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 03:00) (18:00)

2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.0



UNIT 2 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 03:00) (18:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:05) (18:05)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	0.2	0.2

Radiation Survey Data at (T = 03:15) (18:15)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	1.4	1.4

ARM Readings (mR/hr) at (T = 03:15) (18:15)


2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.2

Radiation Survey Data at (T = 03:25) (18:25)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	1.4	1.4

ARM Readings (mR/hr) at (T = 03:25) (18:25)

2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.1



UNIT 2 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 03:30) (18:30)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 03:40) (18:40)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 03:40) (18:40)

2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.1

Contamination and Airborne Survey Data at (T = 04:00) (19:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:00) (19:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:00) (19:00)

2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.1



UNIT 2 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:15) (19:15)

Loc	Closed window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:15) (19:15)


2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.1

Radiation Survey Data at (T = 04:30) (19:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:30) (19:30)

2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.1



UNIT 2 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 04:00) (19:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 04:45) (19:45)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
---	-----	-----	---	-----	-----	---	-----	-----
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 04:45) (19:45)

2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.1

Contamination and Airborne Survey Data at (T = 05:00) (20:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 05:00) (20:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
---	-----	-----	---	-----	-----	---	-----	-----
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 05:00) (20:00)

2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.1



UNIT 2 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 05:00) (20:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 05:30) (20:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 05:30) (20:30)

2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.0

Contamination and Airborne Survey Data at (T = 06:00) (21:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 06:00) (21:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 06:00) (21:00)

2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.0



UNIT 2 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 06:00) (21:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 06:30) (21:30)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
---	-----	-----	---	-----	-----	---	-----	-----
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 06:30) (21:30)

2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.0

Contamination and Airborne Survey Data at (T = 07:00) (22:00)


Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 07:00) (22:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
---	-----	-----	---	-----	-----	---	-----	-----
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1

ARM Readings (mR/hr) at (T = 07:00) (22:00)

2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.0



UNIT 2 TURBINE EL. 269'

TABLE 6.2

IN-PLANT SURVEY AND SAMPLING DATA
----- READINGS ABOVE NORMAL BACKGROUND -----

Unit 2 Turbine Enclosure 269' Elev.

Contamination and Airborne Survey Data at (T = 08:00) (23:00)

Air Sample Contact Rate: < 0.1 cpm/cf sample
 Floor Contamination: < 0.1 cpm/100cm²
 Wall and Equipment Contamination: < 0.1 cpm/100cm²
 Personnel Contamination Rate: < 0.1 cpm/100cm² per minute

Radiation Survey Data at (T = 08:00) (23:00)

Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)	Loc	Closed Window (mR/hr)	Open Window (mR/hr)
---	-----	-----	---	-----	-----	---	-----	-----
A	< 0.1	< 0.1	B	< 0.1	< 0.1	C	< 0.1	< 0.1


ARM Readings (mR/hr) at (T = 08:00) (23:00)

2-RE-25 0.10 2-RE-26 0.10 0-RE-57 1.0

TABLE 6.3.a

ONSITE SURVEY AND SAMPLING DATA (T = 00:00) (15:00)

LOCATION	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf sample)	GROUND CONTAMINATION (cpm/100cm ²)
A	< 0.1	< 0.1	< 0.1	< 0.1
B	< 0.1	< 0.1	< 0.1	< 0.1
C	< 0.1	< 0.1	< 0.1	< 0.1
D	< 0.1	< 0.1	< 0.1	< 0.1
E	< 0.1	< 0.1	< 0.1	< 0.1
F	< 0.1	< 0.1	< 0.1	< 0.1
G	< 0.1	< 0.1	< 0.1	< 0.1
H	< 0.1	< 0.1	< 0.1	< 0.1
I	< 0.1	< 0.1	< 0.1	< 0.1
J	< 0.1	< 0.1	< 0.1	< 0.1
K	< 0.1	< 0.1	< 0.1	< 0.1
L	< 0.1	< 0.1	< 0.1	< 0.1
M	< 0.1	< 0.1	< 0.1	< 0.1
N	< 0.1	< 0.1	< 0.1	< 0.1
O	< 0.1	< 0.1	< 0.1	< 0.1
P	< 0.1	< 0.1	< 0.1	< 0.1
Q	< 0.1	< 0.1	< 0.1	< 0.1
R	< 0.1	< 0.1	< 0.1	< 0.1
S	< 0.1	< 0.1	< 0.1	< 0.1




SITE SURVEY MAP



TABLE 6.3.b

ONSITE SURVEY AND SAMPLING DATA (T = 01:00) (16:00)

LOCATION	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf sample)	GROUND CONTAMINATION (cpm/100cm ²)
A	< 0.1	< 0.1	< 0.1	< 0.1
B	< 0.1	< 0.1	< 0.1	< 0.1
C	< 0.1	< 0.1	< 0.1	< 0.1
D	< 0.1	< 0.1	< 0.1	< 0.1
E	< 0.1	< 0.1	< 0.1	< 0.1
F	< 0.1	< 0.1	< 0.1	< 0.1
G	< 0.1	< 0.1	< 0.1	< 0.1
H	< 0.1	< 0.1	< 0.1	< 0.1
I	< 0.1	< 0.1	< 0.1	< 0.1
J	< 0.1	< 0.1	< 0.1	< 0.1
K	< 0.1	< 0.1	< 0.1	< 0.1
L	< 0.1	< 0.1	< 0.1	< 0.1
M	< 0.1	< 0.1	< 0.1	< 0.1
N	< 0.1	< 0.1	< 0.1	< 0.1
O	< 0.1	< 0.1	< 0.1	< 0.1
P	< 0.1	< 0.1	< 0.1	< 0.1
Q	< 0.1	< 0.1	< 0.1	< 0.1
R	< 0.1	< 0.1	< 0.1	< 0.1
S	< 0.1	< 0.1	< 0.1	< 0.1




SITE SURVEY MAP



TABLE 6.3.c

ONSITE SURVEY AND SAMPLING DATA (T = 02:00) (17:00)

LOCATION	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf sample)	GROUND CONTAMINATION (cpm/100cm ²)
A	< 0.1	< 0.1	< 0.1	< 0.1
B	< 0.1	< 0.1	< 0.1	< 0.1
C	< 0.1	< 0.1	< 0.1	< 0.1
D	< 0.1	< 0.1	< 0.1	< 0.1
E	< 0.1	< 0.1	< 0.1	< 0.1
F	< 0.1	< 0.1	< 0.1	< 0.1
G	< 0.1	< 0.1	< 0.1	< 0.1
H	< 0.1	< 0.1	< 0.1	< 0.1
I	< 0.1	< 0.1	< 0.1	< 0.1
J	< 0.1	< 0.1	< 0.1	< 0.1
K	< 0.1	< 0.1	< 0.1	< 0.1
L	< 0.1	< 0.1	< 0.1	< 0.1
M	< 0.1	< 0.1	< 0.1	< 0.1
N	< 0.1	< 0.1	< 0.1	< 0.1
O	< 0.1	< 0.1	< 0.1	< 0.1
P	< 0.1	< 0.1	< 0.1	< 0.1
Q	< 0.1	< 0.1	< 0.1	< 0.1
R	< 0.1	< 0.1	< 0.1	< 0.1
S	< 0.1	< 0.1	< 0.1	< 0.1




SITE SURVEY MAP

TABLE 6.3.d

ONSITE SURVEY AND SAMPLING DATA (T = 03:00) (18:00)

LOCATION	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf sample)	GROUND CONTAMINATION (cpm/100cm ²)
A	< 0.1	< 0.1	< 0.1	< 0.1
B	< 0.1	< 0.1	< 0.1	< 0.1
C	< 0.1	< 0.1	< 0.1	< 0.1
D	< 0.1	< 0.1	< 0.1	< 0.1
E	< 0.1	< 0.1	< 0.1	< 0.1
F	< 0.1	< 0.1	< 0.1	< 0.1
G	< 0.1	< 0.1	< 0.1	< 0.1
H	< 0.1	< 0.1	< 0.1	< 0.1
I	< 0.1	< 0.1	< 0.1	< 0.1
J	< 0.1	< 0.1	< 0.1	< 0.1
K	< 0.1	< 0.1	< 0.1	< 0.1
L	< 0.1	< 0.1	< 0.1	< 0.1
M	< 0.1	< 0.1	< 0.1	< 0.1
N	< 0.1	< 0.1	< 0.1	< 0.1
O	< 0.1	< 0.1	< 0.1	< 0.1
P	< 0.1	< 0.1	< 0.1	< 0.1
Q	< 0.1	< 0.1	< 0.1	< 0.1
R	< 0.1	< 0.1	< 0.1	< 0.1
S	< 0.1	< 0.1	< 0.1	< 0.1




SITE SURVEY MAP

TABLE 6.3.e

ONSITE SURVEY AND SAMPLING DATA (T = 03:10) (18:10)

LOCATION	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf sample)	GROUND CONTAMINATION (cpm/100cm ²)
A	< 0.1	< 0.1	< 0.1	< 0.1
B	< 0.1	< 0.1	< 0.1	< 0.1
C	< 0.1	< 0.1	< 0.1	< 0.1
D	< 0.1	< 0.1	< 0.1	< 0.1
E	< 0.1	< 0.1	< 0.1	< 0.1
F	< 0.1	< 0.1	< 0.1	< 0.1
G	< 0.1	< 0.1	< 0.1	< 0.1
H	< 0.1	< 0.1	< 0.1	< 0.1
I	< 0.1	< 0.1	< 0.1	< 0.1
J	< 0.1	< 0.1	< 0.1	< 0.1
K	< 0.1	< 0.1	< 0.1	< 0.1
L	< 0.1	< 0.1	< 0.1	< 0.1
M	< 0.1	< 0.1	< 0.1	< 0.1
N	< 0.1	< 0.1	< 0.1	< 0.1
O	< 0.1	< 0.1	< 0.1	< 0.1
P	< 0.1	< 0.1	< 0.1	< 0.1
Q	< 0.1	< 0.1	< 0.1	< 0.1
R	< 0.1	< 0.1	< 0.1	< 0.1
S	< 0.1	< 0.1	< 0.1	< 0.1




SITE SURVEY MAP

s

TABLE 6.3.f

ONSITE SURVEY AND SAMPLING DATA (T = 03:20) (18:20)

LOCATION	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf sample)	GROUND CONTAMINATION (cpm/100cm ²)
A	< 0.1	< 0.1	< 0.1	< 0.1
B	< 0.1	< 0.1	< 0.1	< 0.1
C	< 0.1	< 0.1	< 0.1	< 0.1
D	< 0.1	< 0.1	< 0.1	< 0.1
E	< 0.1	< 0.1	< 0.1	< 0.1
F	< 0.1	< 0.1	< 0.1	< 0.1
G	< 0.1	< 0.1	< 0.1	< 0.1
H	< 0.1	< 0.1	< 0.1	< 0.1
I	< 0.1	< 0.1	< 0.1	< 0.1
J	< 0.1	< 0.1	< 0.1	< 0.1
K	< 0.1	< 0.1	< 0.1	< 0.1
L	< 0.1	< 0.1	< 0.1	< 0.1
M	< 0.1	< 0.1	< 0.1	< 0.1
N	< 0.1	< 0.1	< 0.1	< 0.1
O	< 0.1	< 0.1	< 0.1	< 0.1
P	< 0.1	< 0.1	< 0.1	< 0.1
Q	< 0.1	< 0.1	< 0.1	< 0.1
R	< 0.1	< 0.1	< 0.1	< 0.1
S	< 0.1	< 0.1	< 0.1	< 0.1



SITE SURVEY MAP

TABLE 6.3.g

ONSITE SURVEY AND SAMPLING DATA (T = 03:30) (18:30)

LOCATION	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf sample)	GROUND CONTAMINATION (cpm/100cm ²)
A	< 0.1	< 0.1	< 0.1	< 0.1
B	< 0.1	< 0.1	< 0.1	< 0.1
C	< 0.1	< 0.1	< 0.1	< 0.1
D	< 0.1	< 0.1	< 0.1	< 0.1
E	< 0.1	< 0.1	< 0.1	< 0.1
F	< 0.1	< 0.1	< 0.1	< 0.1
G	< 0.1	< 0.1	< 0.1	< 0.1
H	< 0.1	< 0.1	< 0.1	< 0.1
I	< 0.1	< 0.1	< 0.1	< 0.1
J	< 0.1	< 0.1	< 0.1	< 0.1
K	< 0.1	< 0.1	< 0.1	< 0.1
L	< 0.1	< 0.1	< 0.1	< 0.1
M	< 0.1	< 0.1	< 0.1	< 0.1
N	< 0.1	< 0.1	< 0.1	< 0.1
O	< 0.1	< 0.1	< 0.1	< 0.1
P	< 0.1	< 0.1	< 0.1	< 0.1
Q	< 0.1	< 0.1	< 0.1	< 0.1
R	< 0.1	< 0.1	< 0.1	< 0.1
S	< 0.1	< 0.1	< 0.1	< 0.1




TABLE 6.3.h

ONSITE SURVEY AND SAMPLING DATA (T = 03:40) (18:40)

LOCATION	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf sample)	GROUND CONTAMINATION (cpm/100cm ²)
-----	-----	-----	-----	-----
A	< 0.1	< 0.1	< 0.1	< 0.1
B	< 0.1	< 0.1	< 0.1	< 0.1
C	< 0.1	< 0.1	< 0.1	< 0.1
D	< 0.1	< 0.1	< 0.1	< 0.1
E	< 0.1	< 0.1	< 0.1	< 0.1
F	< 0.1	< 0.1	< 0.1	< 0.1
G	< 0.1	< 0.1	< 0.1	< 0.1
H	< 0.1	< 0.1	< 0.1	< 0.1
I	< 0.1	< 0.1	< 0.1	< 0.1
J	< 0.1	< 0.1	< 0.1	< 0.1
K	< 0.1	< 0.1	< 0.1	< 0.1
L	< 0.1	< 0.1	< 0.1	< 0.1
M	< 0.1	< 0.1	< 0.1	< 0.1
N	< 0.1	< 0.1	< 0.1	< 0.1
O	< 0.1	< 0.1	< 0.1	< 0.1
P	< 0.1	< 0.1	< 0.1	< 0.1
Q	< 0.1	< 0.1	< 0.1	< 0.1
R	< 0.1	< 0.1	< 0.1	< 0.1
S	< 0.1	< 0.1	< 0.1	< 0.1




TABLE 6.3.i

ONSITE SURVEY AND SAMPLING DATA (T = 03:50) (18:50)

LOCATION	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf sample)	GROUND CONTAMINATION (cpm/100cm ²)
A	< 0.1	< 0.1	< 0.1	< 0.1
B	< 0.1	< 0.1	< 0.1	< 0.1
C	< 0.1	< 0.1	< 0.1	< 0.1
D	< 0.1	< 0.1	< 0.1	< 0.1
E	< 0.1	< 0.1	< 0.1	< 0.1
F	< 0.1	< 0.1	< 0.1	< 0.1
G	< 0.1	< 0.1	< 0.1	< 0.1
H	< 0.1	< 0.1	< 0.1	< 0.1
I	< 0.1	< 0.1	< 0.1	< 0.1
J	< 0.1	< 0.1	< 0.1	< 0.1
K	< 0.1	< 0.1	< 0.1	< 0.1
L	< 0.1	< 0.1	< 0.1	< 0.1
M	< 0.1	< 0.1	< 0.1	< 0.1
N	< 0.1	< 0.1	< 0.1	< 0.1
O	< 0.1	< 0.1	< 0.1	< 0.1
P	< 0.1	< 0.1	< 0.1	< 0.1
Q	< 0.1	< 0.1	< 0.1	< 0.1
R	< 0.1	< 0.1	< 0.1	< 0.1
S	< 0.1	< 0.1	< 0.1	< 0.1





TABLE 6.3.j

ONSITE SURVEY AND SAMPLING DATA (T = 04:00) (19:00)

LOCATION	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf sample)	GROUND CONTAMINATION (cpm/100cm ²)
A	< 0.1	< 0.1	< 0.1	< 0.1
B	< 0.1	< 0.1	< 0.1	< 0.1
C	< 0.1	< 0.1	< 0.1	< 0.1
D	< 0.1	< 0.1	< 0.1	< 0.1
E	< 0.1	< 0.1	< 0.1	< 0.1
F	< 0.1	< 0.1	< 0.1	< 0.1
G	< 0.1	< 0.1	< 0.1	< 0.1
H	< 0.1	< 0.1	< 0.1	< 0.1
I	< 0.1	< 0.1	< 0.1	< 0.1
J	< 0.1	< 0.1	< 0.1	< 0.1
K	< 0.1	< 0.1	< 0.1	< 0.1
L	< 0.1	< 0.1	< 0.1	< 0.1
M	< 0.1	< 0.1	< 0.1	< 0.1
N	< 0.1	< 0.1	< 0.1	< 0.1
O	< 0.1	< 0.1	< 0.1	< 0.1
P	< 0.1	< 0.1	< 0.1	< 0.1
Q	< 0.1	< 0.1	< 0.1	< 0.1
R	< 0.1	< 0.1	< 0.1	< 0.1
S	< 0.1	< 0.1	< 0.1	< 0.1




SITE SURVEY MAP

TABLE 6.3.k

ONSITE SURVEY AND SAMPLING DATA (T = 05:00) (20:00)

LOCATION	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf sample)	GROUND CONTAMINATION (cpm/100cm2)
A	< 0.1	< 0.1	< 0.1	< 0.1
B	< 0.1	< 0.1	< 0.1	< 0.1
C	< 0.1	< 0.1	< 0.1	< 0.1
D	< 0.1	< 0.1	< 0.1	< 0.1
E	< 0.1	< 0.1	< 0.1	< 0.1
F	< 0.1	< 0.1	< 0.1	< 0.1
G	< 0.1	< 0.1	< 0.1	< 0.1
H	< 0.1	< 0.1	< 0.1	< 0.1
I	< 0.1	< 0.1	< 0.1	< 0.1
J	< 0.1	< 0.1	< 0.1	< 0.1
K	< 0.1	< 0.1	< 0.1	< 0.1
L	< 0.1	< 0.1	< 0.1	< 0.1
M	< 0.1	< 0.1	< 0.1	< 0.1
N	< 0.1	< 0.1	< 0.1	< 0.1
O	< 0.1	< 0.1	< 0.1	< 0.1
P	< 0.1	< 0.1	< 0.1	< 0.1
Q	< 0.1	< 0.1	< 0.1	< 0.1
R	< 0.1	< 0.1	< 0.1	< 0.1
S	< 0.1	< 0.1	< 0.1	< 0.1




SITE SURVEY MAP



TABLE 6.3.1

ONSITE SURVEY AND SAMPLING DATA (T = 06:00) (21:00)

LOCATION	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf sample)	GROUND CONTAMINATION (cpm/100cm ²)
A	< 0.1	< 0.1	< 0.1	< 0.1
B	< 0.1	< 0.1	< 0.1	< 0.1
C	< 0.1	< 0.1	< 0.1	< 0.1
D	< 0.1	< 0.1	< 0.1	< 0.1
E	< 0.1	< 0.1	< 0.1	< 0.1
F	< 0.1	< 0.1	< 0.1	< 0.1
G	< 0.1	< 0.1	< 0.1	< 0.1
H	< 0.1	< 0.1	< 0.1	< 0.1
I	< 0.1	< 0.1	< 0.1	< 0.1
J	< 0.1	< 0.1	< 0.1	< 0.1
K	< 0.1	< 0.1	< 0.1	< 0.1
L	< 0.1	< 0.1	< 0.1	< 0.1
M	< 0.1	< 0.1	< 0.1	< 0.1
N	< 0.1	< 0.1	< 0.1	< 0.1
O	< 0.1	< 0.1	< 0.1	< 0.1
P	< 0.1	< 0.1	< 0.1	< 0.1
Q	< 0.1	< 0.1	< 0.1	< 0.1
R	< 0.1	< 0.1	< 0.1	< 0.1
S	< 0.1	< 0.1	< 0.1	< 0.1




SITE SURVEY MAP



TABLE 6.3.m

ONSITE SURVEY AND SAMPLING DATA (T = 07:00) (22:00)

LOCATION	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf sample)	GROUND CONTAMINATION (cpm/100cm ²)
A	< 0.1	< 0.1	< 0.1	< 0.1
B	< 0.1	< 0.1	< 0.1	< 0.1
C	< 0.1	< 0.1	< 0.1	< 0.1
D	< 0.1	< 0.1	< 0.1	< 0.1
E	< 0.1	< 0.1	< 0.1	< 0.1
F	< 0.1	< 0.1	< 0.1	< 0.1
G	< 0.1	< 0.1	< 0.1	< 0.1
H	< 0.1	< 0.1	< 0.1	< 0.1
I	< 0.1	< 0.1	< 0.1	< 0.1
J	< 0.1	< 0.1	< 0.1	< 0.1
K	< 0.1	< 0.1	< 0.1	< 0.1
L	< 0.1	< 0.1	< 0.1	< 0.1
M	< 0.1	< 0.1	< 0.1	< 0.1
N	< 0.1	< 0.1	< 0.1	< 0.1
O	< 0.1	< 0.1	< 0.1	< 0.1
P	< 0.1	< 0.1	< 0.1	< 0.1
Q	< 0.1	< 0.1	< 0.1	< 0.1
R	< 0.1	< 0.1	< 0.1	< 0.1
S	< 0.1	< 0.1	< 0.1	< 0.1



SITE SURVEY MAP
S

TABLE 6.3.n

ONSITE SURVEY AND SAMPLING DATA (T = 08:00) (23:00)

LOCATION	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf sample)	GROUND CONTAMINATION (cpm/100cm2)
A	< 0.1	< 0.1	< 0.1	< 0.1
B	< 0.1	< 0.1	< 0.1	< 0.1
C	< 0.1	< 0.1	< 0.1	< 0.1
D	< 0.1	< 0.1	< 0.1	< 0.1
E	< 0.1	< 0.1	< 0.1	< 0.1
F	< 0.1	< 0.1	< 0.1	< 0.1
G	< 0.1	< 0.1	< 0.1	< 0.1
H	< 0.1	< 0.1	< 0.1	< 0.1
I	< 0.1	< 0.1	< 0.1	< 0.1
J	< 0.1	< 0.1	< 0.1	< 0.1
K	< 0.1	< 0.1	< 0.1	< 0.1
L	< 0.1	< 0.1	< 0.1	< 0.1
M	< 0.1	< 0.1	< 0.1	< 0.1
N	< 0.1	< 0.1	< 0.1	< 0.1
O	< 0.1	< 0.1	< 0.1	< 0.1
P	< 0.1	< 0.1	< 0.1	< 0.1
Q	< 0.1	< 0.1	< 0.1	< 0.1
R	< 0.1	< 0.1	< 0.1	< 0.1
S	< 0.1	< 0.1	< 0.1	< 0.1




TABLE 6.4.a

EMERGENCY RESPONSE FACILITY DATA (T = 00:00) (15:00)

Emergency Center	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf)	FLOOR CONTAMINATION (cpm/100cm ²)
MCR	< 0.1	< 0.1	< 0.1	< 0.1
OSC	< 0.1	< 0.1	< 0.1	< 0.1
TSC	< 0.1	< 0.1	< 0.1	< 0.1
Chem Lab	< 0.1	< 0.1	< 0.1	< 0.1
TSC BRE	< 0.1	< 0.1	< 0.1	< 0.1

TABLE 6.4.b

EMERGENCY RESPONSE FACILITY DATA (T = 01:00) (16:00)

Emergency Center	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf)	FLOOR CONTAMINATION (cpm/100cm ²)
MCR	< 0.1	< 0.1	< 0.1	< 0.1
OSC	< 0.1	< 0.1	< 0.1	< 0.1
TSC	< 0.1	< 0.1	< 0.1	< 0.1
Chem Lab	< 0.1	< 0.1	< 0.1	< 0.1
TSC BRE	< 0.1	< 0.1	< 0.1	< 0.1

TABLE 6.4.c

EMERGENCY RESPONSE FACILITY DATA (T = 02:00) (17:00)

Emergency Center	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf)	FLOOR CONTAMINATION (cpm/100cm ²)
MCR	< 0.1	< 0.1	< 0.1	< 0.1
OSC	< 0.1	< 0.1	< 0.1	< 0.1
TSC	< 0.1	< 0.1	< 0.1	< 0.1
Chem Lab	< 0.1	< 0.1	< 0.1	< 0.1
TSC BRE	< 0.1	< 0.1	< 0.1	< 0.1

TABLE 6.4.d

EMERGENCY RESPONSE FACILITY DATA (T = 03:00) (18:00)

Emergency Center	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf)	FLOOR CONTAMINATION (cpm/100cm ²)
MCR	< 0.1	< 0.1	< 0.1	< 0.1
OSC	< 0.1	< 0.1	< 0.1	< 0.1
TSC	< 0.1	< 0.1	< 0.1	< 0.1
Chem Lab	< 0.1	< 0.1	< 0.1	< 0.1
TSC BRE	< 0.1	< 0.1	< 0.1	< 0.1

TABLE 6.4.e

EMERGENCY RESPONSE FACILITY DATA (T = 04:00) (19:00)

Emergency Center	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf)	FLOOR CONTAMINATION (cpm/100cm ²)
MCR	< 0.1	< 0.1	< 0.1	< 0.1
OSC	< 0.1	< 0.1	< 0.1	< 0.1
TSC	< 0.1	< 0.1	< 0.1	< 0.1
Chem Lab	< 0.1	< 0.1	< 0.1	< 0.1
TSC BRE	< 0.1	< 0.1	< 0.1	< 0.1

TABLE 6.4.f

EMERGENCY RESPONSE FACILITY DATA (T = 05:00) (20:00)

Emergency Center	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf)	FLOOR CONTAMINATION (cpm/100cm ²)
MCR	< 0.1	< 0.1	< 0.1	< 0.1
OSC	< 0.1	< 0.1	< 0.1	< 0.1
TSC	< 0.1	< 0.1	< 0.1	< 0.1
Chem Lab	< 0.1	< 0.1	< 0.1	< 0.1
TSC BRE	< 0.1	< 0.1	< 0.1	< 0.1

TABLE 6.4.g

EMERGENCY RESPONSE FACILITY DATA (T = 06:00) (21:00)

Emergency Center	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf)	FLOOR, CONTAMINATION (cpm/100cm ²)
MCR	< 0.1	< 0.1	< 0.1	< 0.1
OSC	< 0.1	< 0.1	< 0.1	< 0.1
TSC	< 0.1	< 0.1	< 0.1	< 0.1
Chem Lab	< 0.1	< 0.1	< 0.1	< 0.1
TSC BRE	< 0.1	< 0.1	< 0.1	< 0.1

TABLE 6.4.h

EMERGENCY RESPONSE FACILITY DATA (T = 07:00) (22:00)

Emergency Center	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf)	FLOOR CONTAMINATION (cpm/100cm ²)
MCR	< 0.1	< 0.1	< 0.1	< 0.1
OSC	< 0.1	< 0.1	< 0.1	< 0.1
TSC	< 0.1	< 0.1	< 0.1	< 0.1
Chem Lab	< 0.1	< 0.1	< 0.1	< 0.1
TSC BRE	< 0.1	< 0.1	< 0.1	< 0.1

TABLE 6.4.i

EMERGENCY RESPONSE FACILITY DATA (T = 08:00) (23:00)

Emergency Center	CLOSED WINDOW (mR/hr)	OPEN WINDOW (mR/hr)	AIR SAMPLE COUNT RATE (cpm/cf)	FLOOR CONTAMINATION (cpm/100cm ²)
MCR	< 0.1	< 0.1	< 0.1	< 0.1
OSC	< 0.1	< 0.1	< 0.1	< 0.1
TSC	< 0.1	< 0.1	< 0.1	< 0.1
Chem Lab	< 0.1	< 0.1	< 0.1	< 0.1
TSC BRE	< 0.1	< 0.1	< 0.1	< 0.1

TABLE 7.1.a

NORTH STACK ACTIVITY CONCENTRATION (T = 00:00) (15:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-135	<LLD uCi/cc
Xe-135m	5.18E-11 uCi/cc

TOTAL GAS SAMPLE	5.24E-11 uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc

TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
La-142	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.1.b

NORTH STACK ACTIVITY CONCENTRATION (T = 01:00) (16:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration	
-----	-----	-----
Xe-135	<LLD	uCi/cc
Xe-135m	<LLD	uCi/cc

TOTAL GAS SAMPLE	<LLD	uCi/cc

I-132	<LLD	uCi/cc
I-133	<LLD	uCi/cc
I-134	<LLD	uCi/cc
I-135	<LLD	uCi/cc

TOTAL CHARCOAL SAMPLE	<LLD	uCi/cc

Sr-91	<LLD	uCi/cc
Sr-92	<LLD	uCi/cc
Ba-139	<LLD	uCi/cc
Y-92	<LLD	uCi/cc
La-142	<LLD	uCi/cc

TOTAL FILTER SAMPLE	<LLD	uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.1.c

NORTH STACK ACTIVITY CONCENTRATION (T = 02:00) (17:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration	
-----	-----	-----
Xe-133	<LLD	uCi/cc
Xe-135	<LLD	uCi/cc
Xe-135m	<LLD	uCi/cc

TOTAL GAS SAMPLE	<LLD	uCi/cc

I-132	<LLD	uCi/cc
I-133	<LLD	uCi/cc
I-134	<LLD	uCi/cc
I-135	<LLD	uCi/cc

TOTAL CHARCOAL SAMPLE	<LLD	uCi/cc

Sr-91	<LLD	uCi/cc
Sr-92	<LLD	uCi/cc
Ba-139	<LLD	uCi/cc
Y-92	<LLD	uCi/cc
La-142	<LLD	uCi/cc

TOTAL FILTER SAMPLE	<LLD	uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.1.d

NORTH STACK ACTIVITY CONCENTRATION (T = 03:00) (18:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-133	<LLD uCi/cc
Xe-135	<LLD uCi/cc
Xe-135m	<LLD uCi/cc

TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc

TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.1.e

NORTH STACK ACTIVITY CONCENTRATION (T = 04:00) (19:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	3.26E-09 uCi/cc
Kr-87	4.29E-09 uCi/cc
Kr-88	7.92E-09 uCi/cc
Xe-133	3.26E-08 uCi/cc
Xe-133m	1.10E-09 uCi/cc
Xe-135	9.15E-09 uCi/cc
Xe-135m	1.23E-09 uCi/cc
Xe-138	3.80E-09 uCi/cc

TOTAL GAS SAMPLE	6.36E-08 uCi/cc
Br-83	2.73E-11 uCi/cc
I-131	3.37E-10 uCi/cc
I-132	3.84E-10 uCi/cc
I-133	5.75E-10 uCi/cc
I-134	3.82E-10 uCi/cc
I-135	5.21E-10 uCi/cc

TOTAL CHARCOAL SAMPLE	2.25E-09 uCi/cc
Rb-88	2.96E-11 uCi/cc
Cs-138	5.29E-11 uCi/cc

TOTAL FILTER SAMPLE	8.26E-11 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
14. ml	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1
Charcoal Filter	mR/hr per cf < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.1.f

NORTH STACK ACTIVITY CONCENTRATION (T = 05:00) (20:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	9.07E-09 uCi/cc
Kr-87	8.18E-09 uCi/cc
Kr-88	2.02E-08 uCi/cc
Xe-133	1.06E-07 uCi/cc
Xe-133m	3.54E-09 uCi/cc
Xe-135	3.04E-08 uCi/cc

TOTAL GAS SAMPLE	1.79E-07 uCi/cc
Br-83	8.26E-11 uCi/cc
I-131	1.34E-09 uCi/cc
I-132	1.16E-09 uCi/cc
I-133	2.25E-09 uCi/cc
I-134	7.19E-10 uCi/cc
I-135	1.88E-09 uCi/cc

TOTAL CHARCOAL SAMPLE	7.45E-09 uCi/cc
Rb-88	7.55E-11 uCi/cc
Cs-138	1.62E-11 uCi/cc

TOTAL FILTER SAMPLE	9.19E-11 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
14. ml	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1
Charcoal Filter	mR/hr per cf < 0.1/ < 0.1 < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1 < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1 < 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.1.g

NORTH STACK ACTIVITY CONCENTRATION (T = 06:00) (21:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	2.50E-07 uCi/cc
Kr-87	1.54E-07 uCi/cc
Kr-88	5.10E-07 uCi/cc
Xe-133	3.40E-06 uCi/cc
Xe-133m	1.13E-07 uCi/cc
Xe-135	9.88E-07 uCi/cc

TOTAL GAS SAMPLE	5.45E-06 uCi/cc
I-131	1.40E-08 uCi/cc
I-132	9.04E-09 uCi/cc
I-133	2.29E-08 uCi/cc
I-134	3.39E-09 uCi/cc
I-135	1.78E-08 uCi/cc

TOTAL CHARCOAL SAMPLE	6.79E-08 uCi/cc
Rb-88	1.91E-09 uCi/cc

TOTAL FILTER SAMPLE	1.96E-09 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.1.h

NORTH STACK ACTIVITY CONCENTRATION (T = 07:00) (22:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	3.75E-07 uCi/cc
Kr-87	1.56E-07 uCi/cc
Kr-88	6.98E-07 uCi/cc
Xe-133	5.93E-06 uCi/cc
Xe-133m	1.95E-07 uCi/cc
Xe-135	1.62E-06 uCi/cc
TOTAL GAS SAMPLE	9.01E-06 uCi/cc
I-131	7.94E-09 uCi/cc
I-132	3.79E-09 uCi/cc
I-133	1.26E-08 uCi/cc
I-134	8.70E-10 uCi/cc
I-135	9.12E-09 uCi/cc
TOTAL CHARCOAL SAMPLE	3.46E-08 uCi/cc
Rb-88	2.61E-09 uCi/cc
TOTAL FILTER SAMPLE	2.62E-09 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
14. ml	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1
Charcoal	mR/hr per cf < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.1.i

NORTH STACK ACTIVITY CONCENTRATION (T = 08:00) (23:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	4.41E-07 uCi/cc
Kr-87	1.24E-07 uCi/cc
Kr-88	7.51E-07 uCi/cc
Xe-133	8.13E-06 uCi/cc
Xe-133m	2.65E-07 uCi/cc
Xe-135	2.08E-06 uCi/cc
TOTAL GAS SAMPLE	1.19E-05 uCi/cc
I-131	6.63E-09 uCi/cc
I-132	2.35E-09 uCi/cc
I-133	1.02E-08 uCi/cc
I-134	3.32E-10 uCi/cc
I-135	6.89E-09 uCi/cc
TOTAL CHARCOAL SAMPLE	2.66E-08 uCi/cc
Rb-88	2.81E-09 uCi/cc
TOTAL FILTER SAMPLE	2.81E-09 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.2.a

SOUTH STACK ACTIVITY CONCENTRATION (T = 00:00) (15:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-135	1.89E-11 uCi/cc
Xe-135m	1.43E-09 uCi/cc
TOTAL GAS SAMPLE	1.45E-09 uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	2.94E-11 uCi/cc
I-135	<LLD uCi/cc
TOTAL CHARCOAL SAMPLE	5.41E-11 uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
La-142	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
14. ml	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1
Charcoal Filter	mR/hr per cf < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.2.b

SOUTH STACK ACTIVITY CONCENTRATION (T = 01:00) (16:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-135	2.39E-11 uCi/cc
Xe-135m	9.56E-11 uCi/cc
TOTAL GAS SAMPLE	1.20E-10 uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	1.92E-11 uCi/cc
I-135	<LLD uCi/cc
TOTAL CHARCOAL SAMPLE	4.93E-11 uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
14. ml	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1
Charcoal	mR/hr per cf < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.2.c

SOUTH STACK ACTIVITY CONCENTRATION (T = 02:00) (17:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-133	<LLD uCi/cc
Xe-135	2.91E-11 uCi/cc
Xe-135m	<LLD uCi/cc

TOTAL GAS SAMPLE	3.58E-11 uCi/cc

I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	1.80E-11 uCi/cc

TOTAL CHARCOAL SAMPLE	4.83E-11 uCi/cc

Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.2.d

SOUTH STACK ACTIVITY CONCENTRATION (T = 03:00) (18:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-133	<LLD uCi/cc
Xe-135	3.56E-11 uCi/cc
Xe-135m	<LLD uCi/cc

TOTAL GAS SAMPLE	3.72E-11 uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	2.23E-11 uCi/cc

TOTAL CHARCOAL SAMPLE	5.07E-11 uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.2.e

SOUTH STACK ACTIVITY CONCENTRATION (T = 04:00) (19:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-133	<LLD uCi/cc
Xe-135	3.43E-11 uCi/cc
TOTAL GAS SAMPLE	3.56E-11 uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	2.04E-11 uCi/cc
TOTAL CHARCOAL SAMPLE	4.20E-11 uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
14. ml	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1
Charcoal Filter	mR/hr per cf < 0.1/ < 0.1 < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1 < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1 < 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.2.f

SOUTH STACK ACTIVITY CONCENTRATION (T = 05:00) (20:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-133	<LLD uCi/cc
Xe-135	3.26E-11 uCi/cc
TOTAL GAS SAMPLE	3.40E-11 uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	1.84E-11 uCi/cc
TOTAL CHARCOAL SAMPLE	3.57E-11 uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.2.g

SOUTH STACK ACTIVITY CONCENTRATION (T = 06:00) (21:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-133	<LLD uCi/cc
Xe-135	3.10E-11 uCi/cc

TOTAL GAS SAMPLE	3.24E-11 uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	1.66E-11 uCi/cc

TOTAL CHARCOAL SAMPLE	3.11E-11 uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.2.h

SOUTH STACK ACTIVITY CONCENTRATION (T = 07:00) (22:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-133	<LLD uCi/cc
Xe-135	2.94E-11 uCi/cc

TOTAL GAS SAMPLE	3.08E-11 uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	1.50E-11 uCi/cc

TOTAL CHARCOAL SAMPLE	2.77E-11 uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
14. ml	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1
Charcoal	mR/hr per cf < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.2.1

SOUTH STACK ACTIVITY CONCENTRATION (T = 08:00) (23:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-133	<LLD uCi/cc
Xe-135	2.79E-11 uCi/cc
TOTAL GAS SAMPLE	2.93E-11 uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-135	<LLD uCi/cc
TOTAL CHARCOAL SAMPLE	2.49E-11 uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Y-92	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

TABLE 7.3.a

DRYWELL GAS ACTIVITY CONCENTRATION (T = 00:00) (15:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	8.27E-08 uCi/cc
Kr-87	1.26E-07 uCi/cc
Kr-88	1.96E-07 uCi/cc
Xe-133	3.87E-07 uCi/cc
Xe-135	1.07E-07 uCi/cc
Xe-135m	4.91E-08 uCi/cc

TOTAL GAS SAMPLE	9.57E-07 uCi/cc
I-131	9.10E-11 uCi/cc
I-132	2.43E-10 uCi/cc
I-133	2.95E-10 uCi/cc
I-134	7.56E-10 uCi/cc
I-135	2.93E-10 uCi/cc

TOTAL CHARCOAL SAMPLE	1.68E-09 uCi/cc
Rb-88	1.11E-08 uCi/cc

TOTAL FILTER SAMPLE	1.12E-08 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 3.0%
Chlorine Concentration: .0 ppm

Cladding Failure: 0.% Fuel Melt: 0.%

TABLE 7.3.b

DRYWELL GAS ACTIVITY CONCENTRATION (T = 01:00) (16:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	7.03E-08 uCi/cc
Kr-87	7.28E-08 uCi/cc
Kr-88	1.52E-07 uCi/cc
Xe-133	3.83E-07 uCi/cc
Xe-133m	9.01E-09 uCi/cc
Xe-135	1.01E-07 uCi/cc
Xe-135m	9.60E-09 uCi/cc
TOTAL GAS SAMPLE	7.97E-07 uCi/cc
I-132	3.21E-10 uCi/cc
I-133	2.05E-10 uCi/cc
I-134	6.15E-10 uCi/cc
I-135	4.71E-10 uCi/cc
TOTAL CHARCOAL SAMPLE	1.62E-09 uCi/cc
Rb-88	1.10E-08 uCi/cc
TOTAL FILTER SAMPLE	1.11E-08 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 3.0%
Chlorine Concentration: .0 ppm

Cladding Failure: 0.% Fuel Melt: 0.%

TABLE 7.3.c

DRYWELL GAS ACTIVITY CONCENTRATION (T = 02:00) (17:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	5.98E-08 uCi/cc
Kr-87	4.19E-08 uCi/cc
Kr-88	1.18E-07 uCi/cc
Xe-133	3.79E-07 uCi/cc
Xe-133m	8.86E-09 uCi/cc
Xe-135	9.47E-08 uCi/cc
-----	-----
TOTAL GAS SAMPLE	7.04E-07 uCi/cc
I-132	3.35E-10 uCi/cc
I-133	2.62E-10 uCi/cc
I-134	3.97E-10 uCi/cc
I-135	5.98E-10 uCi/cc
-----	-----
TOTAL CHARCOAL SAMPLE	1.59E-09 uCi/cc
Rb-88	8.60E-09 uCi/cc
-----	-----
TOTAL FILTER SAMPLE	8.75E-09 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 2.6%
Chlorine Concentration: .0 ppm

Cladding Failure: 0.% Fuel Melt: 0.%

TABLE 7.3.d

DRYWELL GAS ACTIVITY CONCENTRATION (T = 03:00) (18:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	5.09E-08 uCi/cc
Kr-87	2.42E-08 uCi/cc
Kr-88	9.18E-08 uCi/cc
Xe-133	3.76E-07 uCi/cc
Xe-133m	8.72E-09 uCi/cc
Xe-135	8.97E-08 uCi/cc
-----	-----
TOTAL GAS SAMPLE	6.41E-07 uCi/cc
I-132	3.42E-10 uCi/cc
I-133	3.47E-10 uCi/cc
I-134	2.51E-10 uCi/cc
I-135	7.42E-10 uCi/cc
-----	-----
TOTAL CHARCOAL SAMPLE	1.68E-09 uCi/cc
Rb-88	6.69E-09 uCi/cc
-----	-----
TOTAL FILTER SAMPLE	6.82E-09 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 3.0%
Chlorine Concentration: .0 ppm

Cladding Failure: 0.% Fuel Melt: 0.%

TABLE 7.3.e

DRYWELL GAS ACTIVITY CONCENTRATION (T = 04:00) (19:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	3.66E-01 uCi/cc
Kr-87	4.75E-01 uCi/cc
Kr-88	8.88E-01 uCi/cc
Xe-133	3.69E+00 uCi/cc
Xe-133m	1.25E-01 uCi/cc
Xe-135	1.05E+00 uCi/cc
Xe-135m	1.27E-01 uCi/cc
Xe-138	3.95E-01 uCi/cc

TOTAL GAS SAMPLE	7.15E+00 uCi/cc
Br-83	3.41E-03 uCi/cc
I-131	4.24E-02 uCi/cc
I-132	4.80E-02 uCi/cc
I-133	7.25E-02 uCi/cc
I-134	4.72E-02 uCi/cc
I-135	6.52E-02 uCi/cc

TOTAL CHARCOAL SAMPLE	2.81E-01 uCi/cc
Rb-88	6.78E-02 uCi/cc
Cs-137	3.16E-02 uCi/cc
Cs-138	3.98E-01 uCi/cc

TOTAL FILTER SAMPLE	5.33E-01 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
14. ml	mR/hr 15./ 0.5	mR/hr 0.5/ < 0.1	mR/hr < 0.1/ < 0.1
Charcoal	mR/hr per cf 1100./ 39.	mR/hr per cf 40./ 1.4	mR/hr per cf 2.5/ < 0.1
Filter	2000./ 69.	71./ 2.5	4.4/ 0.2

Hydrogen Concentration: .8%
Oxygen Concentration: .9%
Chlorine Concentration: .0 ppm

Cladding Failure: 1.% Fuel Melt: 0.%

TABLE 7.3.f

DRYWELL GAS ACTIVITY CONCENTRATION (T = 05:00) (20:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	2.46E+01 uCi/cc
Kr-87	2.18E+01 uCi/cc
Kr-88	5.47E+01 uCi/cc
Xe-133	2.90E+02 uCi/cc
Xe-133m	9.68E+00 uCi/cc
Xe-135	8.94E+01 uCi/cc

TOTAL GAS SAMPLE	4.97E+02 uCi/cc
Br-83	4.32E-01 uCi/cc
I-131	7.11E+00 uCi/cc
I-132	6.09E+00 uCi/cc
I-133	1.19E+01 uCi/cc
I-134	3.64E+00 uCi/cc
I-135	9.92E+00 uCi/cc

TOTAL CHARCOAL SAMPLE	3.92E+01 uCi/cc
Rb-88	1.91E+00 uCi/cc
Cs-134	1.69E+00 uCi/cc
Cs-137	3.33E+00 uCi/cc
Cs-138	8.47E+00 uCi/cc

TOTAL FILTER SAMPLE	1.55E+01 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	900./ 31.	28./ 1.0	1.7/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal	1.3E5/ 4600.	4100./ 140.	250./ 8.6
Filter	5.0E4/ 1700.	1500./ 53.	93./ 3.2

Hydrogen Concentration: .9%
Oxygen Concentration: .7%
Chlorine Concentration: .0 ppm

Cladding Failure: 3.% Fuel Melt: 0.%

TABLE 7.3.g

DRYWELL GAS ACTIVITY CONCENTRATION (T = 06:00) (21:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	3.14E+01 uCi/cc
Kr-87	1.88E+01 uCi/cc
Kr-88	6.37E+01 uCi/cc
Xe-133	4.31E+02 uCi/cc
Xe-133m	1.43E+01 uCi/cc
Xe-135	1.25E+02 uCi/cc

TOTAL GAS SAMPLE	6.87E+02 uCi/cc
I-131	9.09E-01 uCi/cc
I-132	5.71E-01 uCi/cc
I-133	1.48E+00 uCi/cc
I-134	2.06E-01 uCi/cc
I-135	1.14E+00 uCi/cc

TOTAL CHARCOAL SAMPLE	4.35E+00 uCi/cc
Rb-88	4.50E+00 uCi/cc
Cs-134	1.10E+00 uCi/cc
Cs-137	2.16E+00 uCi/cc
Cs-138	1.81E+00 uCi/cc

TOTAL FILTER SAMPLE	9.57E+00 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
14. ml	mR/hr 1100./ 37.	mR/hr 32./ 1.1	mR/hr 2.1/ < 0.1
Charcoal	mR/hr per cf 1.3E4/ 440.	mR/hr per cf 380./ 13.	mR/hr per cf 25./ 0.9
Filter	2.6E4/ 920.	790./ 28.	52./ 1.8

Hydrogen Concentration: .9%
Oxygen Concentration: .6%
Chlorine Concentration: .0 ppm

Cladding Failure: 3.% Fuel Melt: 0.%

TABLE 7.3.h

DRYWELL GAS ACTIVITY CONCENTRATION (T = 07:00) (22:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	2.68E+01 uCi/cc
Kr-87	1.09E+01 uCi/cc
Kr-88	4.96E+01 uCi/cc
Xe-133	4.28E+02 uCi/cc
Xe-133m	1.41E+01 uCi/cc
Xe-135	1.15E+02 uCi/cc

TOTAL GAS SAMPLE	6.48E+02 uCi/cc
I-131	7.63E-02 uCi/cc
I-132	3.53E-02 uCi/cc
I-133	1.20E-01 uCi/cc
I-134	7.68E-03 uCi/cc
I-135	8.66E-02 uCi/cc

TOTAL CHARCOAL SAMPLE	3.29E-01 uCi/cc
Rb-88	3.61E+00 uCi/cc
Cs-134	4.65E-01 uCi/cc
Cs-137	9.15E-01 uCi/cc

TOTAL FILTER SAMPLE	5.23E+00 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
14. ml	mR/hr 910./ 32.	mR/hr 25./ 0.9	mR/hr 1.6/ < 0.1
Charcoal Filter	mR/hr per cf 870./ 30. 1.3E4/ 450.	mR/hr per cf 24./ 0.8 360./ 12.	mR/hr per cf 1.6/ < 0.1 24./ 0.8

Hydrogen Concentration: .9%
Oxygen Concentration: .6%
Chlorine Concentration: .0 ppm

Cladding Failure: 3.% Fuel Melt: 0.%

TABLE 7.3.1

DRYWELL GAS ACTIVITY CONCENTRATION (T = 08:00) (23:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	2.28E+01 uCi/cc
Kr-87	6.27E+00 uCi/cc
Kr-88	3.85E+01 uCi/cc
Xe-133	4.24E+02 uCi/cc
Xe-133m	1.38E+01 uCi/cc
Xe-135	1.07E+02 uCi/cc

TOTAL GAS SAMPLE	6.15E+02 uCi/cc

I-131	1.39E-02 uCi/cc
I-132	4.81E-03 uCi/cc
I-133	2.13E-02 uCi/cc
I-134	6.53E-04 uCi/cc
I-135	1.43E-02 uCi/cc

TOTAL CHARCOAL SAMPLE	5.53E-02 uCi/cc

Rb-88	2.81E+00 uCi/cc
Cs-134	2.02E-01 uCi/cc
Cs-137	3.98E-01 uCi/cc

TOTAL FILTER SAMPLE	3.44E+00 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	800./ 28.	20./ 0.7	1.3/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal	130./ 4.6	3.3/ 0.1	0.2/ < 0.1
Filter	7900./ 270.	200./ 6.9	13./ 0.4

Hydrogen Concentration: .9%
Oxygen Concentration: .6%
Chlorine Concentration: .0 ppm

Cladding Failure: 3.% Fuel Melt: 0.%

TABLE 7.4.a

WETWELL GAS ACTIVITY CONCENTRATION (T = 00:00) (15:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	9.70E-09 uCi/cc
Kr-87	1.48E-08 uCi/cc
Kr-88	2.30E-08 uCi/cc
Xe-133	4.53E-08 uCi/cc
Xe-133m	1.08E-09 uCi/cc
Xe-135	1.25E-08 uCi/cc
TOTAL GAS SAMPLE	1.06E-07 uCi/cc
I-131	3.81E-10 uCi/cc
I-133	9.64E-11 uCi/cc
TOTAL CHARCOAL SAMPLE	4.77E-10 uCi/cc
Rb-88	1.40E-09 uCi/cc
TOTAL FILTER SAMPLE	1.40E-09 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 1.0%
Chlorine Concentration: .0 ppm

TABLE 7.4.b

WETWELL GAS ACTIVITY CONCENTRATION (T = 01:00) (16:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	8.26E-09 uCi/cc
Kr-87	8.55E-09 uCi/cc
Kr-88	1.79E-08 uCi/cc
Xe-133	4.49E-08 uCi/cc
Xe-133m	1.06E-09 uCi/cc
Xe-135	1.16E-08 uCi/cc
TOTAL GAS SAMPLE	9.22E-08 uCi/cc
I-131	8.69E-10 uCi/cc
I-133	1.26E-10 uCi/cc
TOTAL CHARCOAL SAMPLE	9.95E-10 uCi/cc
Rb-88	1.50E-09 uCi/cc
TOTAL FILTER SAMPLE	1.50E-09 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 1.0%
Chlorine Concentration: .0 ppm

TABLE 7.4.c

WETWELL GAS ACTIVITY CONCENTRATION (T = 02:00) (17:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	7.02E-09 uCi/cc
Kr-87	4.93E-09 uCi/cc
Kr-88	1.39E-08 uCi/cc
Xe-133	4.45E-08 uCi/cc
Xe-133m	1.04E-09 uCi/cc
Xe-135	1.07E-08 uCi/cc
TOTAL GAS SAMPLE	8.21E-08 uCi/cc
I-131	1.17E-09 uCi/cc
I-133	1.42E-10 uCi/cc
TOTAL CHARCOAL SAMPLE	1.32E-09 uCi/cc
Rb-88	1.19E-09 uCi/cc
TOTAL FILTER SAMPLE	1.19E-09 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
14. ml	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1
Charcoal	mR/hr per cf < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%

Oxygen Concentration: 1.0%

Chlorine Concentration: .0 ppm

TABLE 7.4.d

WETWELL GAS ACTIVITY CONCENTRATION (T = 03:00) (18:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	5.97E-09 uCi/cc
Kr-87	2.84E-09 uCi/cc
Kr-88	1.08E-08 uCi/cc
Xe-133	4.41E-08 uCi/cc
Xe-133m	1.02E-09 uCi/cc
Xe-135	9.87E-09 uCi/cc
TOTAL GAS SAMPLE	7.46E-08 uCi/cc
I-131	1.36E-09 uCi/cc
I-133	1.50E-10 uCi/cc
TOTAL CHARCOAL SAMPLE	1.51E-09 uCi/cc
Rb-88	9.24E-10 uCi/cc
TOTAL FILTER SAMPLE	9.24E-10 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 1.0%
Chlorine Concentration: .0 ppm

TABLE 7.4.e

WETWELL GAS ACTIVITY CONCENTRATION (T = 04:00) (19:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	3.25E-02 uCi/cc
Kr-87	4.11E-02 uCi/cc
Kr-88	7.82E-02 uCi/cc
Xe-133	3.29E-01 uCi/cc
Xe-133m	1.11E-02 uCi/cc
Xe-135	8.91E-02 uCi/cc
Xe-135m	9.43E-03 uCi/cc
Xe-138	2.98E-02 uCi/cc

TOTAL GAS SAMPLE	6.24E-01 uCi/cc
Br-83	5.02E-05 uCi/cc
I-131	6.35E-04 uCi/cc
I-132	7.02E-04 uCi/cc
I-133	1.08E-03 uCi/cc
I-134	6.71E-04 uCi/cc
I-135	9.72E-04 uCi/cc

TOTAL CHARCOAL SAMPLE	4.14E-03 uCi/cc
Rb-88	6.02E-03 uCi/cc
Cs-138	2.91E-02 uCi/cc

TOTAL FILTER SAMPLE	3.57E-02 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
14. ml	mR/hr 1.3/ < 0.1	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1
Charcoal	mR/hr per cf 16./ 0.6	mR/hr per cf 0.6/ < 0.1	mR/hr per cf < 0.1/ < 0.1
Filter	130./ 4.6	4.9/ 0.2	0.3/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 1.0%
Chlorine Concentration: .0 ppm

TABLE 7.4.f

WETWELL GAS ACTIVITY CONCENTRATION (T = 05:00) (20:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	2.41E+00 uCi/cc
Kr-87	2.14E+00 uCi/cc
Kr-88	5.35E+00 uCi/cc
Xe-133	2.83E+01 uCi/cc
Xe-133m	9.44E-01 uCi/cc
Xe-135	8.67E+00 uCi/cc

TOTAL GAS SAMPLE	4.84E+01 uCi/cc
Br-83	4.42E-03 uCi/cc
I-131	7.24E-02 uCi/cc
I-132	6.23E-02 uCi/cc
I-133	1.22E-01 uCi/cc
I-134	3.76E-02 uCi/cc
I-135	1.01E-01 uCi/cc

TOTAL CHARCOAL SAMPLE	4.01E-01 uCi/cc
Rb-88	6.52E-02 uCi/cc
Cs-134	1.66E-02 uCi/cc
Cs-137	3.27E-02 uCi/cc
Cs-138	1.00E-01 uCi/cc

TOTAL FILTER SAMPLE	2.16E-01 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
14. ml	mR/hr 83./ 2.9	mR/hr 2.7/ < 0.1	mR/hr 0.2/ < 0.1
Charcoal	mR/hr per cf 1300./ 44.	mR/hr per cf 41./ 1.4	mR/hr per cf 2.7/ < 0.1
Filter	650./ 23.	21./ 0.7	1.4/ < 0.1

Hydrogen Concentration: 2.5%
Oxygen Concentration: 1.0%
Chlorine Concentration: .0 ppm

TABLE 7.4.g

WETWELL GAS ACTIVITY CONCENTRATION (T = 06:00) (21:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	4.26E+00 uCi/cc
Kr-87	2.57E+00 uCi/cc
Kr-88	8.65E+00 uCi/cc
Xe-133	5.83E+01 uCi/cc
Xe-133m	1.93E+00 uCi/cc
Xe-135	1.68E+01 uCi/cc

TOTAL GAS SAMPLE	9.30E+01 uCi/cc
I-131	1.04E-01 uCi/cc
I-132	6.61E-02 uCi/cc
I-133	1.69E-01 uCi/cc
I-134	2.44E-02 uCi/cc
I-135	1.31E-01 uCi/cc

TOTAL CHARCOAL SAMPLE	4.99E-01 uCi/cc
Rb-88	6.83E-01 uCi/cc
Cs-137	4.86E-02 uCi/cc
Cs-138	9.52E-02 uCi/cc

TOTAL FILTER SAMPLE	8.52E-01 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	140./ 5.0	4.4/ 0.2	0.3/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	1400./ 50.	44./ 1.5	2.9/ < 0.1
	2300./ 81.	71./ 2.5	4.7/ 0.2

Hydrogen Concentration: 4.9%
Oxygen Concentration: 1.0%
Chlorine Concentration: .0 ppm

TABLE 7.4.h

WETWELL GAS ACTIVITY CONCENTRATION (T = 07:00) (22:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Fr-85m	3.54E+00 uCi/cc
Kr-87	1.45E+00 uCi/cc
Kr-88	6.56E+00 uCi/cc
Xe-133	5.64E+01 uCi/cc
Xe-133m	1.85E+00 uCi/cc
Xe-135	1.51E+01 uCi/cc
TOTAL GAS SAMPLE	8.54E+01 uCi/cc
I-131	7.56E-02 uCi/cc
I-132	3.58E-02 uCi/cc
I-133	1.20E-01 uCi/cc
I-134	8.12E-03 uCi/cc
I-135	8.65E-02 uCi/cc
TOTAL CHARCOAL SAMPLE	3.28E-01 uCi/cc
Rb-88	5.59E-01 uCi/cc
Cs-137	3.56E-02 uCi/cc
TOTAL FILTER SAMPLE	6.35E-01 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	120./ 4.2	3.4/ 0.1	0.2/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	870./ 30.	24./ 0.8	1.6/ < 0.1
	1600./ 55.	44./ 1.5	2.9/ < 0.1
	Hydrogen Concentration:	4.9%	
	Oxygen Concentration:	1.0%	
	Chlorine Concentration:	.0 ppm	

TABLE 7.4.i

WETWELL GAS ACTIVITY CONCENTRATION (T = 08:00) (23:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	3.00E+00 uCi/cc
Kr-87	8.32E-01 uCi/cc
Kr-88	5.09E+00 uCi/cc
Xe-133	5.58E+01 uCi/cc
Xe-133m	1.82E+00 uCi/cc
Xe-135	1.40E+01 uCi/cc
TOTAL GAS SAMPLE	8.10E+01 uCi/cc
I-131	5.96E-02 uCi/cc
I-132	2.10E-02 uCi/cc
I-133	9.16E-02 uCi/cc
I-134	2.92E-03 uCi/cc
I-135	6.18E-02 uCi/cc
TOTAL CHARCOAL SAMPLE	2.38E-01 uCi/cc
Rb-88	4.36E-01 uCi/cc
Cs-137	2.82E-02 uCi/cc
TOTAL FILTER SAMPLE	4.83E-01 uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	110./ 3.7	2.7/ < 0.1	0.2/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	580./ 20.	15./ 0.5	0.9/ < 0.1
	1100./ 39.	28./ 1.0	1.8/ < 0.1
	Hydrogen Concentration:	4.9%	
	Oxygen Concentration:	1.0%	
	Chlorine Concentration:	.0 ppm	

TABLE 7.5.a

REACTOR BLDG ACTIVITY CONCENTRATION (T = 00:00) (15:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-135	3.21E-11 uCi/cc
Xe-135m	2.21E-09 uCi/cc
TOTAL GAS SAMPLE	2.25E-09 uCi/cc
I-132	1.57E-11 uCi/cc
I-133	<LLD uCi/cc
I-134	4.86E-11 uCi/cc
I-135	1.89E-11 uCi/cc
TOTAL CHARCOAL SAMPLE	9.04E-11 uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
La-142	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal Filter	mR/hr per cf < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: 0.5 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm2
Wall and Equipment Contamination: < 0.1 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 5.6E+3 Hours
Stay Time: ? DAC hr (in mask): 2.8E+5 Hours
Stay Time: 2 DAC hr (in SCBA): 2.8E+7 Hours

TABLE 7.5.b

REACTOR BLDG ACTIVITY CONCENTRATION (T = 01:00) (16:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-135	4.03E-11 uCi/cc
Xe-135m	1.46E-10 uCi/cc
TOTAL GAS SAMPLE	1.87E-10 uCi/cc
I-132	1.65E-11 uCi/cc
I-133	<LLD uCi/cc
I-134	3.17E-11 uCi/cc
I-135	2.43E-11 uCi/cc
TOTAL CHARCOAL SAMPLE	8.24E-11 uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: 0.5 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute
Stay Time: 2 DAC hr (no mask): 1.2E+4 Hours
Stay Time: 2 DAC hr (in mask): 6.2E+5 Hours
Stay Time: 2 DAC hr (in SCBA): 6.2E+7 Hours

TABLE 7.5.c

REACTOR BLDG ACTIVITY CONCENTRATION (T = 02:00) (17:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-133	<LLD uCi/cc
Xe-135	4.90E-11 uCi/cc
Xe-135m	<LLD uCi/cc

TOTAL GAS SAMPLE	5.94E-11 uCi/cc

I-132	1.70E-11 uCi/cc
I-133	<LLD uCi/cc
I-134	2.02E-11 uCi/cc
I-135	3.04E-11 uCi/cc

TOTAL CHARCOAL SAMPLE	8.09E-11 uCi/cc

Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: 0.5 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm2
Wall and Equipment Contamination: < 0.1 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 1.1E+4 Hours
Stay Time: 2 DAC hr (in mask): 5.3E+5 Hours
Stay Time: 2 DAC hr (in SCBA): 5.3E+7 Hours

TABLE 7.5.d

REACTOR BLDG ACTIVITY CONCENTRATION (T = 03:00) (18:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-133	<LLD uCi/cc
Xe-135	5.99E-11 uCi/cc
TOTAL GAS SAMPLE	6.26E-11 uCi/cc
I-132	1.73E-11 uCi/cc
I-133	1.75E-11 uCi/cc
I-134	<LLD uCi/cc
I-135	3.75E-11 uCi/cc
TOTAL CHARCOAL SAMPLE	8.51E-11 uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Charcoal	mR/hr per cf	mR/hr per cf	mR/hr per cf
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: 0.5 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm2
Wall and Equipment Contamination: < 0.1 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 8.3E+3 Hours
Stay Time: 2 DAC hr (in mask): 4.1E+5 Hours
Stay Time: 2 DAC hr (in SCBA): 4.1E+7 Hours

TABLE 7.5.e

REACTOR BLDG ACTIVITY CONCENTRATION (T = 03:15) (18:15)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	2.19E-07 uCi/cc
Kr-87	3.70E-07 uCi/cc
Kr-88	5.64E-07 uCi/cc
Xe-133	1.98E-06 uCi/cc
Xe-133m	6.74E-08 uCi/cc
Xe-135	5.69E-07 uCi/cc
Xe-135m	4.12E-07 uCi/cc
Xe-138	1.10E-06 uCi/cc
TOTAL GAS SAMPLE	5.31E-06 uCi/cc
Br-83	8.71E-09 uCi/cc
Br-84	1.19E-08 uCi/cc
I-131	8.92E-08 uCi/cc
I-132	1.23E-07 uCi/cc
I-133	5.54E-07 uCi/cc
I-134	1.69E-07 uCi/cc
I-135	1.47E-07 uCi/cc
TOTAL CHARCOAL SAMPLE	7.04E-07 uCi/cc
Rb-88	1.39E-07 uCi/cc
Rb-89	1.47E-07 uCi/cc
Cs-138	7.16E-07 uCi/cc
TOTAL FILTER SAMPLE	1.06E-06 uCi/cc

CONTINUED ON NEXT PAGE

TABLE 7.5.e

REACTOR BLDG ACTIVITY CONCENTRATION (T = 03:15) (18:15)
(continued)

Provide current Chem data 30 minutes after sample request

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 1.7 mRad/hr
Airborne Thyroid Dose Rate: 260. mRem/hr
Net Air Sample Contact Rate: 1.0E4 cpm/cf sample

Floor Contamination: 11. cpm/100cm2
Wall and Equipment Contamination: 1.1 cpm/100cm2
Personnel Contamination Rate: 0.6 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 2.4E-1 Hours
Stay Time: 2 DAC hr (in mask): 1.2E+1 Hours
Stay Time: 2 DAC hr (in SCBA): 1.2E+3 Hours

TABLE 7.5.f

REACTOR BLDG ACTIVITY CONCENTRATION (T = 03:30) (18:30)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	5.38E-07 uCi/cc
Kr-87	8.36E-07 uCi/cc
Kr-88	1.36E-06 uCi/cc
Xe-133	5.05E-06 uCi/cc
Xe-133m	1.71E-07 uCi/cc
Xe-135	1.44E-06 uCi/cc
Xe-135m	5.86E-07 uCi/cc
Xe-138	1.65E-06 uCi/cc
TOTAL GAS SAMPLE	1.17E-05 uCi/cc
Br-83	1.45E-08 uCi/cc
Br-84	1.58E-08 uCi/cc
I-131	1.59E-07 uCi/cc
I-132	2.05E-07 uCi/cc
I-133	2.73E-07 uCi/cc
I-134	2.53E-07 uCi/cc
I-135	2.56E-07 uCi/cc
TOTAL CHARCOAL SAMPLE	1.18E-06 uCi/cc
Rb-88	2.15E-07 uCi/cc
Rb-89	1.70E-07 uCi/cc
Cs-138	1.38E-06 uCi/cc
TOTAL FILTER SAMPLE	1.89E-06 uCi/cc

CONTINUED ON NEXT PAGE

TABLE 7.5.f

REACTOR BLDG ACTIVITY CONCENTRATION (T = 03:30) (18:30)
(continued)

Provide current Chem data 30 minutes after sample request

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 3.5 mRad/hr
Airborne Thyroid Dose Rate: 460. mRem/hr
Net Air Sample Contact Rate: 1.7E4 cpm/cf sample

Floor Contamination: 66. cpm/100cm2
Wall and Equipment Contamination: 6.6 cpm/100cm2
Personnel Contamination Rate: 1.0 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 1.3E-1 Hours
Stay Time: 2 DAC hr (in mask): 6.5E+0 Hours
Stay Time: 2 DAC hr (in SCBA): 6.5E+2 Hours

TABLE 7.5.g

REACTOR BLDG ACTIVITY CONCENTRATION (T = 03:45) (18:45)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	7.68E-07 uCi/cc
Kr-87	1.09E-06 uCi/cc
Kr-88	1.90E-06 uCi/cc
Xe-133	7.46E-06 uCi/cc
Xe-133m	2.53E-07 uCi/cc
Xe-135	2.11E-06 uCi/cc
Xe-135m	4.65E-07 uCi/cc
Xe-138	1.38E-06 uCi/cc
TOTAL GAS SAMPLE	1.55E-05 uCi/cc
Br-83	1.16E-08 uCi/cc
Br-84	9.78E-09 uCi/cc
I-131	1.35E-07 uCi/cc
I-132	1.63E-07 uCi/cc
I-133	2.31E-07 uCi/cc
I-134	1.78E-07 uCi/cc
I-135	2.13E-07 uCi/cc
TOTAL CHARCOAL SAMPLE	9.41E-07 uCi/cc
Rb-88	2.11E-07 uCi/cc
Rb-89	1.00E-07 uCi/cc
Cs-137	9.56E-08 uCi/cc
Cs-138	1.43E-06 uCi/cc
TOTAL FILTER SAMPLE	1.88E-06 uCi/cc

CONTINUED ON NEXT PAGE

TABLE 7.5.g

REACTOR BLDG ACTIVITY CONCENTRATION (T = 03:45) (18:45)
(continued)

Provide current Chem data 30 minutes after sample request

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 4.4 mRad/hr
Airborne Thyroid Dose Rate: 390. mRem/hr
Net Air Sample Contact Rate: 1.6E4 cpm/cf sample

Floor Contamination: 130. cpm/100cm2
Wall and Equipment Contamination: 13. cpm/100cm2
Personnel Contamination Rate: 0.9 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 1.4E-1 Hours
Stay Time: 2 DAC hr (in mask): 7.0E+0 Hours
Stay Time: 2 DAC hr (in SCBA): 7.0E+2 Hours

TABLE 7.5.h

REACTOR BLDG ACTIVITY CONCENTRATION (T = 04:00) (19:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	1.08E-06 uCi/cc
Kr-87	1.39E-06 uCi/cc
Kr-88	2.60E-06 uCi/cc
Xe-133	1.08E-05 uCi/cc
Xe-133m	3.67E-07 uCi/cc
Xe-135	3.04E-06 uCi/cc
Xe-135m	3.60E-07 uCi/cc
Xe-138	1.12E-06 uCi/cc

TOTAL GAS SAMPLE	2.09E-05 uCi/cc
Br-83	1.01E-08 uCi/cc
I-131	1.26E-07 uCi/cc
I-132	1.41E-07 uCi/cc
I-133	2.14E-07 uCi/cc
I-134	1.37E-07 uCi/cc
I-135	1.93E-07 uCi/cc

TOTAL CHARCOAL SAMPLE	8.29E-07 uCi/cc
Rb-88	2.35E-07 uCi/cc
Cs-137	1.11E-07 uCi/cc
Cs-138	1.42E-06 uCi/cc

TOTAL FILTER SAMPLE	1.88E-06 uCi/cc

CONTINUED ON NEXT PAGE

TABLE 7.5.h

REACTOR BLDG ACTIVITY CONCENTRATION (T = 04:00) (19:00)
(continued)

Provide current Chem data 30 minutes after sample request

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 5.6 mRad/hr
Airborne Thyroid Dose Rate: 370. mRem/hr
Net Air Sample Contact Rate: 1.5E4 cpm/cf sample

Floor Contamination: 170. cpm/100cm²
Wall and Equipment Contamination: 17. cpm/100cm²
Personnel Contamination Rate: 0.8 cpm/100cm² per minute
Stay Time: 2 DAC hr (no mask): 1.4E-1 Hours
Stay Time: 2 DAC hr (in mask): 6.9E+0 Hours
Stay Time: 2 DAC hr (in SCBA): 6.9E+2 Hours

TABLE 7.5.1

REACTOR BLDG ACTIVITY CONCENTRATION (T = 04:15) (19:15)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	1.28E-06 uCi/cc
Kr-87	1.50E-06 uCi/cc
Kr-88	3.02E-06 uCi/cc
Xe-133	1.34E-05 uCi/cc
Xe-133m	4.51E-07 uCi/cc
Xe-135	3.70E-06 uCi/cc
Xe-138	7.62E-07 uCi/cc
TOTAL GAS SAMPLE	2.44E-05 uCi/cc
Br-83	7.93E-09 uCi/cc
I-131	1.07E-07 uCi/cc
I-132	1.11E-07 uCi/cc
I-133	1.80E-07 uCi/cc
I-134	9.57E-08 uCi/cc
I-135	1.60E-07 uCi/cc
TOTAL CHARCOAL SAMPLE	6.65E-07 uCi/cc
Rb-88	2.47E-07 uCi/cc
Cs-137	1.14E-07 uCi/cc
Cs-138	1.20E-06 uCi/cc
TOTAL FILTER SAMPLE	1.65E-06 uCi/cc

CONTINUED ON NEXT PAGE

TABLE 7.5.i

REACTOR BLDG ACTIVITY CONCENTRATION (T = 04:15) (19:15)
(continued)

Provide current Chem data 30 minutes after sample request

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
14. ml	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1	mR/hr < 0.1/ < 0.1
Charcoal Filter	mR/hr per cf < 0.1/ < 0.1 < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1 < 0.1/ < 0.1	mR/hr per cf < 0.1/ < 0.1 < 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 6.2 mRad/hr
Airborne Thyroid Dose Rate: 310. mRem/hr
Net Air Sample Contact Rate: 1.3E4 cpm/cf sample

Floor Contamination: 210. cpm/100cm2
Wall and Equipment Contamination: 21. cpm/100cm2
Personnel Contamination Rate: 0.7 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 1.5E-1 Hours
Stay Time: 2 DAC hr (in mask): 7.4E+0 Hours
Stay Time: 2 DAC hr (in SCBA): 7.4E+2 Hours

TABLE 7.5.j

REACTOR BLDG ACTIVITY CONCENTRATION (T = 04:30) (19:30)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	1.32E-06 uCi/cc
Kr-87	1.41E-06 uCi/cc
Kr-88	3.07E-06 uCi/cc
Xe-133	1.44E-05 uCi/cc
Xe-133m	4.85E-07 uCi/cc
Xe-135	3.94E-06 uCi/cc
Xe-138	4.48E-07 uCi/cc
TOTAL GAS SAMPLE	2.53E-05 uCi/cc
Br-83	5.64E-09 uCi/cc
I-131	8.14E-08 uCi/cc
I-132	7.88E-08 uCi/cc
I-133	1.37E-07 uCi/cc
I-134	6.00E-08 uCi/cc
I-135	1.19E-07 uCi/cc
TOTAL CHARCOAL SAMPLE	4.84E-07 uCi/cc
Rb-88	2.40E-07 uCi/cc
Cs-137	1.06E-07 uCi/cc
Cs-138	8.74E-07 uCi/cc
TOTAL FILTER SAMPLE	1.29E-06 uCi/cc

CONTINUED ON NEXT PAGE

TABLE 7.5.j

REACTOR BLDG ACTIVITY CONCENTRATION (T = 04:30) (19:30)
(continued)

Provide current Chem data 30 minutes after sample request

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 6.2 mRad/hr
Airborne Thyroid Dose Rate: 230. mRem/hr
Net Air Sample Contact Rate: 1.0E4 cpm/cf sample

Floor Contamination: 230. cpm/100cm2
Wall and Equipment Contamination: 23. cpm/100cm2
Personnel Contamination Rate: 0.5 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 1.8E-1 Hours
Stay Time: 2 DAC hr (in mask): 8.8E+0 Hours
Stay Time: 2 DAC hr (in SCBA): 8.8E+2 Hours

TABLE 7.5.k

REACTOR BLDG ACTIVITY CONCENTRATION (T = 04:45) (19:45)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	1.38E-06 uCi/cc
Kr-87	1.34E-06 uCi/cc
Kr-88	3.12E-06 uCi/cc
Xe-133	1.56E-05 uCi/cc
Xe-133m	5.24E-07 uCi/cc
Xe-135	4.22E-06 uCi/cc
TOTAL GAS SAMPLE	2.66E-05 uCi/cc
Br-83	4.33E-09 uCi/cc
I-131	6.71E-08 uCi/cc
I-132	6.03E-08 uCi/cc
I-133	1.12E-07 uCi/cc
I-134	4.06E-08 uCi/cc
I-135	9.56E-08 uCi/cc
TOTAL CHARCOAL SAMPLE	3.81E-07 uCi/cc
Rb-88	2.39E-07 uCi/cc
Cs-137	9.96E-08 uCi/cc
Cs-138	6.28E-07 uCi/cc
TOTAL FILTER SAMPLE	1.02E-06 uCi/cc

CONTINUED ON NEXT PAGE

TABLE 7.5.k

REACTOR BLDG ACTIVITY CONCENTRATION (T = 04:45) (19:45)
(continued)

Provide current Chem data 30 minutes after sample request

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 6.2 mRad/hr
Airborne Thyroid Dose Rate: 190. mRem/hr
Net Air Sample Contact Rate: 7900. cpm/cf sample

Floor Contamination: 240. cpm/100cm²
Wall and Equipment Contamination: 24. cpm/100cm²
Personnel Contamination Rate: 0.4 cpm/100cm² per minute
Stay Time: 2 DAC hr (no mask): 2.0E-1 Hours
Stay Time: 2 DAC hr (in mask): 9.8E+0 Hours
Stay Time: 2 DAC hr (in SCBA): 9.8E+2 Hours

TABLE 7.5.1

REACTOR BLDG ACTIVITY CONCENTRATION (T = 05:00) (20:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	4.97E-06 uCi/cc
Kr-87	4.41E-06 uCi/cc
Kr-88	1.10E-05 uCi/cc
Xe-133	5.84E-05 uCi/cc
Xe-133m	1.95E-06 uCi/cc
Xe-135	1.73E-05 uCi/cc
TOTAL GAS SAMPLE	9.93E-05 uCi/cc
Br-83	6.39E-08 uCi/cc
I-131	1.13E-06 uCi/cc
I-132	9.70E-07 uCi/cc
I-133	1.90E-06 uCi/cc
I-134	5.85E-07 uCi/cc
I-135	1.58E-06 uCi/cc
TOTAL CHARCOAL SAMPLE	6.25E-06 uCi/cc
Rb-88	5.57E-07 uCi/cc
Cs-134	3.03E-07 uCi/cc
Cs-137	5.96E-07 uCi/cc
Cs-138	1.75E-06 uCi/cc
TOTAL FILTER SAMPLE	3.23E-06 uCi/cc

CONTINUED ON NEXT PAGE

TABLE 7.5.1

REACTOR BLDG ACTIVITY CONCENTRATION (T = 05:00) (20:00)
(continued)

Provide current Chem data 30 minutes after sample request

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 23. mRad/hr
Airborne Thyroid Dose Rate: 3200. mRem/hr
Air Sample Contact Rate: 18. mR/hr / cf sample

Floor Contamination: 300. cpm/100cm2
Wall and Equipment Contamination: 30. cpm/100cm2
Personnel Contamination Rate: 4.6 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask):1.9E-2 Hours
Stay Time: 2 DAC hr (in mask):9.5E-1 Hours
Stay Time: 2 DAC hr (in SCBA):9.5E+1 Hours

TABLE 7.5.m

REACTOR BLDG ACTIVITY CONCENTRATION (T = 05:30) (20:30)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	4.75E-05 uCi/cc
Kr-87	3.48E-05 uCi/cc
Kr-88	1.01E-04 uCi/cc
Xe-133	6.03E-04 uCi/cc
Xe-133m	2.00E-05 uCi/cc
Xe-135	1.80E-04 uCi/cc
TOTAL GAS SAMPLE	9.93E-04 uCi/cc
Br-83	3.32E-07 uCi/cc
I-131	6.30E-06 uCi/cc
I-132	4.65E-06 uCi/cc
I-133	1.04E-05 uCi/cc
I-134	2.18E-06 uCi/cc
I-135	8.37E-06 uCi/cc
TOTAL CHARCOAL SAMPLE	3.23E-05 uCi/cc
Rb-88	6.59E-06 uCi/cc
Cs-134	2.62E-06 uCi/cc
Cs-137	5.15E-06 uCi/cc
Cs-138	7.72E-06 uCi/cc
TOTAL FILTER SAMPLE	2.21E-05 uCi/cc

CONTINUED ON NEXT PAGE

TABLE 7.5.m

REACTOR BLDG ACTIVITY CONCENTRATION (T = 05:30) (20:30)
(continued)

Provide current Chem data 30 minutes after sample request

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal Filter	0.1/ < 0.1 < 0.1/ < 0.1	< 0.1/ < 0.1 < 0.1/ < 0.1	< 0.1/ < 0.1 < 0.1/ < 0.1

Hydrogen C ncentration: .0%
Oxygen C ncentration: 21.0%
Chlorine C ncentration: .0 ppm

Airborne Beta Dose Rate: 210. mRad/hr
Airborne Thyroid Dose Rate: 1.8E4 mRem/hr
Air Sample Contact Rate: 100. mR/hr / cf sample

Floor Contamination: 3000. cpm/100cm2
Wall and Equipment Contamination: 300. cpm/100cm2
Personnel Contamination Rate: 24. cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask):3.0E-3 Hours
Stay Time: 2 DAC hr (in mask):1.5E-1 Hours
Stay Time: 2 DAC hr (in SCBA):1.5E+1 Hours

TABLE 7.5.n

REACTOR BLDG ACTIVITY CONCENTRATION (T = 06:00) (21:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	7.80E-05 uCi/cc
Kr-87	4.70E-05 uCi/cc
Kr-88	1.58E-04 uCi/cc
Xe-133	1.07E-03 uCi/cc
Xe-133m	3.54E-05 uCi/cc
Xe-135	3.09E-04 uCi/cc
TOTAL GAS SAMPLE	1.70E-03 uCi/cc
I-131	4.71E-06 uCi/cc
I-132	2.98E-06 uCi/cc
I-133	7.67E-06 uCi/cc
I-134	1.09E-06 uCi/cc
I-135	5.94E-06 uCi/cc
TOTAL CHARCOAL SAMPLE	2.26E-05 uCi/cc
Rb-88	1.15E-05 uCi/cc
Cs-134	3.29E-06 uCi/cc
Cs-137	6.48E-06 uCi/cc
Cs-138	5.40E-06 uCi/cc
TOTAL FILTER SAMPLE	2.67E-05 uCi/cc

CONTINUED ON NEXT PAGE

TABLE 7.5.n

REACTOR BLDG ACTIVITY CONCENTRATION (T = 06:00) (21:00)
(continued)

Provide current Chem data 30 minutes after sample request

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 350. mRad/hr
Airborne Thyroid Dose Rate: 1.324 mRem/hr
Air Sample Contact Rate: 93. mR/hr / cf sample

Floor Contamination: 5800. cpm/100cm2
Wall and Equipment Contamination: 580. cpm/100cm2
Personnel Contamination Rate: 19. cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 3.1E-3 Hours
Stay Time: 2 DAC hr (in mask): 1.5E-1 Hours
Stay Time: 2 DAC hr (in SCBA): 1.5E+1 Hours

TABLE 7.5.0

REACTOR BLDG ACTIVITY CONCENTRATION (T = 06:30) (21:30)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	9.90E-05 uCi/cc
Kr-87	4.91E-05 uCi/cc
Kr-88	1.92E-04 uCi/cc
Xe-133	1.46E-03 uCi/cc
Xe-133m	4.83E-05 uCi/cc
Xe-135	4.11E-04 uCi/cc
TOTAL GAS SAMPLE	2.27E-03 uCi/cc
I-131	3.31E-06 uCi/cc
I-132	1.80E-06 uCi/cc
I-133	5.31E-06 uCi/cc
I-134	5.14E-07 uCi/cc
I-135	3.97E-06 uCi/cc
TOTAL CHARCOAL SAMPLE	1.50E-05 uCi/cc
Rb-88	1.44E-05 uCi/cc
Cs-134	3.25E-06 uCi/cc
Cs-137	6.39E-06 uCi/cc
Cs-138	2.90E-06 uCi/cc
TOTAL FILTER SAMPLE	2.69E-05 uCi/cc

CONTINUED ON NEXT PAGE

TABLE 7.5.0

REACTOR BLDG ACTIVITY CONCENTRATION (T = 06:30) (21:30)
(continued)

Provide current Chem data 30 minutes after sample request

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 450. mRad/hr
Airborne Thyroid Dose Rate: 9300. mRem/hr
Air Sample Contact Rate: 79. mR/hr / cf sample

Floor Contamination: 7600. cpm/100cm2
Wall and Equipment Contamination: 760. cpm/100cm2
Personnel Contamination Rate: 14. cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 3.4E-3 Hours
Stay Time: 2 DAC hr (in mask): 1.7E-1 Hours
Stay Time: 2 DAC hr (in SCBA): 1.7E+1 Hours

TABLE 7.5.p

REACTOR BLDG ACTIVITY CONCENTRATION (T = 07:00) (22:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	1.14E-04 uCi/cc
Kr-87	4.67E-05 uCi/cc
Kr-88	2.12E-04 uCi/cc
Xe-133	1.82E-03 uCi/cc
Xe-133m	6.00E-05 uCi/cc
Xe-135	4.96E-04 uCi/cc

TOTAL GAS SAMPLE	2.77E-03 uCi/cc
I-131	2.65E-06 uCi/cc
I-132	1.24E-06 uCi/cc
I-133	4.19E-06 uCi/cc
I-134	2.78E-07 uCi/cc
I-135	3.02E-06 uCi/cc

TOTAL CHARCOAL SAMPLE	1.15E-05 uCi/cc
Rb-88	1.60E-05 uCi/cc
Cs-134	2.97E-06 uCi/cc
Cs-137	5.85E-06 uCi/cc
Cs-138	1.42E-06 uCi/cc

TOTAL FILTER SAMPLE	2.62E-05 uCi/cc

CONTINUED ON NEXT PAGE

TABLE 7.5.p

REACTOR BLDG ACTIVITY CONCENTRATION (T = 07:00) (22:00)
(continued)

Provide current Chem data 30 minutes after sample request

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 520. mRad/hr
Airborne Thyroid Dose Rate: 7400. mRem/hr
Air Sample Contact Rate: 71. mR/hr / cf sample

Floor Contamination: 8700. cpm/100cm²
Wall and Equipment Contamination: 870. cpm/100cm²
Personnel Contamination Rate: 11. cpm/100cm² per minute
Stay Time: 2 DAC hr (no mask): 3.7E-3 Hours
Stay Time: 2 DAC hr (in mask): 1.8E-1 Hours
Stay Time: 2 DAC hr (in SCBA): 1.8E+1 Hours

TABLE 7.5.q

REACTOR BLDG ACTIVITY CONCENTRATION (T = 08:00) (23:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	1.34E-04 uCi/cc
Kr-87	3.71E-05 uCi/cc
Kr-88	2.27E-04 uCi/cc
Xe-133	2.49E-03 uCi/cc
Xe-133m	8.12E-05 uCi/cc
Xe-135	6.34E-04 uCi/cc
-----	-----
TOTAL GAS SAMPLE	3.62E-03 uCi/cc
I-131	2.35E-06 uCi/cc
I-132	8.23E-07 uCi/cc
I-133	3.61E-06 uCi/cc
I-134	1.13E-07 uCi/cc
I-135	2.43E-06 uCi/cc
-----	-----
TOTAL CHARCOAL SAMPLE	9.39E-06 uCi/cc
Rb-88	1.71E-05 uCi/cc
Cs-134	2.36E-06 uCi/cc
Cs-137	4.65E-06 uCi/cc
-----	-----
TOTAL FILTER SAMPLE	2.45E-05 uCi/cc

CONTINUED ON NEXT PAGE

TABLE 7.5.g

REACTOR BLDG ACTIVITY CONCENTRATION (T = 08:00) (23:00)
(continued)

Provide current Chem data 30 minutes after sample request

Sample Dose Rate Data (Contact/ 1 ft.)

	Unshielded	2" Lead	4" Lead
	mR/hr	mR/hr	mR/hr
14. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
	mR/hr per cf	mR/hr per cf	mR/hr per cf
Charcoal	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
Filter	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 640. mRad/hr
Airborne Thyroid Dose Rate: 6500. mRem/hr
Air Sample Contact Rate: 64. mR/hr / cf sample

Floor Contamination: 1.0E4 cpm/100cm2
Wall and Equipment Contamination: 1000. cpm/100cm2
Personnel Contamination Rate: 9.5 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 3.8E-3 Hours
Stay Time: 2 DAC hr (in mask): 1.9E-1 Hours
Stay Time: 2 DAC hr (in SCBA): 1.9E+1 Hours

TABLE 7.6.a

REFUEL FLOOR ACTIVITY CONCENTRATION (T = 00:00) (15:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-135	<LLD uCi/cc
Xe-135m	<LLD uCi/cc

TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc

TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
La-142	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm2
Wall and Equipment Contamination: < 0.1 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 4.3E+6 Hours
Stay Time: 2 DAC hr (in mask): 2.2E+8 Hours
Stay Time: 2 DAC hr (in SCBA): 9.9E+9 Hours

TABLE 7.6.b

REFUEL FLOOR ACTIVITY CONCENTRATION (T = 01:00) (16:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-135	<LLD uCi/cc
Xe-135m	<LLD uCi/cc
TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc
TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm2
Wall and Equipment Contamination: < 0.1 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 8.9E+6 Hours
Stay Time: 2 DAC hr (in mask): 4.5E+8 Hours
Stay Time: 2 DAC hr (in SCBA): 9.9E+9 Hours

TABLE 7.6.c

REFUEL FLOOR ACTIVITY CONCENTRATION (T = 02:00) (17:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-133	<LLD uCi/cc
Xe-135	<LLD uCi/cc
Xe-135m	<LLD uCi/cc

TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc

TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute
Stay Time: 2 DAC hr (no mask): 7.8E+6 Hours
Stay Time: 2 DAC hr (in mask): 3.9E+8 Hours
Stay Time: 2 DAC hr (in SCBA): 9.9E+9 Hours

TABLE 7.6.d

REFUEL FLOOR ACTIVITY CONCENTRATION (T = 03:00) (18:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
Xe-133	<LLD uCi/cc
Xe-135	<LLD uCi/cc
TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc
TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute
Stay Time: 2 DAC hr (no mask): 6.0E+6 Hours
Stay Time: 2 DAC hr (in mask): 3.0E+8 Hours
Stay Time: 2 DAC hr (in SCBA): 9.9E+9 Hours

TABLE 7.6.e

REFUEL FLOOR ACTIVITY CONCENTRATION (T = 04:00) (19:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	6.81E-08 uCi/cc
Kr-87	8.86E-08 uCi/cc
Kr-88	1.65E-07 uCi/cc
Xe-133	6.85E-07 uCi/cc
Xe-133m	2.32E-08 uCi/cc
Xe-135	1.92E-07 uCi/cc
Xe-135m	2.38E-08 uCi/cc
Xe-138	7.39E-08 uCi/cc

TOTAL GAS SAMPLE	1.33E-06 uCi/cc

Br-83	7.48E-10 uCi/cc
I-131	9.29E-09 uCi/cc
I-132	1.05E-08 uCi/cc
I-133	1.58E-08 uCi/cc
I-134	1.03E-08 uCi/cc
I-135	1.43E-08 uCi/cc

TOTAL CHARCOAL SAMPLE	6.15E-08 uCi/cc

Rb-88	1.61E-08 uCi/cc
Cs-137	6.49E-09 uCi/cc
Cs-138	9.71E-08 uCi/cc

TOTAL FILTER SAMPLE	1.27E-07 uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 0.4 mRad/hr
Airborne Thyroid Dose Rate: 27. mRem/hr
Net Air Sample Contact Rate: 1100. cpm/cf sample

Floor Contamination: 6.2 cpm/100cm2
Wall and Equipment Contamination: 0.6 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 2.0E+0 Hours
Stay Time: 2 DAC hr (in mask): 1.0E+2 Hours
Stay Time: 2 DAC hr (in SCBA): 1.0E+4 Hours

TABLE 7.6.f

REFUEL FLOOR ACTIVITY CONCENTRATION (T = 05:00) (20:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	4.16E-07 uCi/cc
Kr-87	3.69E-07 uCi/cc
Kr-88	9.23E-07 uCi/cc
Xe-133	4.88E-06 uCi/cc
Xe-133m	1.63E-07 uCi/cc
Xe-135	1.45E-06 uCi/cc
TOTAL GAS SAMPLE	8.31E-06 uCi/cc
Br-83	6.28E-09 uCi/cc
I-131	1.03E-07 uCi/cc
I-132	8.84E-08 uCi/cc
I-133	1.73E-07 uCi/cc
I-134	5.34E-08 uCi/cc
I-135	1.44E-07 uCi/cc
TOTAL CHARCOAL SAMPLE	5.69E-07 uCi/cc
Rb-88	5.04E-08 uCi/cc
Cs-134	2.67E-08 uCi/cc
Cs-137	5.25E-08 uCi/cc
Cs-138	1.64E-07 uCi/cc
TOTAL FILTER SAMPLE	2.96E-07 uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 1.9 mRad/hr
Airborne Thyroid Dose Rate: 300. mRem/hr
Net Air Sample Contact Rate: 4900. cpm/cf sample

Floor Contamination: 22. cpm/100cm2
Wall and Equipment Contamination: 2.2 cpm/100cm2
Personnel Contamination Rate: 0.4 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 2.1E-1 Hours
Stay Time: 2 DAC hr (in mask): 1.1E+1 Hours
Stay Time: 2 DAC hr (in SCBA): 1.1E+3 Hours

TABLE 7.6.g

REFUEL FLOOR ACTIVITY CONCENTRATION (T = 06:00) (21:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	6.87E-06 uCi/cc
Kr-87	4.14E-06 uCi/cc
Kr-88	1.39E-05 uCi/cc
Xe-133	9.40E-05 uCi/cc
Xe-133m	3.11E-06 uCi/cc
Xe-135	2.72E-05 uCi/cc

TOTAL GAS SAMPLE	1.50E-04 uCi/cc

I-131	7.49E-07 uCi/cc
I-132	4.76E-07 uCi/cc
I-133	1.22E-06 uCi/cc
I-134	1.75E-07 uCi/cc
I-135	9.45E-07 uCi/cc

TOTAL CHARCOAL SAMPLE	3.60E-06 uCi/cc

Rb-88	1.22E-06 uCi/cc
Cs-134	3.75E-07 uCi/cc
Cs-137	7.38E-07 uCi/cc
Cs-138	6.30E-07 uCi/cc

TOTAL FILTER SAMPLE	2.97E-06 uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 31. mRad/hr
Airborne Thyroid Dose Rate: 2100. mRem/hr
Net Air Sample Contact Rate: 3.7E4 cpm/cf sample

Floor Contamination: 690. cpm/100cm2
Wall and Equipment Contamination: 69. cpm/100cm2
Personnel Contamination Rate: 2.8 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 2.4E-2 Hours
Stay Time: 2 DAC hr (in mask): 1.2E+0 Hours
Stay Time: 2 DAC hr (in SCBA): 1.2E+2 Hours

TABLE 7.6.h

REFUEL FLOOR ACTIVITY CONCENTRATION (T = 07:00) (22:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	1.01E-05 uCi/cc
Kr-87	4.11E-06 uCi/cc
Kr-88	1.87E-05 uCi/cc
Xe-133	1.60E-04 uCi/cc
Xe-133m	5.28E-06 uCi/cc
Xe-135	4.33E-05 uCi/cc

TOTAL GAS SAMPLE	2.43E-04 uCi/cc
I-131	4.98E-07 uCi/cc
I-132	2.35E-07 uCi/cc
I-133	7.88E-07 uCi/cc
I-134	5.27E-08 uCi/cc
I-135	5.69E-07 uCi/cc

TOTAL CHARCOAL SAMPLE	2.16E-06 uCi/cc
Rb-88	1.78E-06 uCi/cc
Cs-134	4.46E-07 uCi/cc
Cs-137	8.79E-07 uCi/cc
Cs-138	2.22E-07 uCi/cc

TOTAL FILTER SAMPLE	3.33E-06 uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 46. mRad/hr
Airborne Thyroid Dose Rate: 1400. mRem/hr
Net Air Sample Contact Rate: 3.1E4 cpm/cf sample

Floor Contamination: 1200. cps/100cm²
Wall and Equipment Contamination: 120. cpm/100cm²
Personnel Contamination Rate: 1.9 cpm/100cm² per minute
Stay Time: 2 DAC hr (no mask): 2.6E-2 Hours
Stay Time: 2 DAC hr (in mask): 1.3E+0 Hours
Stay Time: 2 DAC hr (in SCBA): 1.3E+2 Hours

TABLE 7.6.i

REFUEL FLOOR ACTIVITY CONCENTRATION (T = 08:00) (23:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	1.18E-05 uCi/cc
Kr-87	3.27E-06 uCi/cc
Kr-88	2.00E-05 uCi/cc
Xe-133	2.19E-04 uCi/cc
Xe-133m	7.15E-06 uCi/cc
Xe-135	5.52E-05 uCi/cc

TOTAL GAS SAMPLE	3.18E-04 uCi/cc

I-131	3.08E-07 uCi/cc
I-132	1.07E-07 uCi/cc
I-133	4.73E-07 uCi/cc
I-134	1.48E-08 uCi/cc
I-135	3.18E-07 uCi/cc

TOTAL CHARCOAL SAMPLE	1.23E-06 uCi/cc

Rb-88	1.94E-06 uCi/cc
Cs-134	4.40E-07 uCi/cc
Cs-137	8.66E-07 uCi/cc

TOTAL FILTER SAMPLE	3.31E-06 uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: 56. mRad/hr
Airborne Thyroid Dose Rate: 850. mRem/hr
Net Air Sample Contact Rate: 2.6E4 cpm/cf sample

Floor Contamination: 1500. cpm/100cm2
Wall and Equipment Contamination: 150. cpm/100cm2
Personnel Contamination Rate: 1.3 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 3.0E-2 Hours
Stay Time: 2 DAC hr (in mask): 1.5E+0 Hours
Stay Time: 2 DAC hr (in SCBA): 1.5E+2 Hours

TABLE 7.7.a

TURBINE BLDG ACTIVITY CONCENTRATION (T = 00:00) (15:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-135	<LLD uCi/cc
Xe-135m	2.02E-11 uCi/cc
TOTAL GAS SAMPLE	2.05E-11 uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc
TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
La-142	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm2
Wall and Equipment Contamination: < 0.1 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 3.3E+5 Hours
Stay Time: 2 DAC hr (in mask): 1.7E+7 Hours
Stay Time: 2 DAC hr (in SCBA): 1.7E+9 Hours

TABLE 7.7.b

TURBINE BLDG ACTIVITY CONCENTRATION (T = 01:00) (16:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-135	<LLD uCi/cc
Xe-135m	<LLD uCi/cc
TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc
TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm2
Wall and Equipment Contamination: < 0.1 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 2.6E+5 Hours
Stay Time: 2 DAC hr (in mask): 1.3E+7 Hours
Stay Time: 2 DAC hr (in SCBA): 1.3E+9 Hours

TABLE 7.7.c

TURBINE BLDG ACTIVITY CONCENTRATION (T = 02:00) (17:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-133	<LLD uCi/cc
Xe-135	<LLD uCi/cc
Xe-135m	<LLD uCi/cc

TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc

TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm2
Wall and Equipment Contamination: < 0.1 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 2.1E+5 Hours
Stay Time: 2 DAC hr (in mask): 1.0E+7 Hours
Stay Time: 2 DAC hr (in SCBA): 1.0E+9 Hours

TABLE 7.7.d

TURBINE BLDG ACTIVITY CONCENTRATION (T = 02:30) (17:30)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-133	<LLD uCi/cc
Xe-135	<LLD uCi/cc
Xe-135m	<LLD uCi/cc

TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc

TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm2
Wall and Equipment Contamination: < 0.1 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 1.8E+5 Hours
Stay Time: 2 DAC hr (in mask): 9.0E+6 Hours
Stay Time: 2 DAC hr (in SCBA): 9.0E+8 Hours

TABLE 7.7.e

TURBINE BLDG ACTIVITY CONCENTRATION (T = 03:00) (18:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-133	<LLD uCi/cc
Xe-135	<LLD uCi/cc
TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc
TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm2
Wall and Equipment Contamination: < 0.1 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 1.6E+5 Hours
Stay Time: 2 DAC hr (in mask): 8.0E+6 Hours
Stay Time: 2 DAC hr (in SCBA): 8.0E+8 Hours

TABLE 7.7.f

TURBINE BLDG ACTIVITY CONCENTRATION (T = 03:30) (18:30)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-133	<LLD uCi/cc
Xe-135	<LLD uCi/cc

TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc

TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute
Stay Time: 2 DAC hr (no mask): 2.1E+5 Hours
Stay Time: 2 DAC hr (in mask): 1.0E+7 Hours
Stay Time: 2 DAC hr (in SCBA): 1.0E+9 Hours

TABLE 7.7.g

TURBINE BLDG ACTIVITY CONCENTRATION (T = 04:00) (19:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-133	<LLD uCi/cc
Xe-135	<LLD uCi/cc
TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc
TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm2
Wall and Equipment Contamination: < 0.1 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 2.2E+5 Hours
Stay Time: 2 DAC hr (in mask): 1.1E+7 Hours
Stay Time: 2 DAC hr (in SCBA): 1.1E+9 Hours

TABLE 7.7.h

TURBINE BLDG ACTIVITY CONCENTRATION (T = 05:00) (20:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-133	<LLD uCi/cc
Xe-135	<LLD uCi/cc
TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc
TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute
Stay Time: 2 DAC hr (no mask): 2.1E+5 Hours
Stay Time: 2 DAC hr (in mask): 1.1E+7 Hours
Stay Time: 2 DAC hr (in SCBA): 1.1E+9 Hours

TABLE 7.7.i

TURBINE BLDG ACTIVITY CONCENTRATION (T = 06:00) (21:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-133	<LLD uCi/cc
Xe-135	<LLD uCi/cc
TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc
TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm2
Wall and Equipment Contamination: < 0.1 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 2.1E+5 Hours
Stay Time: 2 DAC hr (in mask): 1.1E+7 Hours
Stay Time: 2 DAC hr (in SCBA): 1.1E+9 Hours

TABLE 7.7.j

TURBINE BLDG ACTIVITY CONCENTRATION (T = 07:00) (22:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-133	<LLD uCi/cc
Xe-135	<LLD uCi/cc
TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc
TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm2
Wall and Equipment Contamination: < 0.1 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 2.1E+5 Hours
Stay Time: 2 DAC hr (in mask): 1.0E+7 Hours
Stay Time: 2 DAC hr (in SCBA): 1.0E+9 Hours

TABLE 7.7.k

TURBINE BLDG ACTIVITY CONCENTRATION (T = 08:00) (23:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-133	<LLD uCi/cc
Xe-135	<LLD uCi/cc

TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-135	<LLD uCi/cc

TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Y-92	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm2
Wall and Equipment Contamination: < 0.1 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 2.1E+5 Hours
Stay Time: 2 DAC hr (in mask): 1.0E+7 Hours
Stay Time: 2 DAC hr (in SCBA): 1.0E+9 Hours

TABLE 7.8.a

REACTOR WATER ACTIVITY CONCENTRATION (T = 00:00) (15:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-135	4.43E-05 uCi/cc
Xe-135m	2.90E-03 uCi/cc
I-132	2.72E-04 uCi/cc
I-133	1.24E-04 uCi/cc
I-134	8.43E-04 uCi/cc
I-135	3.28E-04 uCi/cc
Sr-91	1.00E-04 uCi/cc
Sr-92	2.24E-04 uCi/cc
Ba-139	3.15E-04 uCi/cc
Y-92	1.26E-05 uCi/cc
La-142	7.51E-05 uCi/cc
TOTAL WATER SAMPLE	5.24E-03 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
0.1 ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

TABLE 7.8.b

REACTOR WATER ACTIVITY CONCENTRATION (T = 01:00) (16:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-135	5.18E-05 uCi/cc
Xe-135m	1.80E-04 uCi/cc
I-132	2.66E-04 uCi/cc
I-133	1.58E-04 uCi/cc
I-134	5.10E-04 uCi/cc
I-135	3.90E-04 uCi/cc
Sr-91	9.29E-05 uCi/cc
Sr-92	1.73E-04 uCi/cc
Ba-139	1.93E-04 uCi/cc
Y-92	3.02E-05 uCi/cc
La-142	4.76E-05 uCi/cc
TOTAL WATER SAMPLE	2.09E-03 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
0.1 ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

TABLE 7.8.c

REACTOR WATER ACTIVITY CONCENTRATION (T = 02:00) (17:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-135	6.12E-05 uCi/cc
Xe-135m	1.13E-05 uCi/cc
I-132	2.61E-04 uCi/cc
I-133	2.03E-04 uCi/cc
I-134	3.10E-04 uCi/cc
I-135	4.66E-04 uCi/cc
Sr-91	8.65E-05 uCi/cc
Sr-92	1.34E-04 uCi/cc
Ba-139	1.17E-04 uCi/cc
Y-92	4.01E-05 uCi/cc
La-142	3.02E-05 uCi/cc
TOTAL WATER SAMPLE	1.72E-03 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
0.1 ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

TABLE 7.8.d

REACTOR WATER ACTIVITY CONCENTRATION (T = 03:00) (18:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-133	2.55E-06 uCi/cc
Xe-135	7.25E-05 uCi/cc
I-132	2.57E-04 uCi/cc
I-133	2.60E-04 uCi/cc
I-134	1.89E-04 uCi/cc
I-135	5.57E-04 uCi/cc
Sr-91	8.04E-05 uCi/cc
Sr-92	1.04E-04 uCi/cc
Ba-139	7.09E-05 uCi/cc
Y-92	4.48E-05 uCi/cc
La-142	1.92E-05 uCi/cc
TOTAL WATER SAMPLE	1.66E-03 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
0.1 ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

TABLE 7.8.e

REACTOR WATER ACTIVITY CONCENTRATION (T = 04:00) (19:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	1.70E+00 uCi/cc
Kr-87	2.19E+00 uCi/cc
Kr-88	4.11E+00 uCi/cc
Xe-133	1.72E+01 uCi/cc
Xe-133m	5.79E-01 uCi/cc
Xe-135	5.18E+00 uCi/cc
Xe-135m	5.63E-01 uCi/cc
Xe-138	1.76E+00 uCi/cc
Br-83	7.53E-01 uCi/cc
Br-84	5.04E-01 uCi/cc
I-131	9.40E+00 uCi/cc
I-132	1.06E+01 uCi/cc
I-133	1.60E+01 uCi/cc
I-134	1.03E+01 uCi/cc
I-135	1.45E+01 uCi/cc
Rb-88	3.14E+00 uCi/cc
Rb-89	2.22E+00 uCi/cc
Cs-134	2.01E+00 uCi/cc
Cs-137	3.96E+00 uCi/cc
Cs-138	2.96E+01 uCi/cc
TOTAL WATER SAMPLE	1.36E+02 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	220./ 7.6	6.9/ 0.2	0.3/ < 0.1
0.1 ml	3.7/ < 0.1	0.1/ < 0.1	< 0.1/ < 0.1

TABLE 7.8.f

REACTOR WATER ACTIVITY CONCENTRATION (T = 05:00) (20:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85	9.27E+00 uCi/cc
Kr-85m	1.29E+02 uCi/cc
Kr-87	1.14E+02 uCi/cc
Kr-88	2.86E+02 uCi/cc
Xe-133	1.53E+03 uCi/cc
Xe-133m	5.09E+01 uCi/cc
Xe-135	4.74E+02 uCi/cc
Xe-138	1.41E+01 uCi/cc
Br-83	5.05E+01 uCi/cc
Br-84	1.24E+01 uCi/cc
I-131	8.35E+02 uCi/cc
I-132	7.13E+02 uCi/cc
I-133	1.40E+03 uCi/cc
I-134	4.24E+02 uCi/cc
I-135	1.16E+03 uCi/cc
Rb-88	1.07E+02 uCi/cc
Rb-89	1.38E+01 uCi/cc
Cs-134	1.77E+02 uCi/cc
Cs-137	3.48E+02 uCi/cc
Cs-138	8.45E+02 uCi/cc
TOTAL WATER SAMPLE	8.71E+03 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	1.3E4/ 430.	340./ 12.	15./ 0.5
0.1 ml	210./ 4.3	5.7/ 0.1	0.3/ < 0.1

TABLE 7.8.g

REACTOR WATER ACTIVITY CONCENTRATION (T = 06:00) (21:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	2.29E+02 uCi/cc
Kr-87	1.36E+02 uCi/cc
Kr-88	4.64E+02 uCi/cc
Xe-133	3.16E+03 uCi/cc
Xe-133m	1.04E+02 uCi/cc
Xe-135	1.01E+03 uCi/cc
Br-83	7.82E+01 uCi/cc
I-131	1.72E+03 uCi/cc
I-132	1.09E+03 uCi/cc
I-133	2.80E+03 uCi/cc
I-134	3.98E+02 uCi/cc
I-135	2.17E+03 uCi/cc
Rb-88	6.62E+01 uCi/cc
Cs-134	3.60E+02 uCi/cc
Cs-137	7.07E+02 uCi/cc
Cs-138	4.78E+02 uCi/cc
TOTAL WATER SAMPLE	1.50E+04 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	2.0E4/ 690.	490./ 17.	20./ 0.7
0.1 ml	330./ 6.9	8.1/ 0.2	0.3/ < 0.1

TABLE 7.8.h

REACTOR WATER ACTIVITY CONCENTRATION (T = 07:00) (22:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	1.96E+02 uCi/cc
Kr-87	7.90E+01 uCi/cc
Kr-88	3.62E+02 uCi/cc
Xe-133	3.16E+03 uCi/cc
Xe-133m	1.03E+02 uCi/cc
Xe-135	1.02E+03 uCi/cc
Br-83	5.86E+01 uCi/cc
I-131	1.71E+03 uCi/cc
I-132	8.06E+02 uCi/cc
I-133	2.71E+03 uCi/cc
I-134	1.81E+02 uCi/cc
I-135	1.95E+03 uCi/cc
Rb-88	3.97E+01 uCi/cc
Cs-134	3.60E+02 uCi/cc
Cs-137	7.08E+02 uCi/cc
Cs-138	1.32E+02 uCi/cc
Te-132	1.48E+01 uCi/cc
-----	-----
TOTAL WATER SAMPLE	1.36E+04 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	1.7E4/ 600.	400./ 14.	16./ 0.5
0.1 ml	290./ 6.0	6.6/ 0.1	0.3/ < 0.1

TABLE 7.8.1

REACTOR WATER ACTIVITY CONCENTRATION (T = 08:00) (23:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	1.67E+02 uCi/cc
Kr-87	4.57E+01 uCi/cc
Kr-88	2.82E+02 uCi/cc
Xe-133	3.15E+03 uCi/cc
Xe-133m	1.02E+02 uCi/cc
Xe-135	1.03E+03 uCi/cc
Br-83	4.39E+01 uCi/cc
I-131	1.70E+03 uCi/cc
I-132	5.97E+02 uCi/cc
I-133	2.62E+03 uCi/cc
I-134	8.22E+01 uCi/cc
I-135	1.76E+03 uCi/cc
Rb-88	2.98E+01 uCi/cc
Cs-134	3.59E+02 uCi/cc
Cs-137	7.07E+02 uCi/cc
Cs-138	3.63E+01 uCi/cc
Te-132	1.47E+01 uCi/cc
TOTAL WATER SAMPLE	1.28E+04 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	1.6E4/ 540.	350./ 12.	13./ 0.5
0.1 ml	260./ 5.4	5.8/ 0.1	0.2/ < 0.1

TABLE 7.9.a

WETWELL WATER ACTIVITY CONCENTRATION (T = 00:00) (15:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-133	2.03E-10 uCi/cc
I-131	9.38E-08 uCi/cc
I-133	1.03E-08 uCi/cc
Rb-88	1.98E-10 uCi/cc
TOTAL WATER SAMPLE	1.05E-07 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
0.1 ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

TABLE 7.9.b

WETWELL WATER ACTIVITY CONCENTRATION (T = 01:00) (16:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-88	1.67E-10 uCi/cc
Xe-133	4.86E-10 uCi/cc
Xe-135	1.08E-10 uCi/cc
I-131	9.29E-08 uCi/cc
I-133	9.92E-09 uCi/cc
Rb-88	3.75E-10 uCi/cc
TOTAL WATER SAMPLE	1.04E-07 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
0.1 ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

TABLE 7.9.c

WETWELL WATER ACTIVITY CONCENTRATION (T = 02:00) (17:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-88	1.98E-10 uCi/cc
Xe-133	7.35E-10 uCi/cc
Xe-135	1.52E-10 uCi/cc
I-131	9.22E-08 uCi/cc
I-133	9.57E-09 uCi/cc
Rb-88	3.36E-10 uCi/cc

TOTAL WATER SAMPLE	1.03E-07 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
0.1 ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

TABLE 7.9.d

WETWELL WATER ACTIVITY CONCENTRATION (T = 03:00) (18:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	1.12E-10 uCi/cc
Kr-88	2.02E-10 uCi/cc
Xe-133	9.57E-10 uCi/cc
Xe-135	1.84E-10 uCi/cc
I-131	9.16E-08 uCi/cc
I-133	9.25E-09 uCi/cc
Rb-88	2.71E-10 uCi/cc
TOTAL WATER SAMPLE	1.03E-07 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
0.1 ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

TABLE 7.9.e

WETWELL WATER ACTIVITY CONCENTRATION (T = 04:00) (19:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	3.51E-04 uCi/cc
Kr-87	4.44E-04 uCi/cc
Kr-88	8.46E-04 uCi/cc
Xe-133	3.60E-03 uCi/cc
Xe-133m	1.21E-04 uCi/cc
Xe-135	1.28E-03 uCi/cc
Xe-135m	1.02E-04 uCi/cc
Xe-138	3.21E-04 uCi/cc
Br-83	4.75E-04 uCi/cc
Br-84	3.01E-04 uCi/cc
I-131	6.02E-03 uCi/cc
I-132	6.65E-03 uCi/cc
I-133	1.02E-02 uCi/cc
I-134	6.34E-03 uCi/cc
I-135	9.20E-03 uCi/cc
Rb-88	2.69E-03 uCi/cc
Rb-89	1.33E-03 uCi/cc
Cs-134	1.41E-03 uCi/cc
Cs-137	2.77E-03 uCi/cc
Cs-138	2.71E-02 uCi/cc
TOTAL WATER SAMPLE	8.16E-02 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1
0.1 ml	< 0.1/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

TABLE 7.9.f

WETWELL WATER ACTIVITY CONCENTRATION (T = 05:00) (20:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	2.96E-02 uCi/cc
Kr-87	2.63E-02 uCi/cc
Kr-88	6.57E-02 uCi/cc
Xe-133	3.47E-01 uCi/cc
Xe-133m	1.16E-02 uCi/cc
Xe-135	1.09E-01 uCi/cc
Br-83	4.82E-02 uCi/cc
Br-84	1.22E-02 uCi/cc
I-131	7.90E-01 uCi/cc
I-132	6.80E-01 uCi/cc
I-133	1.33E+00 uCi/cc
I-134	4.11E-01 uCi/cc
I-135	1.10E+00 uCi/cc
Rb-88	1.97E-01 uCi/cc
Rb-89	1.54E-02 uCi/cc
Cs-134	1.82E-01 uCi/cc
Cs-137	3.57E-01 uCi/cc
Cs-138	9.36E-01 uCi/cc
TOTAL WATER SAMPLE	6.66E+00 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	9.9/ 0.3	0.3/ < 0.1	< 0.1/ < 0.1
0.1 ml	0.2/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

TABLE 7.9.g

WETWELL WATER ACTIVITY CONCENTRATION (T = 06:00) (21:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	7.46E-02 uCi/cc
Kr-87	4.51E-02 uCi/cc
Kr-88	1.51E-01 uCi/cc
Xe-133	1.03E+00 uCi/cc
Xe-133m	3.38E-02 uCi/cc
Xe-135	3.82E-01 uCi/cc
Br-83	7.83E-02 uCi/cc
I-131	1.70E+00 uCi/cc
I-132	1.09E+00 uCi/cc
I-133	2.78E+00 uCi/cc
I-134	4.04E-01 uCi/cc
I-135	2.16E+00 uCi/cc
Rb-88	2.02E-01 uCi/cc
Cs-134	4.06E-01 uCi/cc
Cs-137	7.99E-01 uCi/cc
Cs-138	6.01E-01 uCi/cc
TOTAL WATER SAMPLE	1.20E+01 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	16./ 0.6	0.4/ < 0.1	< 0.1/ < 0.1
0.1 ml	0.3/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

TABLE 7.9.h

WETWELL WATER ACTIVITY CONCENTRATION (T = 07:00) (22:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Kr-85m	7.80E-02 uCi/cc
Kr-87	3.20E-02 uCi/cc
Kr-88	1.45E-01 uCi/cc
Xe-133	1.27E+00 uCi/cc
Xe-133m	4.09E-02 uCi/cc
Xe-135	4.90E-01 uCi/cc
Br-83	5.97E-02 uCi/cc
I-131	1.73E+00 uCi/cc
I-132	8.21E-01 uCi/cc
I-133	2.74E+00 uCi/cc
I-134	1.87E-01 uCi/cc
I-135	1.98E+00 uCi/cc
Rb-88	1.64E-01 uCi/cc
Cs-134	4.13E-01 uCi/cc
Cs-137	8.13E-01 uCi/cc
Cs-138	1.77E-01 uCi/cc
TOTAL WATER SAMPLE	1.11E+01 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	15./ 0.5	0.3/ < 0.1	< 0.1/ < 0.1
0.1 ml	0.2/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

TABLE 7.9.i

WETWELL WATER ACTIVITY CONCENTRATION (T = 08:00) (23:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Kr-85m	7.74E-02 uCi/cc
Kr-87	2.15E-02 uCi/cc
Kr-88	1.31E-01 uCi/cc
Xe-133	1.47E+00 uCi/cc
Xe-133m	4.69E-02 uCi/cc
Xe-135	5.67E-01 uCi/cc
Br-83	4.53E-02 uCi/cc
I-131	1.74E+00 uCi/cc
I-132	6.14E-01 uCi/cc
I-133	2.68E+00 uCi/cc
I-134	8.60E-02 uCi/cc
I-135	1.81E+00 uCi/cc
Rb-88	1.31E-01 uCi/cc
Cs-134	4.18E-01 uCi/cc
Cs-137	8.22E-01 uCi/cc
Cs-138	5.13E-02 uCi/cc
TOTAL WATER SAMPLE	1.07E+01 uCi/cc

PASS Sample Dose Rates (Contact mR/hr/ 1 ft. mR/hr)

	Unshielded	2" Lead	4" Lead
10. ml	14./ 0.5	0.3/ < 0.1	< 0.1/ < 0.1
0.1 ml	0.2/ < 0.1	< 0.1/ < 0.1	< 0.1/ < 0.1

TABLE 7.10a

OFFSITE SURVEY AND SAMPLING DATA (T = 00:00) (15:00)

FIELD MONITOR POINT	MONITOR READINGS				AIR SAMPLES (10 CF)			15-min RAD DATA		*CONTROLLER INFO*			
	CLOSED WINDOW waist (mR/hr)	WINDOW ground (mR/hr)	OPEN WINDOW waist (mR/hr)	WINDOW ground (mR/hr)	Ground Frisk (cpm)	bare zeolite CPM	filter-zeolite CPM	change in SRD mR	contam cpm/100cm2	I-131 conc. uCi/cc	Child thyroid mrem/hr	SRD dose Plm	percent contrib Grd
ALL	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	60.	< 0.1	< 0.1	0.0E+00	0.0E+00	0	0 0

Air Sample Background is 60 CPM

Ground Frisk readings assume a perfectly shielded probe and do not include any readings from the plume.

FOR CONTROLLER/OBSERVER USE ONLY
(Not to be Provided to Players):

Current Stability Class D

Primary Release Pt: SS Flow: 1.3E+2 m3/sec
 Release Concentration-GIP (uCi/cc): 1.7E-09 4.2E-11 2.2E-12
 (Flow & Release Integrated & Averaged over previous 15 minutes)
 Whole Body Dose Projection: < 0.1 mRem/hr
 Adult Thyroid Dose Projection: < 0.1 mRem/hr
 at a distance of: .25 miles downwind
 Maximums and Projections do not include plant shine or ground shine
 Maximum Plume Whole-Body Dose Rate: < 0.1 mRem/hr
 at a distance of: .25 miles downwind
 Maximum Adult Thyroid Dose Commitment: < 0.1 mRem/hr
 at a distance of: .25 miles downwind

TABLE 7.10b

OFFSITE SURVEY AND SAMPLING DATA (T = 01:00) (16:00)

FIELD MONITOR POINT	MONITOR READINGS				AIR SAMPLES (10 CF)				15-min RAD DATA		*CONTROLLER INFO*		
	CLOSED WINDOW waist (mR/hr)	WINDOW ground (mR/hr)	OPEN WINDOW waist (mR/hr)	WINDOW ground (mR/hr)	Ground Frisk (cpm)	bare zeolite CPM	filter-zeolite CPM	change in SRD mR	contam cpm/100cm2	I-131 conc. uCi/cc	Child thyroid mrem/hr	SRD dose Plm	percent contrib Plt Grd
ALL	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	60.	< 0.1	< 0.1	0.0E+00	0.0E+00	0	0 0

Air Sample Background is 60 CPM

Ground Frisk readings assume a perfectly shielded probe and do not include any readings from the plume.

FOR CONTROLLER/OBSERVER USE ONLY
(Not to be Provided to Players):

Current Stability Class D

Primary Release Pt: SS Flow: 1.3E+2 m3/sec
 Release Concentration-GIP (uCi/cc): 1.8E-10 5.4E-11 2.6E-12
 (Flow & Release Integrated & Averaged over previous 15 minutes)
 Whole Body Dose Projection: < 0.1 mRem/hr
 Adult Thyroid Dose Projection: < 0.1 mRem/hr
 at a distance of: .25 miles downwind
 Maximums and Projections do not include plant shine or ground shine
 Maximum Plume Whole-Body Dose Rate: < 0.1 mRem/hr
 at a distance of: .25 miles downwind
 Maximum Adult Thyroid Dose Commitment: < 0.1 mRem/hr
 at a distance of: .25 miles downwind

TABLE 7.10c

OFFSITE SURVEY AND SAMPLING DATA (T = 02:00) (17:00)

FIELD MONITOR POINT	MONITOR READINGS				AIR SAMPLES (10 CF)			15-min RAD DATA		*CONTROLLER INFO*				
	CLOSED WINDOW waist (mR/hr)	WINDOW ground (mR/hr)	OPEN WINDOW waist (mR/hr)	WINDOW ground (mR/hr)	Ground Frisk (cpm)	bare zeolite CPM	filter- zeolite CPM	change in SRD mR	contam cpm/100cm2	I-131 conc. uCi/cc	Child thyroid mrem/hr	SRD percent dose contrib Plm	percent dose contrib Plt	Grd
ALL	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	60.	< 0.1	< 0.1	0.0E+00	0.0E+00	0	0	0

Air Sample Background is 60 CPM

Ground Frisk readings assume a perfectly shielded probe and do not include any readings from the plume.

FOR CONTROLLER/OBSERVER USE ONLY
(Not to be Provided to Players):

Current Stability Class D

Primary Release Pt: SS Flow: 1.3E+2 m3/sec
 Release Concentration-GIP (uCi/cc): 4.5E-11 5.2E-11 2.2E-12
 (Flow & Release Integrated & Averaged over previous 15 minutes)
 Whole Body Dose Projection: < 0.1 mRem/hr
 Adult Thyroid Dose Projection: < 0.1 mRem/hr
 at a distance of: .25 miles downwind
 Maximums and Projections do not include plant shine or ground shine
 Maximum Plume Whole-Body Dose Rate: < 0.1 mRem/hr
 at a distance of: .25 miles downwind
 Maximum Adult Thyroid Dose Commitment: < 0.1 mRem/hr
 at a distance of: .25 miles downwind

TABLE 7.10d

OFFSITE SURVEY AND SAMPLING DATA (T = 03:00) (18:00)

FIELD MONITOR POINT	MONITOR READINGS				AIR SAMPLES (10 CF)			15-min RAD DATA		*CONTROLLER INFO*		
	CLOSED WINDOW		OPEN WINDOW		Ground	bare	filter-	change	contam	I-131	Child	SRD percent
	waist	ground	waist	ground	Frisk	zeolite	zeolite	in SRD	cpm/ 100cm2	conc.	thyroid	dose contrib
	(mR/hr)	(mR/hr)	(mR/hr)	(mR/hr)	(cpm)	CPM	CPM	mR		uCi/cc	mrem/hr	Plm Pit Grd
ALL	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	60.	< 0.1	< 0.1	0.0E+00	0.0E+00	0 0 0

Air Sample Background is 60 CPM

Ground Frisk readings assume a perfectly shielded probe and do not include any readings from the plume.

FOR CONTROLLER/OBSERVER USE ONLY
(Not to be Provided to Players):

Current Stability Class D

Primary Release Pt: SS Flow: 1.3E+2 m3/sec
Release Concentration-GIP (uCi/cc): 4.4E-11 5.5E-11 1.8E-12
(Flow & Release Integrated & Averaged over previous 15 minutes)

Whole Body Dose Projection: < 0.1 mRem/hr
Adult Thyroid Dose Projection: < 0.1 mRem/hr
at a distance of: .25 miles downwind

Maximums and Projections do not include plant shine or ground shine

Maximum Plume Whole-Body Dose Rate: < 0.1 mRem/hr
at a distance of: .25 miles downwind

Maximum Adult Thyroid Dose Commitment: < 0.1 mRem/hr
at a distance of: .25 miles downwind

TABLE 7.10f

OFFSITE SURVEY AND SAMPLING DATA (T = 03:15) (18:15)

FIELD MONITOR POINT	MONITOR READINGS				Ground Frisk (cpm)	AIR SAMPLES (10 CF)		15-min RAD DATA		*CONTROLLER INFO*				
	CLOSED WINDOW waist (mR/hr)	WINDOW ground (mR/hr)	OPEN WINDOW waist (mR/hr)	WINDOW ground (mR/hr)		bare zeolite CPM	filter-zeolite CPM	change in SRD mR	contam cpm/100cm2	I-131 conc. uCi/cc	Child thyroid mrem/hr	SRD dose Plm	percent contrib Plt	Grd
Air Sample Background is 60 CPM														
C/L 0.5	4.1	4.1	6.6	6.6	< 0.1	710.	790.	1.0	18.	5.7E-08	8.9E+02	100	0	0
C/L 1.0	1.6	1.6	2.5	2.5	< 0.1	310.	340.	0.4	6.9	2.2E-08	3.4E+02	100	0	0
C/L 1.5	0.8	0.8	1.3	1.3	< 0.1	190.	210.	0.2	3.6	1.1E-08	1.8E+02	100	0	0
C/L 2.0	0.5	0.5	0.8	0.8	< 0.1	140.	150.	0.1	2.3	7.1E-09	1.1E+02	100	0	0
C/L 2.5	0.0	0.0	0.0	0.0	< 0.1	60.	60.	< 0.1	< 0.1	0.0E+00	0.0E+00	0	0	0

OTHERS	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	60.	< 0.1	< 0.1	0.0E+00	0.0E+00	0	0	0

Ground Frisk readings assume a perfectly shielded probe and do not include any readings from the plume.

CONTINUED ON NEXT PAGE

TABLE 7.10f

OFFSITE SURVEY AND SAMPLING DATA (T = 03:15) (18:15)
(continued)

FOR CONTROLLER/OBSERVER USE ONLY
(Not to be Provided to Players):

Current Stability Class D

Primary Release Pt: NS Flow: 1.9E+2 m3/sec
Release Concentration-GIP (uCi/cc): 1.6E-03 9.3E-05 5.7E-06
(Flow & Release Integrated & Averaged over previous 15 minutes)
Whole Body Dose Projection: 7.8 mRem/hr
Adult Thyroid Dose Projection: 320. mRem/hr
at a distance of: .25 miles downwind
Maximums and Projections do not include plant shine or ground shine

Maximum Plume Whole-Body Dose Rate: 7.8 mRem/hr
at a distance of: .25 miles downwind

Maximum Adult Thyroid Dose Commitment: 320. mRem/hr
at a distance of: .25 miles downwind

LIMERICK GENERATING STATION
ANNUAL EXERCISE

SCENARIO L53
UNIT 1 REV 0

TABLE 7.10g

OFFSITE SURVEY AND SAMPLING DATA (T = 03:30) (18:30)

FIELD MONITOR POINT	MONITOR READINGS				Ground Frisk (cpm)	AIR SAMPLES (10 CF)		15-min RAD DATA		*CONTROLLER INFO*				
	CLOSED WINDOW waist (mR/hr)	CLOSED WINDOW ground (mR/hr)	OPEN WINDOW waist (mR/hr)	OPEN WINDOW ground (mR/hr)		zeolite CPM	filter-zeolite CPM	change in SRD mR	contam cpm/100cm?	I-131 conc. uCi/cc	Child thyroid mrem/hr	SRD dose Plm	percent contrib Plt Grd	
Air Sample Background is 60 CPM														
C/L 0.5	7.9	7.9	13.	15.	1600.	800.	900.	2.0	30.	1.1E-07	1.6E+03	98	0	1
C/L 1.0	3.0	3.0	4.8	5.9	1000.	510.	570.	0.8	12.	4.0E-08	6.2E+02	98	0	1
C/L 1.5	1.6	1.6	2.5	3.1	520.	300.	330.	0.4	6.1	2.1E-08	3.3E+02	98	0	1
C/L 2.0	1.0	1.0	1.6	1.9	330.	210.	230.	0.2	3.8	1.3E-08	2.0E+02	98	0	1
C/L 2.5	0.7	0.7	1.1	1.3	230.	160.	170.	0.2	2.6	9.1E-09	1.4E+02	98	0	1
C/L 3.0	0.5	0.5	0.8	1.0	170.	140.	140.	0.1	1.9	6.7E-09	1.0E+02	98	0	1
C/L 3.5	0.4	0.4	0.6	0.7	130.	120.	120.	< 0.1	1.5	5.2E-09	8.0E+01	98	0	2
C/L 4.0	0.3	0.3	0.5	0.6	100.	110.	110.	< 0.1	1.2	4.1E-09	6.3E+01	98	0	1
C/L 4.5	0.3	0.3	0.4	0.5	85.	98.	100.	< 0.1	1.0	3.4E-09	5.2E+01	98	0	2
C/L 5.0	0.2	0.2	0.3	0.4	72.	92.	95.	< 0.1	0.8	2.8E-09	4.3E+01	97	0	2
C/L 5.5	0.2	0.2	0.3	0.3	59.	87.	90.	< 0.1	0.7	2.4E-09	3.7E+01	98	0	1
C/L 6.5	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	70.	93.	< 0.1	0.3	9.0E-10	1.4E+01	100	0	0
C/L 7.0	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	69.	89.	< 0.1	0.3	8.0E-10	1.2E+01	100	0	0
C/L 7.5	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	68.	86.	< 0.1	0.2	7.2E-10	1.1E+01	100	0	0
C/L 8.0	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	67.	84.	< 0.1	0.2	6.4E-10	9.9E+00	100	0	0
C/L 8.5	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	67.	81.	< 0.1	0.2	5.8E-10	8.9E+00	100	0	0
C/L 9.0	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	66.	79.	< 0.1	0.2	5.1E-10	8.0E+00	100	0	0
C/L 9.5	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	65.	77.	< 0.1	0.2	4.8E-10	7.4E+00	100	0	0
WNW9.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	61.	< 0.1	< 0.1	2.0E-11	3.1E+01	100	0	0
WNW8.3	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	61.	64.	< 0.1	< 0.1	1.1E-10	1.7E+00	100	0	0
WNW8.2	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	66.	81.	< 0.1	0.2	5.6E-10	8.7E+00	100	0	0
WNW7.2	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	66.	79.	< 0.1	0.2	5.1E-10	8.0E+00	100	0	0
WNW7.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	61.	< 0.1	< 0.1	3.8E-11	5.8E-01	100	0	0
WNW6.2	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	70.	91.	< 0.1	0.3	8.5E-10	1.3E+01	100	0	0
WNW3	0.5	0.5	0.7	0.9	140.	130.	140.	0.1	1.7	6.0E-09	9.3E+01	98	0	1
WNW1	0.2	0.2	0.3	0.6	330.	88.	91.	< 0.1	0.7	2.5E-09	3.8E+01	90	0	9
NW1	2.8	2.8	4.6	4.7	82.	500.	550.	0.7	11.	3.9E-08	6.0E+02	99	0	0
OTHERS	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	60.	< 0.1	< 0.1	0.0E+00	0.0E+00	0	0	0

Ground Frisk readings assume a perfectly shielded probe and do not include any readings from the plume.

CONTINUED ON NEXT PAGE

TABLE 7.10g

OFFSITE SURVEY AND SAMPLING DATA (T = 03:30) (18:30)
(continued)

FOR CONTROLLER/OBSERVER USE ONLY
(Not to be Provided to Players):

Current Stability Class D

Primary Release Pt: NS Flow: 1.9E+2 m3/sec
Release Concentration-GIP (uCi/cc): 2.7E-03 1.6E-04 9.4E-06
(Flow & Release Integrated & Averaged over previous 15 minutes)
Whole Body Dose Projection: 15. mRem/hr
Adult Thyroid Dose Projection: 600. mRem/hr
at a distance of: .25 miles downwind
Maximums and Projections do not include plant shine or ground shine
Maximum Plume Whole-Body Dose Rate: 15. mRem/hr
at a distance of: .25 miles downwind
Maximum Adult Thyroid Dose Commitment: 600. mRem/hr
at a distance of: .25 miles downwind

TABLE 7.10h
OFFSITE SURVEY AND SAMPLING DATA (T = 03:45) (18:45)

FIELD MONITOR POINT	MONITOR READINGS				Ground Frisk (cpm)	AIR SAMPLES (10 CF)		15-min RAD DATA		*CONTROLLER INFO*				
	CLOSED WINDOW waist (mR/hr)	CLOSED WINDOW ground (mR/hr)	OPEN WINDOW waist (mR/hr)	OPEN WINDOW ground (mR/hr)		bare zeolite CPM	filter-zeolite CPM	change in SRD mR	contam cpm/100cm2	I-131 conc. uCi/cc	Child thyroid mrem/hr	SRD dose Plm	percent contrib Plt Grd	
Air Sample Background is 60 CPM														
C/L 0.5	0.4	0.6	0.4	7.1	7000.	60.	60.	0.1	< 0.1	1.9E-12	2.7E-02	0	0	99
C/L 1.0	0.2	0.2	0.2	2.7	2600.	60.	60.	< 0.1	< 0.1	7.4E-13	1.0E-02	0	0	99
C/L 1.5	< 0.1	0.1	< 0.1	1.4	1400.	60.	60.	< 0.1	< 0.1	3.9E-13	5.5E-03	0	0	99
C/L 2.0	< 0.1	< 0.1	< 0.1	0.9	860.	60.	60.	< 0.1	< 0.1	2.4E-13	3.4E-03	0	0	99
C/L 2.5	< 0.1	< 0.1	< 0.1	0.6	610.	60.	60.	< 0.1	< 0.1	1.7E-13	2.4E-03	0	0	99
C/L 3.0	< 0.1	< 0.1	< 0.1	0.4	440.	60.	60.	< 0.1	< 0.1	1.2E-13	1.7E-03	0	0	99
C/L 3.5	< 0.1	< 0.1	< 0.1	0.3	340.	60.	60.	< 0.1	< 0.1	9.5E-14	1.3E-03	0	0	99
C/L 4.0	< 0.1	< 0.1	< 0.1	0.3	270.	60.	60.	< 0.1	< 0.1	7.6E-14	1.1E-03	0	0	99
C/L 4.5	< 0.1	< 0.1	< 0.1	0.2	220.	60.	60.	< 0.1	< 0.1	6.2E-14	8.7E-04	0	0	99
C/L 5.0	< 0.1	< 0.1	< 0.1	0.2	180.	60.	60.	< 0.1	< 0.1	5.2E-14	7.3E-04	0	0	99
C/L 6.0	0.1	0.1	0.2	0.2	49.	81.	130.	< 0.1	0.6	2.1E-09	2.9E+01	97	0	2
C/L 6.5	< 0.1	< 0.1	0.2	0.2	48.	78.	120.	< 0.1	0.6	1.8E-09	2.5E+01	97	0	2
C/L 7.0	< 0.1	< 0.1	0.1	0.2	41.	77.	110.	< 0.1	0.5	1.7E-09	2.3E+01	97	0	2
C/L 7.5	< 0.1	< 0.1	0.1	0.2	37.	74.	110.	< 0.1	0.4	1.4E-09	1.9E+01	97	0	2
C/L 8.0	< 0.1	< 0.1	0.1	0.1	33.	73.	100.	< 0.1	0.4	1.3E-09	1.8E+01	97	0	2
C/L 8.5	< 0.1	< 0.1	< 0.1	0.1	30.	72.	98.	< 0.1	0.4	1.2E-09	1.6E+01	97	0	2
C/L 10.0	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	65.	78.	< 0.1	0.1	4.4E-10	6.2E+00	100	0	0
WNW9.2	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	63.	72.	< 0.1	< 0.1	3.0E-10	4.3E+00	100	0	0
WNW8.3	< 0.1	< 0.1	< 0.1	< 0.1	5.9	69.	89.	< 0.1	0.3	8.7E-10	1.2E+01	99	0	0
WNW8.2	< 0.1	< 0.1	< 0.1	< 0.1	29.	66.	78.	< 0.1	0.2	5.4E-10	7.6E+00	94	0	5
WNW7.2	< 0.1	< 0.1	0.1	0.2	27.	76.	110.	< 0.1	0.5	1.5E-09	2.1E+01	98	0	1
WNW6.2	< 0.1	< 0.1	< 0.1	0.1	44.	68.	86.	< 0.1	0.2	7.7E-10	1.1E+01	94	0	5
WNW3	< 0.1	< 0.1	< 0.1	0.4	390.	60.	60.	< 0.1	< 0.1	1.2E-13	1.7E-03	0	0	99
WNW1	< 0.1	< 0.1	< 0.1	0.4	410.	60.	60.	< 0.1	< 0.1	1.9E-13	2.7E-03	0	0	99
NW1	< 0.1	0.1	< 0.1	1.7	1700.	60.	60.	< 0.1	< 0.1	2.4E-13	3.3E-03	0	0	99
OTHERS	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	60.	< 0.1	< 0.1	0.0E+00	0.0E+00	0	0	0

Ground Frisk readings assume a perfectly shielded probe and do not include any readings from the plume.

CONTINUED ON NEXT PAGE

TABLE 7.10h

OFFSITE SURVEY AND SAMPLING DATA (T = 03:45) (18:45)
(continued)

FOR CONTROLLER/OBSERVER USE ONLY
(Not to be Provided to Players):

Current Stability Class D

Primary Release Pt: NS Flow: 1.9E+2 m3/sec
Release Concentration-GIP (uCi/cc): 4.0E-08 2.7E-09 8.6E-11
(Flow & Release Integrated & Averaged over previous 15 minutes)
Whole Body Dose Projection: < 0.1 mRem/hr
Adult Thyroid Dose Projection: < 0.1 mRem/hr
at a distance of: .25 miles downwind
Maximums and Projections do not include plant shine or ground shine
Maximum Plume Whole-Body Dose Rate: 0.4 mRem/hr
at a distance of: 2.92 miles downwind
Maximum Adult Thyroid Dose Commitment: 21. mRem/hr
at a distance of: 2.92 miles downwind

TABLE 7.10i

OFFSITE SURVEY AND SAMPLING DATA (T = 04:00) (19:00)

FIELD MONITOR POINT	MONITOR READINGS				AIR SAMPLING (10 CF)					15-min RAD DATA					*CONTROLLER INFO*		
	CLOSED WINDOW		OPEN WINDOW		Ground Frisk	bare zeolite	filter-zeolite	change in SRD	contam cpm/100cm2	I-131 conc. uCi/cc	Child thyroid mrem/hr	SRD dose Plm	percent contrib	Plt	Grd		
	waist (mR/hr)	ground (mR/hr)	waist (mR/hr)	ground (mR/hr)	(cpm)	CPM	CPM	mR									
Air Sample Background is 60 CPM																	
C/L 0.5	0.4	0.5	0.4	6.5	6600.	60.	60.	< 0.1	< 0.1	1.9E-12	2.6E-02	0	0	99			
C/L 1.0	0.1	0.2	0.1	2.4	2500.	60.	60.	< 0.1	< 0.1	7.4E-13	9.1E-03	0	0	99			
C/L 1.5	< 0.1	< 0.1	< 0.1	1.3	1300.	60.	60.	< 0.1	< 0.1	3.9E-13	5.2E-03	0	0	99			
C/L 2.0	< 0.1	< 0.1	< 0.1	0.8	810.	60.	60.	< 0.1	< 0.1	2.4E-13	3.2E-03	0	0	99			
C/L 2.5	< 0.1	< 0.1	< 0.1	0.6	570.	60.	60.	< 0.1	< 0.1	1.7E-13	2.2E-03			0	99		
C/L 3.0	< 0.1	< 0.1	< 0.1	0.4	410.	60.	60.	< 0.1	< 0.1	1.2E-13	1.6E-03	0	0	99			
C/L 3.5	< 0.1	< 0.1	< 0.1	0.3	320.	60.	60.	< 0.1	< 0.1	9.4E-14	1.3E-03	0	0	99			
C/L 4.0	< 0.1	< 0.1	< 0.1	0.2	250.	60.	60.	< 0.1	< 0.1	7.5E-14	1.0E-03	0	0	99			
C/L 4.5	< 0.1	< 0.1	< 0.1	0.2	210.	60.	60.	< 0.1	< 0.1	6.1E-14	8.2E-04	0	0	99			
C/L 5.0	< 0.1	< 0.1	< 0.1	0.2	170.	60.	60.	< 0.1	< 0.1	5.1E-14	6.8E-04	0	0	99			
C/L 9.0	< 0.1	< 0.1	< 0.1	0.1	25.	70.	100.	< 0.1	0.3	1.0E-09	1.4E+01	97	0	2			
C/L 9.5	< 0.1	< 0.1	< 0.1	< 0.1	23.	69.	97.	< 0.1	0.3	9.5E-10	1.3E+01	97	0	2			
C/L 10.0	< 0.1	< 0.1	< 0.1	< 0.1	22.	68.	94.	< 0.1	0.2	8.6E-10	1.1E+01	97	0	2			
WNW10.2	< 0.1	< 0.1	< 0.1	< 0.1	0.3	62.	66.	< 0.1	< 0.1	1.6E-10	2.1E+00	99	0	0			
WNW9.2	< 0.1	< 0.1	< 0.1	< 0.1	15.	61.	64.	< 0.1	< 0.1	1.0E-10	1.4E+00	85	0	14			
WNW9.3	< 0.1	< 0.1	< 0.1	< 0.1	0.8	63.	73.	< 0.1	< 0.1	3.2E-10	4.3E+00	99	0	0			
WNW3	< 0.1	< 0.1	< 0.1	0.4	370.	60.	60.	< 0.1	< 0.1	2.7E-15	3.6E-05	0	0	100			
WNW1	< 0.1	< 0.1	< 0.1	0.4	390.	60.	60.	< 0.1	< 0.1	1.4E-13	1.9E-03	0	0	99			
NW1	< 0.1	0.1	< 0.1	1.6	1600.	60.	60.	< 0.1	< 0.1	2.5E-20	3.3E-10	0	0	100			
OTHERS	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	60.	< 0.1	< 0.1	0.0E+00	0.0E+00	0	0	0			

Ground Frisk readings assume a perfectly shielded probe and do not include any readings from the plume.

CONTINUED ON NEXT PAGE

TABLE 7.10i

OFFSITE SURVEY AND SAMPLING DATA (T = 04:00) (19:00)
(continued)

FOR CONTROLLER/OBSERVER USE ONLY
(Not to be Provided to Players):

Current Stability Class D

Primary Release Pt: NS Flow: 1.9E+2 m3/sec
Release Concentration-GIP (uCi/cc): 5.5E-08 2.4E-09 8.4E-11
(Flow & Release Integrated & Averaged over previous 15 minutes)
Whole Body Dose Projection: < 0.1 mRem/hr
Adult Thyroid Dose Projection: < 0.1 mRem/hr
at a distance of: .25 miles downwind
Maximums and Projections do not include plant shine or ground shine

Maximum Plume Whole-Body Dose Rate: < 0.1 mRem/hr
at a distance of: 5.90 miles downwind

Maximum Adult Thyroid Dose Commitment: 6.4 mRem/hr
at a distance of: 5.90 miles downwind

TABLE 7.10j

OFFSITE SURVEY AND SAMPLING DATA (T = 04:15) (19:15)

FIELD MONITOR POINT	MONITOR READINGS				Ground Frisk (cpm)	AIR SAMPLES (10 CF)		15-min RAD DATA		*CONTROLLER INFO*				
	CLOSED WINDOW		OPEN WINDOW			bare zeolite CPM	filter-zeolite CPM	change in SRD mR	contam cpm/100cm2	I-131 conc. uCi/cc	Child thyroid mrem/hr	SRD dose Plm	percent contrib Plt Grd	
Air Sample Background is 60 CPM														
C/L 0.5	0.3	0.5	0.3	5.9	6300.	60.	60.	< 0.1	< 0.1	2.0E-12	2.5E-02	0	0	99
C/L 1.0	0.1	0.2	0.1	2.2	2400.	60.	60.	< 0.1	< 0.1	7.7E-13	9.6E-03	0	0	99
C/L 1.5	< 0.1	< 0.1	< 0.1	1.2	1200.	60.	60.	< 0.1	< 0.1	4.0E-13	5.1E-03	0	0	99
C/L 2.0	< 0.1	< 0.1	< 0.1	0.7	770.	60.	60.	< 0.1	< 0.1	2.5E-13	3.2E-03	0	0	99
C/L 2.5	< 0.1	< 0.1	< 0.1	0.5	540.	60.	60.	< 0.1	< 0.1	1.7E-13	2.2E-03	0	0	99
C/L 3.0	< 0.1	< 0.1	< 0.1	0.4	390.	60.	60.	< 0.1	< 0.1	1.3E-13	1.6E-03	0	0	99
C/L 3.5	< 0.1	< 0.1	< 0.1	0.3	300.	60.	60.	< 0.1	< 0.1	9.8E-14	1.2E-03	0	0	99
C/L 4.0	< 0.1	< 0.1	< 0.1	0.2	240.	60.	60.	< 0.1	< 0.1	7.9E-14	9.8E-04	0	0	99
C/L 4.5	< 0.1	< 0.1	< 0.1	0.2	200.	60.	60.	< 0.1	< 0.1	6.4E-14	8.0E-04	0	0	99
WNW3	< 0.1	< 0.1	< 0.1	0.3	350.	60.	60.	< 0.1	< 0.1	2.8E-15	3.6E-05	0	0	100
WNW1	< 0.1	< 0.1	< 0.1	0.3	370.	60.	60.	< 0.1	< 0.1	1.5E-13	1.9E-03	0	0	99
NW1	< 0.1	0.1	< 0.1	1.4	1500.	60.	60.	< 0.1	< 0.1	2.6E-20	3.3E-10	0	0	100
OTHERS	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	60.	< 0.1	< 0.1	0.0E+00	0.0E+00	0	0	0

Ground Frisk readings assume a perfectly shielded probe and do not include any readings from the plume.

FOR CONTROLLER/OBSERVER USE ONLY
(Not to be Provided to Players):

Current Stability Class D

Primary Release Pt: NS Flow: 1.9E+2 m3/sec
Release Concentration-GIP (uCi/cc): 7.3E-08 2.1E-09 8.0E-11
(Flow & Release Integrated & Averaged over previous 15 minutes)

Whole Body Dose Projection: < 0.1 mRem/hr

Adult Thyroid Dose Projection: < 0.1 mRem/hr

at a distance of: .25 miles downwind

Maximums and Projections do not include plant shine or ground shine

Maximum Plume Whole-Body Dose Rate: < 0.1 mRem/hr
at a distance of: 8.70 miles downwind

Maximum Adult Thyroid Dose Commitment: 3.1 mRem/hr
at a distance of: 8.70 miles downwind

TABLE 7.10k

OFFSITE SURVEY AND SAMPLING DATA (T = 04:30) (19:30)

FIELD MONITOR POINT	MONITOR READINGS				Ground Frisk (cpm)	AIR SAMPLES (10 CF)			15-min RAD DATA		*CONTROLLER INFO*			
	CLOSED waist (mR/hr)	WINDOW ground (mR/hr)	OPEN waist (mR/hr)	WINDOW ground (mR/hr)		bare zeolite CPM	filter- zeolite CPM	change in SRD mR	contam cpm/100cm2	I-131 conc. uCi/cc	Child thyroid mrem/hr	SRD dose Plm	percent contrib Plt	Grd
Air Sample Background is 60 CPM														
C/L 0.5	0.3	0.4	0.3	5.5	6000.	60.	60.	< 0.1	< 0.1	1.9E-12	2.2E-02	0	0	99
C/L 1.0	0.1	0.2	0.1	2.1	2200.	60.	60.	< 0.1	< 0.1	7.1E-13	8.5E-03	0	0	99
C/L 1.5	< 0.1	< 0.1	< 0.1	1.1	1200.	60.	60.	< 0.1	< 0.1	3.8E-13	4.5E-03	0	0	99
C/L 2.0	< 0.1	< 0.1	< 0.1	0.7	730.	60.	60.	< 0.1	< 0.1	2.3E-13	2.8E-03	0	0	99
C/L 2.5	< 0.1	< 0.1	< 0.1	0.5	510.	60.	60.	< 0.1	< 0.1	1.6E-13	1.9E-03	0	0	99
C/L 3.0	< 0.1	< 0.1	< 0.1	0.3	370.	60.	60.	< 0.1	< 0.1	1.2E-13	1.4E-03	0	0	99
C/L 3.5	< 0.1	< 0.1	< 0.1	0.3	290.	60.	60.	< 0.1	< 0.1	9.1E-14	1.1E-03	0	0	99
C/L 4.0	< 0.1	< 0.1	< 0.1	0.2	230.	60.	60.	< 0.1	< 0.1	7.2E-14	8.6E-04	0	0	99
C/L 4.5	< 0.1	< 0.1	< 0.1	0.2	190.	60.	60.	< 0.1	< 0.1	5.9E-14	7.1E-04	0	0	99
WNW3	< 0.1	< 0.1	< 0.1	0.3	330.	60.	60.	< 0.1	< 0.1	3.0E-15	3.6E-05	0	0	100
WNW1	< 0.1	< 0.1	< 0.1	0.3	350.	60.	60.	< 0.1	< 0.1	6.1E-28	7.3E-18	0	0	100
NW1	< 0.1	0.1	< 0.1	1.3	1500.	60.	60.	< 0.1	< 0.1	2.8E-20	3.3E-10	0	0	100
OTHERS	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	60.	< 0.1	< 0.1	0.0E+00	0.0E+00	0	0	0

Ground Frisk readings assume a perfectly shielded probe and do not include any readings from the plume.

FOR CONTROLLER/OBSERVER USE ONLY
(Not to be Provided to Players):

Current Stability Class D

Primary Release Pt: NS Flow: 1.9E+2 m3/sec
 Release Concentration-GIP (uCi/cc): 8.0E-08 1.6E-09 6.6E-11
 (Flow & Release Integrated & Averaged over previous 15 minutes)
 Whole Body Dose Projection: < 0.1 mRem/hr
 Adult Thyroid Dose Projection: < 0.1 mRem/hr
 at a distance of: .25 miles downwind
 Maximums and Projections do not include plant shine or ground shine
 Maximum Plume Whole-Body Dose Rate: < 0.1 mRem/hr
 at a distance of: 11.81 miles downwind
 Maximum Adult Thyroid Dose Commitment: 1.9 mRem/hr
 at a distance of: 11.81 miles downwind

TABLE 7.101

OFFSITE SURVEY AND SAMPLING DATA (T = 05:00) (20:00)

FIELD MONITOR POINT	MONITOR READINGS				Ground Frisk (cpm)	AIR SAMPLES (10 CF ³)			15-min RAD DATA		*CONTROLLER INFO*			
	CLOSED WINDOW waist (mR/hr)	CLOSED WINDOW ground (mR/hr)	OPEN WINDOW waist (mR/hr)	OPEN WINDOW ground (mR/hr)		bare zeolite CPM	filter- zeolite CPM	change in SRD mR	contam cpm/100cm ²	I-131 conr. uCi/cc	Child thyroid mrem/hr	SRD dose Plm	percent contrib Plt	Grd
Air Sample Background is 60 CPM														
C/L 0.5	0.3	0.4	0.3	4.7	5500.	60.	60.	< 0.1	< 0.1	2.2E-12	2.4E-02	0	0	99
C/L 1.0	0.1	0.1	0.1	1.8	2100.	60.	60.	< 0.1	< 0.1	8.3E-13	9.1E-03	0	0	99
C/L 1.5	< 0.1	< 0.1	< 0.1	0.9	1100.	60.	60.	< 0.1	< 0.1	4.4E-13	4.8E-03	0	0	99
C/L 2.0	< 0.1	< 0.1	< 0.1	0.6	670.	60.	60.	< 0.1	< 0.1	2.7E-13	3.0E-03	0	0	99
C/L 2.5	< 0.1	< 0.1	< 0.1	0.4	470.	60.	60.	< 0.1	< 0.1	1.9E-13	2.0E-03	0	0	99
C/L 3.0	< 0.1	< 0.1	< 0.1	0.3	340.	60.	60.	< 0.1	< 0.1	1.4E-13	1.5E-03	0	0	99
C/L 3.5	< 0.1	< 0.1	< 0.1	0.2	260.	60.	60.	< 0.1	< 0.1	1.1E-13	1.2E-03	0	0	99
C/L 4.0	< 0.1	< 0.1	< 0.1	0.2	210.	60.	60.	< 0.1	< 0.1	8.5E-14	9.2E-04	0	0	99
WNW3	< 0.1	< 0.1	< 0.1	0.3	300.	60.	60.	< 0.1	< 0.1	3.3E-15	3.6E-05	0	0	100
WNW1	< 0.1	< 0.1	< 0.1	0.3	320.	60.	60.	< 0.1	< 0.1	6.7E-28	7.3E-18	0	0	100
NW1	< 0.1	< 0.1	< 0.1	1.1	1300.	60.	60.	< 0.1	< 0.1	3.0E-20	3.3E-10	0	0	100
OTHERS	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	60.	< 0.1	< 0.1	0.0E+00	0.0E+00	0	0	0

Ground Frisk readings assume a perfectly shielded probe and do not include any readings from the plume.

FOR CONTROLLER/OBSERVER USE ONLY
(Not to be Provided to Players):

Current Stability Class D

Primary Release Pt: NS Flow: 1.9E+2 m³/sec
 Release Concentration-GIP (uCi/cc): 1.0E-07 2.0E-09 5.5E-11
 (Flow & Release Integrated & Averaged over previous 15 minutes)
 Whole Body Dose Projection: < 0.1 mRem/hr
 Adult Thyroid Dose Projection: < 0.1 mRem/hr
 at a distance of: .25 miles downwind
 Maximums and Projections do not include plant shine or ground shine
 Maximum Plume Whole-Body Dose Rate: < 0.1 mRem/hr
 at a distance of: 17.40 miles downwind
 Maximum Adult Thyroid Dose Commitment: 0.9 mRem/hr
 at a distance of: 17.40 miles downwind

TABLE 7.10m

OFFSITE SURVEY AND SAMPLING DATA (T = 05:30) (20:30)

FIELD MONITOR POINT	MONITOR READINGS				Ground Frisk (cpm)	AIR SAMPLES (10 CF)			15-min RAD DATA		*CONTROLLER INFO*			
	CLOSED waist (mR/hr)	WINDOW ground (mR/hr)	OPEN waist (mR/hr)	WINDOW ground (mR/hr)		bare zeolite CPM	filter- zeolite CPM	change in SRD mR	contam cpm/100cm2	I-131 conc. uCi/cc	Child thyroid mrem/hr	SRD dose Plm	percent contrib Plt	
Air Sample Background is 60 CPM														
C/L 0.5	0.3	0.4	0.3	4.2	5100.	61.	61.	< 0.1	< 0.1	1.2E-10	1.2E+00	1	0	98
C/L 1.0	< 0.1	0.1	< 0.1	1.6	1900.	60.	60.	< 0.1	< 0.1	4.5E-11	4.5E-01	1	0	98
C/L 1.5	< 0.1	< 0.1	< 0.1	0.8	990.	60.	60.	< 0.1	< 0.1	2.3E-11	2.4E-01	1	0	98
C/L 2.0	< 0.1	< 0.1	< 0.1	0.5	620.	60.	60.	< 0.1	< 0.1	1.5E-11	1.5E-01	1	0	98
C/L 2.5	< 0.1	< 0.1	< 0.1	0.4	440.	60.	60.	< 0.1	< 0.1	1.0E-11	1.0E-01	1	0	98
C/L 3.0	< 0.1	< 0.1	< 0.1	0.3	320.	60.	60.	< 0.1	< 0.1	7.4E-12	7.5E-02	1	0	98
C/L 3.5	< 0.1	< 0.1	< 0.1	0.2	240.	60.	60.	< 0.1	< 0.1	5.7E-12	5.8E-02	1	0	98
C/L 4.0	< 0.1	< 0.1	< 0.1	0.2	190.	60.	60.	< 0.1	< 0.1	4.5E-12	4.6E-02	1	0	98
WNW3	< 0.1	< 0.1	< 0.1	0.2	280.	60.	60.	< 0.1	< 0.1	3.3E-25	3.3E-15	0	0	100
WNW1	< 0.1	< 0.1	< 0.1	0.2	300.	60.	60.	< 0.1	< 0.1	1.4E-21	1.4E-11	0	0	100
NW1	< 0.1	< 0.1	< 0.1	1.0	1200.	60.	60.	< 0.1	< 0.1	3.3E-20	3.3E-10	0	0	100
OTHERS	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	60.	< 0.1	< 0.1	0.0E+00	0.0E+00	0	0	0

Ground Frisk readings assume a perfectly shielded probe and do not include any readings from the plume.

FOR CONTROLLER/OBSERVER USE ONLY
(Not to be Provided to Players):

Current Stability Class D

Primary Release Pt: NS Flow: 1.9E+2 m3/sec
 Release Concentration-GIP (uCi/cc): 2.4E-06 8.7E-08 1.0E-09
 (Flow & Release Integrated & Averaged over previous 15 minutes)
 Whole Body Dose Projection: < 0.1 mRem/hr
 Adult Thyroid Dose Projection: 0.6 mRem/hr
 at a distance of: .25 miles downwind
 Maximums and Projections do not include plant shine or ground shine
 Maximum Plume Whole-Body Dose Rate: < 0.1 mRem/hr
 at a distance of: .25 miles downwind
 Maximum Adult Thyroid Dose Commitment: 0.6 mRem/hr
 at a distance of: .25 miles downwind

TABLE 7.10n

OFFSITE SURVEY AND SAMPLING DATA (T = 06:00) (21:00)

FIELD MONITOR POINT	MONITOR READINGS				AIR SAMPLES (10 CF)			15-min RAD DATA		*CONTROLLER INFO*				
	CLOSED WINDOW waist (mR/hr)	CLOSED WINDOW ground (mR/hr)	OPEN WINDOW waist (mR/hr)	OPEN WINDOW ground (mR/hr)	Ground Frisk (cpm)	bare zeolite CPM	filter-zeolite CPM	change in SRD mR	contam cpm/100cm2	I-131 conc. uCi/cc	Child thyroid mrem/hr	SRD percent dose contrib Plm Plt Grd		
Air Sample Background is 60 CPM														
C/L 0.5	0.3	0.3	0.3	3.8	4800.	61.	62.	< 0.1	< 0.1	2.1E-10	2.0E+00	7	0	92
C/L 1.0	< 0.1	0.1	0.1	1.4	1800.	61.	61.	< 0.1	< 0.1	1.1E-10	1.0E+00	9	0	90
C/L 1.5	< 0.1	< 0.1	< 0.1	0.7	930.	60.	61.	< 0.1	< 0.1	6.7E-11	6.4E-01	10	0	89
C/L 2.0	< 0.1	< 0.1	< 0.1	0.5	590.	60.	60.	< 0.1	< 0.1	4.7E-11	4.5E-01	11	0	88
C/L 2.5	< 0.1	< 0.1	< 0.1	0.3	410.	60.	60.	< 0.1	< 0.1	3.5E-11	3.3E-01	12	0	87
C/L 3.0	< 0.1	< 0.1	< 0.1	0.2	300.	60.	60.	< 0.1	< 0.1	2.8E-11	2.6E-01	13	0	86
C/L 3.5	< 0.1	< 0.1	< 0.1	0.2	230.	60.	60.	< 0.1	< 0.1	2.3E-11	2.2E-01	14	0	85
WNWS	< 0.1	< 0.1	< 0.1	0.2	260.	60.	60.	< 0.1	< 0.1	2.7E-22	2.6E-12	0	0	100
WNW1	< 0.1	< 0.1	< 0.1	0.2	280.	60.	60.	< 0.1	< 0.1	7.6E-19	7.3E-09	0	0	100
NW1	< 0.1	< 0.1	< 0.1	0.9	1200.	60.	60.	< 0.1	< 0.1	3.5E-20	3.3E-10	0	0	100
OTHERS	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	60.	< 0.1	< 0.1	0.0E+00	0.0E+00	0	0	0

Ground Frisk readings assume a perfectly shielded probe and do not include any readings from the plume.

FOR CONTROLLER/OBSERVER USE ONLY
(Not to be Provided to Players):

Current Stability Class E

Primary Release Pt: NS Flow: 1.9E+2 m3/sec
 Release Concentration-GIP (uCi/cc): 4.9E-06 7.4E-08 1.8E-09
 (Flow & Release Integrated & Averaged over previous 15 minutes)
 Whole Body Dose Projection: < 0.1 mRem/hr
 Adult Thyroid Dose Projection: 1.2 mRem/hr
 at a distance of: .25 miles downwind
 Maximums and Projections do not include plant shine or ground shine
 Maximum Plume Whole-Body Dose Rate: < 0.1 mRem/hr
 at a distance of: .25 miles downwind
 Maximum Adult Thyroid Dose Commitment: 1.2 mRem/hr
 at a distance of: .25 miles downwind

TABLE 7.10o

OFFSITE SURVEY AND SAMPLING DATA (T = 07:00) (22:00)

FIELD MONITOR POINT	MONITOR READINGS				Ground Frisk (cpm)	AIR SAMPLES (10 CF)		15-min RAD DATA		*CONTROLLER INFO*				
	CLOSED WINDOW waist (mR/hr)	CLOSED WINDOW ground (mR/hr)	OPEN WINDOW waist (mR/hr)	OPEN WINDOW ground (mR/hr)		bare zeolite CPM	filter- zeolite CPM	change in SRD mR	contam cpm/100cm2	I-131 conc. uCi/cc	Child thyroid mrem/hr	SRD percent dose contrib Plm	percent dose contrib Plt	Grd
Air Sample Background is 60 CPM														
C/L 0.5	0.2	0.3	0.2	3.2	4300.	60.	60.	< 0.1	< 0.1	6.6E-11	5.6E-01	7	0	93
C/L 1.0	< 0.1	0.1	< 0.1	1.2	1600.	60.	60.	< 0.1	< 0.1	2.5E-11	2.2E-01	7	0	92
C/L 1.5	< 0.1	< 0.1	< 0.1	0.6	840.	60.	60.	< 0.1	< 0.1	1.3E-11	1.1E-01	7	0	92
C/L 2.0	< 0.1	< 0.1	< 0.1	0.4	530.	60.	60.	< 0.1	< 0.1	8.3E-12	7.1E-02	7	0	92
C/L 2.5	< 0.1	< 0.1	< 0.1	0.3	370.	60.	60.	< 0.1	< 0.1	5.7E-12	4.9E-02	7	0	92
C/L 3.0	< 0.1	< 0.1	< 0.1	0.2	270.	60.	60.	< 0.1	< 0.1	4.2E-12	3.6E-02	7	0	92
C/L 4.0	< 0.1	< 0.1	< 0.1	0.1	160.	60.	60.	< 0.1	< 0.1	1.2E-11	9.9E-02	21	0	78
WNW3	< 0.1	< 0.1	< 0.1	0.2	240.	60.	60.	< 0.1	< 0.1	3.0E-22	2.6E-12	0	0	100
WNW1	< 0.1	< 0.1	< 0.1	0.2	250.	60.	60.	< 0.1	< 0.1	5.5E-24	4.7E-14	0	0	100
NW1	< 0.1	< 0.1	< 0.1	0.8	1000.	60.	60.	< 0.1	< 0.1	3.9E-20	3.3E-10	0	0	100
OTHERS	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	60.	< 0.1	< 0.1	0.0E+00	0.0E+00	0	0	0

Ground Frisk readings assume a perfectly shielded probe and do not include any readings from the plume.

FOR CONTROLLER/OBSERVER USE ONLY
(Not to be Provided to Players):

Current Stability Class D

Primary Release Pt: NS Flow: 1.9E+2 m3/sec
 Release Concentration-GIP (uCi/cc): 8.6E-06 3.7E-08 2.6E-09
 (Flow & Release Integrated & Averaged over previous 15 minutes)
 Whole Body Dose Projection: < 0.1 mRem/hr
 Adult Thyroid Dose Projection: 0.4 mRem/hr
 at a distance of: .25 miles downwind
 Maximums and Projections do not include plant shine or ground shine
 Maximum Plume Whole-Body Dose Rate: < 0.1 mRem/hr
 at a distance of: .25 miles downwind
 Maximum Adult Thyroid Dose Commitment: 0.4 mRem/hr
 at a distance of: .25 miles downwind

TABLE 7.10p
OFFSITE SURVEY AND SAMPLING DATA (T = 08:00) (23:00)

FIELD MONITOR POINT	MONITOR READINGS				Ground Frisk (cpm)	AIR SAMPLES (10 CF)			15-min RAD DATA		*CONTROLLER INFO*		
	CLOSED waist (mR/hr)	WINDOW ground (mR/hr)	OPEN waist (mR/hr)	WINDOW ground (mR/hr)		bare zeolite CPM	filter- zeolite CPM	change in SRD mR	contam cpm/100cm2	I-131 conc. uCi/cc	Child thyroid mrem/hr	SRD dose Plm	percent contrib Plt Grd
Air Sample Background is 60 CPM													
C/L 0.5	0.2	0.3	0.2	2.8	4000.	60.	60.	< 0.1	< 0.1	5.3E-11	4.2E-01	9	0 90
C/L 1.0	< 0.1	< 0.1	< 0.1	1.1	1500.	60.	60.	< 0.1	< 0.1	2.0E-11	1.6E-01	9	0 90
C/L 1.5	< 0.1	< 0.1	< 0.1	0.6	780.	60.	60.	< 0.1	< 0.1	1.1E-11	8.4E-02	9	0 90
C/L 2.0	< 0.1	< 0.1	< 0.1	0.3	490.	60.	60.	< 0.1	< 0.1	6.6E-12	5.2E-02	9	0 90
C/L 2.5	< 0.1	< 0.1	< 0.1	0.2	340.	60.	60.	< 0.1	< 0.1	4.6E-12	3.6E-02	9	0 90
C/L 3.0	< 0.1	< 0.1	< 0.1	0.2	250.	60.	60.	< 0.1	< 0.1	3.4E-12	2.6E-02	9	0 90
NW1	< 0.1	< 0.1	< 0.1	0.7	960.	60.	60.	< 0.1	< 0.1	4.2E-20	3.3E-10	0	0 100
OTHERS	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	60.	60.	< 0.1	< 0.1	0.0E+00	0.0E+00	0	0 0

Ground Frisk readings assume a perfectly shielded probe and do not include any readings from the plume.


FOR CONTROLLER/OBSERVER USE ONLY
(Not to be Provided to Players):

Current Stability Class D

Primary Release Pt: NS Flow: 1.9E+2 m3/sec
 Release Concentration-GIP (uCi/cc): 1.2E-05 2.7E-08 2.8E-09
 (Flow & Release Integrated & Averaged over previous 15 minutes)
 Whole Body Dose Projection: < 0.1 mRem/hr
 Adult Thyroid Dose Projection: 0.3 mRem/hr
 at a distance of: .25 miles downwind
 Maximums and Projections do not include plant shine or ground shine

Maximum Plume Whole-Body Dose Rate: < 0.1 mRem/hr
 at a distance of: .25 miles downwind

Maximum Adult Thyroid Dose Commitment: 0.3 mRem/hr
 at a distance of: .25 miles downwind



MILES

2 Miles

1 Mile

1 Mile

Limerick Generating Station

Stability Class Neutral

EAST VINCENT

SPRING

UPPER PROVIDENCE

REVERSFORD

LIMERICK

LOWER POTTSBORO

POTTSBORO

MONTGOMERY CO.

EASTERN STATE GAME FARM

CHESTER

PHEASANT RUN

SNOWDENVILLE

STONY

STONY

STONY

STONY

STONY

STONY

STONY

STONY

STONY

2.1

2.1

1.0

1.0

1.0

0.0

0.0

0.0

0.0

0.0

1.0

1.0

1.0

2.0

2.0

3.0

3.0

4.0

4.0

4.0

3.0

3.0

3.0

3.0

3.0

3.0

3.0

3.0

3.0

3.0

3.0

3.0

3.0

3.0

3.0

3.0

3.0

3.0

3.0

3.0

3.1

3.1

3.1

3.1

3.1

3.1

3.1

3.1

3.1

3.1

3.1

3.1

3.1

3.1

3.1

3.1

3.1

3.1

3.1

3.1

3.2

3.2

3.2

3.2

3.2

3.2

3.2

3.2

3.2

3.2

3.2

3.2

3.2

3.2

3.2

3.2

3.2

3.2

3.2

3.2

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

4.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0

5.0


5.0

5.0

5.0

5.0

5.0



AC
ATURE
CARD

Also Available on
Aperture Card

9511010121-01

TABLE 7.11a

ENVIRONMENTAL SAMPLING DATA (T = 00:00) (15:00)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	----- (cpm/100cm ²)

ALL SAMPLES LESS THAN MDA

TABLE 7.11b

ENVIRONMENTAL SAMPLING DATA (T = 01:00) (16:00)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm2)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
C/L 0.5	4.2	4.3	< 0.1
C/L 1.0	1.6	1.6	< 0.1
C/L 1.5	0.8	0.8	< 0.1
C/L 2.0	0.5	0.5	< 0.1
C/L 2.5	0.4	0.4	< 0.1
C/L 3.0	0.3	0.3	< 0.1
C/L 3.5	0.2	0.2	< 0.1
C/L 4.0	0.2	0.2	< 0.1
C/L 4.5	0.1	0.1	< 0.1
C/L 5.0	0.1	0.1	< 0.1
C/L 5.5	< 0.1	< 0.1	< 0.1
WNW3	0.1	0.1	< 0.1
WNW1	0.4	0.5	< 0.1
W-0	0.6	0.6	< 0.1

OTHER SAMPLES LESS THAN MDA

TABLE 7.11c

ENVIRONMENTAL SAMPLING DATA (T = 02:00) (17:00)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm2)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
C/L 0.5	7.8	7.9	< 0.1
C/L 1.0	3.0	3.0	< 0.1
C/L 1.5	1.6	1.6	< 0.1
C/L 2.0	1.0	1.0	< 0.1
C/L 2.5	0.7	0.7	< 0.1
C/L 3.0	0.5	0.5	< 0.1
C/L 3.5	0.4	0.4	< 0.1
C/L 4.0	0.3	0.3	< 0.1
C/L 4.5	0.3	0.3	< 0.1
C/L 5.0	0.2	0.2	< 0.1
C/L 5.5	0.2	0.2	< 0.1
C/L 6.0	0.1	0.1	< 0.1
C/L 6.5	0.1	0.1	< 0.1
C/L 7.0	< 0.1	< 0.1	< 0.1
C/L 7.5	< 0.1	< 0.1	< 0.1
C/L 8.0	< 0.1	< 0.1	< 0.1
WNW3	0.2	0.2	< 0.1
WNW1	0.7	0.7	< 0.1
W2	0.1	0.1	< 0.1
W-0	1.5	1.5	< 0.1
W1	< 0.1	< 0.1	< 0.1

OTHER SAMPLES LESS THAN MDA

TABLE 7.11d

ENVIRONMENTAL SAMPLING DATA (T = 03:00) (18:00)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm2)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
C/L 0.5	11.	11.	< 0.1
C/L 1.0	4.3	4.3	< 0.1
C/L 1.5	2.2	2.2	< 0.1
C/L 2.0	1.4	1.4	< 0.1
C/L 2.5	1.0	1.0	< 0.1
C/L 3.0	0.7	0.7	< 0.1
C/L 3.5	0.5	0.5	< 0.1
C/L 4.0	0.4	0.4	< 0.1
C/L 4.5	0.4	0.4	< 0.1
C/L 5.0	0.3	0.3	< 0.1
C/L 5.5	0.2	0.3	< 0.1
C/L 6.0	0.2	0.2	< 0.1
C/L 6.5	0.2	0.2	< 0.1
C/L 7.0	0.1	0.1	< 0.1
C/L 7.5	0.1	0.1	< 0.1
C/L 8.0	0.1	0.1	< 0.1
C/L 8.5	< 0.1	< 0.1	< 0.1
C/L 9.0	< 0.1	< 0.1	< 0.1
WNW6.2	< 0.1	< 0.1	< 0.1
WNW3	0.3	0.3	< 0.1
WNW1	1.2	1.2	< 0.1
W2	< 0.1	< 0.1	< 0.1
W-0	1.5	1.5	< 0.1

OTHER SAMPLES LESS THAN MDA

TABLE 7.11e

ENVIRONMENTAL SAMPLING DATA (T = 03:15) (18:15)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm ²)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
C/L 0.5	12.	12.	< 0.1
C/L 1.0	4.5	4.5	< 0.1
C/L 1.5	2.3	2.3	< 0.1
C/L 2.0	1.5	1.5	< 0.1
C/L 2.5	1.0	1.0	< 0.1
C/L 3.0	0.7	0.7	< 0.1
C/L 3.5	0.6	0.6	< 0.1
C/L 4.0	0.5	0.5	< 0.1
C/L 4.5	0.4	0.4	< 0.1
C/L 5.0	0.3	0.3	< 0.1
C/L 5.5	0.3	0.3	< 0.1
C/L 6.0	0.2	0.2	< 0.1
C/L 6.5	0.2	0.2	< 0.1
C/L 7.0	0.2	0.2	< 0.1
C/L 7.5	0.1	0.1	< 0.1
C/L 8.0	0.1	0.1	< 0.1
C/L 8.5	< 0.1	< 0.1	< 0.1
C/L 9.0	< 0.1	< 0.1	< 0.1
C/L 9.5	< 0.1	< 0.1	< 0.1
WNW6.2	0.1	0.1	< 0.1
WNW3	0.3	0.3	< 0.1
WNW1	1.2	1.2	< 0.1
W2	< 0.1	< 0.1	< 0.1
NW1	0.4	0.4	< 0.1
W-0	1.4	1.4	< 0.1

OTHER SAMPLES LESS THAN MDA

TABLE 7.11f

ENVIRONMENTAL SAMPLING DATA (T = 03:30) (18:30)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm2)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
C/L 0.5	2.0E6	2.0E6	180.
C/L 1.0	7.7E5	7.8E5	69.
C/L 1.5	4.0E5	4.0E5	36.
C/L 2.0	2.5E5	2.5E5	22.
C/L 2.5	1.7E5	1.8E5	16.
C/L 3.0	1.3E5	1.3E5	11.
C/L 3.5	1.0E5	1.0E5	8.9
C/L 4.0	7.7E4	7.8E4	6.9
C/L 4.5	6.5E4	6.5E4	5.8
C/L 5.0	5.5E4	5.5E4	4.9
C/L 5.5	4.5E4	4.5E4	4.0
C/L 6.0	4.0E4	4.0E4	3.6
C/L 6.5	0.2	0.2	< 0.1
C/L 7.0	0.2	0.2	< 0.1
C/L 7.5	0.1	0.1	< 0.1
C/L 8.0	0.1	0.1	< 0.1
C/L 8.5	0.1	0.1	< 0.1
C/L 9.0	< 0.1	< 0.1	< 0.1
C/L 9.5	< 0.1	< 0.1	< 0.1
WNW6.2	0.1	0.1	< 0.1
WNW6.1	1100.	1100.	< 0.1
WNW5.1	1800.	1800.	0.2
WNW3	1.1E5	1.1E5	9.8
WNW1	2.5E5	2.5E5	22.
W2	< 0.1	< 0.1	< 0.1
NW1	6.2E4	6.3E4	5.6
W-0	1.3	1.3	< 0.1

OTHER SAMPLES LESS THAN MDA

TABLE 7.11g

ENVIRONMENTAL SAMPLING DATA (T = 03:45) (18:45)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm2)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
C/L 0.5	5.4E6	5.4E6	480.
C/L 1.0	2.0E6	2.0E6	180.
C/L 1.5	1.1E6	1.1E6	94.
C/L 2.0	6.6E5	6.6E5	59.
C/L 2.5	4.6E5	4.7E5	41.
C/L 3.0	3.3E5	3.4E5	30.
C/L 3.5	2.6E5	2.6E5	23.
C/L 4.0	2.1E5	2.1E5	18.
C/L 4.5	1.7E5	1.7E5	15.
C/L 5.0	1.4E5	1.4E5	13.
C/L 5.5	1.2E5	1.2E5	11.
C/L 6.0	3.8E4	3.8E4	3.3
C/L 6.5	3.2E4	3.7E4	3.3
C/L 7.0	2.7E4	3.1E4	2.8
C/L 7.5	2.5E4	2.8E4	2.5
C/L 8.0	2.2E4	2.5E4	2.2
C/L 8.5	2.0E4	2.3E4	2.0
C/L 9.0	1.8E4	2.1E4	1.8
C/L 9.5	1.7E4	1.9E4	1.7
C/L 10.0	< 0.1	< 0.1	< 0.1
WNW9.1	700.	800.	< 0.1
WNW9.3	570.	650.	< 0.1
NW7.1	0.2	0.2	< 0.1
WNW8.3	4000.	4500.	0.4
WNW8.2	2.0E4	2.2E4	2.0
WNW7.2	1.8E4	2.1E4	1.8
WNW8.1	40.	46.	< 0.1
WNW7.1	1300.	1500.	0.1
WNW6.2	3.0E4	3.4E4	3.0
WNW6.1	1000.	1000.	< 0.1
WNW5.1	1800.	1800.	0.2
NW5.1	10.	10.	< 0.1
WNW3	3.0E5	3.0E5	27.
WNW1	3.1E5	3.2E5	28.
W2	< 0.1	< 0.1	< 0.1
NW1	1.3E6	1.3E6	120.
W-0	1.2	1.2	< 0.1

OTHER SAMPLES LESS THAN MDA

TABLE 7.11h

ENVIRONMENTAL SAMPLING DATA (T = 04:00) (19:00)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm2)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
C/L 0.5	5.1E6	5.1E6	450.
C/L 1.0	1.9E6	1.9E6	170.
C/L 1.5	9.9E5	9.9E5	88.
C/L 2.0	6.2E5	6.2E5	55.
C/L 2.5	4.4E5	4.4E5	39.
C/L 3.0	3.2E5	3.2E5	28.
C/L 3.5	2.4E5	2.4E5	22.
C/L 4.0	1.9E5	1.9E5	17.
C/L 4.5	1.6E5	1.6E5	14.
C/L 5.0	1.3E5	1.3E5	12.
C/L 5.5	1.1E5	1.1E5	10.
C/L 6.0	9.8E4	1.1E5	9.4
C/L 6.5	8.3E4	9.3E4	8.3
C/L 7.0	7.3E4	8.2E4	7.3
C/L 7.5	6.6E4	7.4E4	6.6
C/L 8.0	5.8E4	6.6E4	5.8
C/L 8.5	5.4E4	6.0E4	5.4
C/L 9.0	1.7E4	1.9E4	1.7
C/L 9.5	1.6E4	1.7E4	1.5
C/L 10.0	1.4E4	1.7E4	1.5
WNW10.2	180.	210.	< 0.1
WNW9.2	9500.	1.1E4	1.0
WNW10.1	5.3	6.2	< 0.1
WNW9.1	660.	720.	< 0.1
WNW9.3	540.	590.	< 0.1
NW7.1	48.	54.	< 0.1
WNW8.3	2.9E4	3.3E4	2.9
NW6.1	1.0	1.1	< 0.1
WNW8.2	3.4E4	3.8E4	3.4
WNW7.2	6.0E4	6.7E4	6.0
WNW8.1	38.	42.	< 0.1
WNW7.1	1300.	1500.	0.1
WNW6.2	5.1E4	5.6E4	5.0
WNW6.1	1000.	1000.	< 0.1
WNW5.1	1700.	1700.	0.1
NW5.1	9.5	9.5	< 0.1
WNW3	2.8E5	2.8E5	25.
WNW1	3.0E5	3.0E5	26.
NW1	1.2E6	1.2E6	110.
W-0	1.1	1.1	< 0.1

OTHER SAMPLES LESS THAN MDA

TABLE 7.111

ENVIRONMENTAL SAMPLING DATA (T = 04:30) (19:30)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm2)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
C/L 0.5	4.6E6	4.6E6	410.
C/L 1.0	1.7E6	1.7E6	150.
C/L 1.5	9.0E5	9.0E5	80.
C/L 2.0	5.6E5	5.6E5	50.
C/L 2.5	4.0E5	4.0E5	35.
C/L 3.0	2.9E5	2.9E5	25.
C/L 3.5	2.2E5	2.2E5	20.
C/L 4.0	1.7E5	1.8E5	16.
C/L 4.5	1.4E5	1.4E5	13.
C/L 5.0	1.2E5	1.2E5	11.
C/L 5.5	1.0E5	1.0E5	9.1
C/L 6.0	8.8E4	9.2E4	8.2
C/L 6.5	7.5E4	7.9E4	7.0
C/L 7.0	6.6E4	7.0E4	6.2
C/L 7.5	6.0E4	6.3E4	5.6
C/L 8.0	5.3E4	5.6E4	4.9
C/L 8.5	4.9E4	5.1E4	4.6
C/L 9.0	4.2E4	4.6E4	4.1
C/L 9.5	3.8E4	4.2E4	3.7
C/L 10.0	3.6E4	3.9E4	3.5
WNW10.2	4400.	5000.	0.4
NW9.1	0.2	0.2	< 0.1
WNW9.2	1.1E4	1.2E4	1.1
WNW10.1	4.8	5.2	< 0.1
WNW9.1	630.	660.	< 0.1
WNW9.3	9100.	1.0E4	0.9
NW7.1	43.	46.	< 0.1
WNW8.3	2.6E4	2.8E4	2.4
NW6.1	0.9	1.0	< 0.1
WNW8.2	3.1E4	3.2E4	2.9
WNW7.2	5.4E4	5.7E4	5.1
WNW8.1	35.	36.	< 0.1
WNW7.1	1200.	1300.	0.1
WNW6.2	4.6E4	4.8E4	4.3
WNW6.1	900.	910.	< 0.1
WNW5.1	1500.	1500.	0.1
W5.2	0.2	0.2	< 0.1
NW5.1	8.5	8.6	< 0.1
WNW3	2.5E5	2.5E5	23.
WNW1	2.7E5	2.7E5	24.

CONTINUED ON NEXT PAGE

TABLE 7.11j

ENVIRONMENTAL SAMPLING DATA (T = 04:30) (19:30)
(continued)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm2)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
W2	1.6	1.6	< 0.1
NW1	1.1E6	1.1E6	99.
W3	1.8	1.8	< 0.1
W-0	1.0	1.0	< 0.1
W4	1.6	1.6	< 0.1
W1	5.5	5.6	< 0.1

OTHER SAMPLES LESS THAN MDA

TABLE 7.11j

ENVIRONMENTAL SAMPLING DATA (T = 05:00) (20:00)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm ²)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
C/L 0.5	4.2E6	4.2E6	380.
C/L 1.0	1.6E6	1.6E6	140.
C/L 1.5	8.2E5	8.2E5	73.
C/L 2.0	5.2E5	5.2E5	46.
C/L 2.5	3.6E5	3.6E5	32.
C/L 3.0	2.6E5	2.6E5	23.
C/L 3.5	2.0E5	2.0E5	18.
C/L 4.0	1.6E5	1.6E5	14.
C/L 4.5	1.3E5	1.3E5	12.
C/L 5.0	1.1E5	1.1E5	9.8
C/L 5.5	9.4E4	9.4E4	8.3
C/L 6.0	8.1E4	8.2E4	7.3
C/L 6.5	6.9E4	7.0E4	6.3
C/L 7.0	6.1E4	6.2E4	5.5
C/L 7.5	5.5E4	5.6E4	5.0
C/L 8.0	4.9E4	5.0E4	4.4
C/L 8.5	4.5E4	4.6E4	4.1
C/L 9.0	3.8E4	4.0E4	3.5
C/L 9.5	3.5E4	3.6E4	3.2
C/L 10.0	3.3E4	3.4E4	3.0
WNW10.2	4100.	4300.	0.4
NW9.1	0.2	0.2	< 0.1
WNW9.2	1.0E4	1.1E4	< 0.9
WNW10.1	4.5	4.6	< 0.1
WNW9.1	580.	590.	< 0.1
W9.3	0.2	0.2	< 0.1
WNW9.3	8300.	8700.	< 0.8
NW7.1	40.	40.	< 0.1
WNW8.3	2.4E4	2.4E4	< 2.2
NW6.1	0.8	0.8	< 0.1
WNW8.2	2.8E4	2.9E4	< 2.6
WNW7.2	5.0E4	5.1E4	< 4.5
WNW8.1	32.	33.	< 0.1
WNW7.1	1100.	1100.	< 0.1
WNW6.2	4.2E4	4.3E4	< 3.8
WNW6.1	830.	830.	< 0.1
WNW5.1	1400.	1400.	< 0.1
W8.3	0.1	0.1	< 0.1
W7.2	0.5	0.5	< 0.1
W5.2	0.6	0.6	< 0.1

CONTINUED ON NEXT PAGE

TABLE 7.11k

ENVIRONMENTAL SAMPLING DATA (T = 05:00) (20:00)
(continued)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm2)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
NW5.1	7.8	7.8	< 0.1
WNW3	2.3E5	2.3E5	21.
WNW1	2.5E5	2.5E5	22.
W2	5.3	5.3	< 0.1
NW1	1.0E6	1.0E6	91.
W3	4.6	4.6	< 0.1
W-0	0.9	0.9	< 0.1
W8.2	0.4	0.5	< 0.1
W4	3.5	3.5	< 0.1
W1	13.	13.	< 0.1

OTHER SAMPLES LESS THAN MDA

TABLE 7.11k

ENVIRONMENTAL SAMPLING DATA (T = 05:30) (20:30)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	----- (cpm/100cm2)
C/L 0.5	3.9E6	3.9E6	350.
C/L 1.0	1.5E6	1.5E6	130.
C/L 1.5	7.6E5	7.6E5	68.
C/L 2.0	4.8E5	4.8E5	43.
C/L 2.5	3.4E5	3.4E5	30.
C/L 3.0	2.4E5	2.4E5	22.
C/L 3.5	1.9E5	1.9E5	17.
C/L 4.0	1.5E5	1.5E5	13.
C/L 4.5	1.2E5	1.2E5	11.
C/L 5.0	1.0E5	1.0E5	9.1
C/L 5.5	8.7E4	8.7E4	7.7
C/L 6.0	7.5E4	7.6E4	6.7
C/L 6.5	6.4E4	6.5E4	5.7
C/L 7.0	5.7E4	5.7E4	5.1
C/L 7.5	5.1E4	5.1E4	4.6
C/L 8.0	4.5E4	4.5E4	4.0
C/L 8.5	4.2E4	4.2E4	3.7
C/L 9.0	3.6E4	3.6E4	3.2
C/L 9.5	3.2E4	3.3E4	2.9
C/L 10.0	3.0E4	3.1E4	2.7
WNW10.2	3800.	3900.	0.3
NW9.1	0.2	0.2	< 0.1
WNW9.2	9600.	9700.	0.9
WNW10.1	4.2	4.2	< 0.1
WNW9.1	540.	540.	< 0.1
W9.3	0.6	0.6	< 0.1
WNW9.3	7700.	7900.	0.7
NW7.1	37.	37.	< 0.1
WNW8.3	2.2E4	2.2E4	2.0
NW6.1	0.8	0.8	< 0.1
WNW8.2	2.6E4	2.6E4	2.4
WNW7.2	4.6E4	4.6E4	4.1
WNW8.1	30.	30.	< 0.1
WNW7.1	1000.	1000.	< 0.1
WNW6.2	3.9E4	3.9E4	3.5
WNW6.1	770.	770.	< 0.1
WNW5.1	1300.	1300.	0.1
W8.3	0.4	0.4	< 0.1
W6.2	0.1	0.1	< 0.1
W7.2	1.8	1.8	< 0.1

CONTINUED ON NEXT PAGE

TABLE 7.111

ENVIRONMENTAL SAMPLING DATA (T = 05:30) (20:30)
(continued)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm2)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
W5.2	17.	17.	< 0.1
NW5.1	7.3	7.3	< 0.1
WNW3	2.2E5	2.2E5	19.
WNW1	2.3E5	2.3E5	20.
W2	98.	98.	< 0.1
NW1	9.5E5	9.5E5	85.
W3	51.	51.	< 0.1
W-0	0.9	0.9	< 0.1
W8.2	1.0	1.0	< 0.1
W4	27.	27.	< 0.1
W1	120.	120.	< 0.1
W5.1	0.1	0.1	< 0.1

OTHER SAMPLES LESS THAN MDA

TABLE 7.111

ENVIRONMENTAL SAMPLING DATA (T = 06:00) (21:00)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm ²)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
C/L 0.5	3.7E6	3.7E6	330.
C/L 1.0	1.4E6	1.4E6	120.
C/L 1.5	7.2E5	7.2E5	64.
C/L 2.0	4.5E5	4.5E5	40.
C/L 2.5	3.2E5	3.2E5	28.
C/L 3.0	2.3E5	2.3E5	20.
C/L 3.5	1.8E5	1.8E5	16.
C/L 4.0	1.4E5	1.4E5	12.
C/L 4.5	1.2E5	1.2E5	10.
C/L 5.0	9.7E4	9.7E4	8.6
C/L 5.5	8.2E4	8.2E4	7.3
C/L 6.0	7.1E4	7.1E4	6.3
C/L 6.5	6.0E4	6.0E4	5.4
C/L 7.0	5.3E4	5.3E4	4.7
C/L 7.5	4.8E4	4.8E4	4.3
C/L 8.0	4.2E4	4.2E4	3.8
C/L 8.5	3.9E4	3.9E4	3.5
C/L 9.0	3.3E4	3.4E4	3.0
C/L 9.5	3.1E4	3.1E4	2.7
C/L 10.0	2.9E4	2.9E4	2.6
WNW10.2	3600.	3600.	0.3
NW9.1	0.2	0.2	< 0.1
WNW9.2	9000.	9000.	0.8
WNW10.1	3.9	4.0	< 0.1
WNW9.1	500.	510.	< 0.1
W9.4	1.1	1.1	< 0.1
W9.3	8.5	8.7	< 0.1
WNW9.3	7300.	7300.	0.6
NW7.1	35.	35.	< 0.1
WNW8.3	2.1E4	2.1E4	1.9
NW6.1	0.7	0.7	< 0.1
WNW8.2	2.5E4	2.5E4	2.2
WNW7.2	4.3E4	4.3E4	3.8
WNW8.1	28.	28.	< 0.1
WNW7.1	960.	960.	< 0.1
WNW6.2	3.7E4	3.7E4	3.3
WNW6.1	720.	720.	< 0.1
WNW5.1	1200.	1200.	0.1
W8.3	8.4	8.4	< 0.1
W6.2	18.	18.	< 0.1

CONTINUED ON NEXT PAGE

TABLE 7.11m

ENVIRONMENTAL SAMPLING DATA (T = 06:00) (21:00)
(continued)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm2)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
W7.2	11.	11.	< 0.1
W5.2	56.	57.	< 0.1
NW5.1	6.8	6.8	< 0.1
WNW3	2.0E5	2.0E5	18.
WNW1	2.1E5	2.1E5	19.
W2	470.	470.	< 0.1
NW1	8.9E5	8.9E5	79.
W3	180.	180.	< 0.1
W-0	41.	41.	< 0.1
W8.2	7.0	7.2	< 0.1
W4	57.	57.	< 0.1
W1	360.	360.	< 0.1
W9.2	< 0.1	< 0.1	< 0.1
W5.1	0.1	0.1	< 0.1

OTHER SAMPLES LESS THAN MDA

TABLE 7.11m

ENVIRONMENTAL SAMPLING DATA (T = 06:30) (21:30)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm2)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
C/L 0.5	3.5E6	3.5E6	310.
C/L 1.0	1.3E6	1.3E6	120.
C/L 1.5	6.8E5	6.8E5	60.
C/L 2.0	4.3E5	4.3E5	38.
C/L 2.5	3.0E5	3.0E5	27.
C/L 3.0	2.2E5	2.2E5	19.
C/L 3.5	1.7E5	1.7E5	15.
C/L 4.0	1.3E5	1.3E5	12.
C/L 4.5	1.1E5	1.1E5	9.7
C/L 5.0	9.2E4	9.2E4	8.1
C/L 5.5	7.7E4	7.7E4	6.9
C/L 6.0	6.7E4	6.7E4	6.0
C/L 6.5	5.7E4	5.7E4	5.1
C/L 7.0	5.0E4	5.0E4	4.5
C/L 7.5	4.5E4	4.5E4	4.0
C/L 8.0	4.0E4	4.0E4	3.6
C/L 8.5	3.7E4	3.7E4	3.3
C/L 9.0	3.2E4	3.2E4	2.8
C/L 9.5	2.9E4	2.9E4	2.6
C/L 10.0	2.7E4	2.7E4	2.4
WNW10.2	3400.	3400.	0.3
NW9.1	0.2	0.2	< 0.1
WNW9.2	8500.	8500.	0.8
WNW10.1	3.9	3.9	< 0.1
WNW9.1	480.	480.	< 0.1
W9.4	5.3	5.4	< 0.1
W9.3	24.	24.	< 0.1
WNW9.3	6900.	6900.	0.6
NW7.1	33.	33.	< 0.1
WNW8.3	2.0E4	2.0E4	1.8
NW6.1	0.7	0.7	< 0.1
WNW8.2	2.3E4	2.3E4	2.1
WNW7.2	4.1E4	4.1E4	3.6
WNW8.1	27.	27.	< 0.1
WNW7.1	910.	910.	< 0.1
WNW6.2	3.5E4	3.5E4	3.1
WNW6.1	680.	680.	< 0.1
WNW5.1	1200.	1200.	0.1
W8.3	26.	26.	< 0.1
W6.2	42.	43.	< 0.1

CONTINUED ON NEXT PAGE

TABLE 7.11n

ENVIRONMENTAL SAMPLING DATA (T = 06:30) (21:30)
(continued)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm2)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
W7.2	32.	32.	< 0.1
W5.2	120.	120.	< 0.1
NW5.1	6.5	6.5	< 0.1
WNW3	1.9E5	1.9E5	17.
WNW1	2.0E5	2.0E5	18.
W2	930.	930.	< 0.1
NW1	3.4E5	8.5E5	75.
W3	660.	660.	< 0.1
W-0	39.	39.	< 0.1
W8.2	15.	15.	< 0.1
W4	210.	220.	< 0.1
W1	1300.	1300.	0.1
W9.2	< 0.1	< 0.1	< 0.1
W5.1	0.1	0.1	< 0.1

OTHER SAMPLES LESS THAN MDA

TABLE 7.11n

ENVIRONMENTAL SAMPLING DATA (T = 07:00) (22:00)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	----- (cpm/100cm2)
C/L 0.5	3.3E6	3.3E6	300.
C/L 1.0	1.3E6	1.3E6	110.
C/L 1.5	6.5E5	6.5E5	58.
C/L 2.0	4.1E5	4.1E5	36.
C/L 2.5	2.9E5	2.9E5	25.
C/L 3.0	2.1E5	2.1E5	18.
C/L 3.5	1.6E5	1.6E5	14.
C/L 4.0	1.3E5	1.3E5	11.
C/L 4.5	1.0E5	1.0E5	9.3
C/L 5.0	8.8E4	8.8E4	7.8
C/L 5.5	7.4E4	7.4E4	6.6
C/L 6.0	6.4E4	6.4E4	5.7
C/L 6.5	5.4E4	5.4E4	4.8
C/L 7.0	4.8E4	4.8E4	4.3
C/L 7.5	4.3E4	4.3E4	3.8
C/L 8.0	3.8E4	3.8E4	3.4
C/L 8.5	3.5E4	3.5E4	3.1
C/L 9.0	3.0E4	3.0E4	2.7
C/L 9.5	2.8E4	2.8E4	2.4
C/L 10.0	2.6E4	2.6E4	2.3
WNW10.2	3200.	3200.	0.3
NW9.1	0.2	0.2	< 0.1
WNW9.2	8100.	8100.	0.7
WNW10.1	4.8	4.8	< 0.1
WNW9.1	450.	450.	< 0.1
W9.4	15.	15.	< 0.1
W9.3	34.	34.	< 0.1
WNW9.3	6500.	6500.	0.6
NW7.1	31.	31.	< 0.1
WNW8.3	1.9E4	1.9E4	1.7
NW6.1	0.7	0.7	< 0.1
WNW8.2	2.2E4	2.2E4	2.0
WNW7.2	3.9E4	3.9E4	3.5
WNW8.1	26.	26.	< 0.1
WNW7.1	970.	870.	< 0.1
WNW6.2	3.3E4	3.3E4	2.9
WNW6.1	650.	650.	< 0.1
WNW5.1	1100.	1100.	< 0.1
W8.3	65.	67.	< 0.1
W6.2	41.	41.	< 0.1

CONTINUED ON NEXT PAGE

TABLE 7.110

ENVIRONMENTAL SAMPLING DATA (T = 07:00) (22:00)
(continued)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	----- (cpm/100cm2)
W7.2	120.	120.	< 0.1
W5.2	240.	240.	< 0.1
NW5.1	6.2	6.2	< 0.1
WNW3	1.8E5	1.8E5	16.
WNW1	1.9E5	1.9E5	17.
W2	1400.	1400.	0.1
NW1	8.0E5	8.0E5	71.
W3	780.	780.	< 0.1
W-0	37.	37.	< 0.1
W8.2	69.	71.	< 0.1
W4	320.	330.	< 0.1
W1	1400.	1400.	0.1
W9.2	< 0.1	< 0.1	< 0.1
W5.1	< 0.1	< 0.1	< 0.1

OTHER SAMPLES LESS THAN MDA

TABLE 7.110

ENVIRONMENTAL SAMPLING DATA (T = 08:00) (23:00)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm2)
	iodine (pCi/kg)	total (pCi/kg)	
C/L 0.5	3.1E6	3.1E6	270.
C/L 1.0	1.2E6	1.2E6	100.
C/L 1.5	6.0E5	6.0E5	53.
C/L 2.0	3.8E5	3.8E5	33.
C/L 2.5	2.6E5	2.6E5	23.
C/L 3.0	1.9E5	1.9E5	17.
C/L 3.5	1.5E5	1.5E5	13.
C/L 4.0	1.2E5	1.2E5	10.
C/L 4.5	9.6E4	9.6E4	8.5
C/L 5.0	8.1E4	8.1E4	7.2
C/L 5.5	6.8E4	6.8E4	6.1
C/L 6.0	5.9E4	5.9E4	5.2
C/L 6.5	5.0E4	5.0E4	4.5
C/L 7.0	4.4E4	4.4E4	3.9
C/L 7.5	4.0E4	4.0E4	3.5
C/L 8.0	3.5E4	3.5E4	3.1
C/L 8.5	3.3E4	3.3E4	2.9
C/L 9.0	2.8E4	2.8E4	2.5
C/L 9.5	2.5E4	2.6E4	2.3
C/L 10.0	2.4E4	2.4E4	2.1
WNW10.2	2900.	2900.	0.3
NW9.1	0.1	0.1	< 0.1
WNW9.2	7400.	7400.	0.7
WNW10.1	4.4	4.5	< 0.1
WNW9.1	420.	420.	< 0.1
W9.4	32.	33.	< 0.1
W9.3	180.	190.	< 0.1
WNW9.3	6000.	6000.	0.5
NW7.1	29.	29.	< 0.1
WNW8.3	1.7E4	1.7E4	1.5
NW6.1	0.6	0.6	< 0.1
WNW8.2	2.0E4	2.0E4	1.8
WNW7.2	3.6E4	3.6E4	3.2
WNW8.1	24.	24.	< 0.1
WNW7.1	800.	800.	< 0.1
WNW6.2	3.0E4	3.0E4	2.7
WNW6.1	600.	600.	< 0.1
WNW5.1	1000.	1000.	< 0.1
W8.3	170.	170.	< 0.1
W6.2	96.	97.	< 0.1

CONTINUED ON NEXT PAGE

TABLE 7.11p

ENVIRONMENTAL SAMPLING DATA (T = 08:00) (23:00)
(continued)

OFFSITE MONITORING LOCATION -----	LEAFY VEGETATION		GROUND DEPOSITION ----- (cpm/100cm2)
	iodine ----- (pCi/kg)	total ----- (pCi/kg)	
W7.2	210.	210.	< 0.1
W5.2	310.	310.	< 0.1
NW5.1	5.7	5.7	< 0.1
WNW3	1.7E5	1.7E5	15.
WNW1	1.8E5	1.8E5	16.
W2	1600.	1600.	0.1
NW1	7.4E5	7.4E5	66.
W3	920.	920.	< 0.1
W-0	34.	34.	< 0.1
W8.2	110.	120.	< 0.1
W4	390.	400.	< 0.1
W1	1700.	1800.	0.2
W9.2	0.2	0.2	< 0.1
W5.1	0.9	0.9	< 0.1

OTHER SAMPLES LESS THAN MDA

TABLE 7.12a

ENVIRONMENTAL ACTIVITY CONCENTRATION (1 = 00:00) (15:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-135	<LLD uCi/cc
Xe-135m	<LLD uCi/cc

TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc

TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
La-142	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute
Stay Time: 2 DAC hr (no mask): 4.3E+7 Hours
Stay Time: 2 DAC hr (in mask): 2.1E+9 Hours
Stay Time: 2 DAC hr (in SCBA): 9.9E+9 Hours

TABLE 7.12b

ENVIRONMENTAL ACTIVITY CONCENTRATION (T = 01:00) (16:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-135	<LLD uCi/cc
Xe-135m	<LLD uCi/cc

TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc

TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm2
Wall and Equipment Contamination: < 0.1 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 1.0E+8 Hours
Stay Time: 2 DAC hr (in mask): 5.0E+9 Hours
Stay Time: 2 DAC hr (in SCBA): 9.9E+9 Hours

TABLE 7.12c

ENVIRONMENTAL ACTIVITY CONCENTRATION (T = 02:00) (17:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----
Xe-133	<LLD uCi/cc
Xe-135	<LLD uCi/cc
Xe-135m	<LLD uCi/cc

TOTAL GAS SAMPLE	<LLD uCi/cc

I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc

TOTAL CHARCOAL SAMPLE	<LLD uCi/cc

Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm2
Wall and Equipment Contamination: < 0.1 cpm/100cm2
Personnel Contamination Rate: < 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr (no mask): 8.9E+7 Hours
Stay Time: 2 DAC hr (in mask): 4.4E+9 Hours
Stay Time: 2 DAC hr (in SCBA): 9.9E+9 Hours

TABLE 7.12d

ENVIRONMENTAL ACTIVITY CONCENTRATION (T = 03:00) (18:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
Xe-133	<LLD uCi/cc
Xe-135	<LLD uCi/cc
Xe-135m	<LLD uCi/cc

TOTAL GAS SAMPLE	<LLD uCi/cc
I-132	<LLD uCi/cc
I-133	<LLD uCi/cc
I-134	<LLD uCi/cc
I-135	<LLD uCi/cc

TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
Sr-91	<LLD uCi/cc
Sr-92	<LLD uCi/cc
Ba-139	<LLD uCi/cc
Y-92	<LLD uCi/cc
La-142	<LLD uCi/cc

TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute
Stay Time: 2 DAC hr (no mask): 6.7E+7 Hours
Stay Time: 2 DAC hr (in mask): 3.4E+9 Hours
Stay Time: 2 DAC hr (in SCBA): 9.9E+9 Hours

TABLE 7.12e

ENVIRONMENTAL ACTIVITY CONCENTRATION (T = 04:00) (19:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----

TOTAL GAS SAMPLE	<LLD uCi/cc
------------------	-------------

TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
-----------------------	-------------

TOTAL FILTER SAMPLE	<LLD uCi/cc
---------------------	-------------

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute
Stay Time: 2 DAC hr (no mask): 9.9E+9 Hours
Stay Time: 2 DAC hr (in mask): 9.9E+9 Hours
Stay Time: 2 DAC hr (in SCBA): 9.9E+9 Hours

TABLE 7.12f

ENVIRONMENTAL ACTIVITY CONCENTRATION (T = 05:00) (20:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
TOTAL GAS SAMPLE	<LLD uCi/cc -----
TOTAL CHARCOAL SAMPLE	<LLD uCi/cc -----
TOTAL FILTER SAMPLE	<LLD uCi/cc -----
Hydrogen Concentration:	.0%
Oxygen Concentration:	21.0%
Chlorine Concentration:	.0 ppm
Airborne Beta Dose Rate:	< 0.1 mRad/hr
Airborne Thyroid Dose Rate:	< 0.1 mRem/hr
Net Air Sample Contact Rate:	< 0.1 cpm/cf sample
Floor Contamination:	< 0.1 cpm/100cm2
Wall and Equipment Contamination:	< 0.1 cpm/100cm2
Personnel Contamination Rate:	< 0.1 cpm/100cm2 per minute
Stay Time: 2 DAC hr	(no mask):9.9E+9 Hours
Stay Time: 2 DAC hr	(in mask):9.9E+9 Hours
Stay Time: 2 DAC hr	(in SCBA):9.9E+9 Hours

TABLE 7.12g

ENVIRONMENTAL ACTIVITY CONCENTRATION (T = 06:00) (21:00)

Provide current Chem data 30 minutes after sample request

Nuclide -----	Concentration -----
------------------	------------------------

TOTAL GAS SAMPLE	<LLD uCi/cc
------------------	-------------

TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
-----------------------	-------------

TOTAL FILTER SAMPLE	<LLD uCi/cc
---------------------	-------------

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute
Stay Time: 2 DAC hr (no mask): 9.9E+9 Hours
Stay Time: 2 DAC hr (in mask): 9.9E+9 Hours
Stay Time: 2 DAC hr (in SCBA): 9.9E+9 Hours

TABLE 7.12h

ENVIRONMENTAL ACTIVITY CONCENTRATION (T = 07:00) (22:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----

TOTAL GAS SAMPLE	<LLD uCi/cc
------------------	-------------

TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
-----------------------	-------------

TOTAL FILTER SAMPLE	<LLD uCi/cc
---------------------	-------------

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute
Stay Time: 2 DAC hr (no mask): 9.9E+9 Hours
Stay Time: 2 DAC hr (in mask): 9.9E+9 Hours
Stay Time: 2 DAC hr (in SCBA): 9.9E+9 Hours

TABLE 7.121

ENVIRONMENTAL ACTIVITY CONCENTRATION (T = 08:00) (23:00)

Provide current Chem data 30 minutes after sample request

Nuclide	Concentration
-----	-----

TOTAL GAS SAMPLE	<LLD uCi/cc
TOTAL CHARCOAL SAMPLE	<LLD uCi/cc
TOTAL FILTER SAMPLE	<LLD uCi/cc

Hydrogen Concentration: .0%
Oxygen Concentration: 21.0%
Chlorine Concentration: .0 ppm

Airborne Beta Dose Rate: < 0.1 mRad/hr
Airborne Thyroid Dose Rate: < 0.1 mRem/hr
Net Air Sample Contact Rate: < 0.1 cpm/cf sample

Floor Contamination: < 0.1 cpm/100cm²
Wall and Equipment Contamination: < 0.1 cpm/100cm²
Personnel Contamination Rate: < 0.1 cpm/100cm² per minute
Stay Time: 2 DAC hr (no mask): 9.9E+9 Hours
Stay Time: 2 DAC hr (in mask): 9.9E+9 Hours
Stay Time: 2 DAC hr (in SCBA): 9.9E+9 Hours