



**PERRY NUCLEAR POWER PLANT**

10 CENTER ROAD  
PERRY, OHIO 44081  
(216) 259-3737

Mail Address:  
P.O. BOX 97  
PERRY, OHIO 44081

**Donald C. Shelton**  
SENIOR VICE PRESIDENT  
NUCLEAR

October 25, 1995  
PY-CEI/NRR-1993L

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Perry Nuclear Power Plant  
Docket No. 50-440  
Ohio Environmental Protection Agency Approval for Essential Maintenance  
Discharge Change

Gentlemen:

Enclosed is a copy of the Ohio Environmental Protection Agency's (OEPA) approval for a revision to an essential maintenance discharge change requested for the Perry Nuclear Power Plant (PNPP). This information is provided in accordance with the PNPP Operating License, NPF-58, Appendix B, Environmental Protection Plan, Section 3.2.

If you have questions or require additional information please contact Louise Barton at (216) 280-5512.

Very truly yours,

A handwritten signature in dark ink, appearing to read 'D. Shelton', with a long horizontal flourish extending to the right.

Enclosure

LKB:vah

cc: NRR Project Manager  
Resident Inspector Office  
NRC Region III

9511010283 951025  
PDR ADOCK 05000440  
S PDR

Operating Companies  
Cleveland Electric Illuminating  
Toledo Edison

JE23



State of Ohio Environmental Protection Agency

**Northeast District Office**

2110 E. Aurora Road  
Twinsburg, Ohio 44087-1969  
(216) 425-9171  
FAX (216) 487-0769

George V. Voinovich  
Governor

October 11, 1995

Re: 3IB00016  
Perry Nuclear Power Plant  
Essential Maintenance Discharge Change  
Lake County  
Industrial

Cleveland Electric Illuminating Co.  
Perry Nuclear Power Plant  
P.O. Box 97  
Perry, Ohio 44081

Attn.: Donald C. Shelton, Sr. VP, Nuclear

Dear Mr. Shelton:


This writer has no objection to the changes in pumping activities that are described in your correspondence letter dated September 1, 1995. The total volume of water being pumped is unchanged and does not exceed the design capacity of each storm drain system. Monitoring of the discharge is required as stated in this writer's letter to you dated July 31, 1995.

Should you have any questions, please contact the undersigned at (216)963-1183.

Sincerely,

Marie F. Underwood  
District Engineer  
Division of Surface Water

MFU:crh



**PERRY NUCLEAR POWER PLANT**

10 CENTER ROAD  
PERRY, OHIO 44081  
(216) 259-3737

Mail Address:  
PO. BOX 97  
PERRY, OHIO 44081

**Donald C. Shelton**  
SENIOR VICE PRESIDENT  
NUCLEAR

September 1, 1995  
PY-CEI/OEPA-0228L

Attention: Marie Underwood  
Ohio Environmental Protection Agency  
Northeast District Office  
2110 East Aurora Road  
Twinsburg, Ohio 44087

Perry Nuclear Power Plant  
NPDES Permit No. 3IB0016\*DD  
Essential Maintenance Discharge Change

Ladies and Gentlemen:

Following is the information we discussed during our phone conversation on August 9, 1995 about revisions to the flow rates to the plant storm drain systems during essential maintenance to be performed on the Perry Nuclear Power Plant service water and circulating water systems.

The changes pertain only to the pumping activities starting on or near 1/25/96. Instead of 10,000 gpd over a ten day period being pumped to the storm drain system on the east side of the plant site, the maximum flow will be 50,000 gpd for a minimum of two days.

The maximum flow to the storm drain system on the west side of the plant site will be 130,000 gpd for a minimum of two days instead of 26,000 gpd for ten days.

Note that the total volumes to be pumped have not changed.

The capacity of each storm drain system is 56,160,000 gpd; the proposed flows will not exceed this value.

If you have questions or require additional information, please contact Louise Barton at (216) 280-5512.

Very truly yours,

*A. B. Smith for D. C. Shelton*

LKB:sc

cc: NRC Document Control Desk (Docket Number: 50-440)  
NRC Project Manager  
NRC Resident Inspectors Office  
NRC Region III

Operating Companies  
Cleveland Electric Illuminating  
Toledo Edison