

TABLE OF CONTENTS

	<u>Page</u>
1.0. DEFINITIONS .....	3
2.0. SAFETY LIMIT AND LIMITING SAFETY SYSTEMS SETTINGS .....	10
2.1. Safety Limit .....	10
2.2. Limiting Safety System Settings .....	14
3.0. LIMITING CONDITIONS FOR OPERATION .....	15
3.1. Reactivity .....	15
3.2. Reactor Safety System .....	17
3.3. Reactor Instrumentation .....	19
3.4. Radioactive Effluents .....	21
3.5. Confinement .....	22
3.6. Limitations on Experiments .....	23
3.7. Operation with Fueled Experiments .....	25
3.8. Height of Water Above the Core in Natural Convection Mode of Operation .....	26
3.9. Rod-Drop Times .....	27
3.10. Emergency Removal of Decay Heat .....	28
3.11. Primary Coolant Condition .....	29
4.0. SURVEILLANCE REQUIREMENTS .....	30
4.1. Shim Rods .....	30
4.2. Reactor Safety System .....	31
4.3. Emergency Core Spray System .....	32
4.4. Area Radiation Monitoring Equipment .....	33
4.5. Maintenance .....	34
4.6. Confinement .....	35
4.7. Airborne Effluents .....	36
4.8. Primary Coolant Conditions .....	37
4.9. Surveillance of Activity in Secondary Cooling System (Amendment No. 22) .....	37a
5.0. DESIGN FEATURES .....	38
5.1. Reactor Fuel Specifications .....	38
5.2. Reactor Building .....	40
5.3. Fuel Use and Storage .....	41
6.0. ADMINISTRATIVE CONTROLS .....	42
6.1. Organization .....	42
6.2. Reactor Safety Committee .....	44
6.3. Standard Operating Procedures .....	47
6.4. Review and Approval of Experiments .....	49
6.5. Plant Operating Records .....	52
6.6. Required Actions .....	54
6.7. Reporting Requirements .....	56

4.9. Surveillance of Activity in Secondary Cooling System

Applicability: This specification applies to the surveillance frequency of cooling tower (secondary system) water for identification of potential radioisotope concentrations.

Objective: The objective is to discover incipient primary-to-secondary heat exchanger leaks, either newly-formed or due to secondary tube plug failure(s), by identification of sodium-24 or other reactor-produced radionuclides in the secondary water. A second and related objective is to satisfy TS 3.1.4 (Radioactive Effluents; Airborne Effluents), TS 3.4.2 (Radioactive Effluents; Liquid Effluents), and 10 CFR 20 limits. If sodium-24 or other radionuclide activity is observed in secondary system water, appropriate maintenance on the secondary system will be initiated.

Specification: Cooling tower (secondary system) water shall be sampled and analyzed for radionuclides, at least weekly.

Bases: The plugging of heat exchanger secondary tubes and the impact of primary-to-secondary heat exchanger leaks are analyzed in UVAR LEU-SAR Section 9.19 and Section 9.20, respectively. It is reasoned that incipient secondary tube plug failures and new secondary tube pinhole leaks (possibly caused by corrosion and/or erosion) would be associated with initially very small and slowly-increasing leak rates. This TS 4.9, "Surveillance of Activity in Secondary Cooling System", specifies a secondary system water sampling and counting interval appropriate to ensure small leak identification long before time-averaged liquid and airborne release concentration limits are challenged.

This TS 4.9 is not material to the secondary tube double-ended-guillotine-break (DEGTB) analyzed in LEU-SAR Section 9.20.8, which would result in a leak rate sufficiently large for rapid (<1 day) discovery (by visible and noticeably rapid falling pool water level). Mitigation of the consequences of this hypothetically most-severe case would also occur before time-averaged liquid and airborne release concentration limits are challenged. Specification of a very short secondary water sampling interval is not appropriate for large-scale leaks.