



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ARKANSAS POWER & LIGHT COMPANY

DOCKET NO. 50-313

ARKANSAS NUCLEAR ONE, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 83
License No. DPR-51


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Arkansas Power and Light Company (the licensee) dated February 27, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.c.(2) of Facility Operating License No. DPR-51 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 83, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



George W. Rivenbark, Acting Chief
Operating Reactors Branch No. 4
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 27, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 83

FACILITY OPERATING LICENSE NO. DPR-51

DOCKET NO. 50-313

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the area of change.

Remove

18a
19
20
20a
20b
20c

Insert

18a
19
20
20a
20b
20c

- 3.1.2.7 Prior to reaching fifteen effective full power years of operation, Figures 3.1.2-1, 3.1.2-2 and 3.1.2-3 shall be updated for the next service period in accordance with 10CFR50, Appendix G, Section V.B. The service period shall be of sufficient duration to permit the scheduled evaluation of a portion of the surveillance data scheduled in accordance with Specification 4.2.7. The highest predicted adjusted reference temperature of all the beltline region materials shall be used to determine the adjusted reference temperature at the end of the service period. The basis for this prediction shall be submitted for NRC staff review in accordance with Specification 3.1.2.8. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.
- 3.1.2.8 The updated proposed technical specifications referred to in 3.1.2.7 shall be submitted for NRC review at least 90 days prior to the end of the service period. Appropriate additional NRC review time shall be allowed for proposed technical specifications submitted in accordance with 10 CFR Part 50, Appendix G, Section V.C.

Bases

All reactor coolant system components are designed to withstand the effects of cyclic loads due to system temperature and pressure changes.⁽¹⁾ These cyclic loads are introduced by unit load transients, reactor trips, and unit heatup and cooldown operations. The number of thermal and loading cycles used for design purposes are shown in Table 4-8 of the FSAR. The maximum unit heatup and cooldown rate of 100F per hour satisfies stress limits for cyclic operation.⁽²⁾ The 200 psig pressure limit for the secondary side of the steam generator at a temperature less than 100F satisfies stress levels for temperatures below the DTT.⁽³⁾

The major components of the reactor coolant pressure boundary have been analyzed in accordance with Appendix G to 10CFR50. Results of this analysis, including the actual pressure-temperature limitations of the reactor coolant pressure boundary, are given in BAW-1440⁽⁴⁾ and BAW-1698⁽⁵⁾. The limiting weld material is being irradiated as part of the B&W Owners Group Integrated Reactor Vessel Material Surveillance Program and the identification and locations of the capsules containing the limiting weld material is discussed in the B&W report, BAW 1543, Revision 1.⁽⁶⁾ The chemical composition of the limiting weld material is reported in the B&W Report, BAW 1511P.⁽⁷⁾ The effect of neutron irradiation on the RT_{NDT}⁽⁸⁾ of the limiting weld material is reported in the B&W Report, BAW 1436.

Figures 3.1.2-1, 3.1.2-2, and 3.1.2-3 present the pressure-temperature limit curves for hydrostatic test, normal heatup, and normal cooldown respectively. The limit curves are applicable through the fifteenth effective full power year of operation. These curves are adjusted by 25 psi and 10F for possible errors in the pressure and temperature sensing instruments. The pressure limit is also adjusted for the pressure differential between the point of system pressure measurement and the limiting component for all operating reactor coolant pump combinations.

The pressure-temperature limit lines shown on Figure 3.1.2-2 for reactor criticality and on Figure 3.1.2-1 for hydrostatic testing have been provided to assure compliance with the minimum temperature requirements of Appendix G to 10CFR50 for reactor criticality and for inservice hydrostatic testing.


The actual shift in RT_{NDT} of the beltline region material will be established periodically during operation by removing and evaluating, in accordance with Appendix H to 10CFR50, reactor vessel material irradiation surveillance specimens which are installed near the inside wall of this or a similar reactor vessel in the core region.

The spray temperature difference restriction based on a stress analysis of the spray line nozzle is imposed to maintain the thermal stresses at the pressurizer spray line nozzle below the design limits. Temperature requirements for the steam generator correspond with the measured NDTT for the shell.

The heatup and cooldown rates stated in this specification are intended as the maximum changes in temperature in one direction in a one hour period. The actual temperature linear ramp rate may exceed the stated limits for a time period provided that the maximum total temperature difference does not exceed the limit and that a temperature hold is observed to prevent the total temperature difference from exceeding the limit for the one hour period.

REFERENCES

- (1) FSAR, Section 4.1.2.4
- (2) ASME Boiler and Pressure Code, Section III, N-415
- (3) FSAR, Section 4.3.11.5
- (4) BAW-1440
- (5) BAW-1698
- (6) BAW-1547, Revision 1
- (7) BAW-1511 P
- (8) BAW-1436




REACTOR COOLANT SYSTEM INSERVICE HYDROSTATIC TEST HEATUP AND COOLDOWN LIMITATIONS APPLICABLE FOR FIRST 15.0 EFFECTIVE FULL POWER YEARS

Figure 3.1.2-1

POINT	PRESSURE	TEMPERATURE
A	285	70
B	285	180
C	575	300
D	2250	415
E	0	323
F	285	323
G	575	340
H	2250	455

THE ACCEPTABLE PRESSURE-TEMPERATURE COMBINATIONS ARE BELOW AND TO THE RIGHT OF THE LIMIT CURVE(S). THE LIMIT CURVES INCLUDE THE PRESSURE DIFFERENTIAL BETWEEN THE POINT OF SYSTEM PRESSURE MEASUREMENT AND THE PRESSURE ON THE REACTOR VESSEL REGION CONTROLLING THE LIMIT CURVE. THEY INCLUDE AN ADDITIONAL MARGIN OF SAFETY FOR POSSIBLE INSTRUMENT ERROR (25 PSI AND 10°F). THE REACTOR MUST NOT BE MADE CRITICAL UNTIL THE PRESSURE-TEMPERATURE COMBINATIONS ARE TO THE RIGHT OF THE CRITICALITY LIMIT.

APPLICABLE FOR HEATUP RATES OF
 < 100°F/HR
 (< 50°F IN ANY 1/2 HOUR PERIOD)




REACTOR COOLANT SYSTEM, NORMAL OPERATION-HEATUP LIMITATIONS,
 APPLICABLE FOR FIRST 15.0 EFFECTIVE FULL POWER YEARS

Figure 3.1.2-2

ARKANSAS NUCLEAR ONE - UNIT 1

1. WHEN THE DECAY HEAT REMOVAL (DHR) SYSTEM IS OPERATING WITH NO RC PUMPS OPERATING, THE INDICATED DHR SYSTEM RETURN TEMPERATURE TO THE REACTOR VESSEL SHALL BE USED.
2. A MAXIMUM STEP TEMPERATURE CHANGE OF 75°F IS ALLOWABLE WHEN REMOVING ALL RC PUMPS FROM OPERATION WITH THE DHR SYSTEM OPERATING. THE STEP TEMPERATURE CHANGE IS DEFINED AS THE RC TEMP (PRIOR TO STOPPING ALL RC PUMPS) MINUS THE ON RETURN TEMP (AFTER STOPPING ALL RC PUMPS). THE 100°F/HR RAMP DECREASE IS ALLOWABLE BOTH BEFORE AND AFTER THE STEP TEMP CHANGE.

POINT	PRESS.	TEMP. °F
A	100	70
B	510	230
C	1800	325
D	2250	378



REACTOR COOLANT SYSTEM, NORMAL OPERATION-COOLOWN LIMITATIONS APPLICABLE FOR FIRST 15.0 EFFECTIVE FULL POWER YEARS