

Commonwealth Edison Company  
Quad Cities Generating Station  
22710 200th Avenue North  
Cordova, IL 61242-9740  
Tel 309-654-2241



LWP-95-097

October 26, 1995

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Reference: Quad Cities Nuclear Power Station  
Docket Number 50-265, DPR-30, Unit Two

Enclosed is Licensee Event Report (LER) 95-007, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(v)(D). The licensee shall report any event or condition that alone could have prevented the fulfillment of the safety function of structures or systems than are needed to mitigate the consequences of an accident.

The following commitments are being made by this letter:

The Unit 2 HPCI System will be tested on an increased testing frequency with a chart recorder monitoring the turning gear logic. Engineering will evaluate the data after each run to ensure the logic is responding as designed. Engineering will also monitor the AC input and the DC output of the 250 VDC in-service battery charger during the surveillance to monitor for any possible electrical disturbances within the distribution system. The system will be tested on an increased frequency to assure system reliability. This will be continued until adequate confidence is obtained.

If there are any questions or comments concerning this letter, please refer them to Nick Chrissotimos, Regulatory Assurance Administrator at 309-654-2241, ext. 3100.

Respectfully,

COMMONWEALTH EDISON COMPANY  
QUAD CITIES NUCLEAR POWER STATION

*D. B. Cook for*

L. W. Pearce  
Station Manager

LWP/NC/plm  
Enclosure

cc: J. Schrage  
C. Miller  
INPO Records Center  
0200-NRC Region III

*IEJ*  
*1/1*