

ADMINISTRATIVE CONTROLSSPECIAL REPORTS

6.9.2 Special reports shall be submitted to the U.S. Nuclear Regulatory Commission in accordance with 10 CFR 50.4 within the time period specified for each report. These reports shall be submitted covering the activities identified below pursuant to the requirements of the applicable reference specifications:

- a. ECCS Actuation. Specifications 3.5.2 and 3.5.3.
- b. ~~Deleted Inoperable Seismic Monitoring Instrumentation. Specification 3.3.3.3.~~
- c. ~~Deleted Inoperable Meteorological Monitoring Instrumentation. Specification 3.3.3.4.~~
- d. ~~Deleted Seismic event analysis. Specification 4.3.3.3.2.~~
- e. Deleted
- f. Deleted
- g. Inoperable Remote Shutdown System control circuit(s) or transfer switch(es) required for a serious control room or cable spreading room fire. Specification 3.3.3.5.2.

6.10 RECORD RETENTION

6.10.1 The following records shall be retained for at least five years:

- a. Records and logs of facility operation covering time interval at each power level.
- b. Records and logs of principal maintenance activities, inspections, repair and replacement of principal items of equipment related to nuclear safety.
- c. All REPORTABLE EVENTS.
- d. Records of surveillance activities, inspections and calibrations required by these Technical Specifications.
- e. Records of changes made to Operating Procedures.
- f. Records of radioactive shipments.
- g. Records of sealed source and fission detector leak tests and results.
- h. Records of annual physical inventory of all sealed source material of record.


Davis-Besse Nuclear Power Station

Dale R. Wuokko, Supervisor
Office of Nuclear Regulatory Affairs
Telephone: (419) 249-2357

5501 North State Route 2
Oak Harbor, Ohio 43449
Fax: (419) 249-2302

TO: LL Gundrum

Attached is documentation regarding the need
to delete TS 6.9.2d (pg 6-18).


10/31/95.