

UNITED STATES NUCLEAR REGULATORY COMMISSION

WISCONSIN ELECTRIC POWER COMPANY

DOCKET NOS. 50-266 AND 50-301

POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

CORRECTION TO NOTICE OF EXEMPTION

On July 24, 1995, the FEDERAL REGISTER published the Notice of Exemption from certain technical requirements of Appendix R to 10 CFR Part 50 for Point Beach Nuclear Power, Units 1 and 2. On page 37909, the fifth sentence in the third full paragraph in the third column incorrectly refers to cable tray GC01-02 instead of cable tray GG01-04. On page 37910, the second sentence in the second full paragraph in the second column incorrectly states the separation between the steam-driven auxiliary feedwater pumps as 29 feet instead of 44 feet. These corrections do not impact the findings providing the basis for granting the exemption.

Dated at Rockville, Maryland, this 24th day of October 1995.

FOR THE NUCLEAR REGULATORY COMMISSION

ORIGINAL SIGNED BY:

Allen G. Hansen, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

DOCUMENT NAME: G:\PTBEACH\PTB90067.LTR

* See previous concurrence

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure
"N" = No copy

OFFICE	LA:PDIII-3	E	PM:PDIII-3	E	OGC	PD:PDIII-3
NAME	DFoster-Curseen		AHansen		SHorn *	GMarcus <i>GM</i>
DATE	10/13/95		10/13/95		10/18/95	10/25/95

OFFICIAL RECORD COPY