

December 13, 1991

Docket No. 50-341

Mr. William S. Orser  
Senior Vice President - Nuclear  
Operations  
Detroit Edison Company  
6400 North Dixie Highway  
Newport, Michigan 48166

DISTRIBUTION

Docket File	OGC
NRC & LPDRs	EJordan MNBB-3701
PD31 Rdg File	ACRS(10)
BBoger	Fermi R/F
JZwolinski	WShafer RIII
LMarsh	WSwenson
MShuttleworth	
MGamberoni	
JStang	
GCarpenter	

Dear Mr. Orser:

SUBJECT: FERMI-2 - GENERIC LETTER 83-28, ITEM 1.2 "POST TRIP REVIEW: DATA AND INFORMATION CAPABILITY" (TAC NO. M79229)

License Condition 2.C(18) to Facility Operating License No. NPF-43 for the Fermi-2 facility required Detroit Edison Company (DECo) to submit responses and implement the requirements of Generic Letter (GL) 83-28. By letter dated November 3, 1983, DECo provided responses to GL 83-28, specifically to Item 1.2 "Post Trip Review: Data and Information Capability."

Enclosed is our staff evaluation for Salem ATWS Item 1.2, for the Fermi-2 nuclear plant. Specifically, Item 1.2 -Post Trip Review - Data and Information Capability - requires that licensees have the capability to record, recall, and display data and information to permit diagnosing the causes of unscheduled reactor shutdowns and the proper functioning of safety-related equipment during those events using systematic safety assessment procedures.

The staff has reviewed your responses and has concluded that you meet the intent of the review criteria for GL 83-28, Item 1.2. Therefore, we find that the Post-Trip Review - Data and Information Capability is acceptable. This completes our review of TAC No. M79229, Salem ATWS, Item 1.2, for the Fermi-2 nuclear plant.

Sincerely,

Original signed by

Marsha Gamberoni, Acting Project Manager  
Project Directorate III-1  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc w/enclosure:  
See next page

OFC	: LA: PDIII-1	: APM: PDIII-1	: APM: PDIII-1	: D: PDIII-1	:
NAME	: MShuttleworth	: MGamberoni	: CCarpenter	: LMarsh	:
DATE	: 12/12/91	: 12/12/91	: 12/12/91	: 12/13/91	:

OFFICIAL RECORD COPY  
Document Name: FERMI GL 8328

9112240253 911213  
PDR ADOCK 05000341  
PDR

NRC FILE CENTER COPY

*DF01*

Mr. William Orser  
Detroit Edison Company

Fermi-2 Facility

cc:

John Flynn, Esq.  
Senior Attorney  
Detroit Edison Company  
2000 Second Avenue  
Detroit, Michigan 48225

Nuclear Facilities and Environmental  
Monitoring Section Office  
Division of Radiological Health  
3423 N. Logan Street  
P. O. Box 30195  
Lansing, Michigan 48909

Mr. Stan Stasek  
U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
6450 W. Dixie Highway  
Newport, Michigan 48166

Monroe County Office of Civil  
Preparedness  
963 South Raisinville  
Monroe, Michigan 48161

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Ms. Lynne Goodman  
Director - Nuclear Licensing  
Detroit Edison Company  
Fermi Unit 2  
6400 North Dixie Highway  
Newport, Michigan 48166