Entergy Operations, Inc. P.O. Box B Kilona LA 20066

R. F. Burski

Quaytia. Names Sat.

W3F1-95-0100 A4.05 PR

June 23, 1995

U.S. Nuclear Regulatory Commission Region IV ATTN: L.J. Callan 600 Ryan Plaza, Suite 400 Arlington, TX 76011

Subject:

Waterford 3 SES Docket No. 50-382 License No. NPF-38 Fire Brigade Dispatch

Gentlemen:

The purpose of this letter is to reiterate our commitment to dispatch promptly the fire brigade following the declaration of a fire at the Waterford 3 plant. Although a time delay would be expected between the start of a fire and eventual detection, Waterford 3 is committed to ensuring timely fire suppression by the plant fire brigade before significant damage occurs.

Waterford 3 placed a Standing Instruction in the Control Room subsequent to the June 10, 1995, fire in the protected area. The standing instruction states that a fire should be declared even without the actual observance of flames should the smoke and/or heat be of such degree that the use of protective gear and/or Self Contained Breathing Apparatus (SCBA) equipment is considered.

060020

9511060290 950623 PDR ADOCK 05000382 F PDR 1005 10

Fire Brigade Dispatch W3F1-95-0100 Page 2 June 23 1995

Additionally, this Standing Instruction will be modified as follows. A fire should be declared even without the actual observance of flames should the smoke or heat be of such degree that additional assistance may be necessary or the use of protective gear or SCBA equipment is considered.

This clarification will be incorporated into a new Standing Instruction prior to startup and into appropriate fire protection procedures by September 1, 1995. This Standing Instruction will also be the subject of shift crew briefings. Additionally, this clarification will be covered in subsequent fire brigade training.

Very truly yours,

R.F. Burski Director

Nuclear Safety

CPf Sunsk

RFB/CJT/tmm

cc:

T.P. Gwynn, NRC-RIV

C.P. Patel, NRC-NRR

R.B. McGehee N.S. Reynolds

NRC Resident Inspectors Office