

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Dresden Nuclear Power Station, Unit 2	DOCKET NUMBER (2) 0 5 0 0 0 2 B 1 7	PAGE (3) 1 OF 0 2
--	--	----------------------

TITLE (4)  
HPCI Turbine Trip Low Reactor Pressure Surveillance Performed Late

EVENT DATE (5)			LER NUMBER (8)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		
0 1	0 9	8 4	8 4	0 1 4		0 0	0 8	0 2	N/A		
									DOCKET NUMBER(S)		
									0 5 0 0 0 0		
									N/A		
									0 5 0 0 0 0		

OPERATING MODE (9)	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)				
POWER LEVEL (10)	<input type="checkbox"/> 20.402(b)	<input type="checkbox"/> 20.406(e)	<input type="checkbox"/> 50.73(a)(2)(i)-(v)	<input type="checkbox"/> 73.71(b)	OTHER (Specify in Abstract below and in Text, NRC Form 366A)
	<input type="checkbox"/> 20.405(a)(1)(i)	<input type="checkbox"/> 50.38(a)(1)	<input type="checkbox"/> 50.73(a)(2)(v)	<input type="checkbox"/> 73.71(c)	
	<input type="checkbox"/> 20.405(a)(1)(ii)	<input type="checkbox"/> 50.38(a)(2)	<input type="checkbox"/> 50.73(a)(2)(vii)		
	<input type="checkbox"/> 20.405(a)(1)(iii)	<input checked="" type="checkbox"/> 50.73(a)(2)(i)	<input type="checkbox"/> 50.73(a)(2)(viii)(A)		
	<input type="checkbox"/> 20.405(a)(1)(iv)	<input type="checkbox"/> 50.73(a)(2)(ii)	<input type="checkbox"/> 50.73(a)(2)(viii)(B)		
	<input type="checkbox"/> 20.405(a)(1)(v)	<input type="checkbox"/> 50.73(a)(2)(iii)	<input type="checkbox"/> 50.73(a)(2)(x)		

LICENSEE CONTACT FOR THIS LER (12)	
NAME Gary L. Smith (X-610)	TELEPHONE NUMBER AREA CODE: 8 1 5 9 4 2 - 2 9 2 0

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)										
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRRDS	
X										

SUPPLEMENTAL REPORT EXPECTED (14)			EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR
<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)	<input checked="" type="checkbox"/> NO					

ABSTRACT (Limit to 400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

During normal operations, HPCI Turbine Trip Low Reactor Pressure Surveillance DIS 2300-3 (T.S. 4.2.1) was performed two days past the latest due date. Safety significance was minimal because the surveillance was immediately performed and no discrepancies were found. Previous occurrence reported by DVR 12-2-83-161.

Originally this event was misclassified as non-reportable due to station personnel not being completely familiar with the recently revised 10 CFR 50.73 rules. Additional training has been provided to all personnel involved in classification of LER's.

8408090151 840802  
PDR ADOCK 05000237  
S PDR

IE22  
1/1

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1)  Dresden Nuclear Power Station Unit 2	DOCKET NUMBER (2)  205000237	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		84	014	00	02	OF 02

TEXT (If more space is required, use additional NRC Form 366A's) (17)

The HPCI Turbine Trip Low Reactor Pressure Surveillance was performed two days past the latest due date. The cause of this event was due to a floating point error in the computer program which mistakenly printed the latest date due to be four days later than the actual date. On March 19, 1984 a new general surveillance program was installed on the computer and all the current surveillances were entered, until the new program was installed, however, all the surveillance due dates and completion dates were independently verified to be correct.

Originally the event was mistakenly classified as a non-reportable occurrence. However, since the surveillance was missed by two days, HPCI was inoperable during this time, and since no other ECCS systems were run per T.S. 3.5.C.2, the event is reportable per 10 CFR 50.73 (a)(2)(i)(B).

Review of the circumstances which led to misclassification indicate that station personnel were not completely familiar with recent changes to 10 CFR 50.73. All personnel directly involved in determining reportability were given additional training on this subject during the month of July. This training should prevent a recurrence of misclassifications in the future.



**Commonwealth Edison**

Dresden Nuclear Power Station

R.R. #1

Morris, Illinois 60450

Telephone 815/942-2920

August 2, 1984

DJS Ltr #84-758

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Licensee Event Report #84-014-0, Docket #050237 is being submitted  
as required by Technical Specification 6.6, NUREG 1022 and 10 CFR 50.73  
(a)(2)(i)(B).

D.J. Scott  
Station Superintendent  
Dresden Nuclear Power Station

DJS/kjl

Enclosure

cc: J.G. Keppler, Regional Administrator, Region III  
File/NRC  
File/Numerical

IE22  
1/1