



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

JUL 17 2 4:10 PM '84
July 12, 1984

NUCLEAR LICENSING & SAFETY DEPARTMENT

U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30323

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report No. 84-026/0 -
Upper Control Room
Temperature Exceeded
Technical Specification
Limit
AECM-84/0363

Beginning on June 13, 1984, the temperature in the Upper Control Room exceeded the Technical Specification limit of 77°F for a period of more than eight hours. The maximum temperatures and cumulative times the limit was exceeded are listed below.

<u>DATE</u>	<u>TIME OF LCO</u>	<u>MAXIMUM TEMPERATURE</u>
6/13/84	20.25 hours	81°F
6/16/84	23 hours	77.8°F
6/17/84	18 hours	82°F
6/18/84 to 7/3/84	374 hours	84°F

All Control Room equipment is qualified to at least a maximum of 90°F, therefore there was no affect on the availability of or operability of equipment within this area. This is being submitted as a Special Report pursuant to Technical Specification 3.7.8 and 6.9.2. This is a final report.

Yours truly,

L. F. Dale
L. F. Dale
Director

8408090163 840712
PDR ADOCK 05000416
S PDR

EBS:lm

cc: (See Next Page)

RECEIVED
JUL 22 1984
1/0

MISSISSIPPI POWER & LIGHT COMPANY

AECM-84/0363

Page 2

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. N. S. Reynolds
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555