



South Carolina Electric & Gas Company
P.O. Box 88
Jenkinsville, SC 29065
(803) 345-4344

Gary J. Taylor
Vice President
Nuclear Operations

October 27, 1995
RC-95-0275

Mr. S. D. Ebnetter
Regional Administrator
U. S. Nuclear Regulatory Commission
Region II, Suite 2900
101 Marietta Street, NW
Atlanta, GA 30323

Dear Mr. Ebnetter:


Subject: VIRGIL C. SUMMER NUCLEAR STATION
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
SPECIAL REPORT (SPR 950002)

South Carolina Electric & Gas Company (SCE&G) is submitting this special report pursuant to the requirements of Technical Specification 6.9.2 as required by Action 30 of specification 3.3.3.1, Table 3.3-6, Item 2.d.ii.

On October 13, 1995, at 2030 hours, the Main Steam Radiation Monitor, RMG-19B, was declared inoperable due to spiking above the high radiation setpoint four times within thirty minutes. A preplanned alternate method of monitoring the appropriate parameters was established as required by Action 30 of Technical Specification 3.3.3.1. Trouble-shooting of this instrumentation failed to reveal a cause for the spiking. RMG-19B was subsequently placed online and monitored for additional spiking. On October 17, 1995, an operability test was performed on RMG-19B and the monitor was declared operable on October 18, 1995.

Should you have any questions please call Mr. Ricky Myers at (803) 345-4384, at your convenience.

Very truly yours,


Gary J. Taylor

RAM/GJT/nkk
Attachment

c: J. L. Skolds
O. W. Dixon
R. R. Mahan (w/o attachment)
R. J. White
S. Dembek
J. B. Knotts, Jr.
Marsh & McLennan
INPO Records Center

Document Control Desk
NRC Resident Inspector
NSRC
S. F. Fipps
Central File System
RTS (ONO 950123)
File (818.08, 818.05)

9511070198 951027
PDR ADOCK 05000395
S PDR

NUCLEAR EXCELLENCE - A SUMMER TRADITION!



000050

Handwritten initials/signature