



Consumers Power Company

James W Cook
Vice President - Projects, Engineering and Construction

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0453

July 27, 1984

PRINCIPAL STAFF	
D/RA	DRP
RC	DRS
PAO	DRSS
SGA	ML
EIC	IOL
DRMA	OI
	FILE

Mr J G Keppler, Regional Administrator
U S Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

MIDLAND ENERGY CENTER PROJECT
DOCKET NOS 50-329 AND 50-330
STATUS OF 10CFR50.55(e) ISSUES
FILE: 0.4.9 SERIAL: 31797

The attached table is a listing of 10CFR50.55(e) issues for which final reports have not been submitted to your office. Please be advised that because of the current deactivation of the Midland Project, no further reports will be submitted.

For each 10CFR50.55(e) issue listed, the table shows a due date for the next report that would have been submitted. Initial reports for the four most recent issues already have accounted for the status of Project activity. Efforts regarding safety evaluations which were in process have ceased. We are currently not aware of any conditions considered to meet the 10CFR50.55(e) regulation which required immediate reportability. CPCo is revising procedures to assure proper handling and reporting of any additional 10CFR50.55(e) items which are discovered during the current status of the project.

James W. Cook

JWC/AHB/lr

CC: Document Control Desk, NRC
Washington, DC

NRC Resident Inspector's Office
Midland Nuclear Plant

DSHood, NRC Office of NRR
Bethesda, MD

INPO Records Center

OC0784-0037A-MP01

8408090284 840727
PDR ADOCK 05000329
S PDR

AUG 1 1984

IF27

10CFR50.55(e) STATUS REPORT

<u>Assigned NRC Number</u>	<u>File No</u>	<u>Description</u>	<u>Initial CPCo Report</u>	<u>Next CPCo Report</u>
78-05	0.4.9.17	RB Spray Piping Supports	03/22/78	01/25/85
79-03	0.4.9.28	Small Break/RC Pump Operation Interaction	07/16/79	08/31/84
80-04	0.4.9.41	HELBA Restraints	08/21/80	09/28/84
80-09	0.4.9.46	LAQTS Bolts	11/26/80	11/30/84
82-06	0.4.9.62	OTSG Aux Feedwater Header	04/26/82	11/30/84
82-16	0.4.9.72	Electrical Supplier Workmanship	12/03/82	12/31/84
83-02	0.4.9.74	Seismic Qualification of Control & Instrument Cabinets	01/12/83	12/21/84
83-03	0.4.9.75	Core Support Bolting	04/19/83	09/28/84
83-06	0.4.9.78	Electrical Raceway Systems	07/30/83	11/30/84
83-09	0.4.9.81	Control of Field Design Changes	10/22/83	12/31/84
83-10	0.4.9.82	Engineering/Construction Hold Process	11/10/83	08/10/84
83-12	0.4.9.84	ITT Grinnell Mechanical Snubbers	12/09/83	08/10/84
83-14	0.4.9.86	Diesel Generator Piping Analysis	12/14/83	09/28/84

10CFR50.55(e) STATUS REPORT

<u>Assigned NRC Number</u>	<u>File No</u>	<u>Description</u>	<u>Initial CPCo Report</u>	<u>Next CPCo Report</u>
84-01	0.4.9.88	Excessive Voltage Drop - 125V DC Valve Actuators	01/06/84	08/17/84
84-03	0.4.9.90	Expansion Anchors in Metal Decking	02/28/84	07/27/84
84-05	0.4.9.92	DG Piston Skirt Castings	03/29/84	07/27/84
84-06	0.4.9.93	Foxboro Modules	03/29/84	10/26/84
84-08	0.4.9.95	Retroactive Design Changes	05/18/84	11/30/84
84-09	0.4.9.96	Core Flood Line Failure	06/06/84	TBD*
84-10	0.4.9.97	RCP Cover & Seal	06/22/84	TBD*
84-11	0.4.9.98	ITT Grinnell Struts & Extensions	07/05/84	TBD*
84-12	0.4.9.99	ECCAS/NI-RPS Power Supplies	07/05/84	TBD*

*Date not established due to Project deactivation.

OM/OL SERVICE LIST

Mr Frank J Kelley
 Attorney General of the
 State of Michigan
 Ms Carole Steinberg
 Assistant Attorney General
 Environmental Protection Division
 720 Law Building
 Lansing, MI 48913

Mr Myron M Cherry, Esq
 Suite 3700
 Three First National Plaza
 Chicago, IL 60602

Mr Wendell H Marshall
 RFD 10
 Midland, MI 48640

Mr Charles Bechhoefer, Esq
 Atomic Safety & Licensing
 Board Panel
 U S Nuclear Regulatory Commission
 East-West Towers, Room E-413
 Bethesda, MD 20014

Dr Frederick P Cowan
 6152 N Verde Trail
 Apt B-125
 Boca Raton, FL 33433

Mr Fred C Williams
 Isham, Lincoln & Beale
 1120 Connecticut Ave, NW, Suite 840
 Washington, DC 20036

Mr James E Brunner, Esq
 Consumers Power Company
 212 West Michigan Avenue
 Jackson, MI 49201

Mr D F Judd
 Babcock & Wilcox
 PO Box 1260
 Lynchburg, VA 24505

Mr Steve Gadler, Esq
 2120 Carter Avenue
 St Paul, MN 55108

Mr P Robert Brown
 Clark, Klein & Beaumont
 1600 First Federal Bldg
 Woodward Ave
 Detroit, MI 48226
 OC0784-0037A-MP01

Atomic Safety & Licensing
 Appeal Board
 U S Nuclear Regulatory Commission
 Washington, DC 20555

Mr C R Stephens (3)
 Chief, Docketing & Services
 U S Nuclear Regulatory Commission
 Office of the Secretary
 Washington, DC 20555

Ms Mary Sinclair
 5711 Summerset Street
 Midland, MI 48640

Mr William D Paton, Esq
 Counsel for the NRC Staff
 U S Nuclear Regulatory Commission
 Washington, DC 20555

Atomic Safety & Licensing
 Board Panel
 U S Nuclear Regulatory Commission
 Washington, DC 20555

Ms Barbara Stamaris
 5795 North River Road
 Rt 3
 Freeland, MI 48623

Dr Jerry Harbour
 Atomic Safety & Licensing
 Board Panel
 U S Nuclear Regulatory Commission
 East-West Towers, Room E-454
 Bethesda, MD 20014

Mr M I Miller, Esq
 Isham, Lincoln & Beale
 Three First National Plaza
 52nd Floor
 Chicago, IL 60602

Mr John DeMeester, Esq
 Dow Chemical Building
 Michigan Division
 Midland MI 48640

Ms Lynne Bernabei
 Government Accountability Project
 1901 Q Street, NW
 Washington, DC 20009