

BEFORE THE
UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of the Facility Operating License))
of) Docket No. 50-267
PUBLIC SERVICE COMPANY OF COLORADO))

Application for Amendment to
Appendix A of Facility Operating License
License No. DPR-34

OF THE
PUBLIC SERVICE COMPANY OF COLORADO
FOR THE
FORT ST. VRAIN NUCLEAR GENERATING STATION

This application for Amendment to Appendix A of
Facility Operating License, License No. DPR-34,
is submitted for NRC review and approval.

Respectfully submitted,
PUBLIC SERVICE COMPANY OF COLORADO
By O. R. Lee, Vice President

KELLY, STANSFIELD & O'DONNELL
Bryant O'Donnell
Robert E. Thompson
Public Service Company Building
Denver, Colorado 80202

Attorneys for Applicant

ATTACHMENT 1

SUMMARY OF PROPOSED CHANGES

SUMMARY OF PROPOSED CHANGES

<u>SECTION</u>	<u>DESCRIPTION OF CHANGE</u>
Section 4.4.3	<ol style="list-style-type: none">1) In implementation of NUREG 0737 Item II.F.1.3 (Accident Monitoring; Containment High-Range Monitor) a new area radiation monitor, RT93250-14, was added to the group listing along with specific action requirements for inoperability as committed in P-84101 (Reference 2).2) The inoperability requirements for the Hot Service Facility (HSF) monitors, Group 2, were modified to allow for NRC reporting when repair or replacement measures might be contradictory to ALARA commitments.3) The location designations for Table 4.4.3-1 were changed to be consistent with Revision 2 of the Updated FSAR (Table 11.2-3) and other applicable documents. No elevation or area changes have been made.
LCO's 4.4.7 & 4.4.8	These LCO's were added for implementation of NUREG 0737 Item III.D.3.4 (Control Room Habitability Requirements) and are consistent with the commitments of P-84101 (Reference 2).
LCO 4.10.1	This LCO was modified to apply only to HVAC "isolation" dampers and to allow an extended repair period when the isolation function can be maintained with redundant, operable dampers.
SR 5.4.14	This SR was added to maintain operability of the chlorine detection system required to be operable by LCO 4.4.8.
SR 5.10.1	This SR was modified to include annual fan and damper testing of the Control Room Emergency Ventilation System in accordance with LCO 4.4.7 in addition to the Halon Fire Suppression System.
AC 7.4.a.9	This requirement was added for implementation of NUREG 0737 Item II.B.3 (Post-Accident Sampling). Identification of specific procedures, controls and sampling program areas is in accordance with the Standard Technical Specifications.

AC 7.5.e

This section was added to identify the specific NRC reporting requirements which must be implemented in the event that both of the area monitors in group 2, or the monitor in group 7, become inoperable and corrective action to restore one to operable status within 7 days is unsuccessful.

ATTACHMENT 2

PROPOSED CHANGES