



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

November 3, 1995

Mr. Nicholas J. Liparulo  
Nuclear Safety and Regulatory Activities  
Westinghouse Electric Corporation  
P.O. Box 355  
Pittsburgh, Pennsylvania 15230

SUBJECT: FOLLOWON QUESTIONS ON THE AP600

Dear Mr. Liparulo:

During meetings held on August 15 and 24, 1995, Westinghouse presented preliminary information regarding potential improvements to existing features and additional features that could reduce containment pressure and radioactive aerosol following a severe accident. Two of the four options considered were the primary focus of the presentation: fan coolers and a spray header. The following additional information is needed solely to assess whether the fan cooler option adequately addresses the staff's concerns regarding the ability of the design to cope with accidents beyond the design basis accident.

470.24 The evaluation results given in terms of effective containment pressure and radioactive aerosol reductions were predicated on a design basis accident (DBA) scenario; i.e., the first three of the NUREG-1465 five fission product release phases (coolant, gap, and early in-vessel). Westinghouse's evaluation should also address the ex-vessel and late in-vessel release phases, including non-condensable gas generation, to address severe accident concerns. Provide the results of such an evaluation that addresses these phases.

470.25 Provide the technical bases for the operability and aerosol removal efficiency of fan coolers. The background information is needed to assess (a) reliance on supporting systems, (b) the degree of effectiveness of removal, and (c) system performance degradation with radioactive and non-radioactive aerosol loading. Also, with two trains of fan coolers available, what are the maximum pressure and radioactive aerosol reduction benefits that can be derived? Provide justification for these values.

470.26 In order to assist the staff to better understand the risk reduction that could be achieved through the use of fan coolers, provide the following information: (a) the estimated availability of the fan coolers and support systems (chilled water, component cooling water, ac-power, etc.) in each of the major sequence categories for the AP600, (b) the fraction of core melt sequences where the fan coolers would be available (weighted over all sequences), and (c) the improvement in system availability and the reduction in total risk that would be achieved if the fan coolers and/or support systems were expanded to include availability/operation during severe accidents.

470.27 Westinghouse's detailed scenarios were focussed on a natural aerosol deposition removal rate ( $\lambda$ ) of  $0.5 \text{ hr}^{-1}$ . Because of the uncertainties associated with aerosol removal, assessments of the fan cooler performance (removal of radioactive aerosol) should be made for a range of  $\lambda$ s ( $0.15$  to  $0.5 \text{ hr}^{-1}$ ). Provide such assessments.

These followon questions affect nine or fewer respondents, and therefore are not subject to review by the Office of Management and Budget under P.L. 96-511.

We request that you respond to these questions within 60 days of the date of this letter. If you have any questions regarding this matter, you can contact me at (301) 504-1120.

Sincerely,

original signed by:

Thomas J. Kenyon, Project Manager  
Standardization Project Directorate  
Division of Reactor Program Management  
Office of Nuclear Reactor Regulation

Docket No. 52-003

cc: See next page

DISTRIBUTION:

Docket File  
PUBLIC  
RArchitzel  
DJackson  
GSuh (2), 0-12 E4  
EJordan, T-4 D18  
CMiller, 0-10 D4  
CBerlinger, 0-8 H7  
MSnodderly, 0-8 H7

PDST R/F  
BGrimes  
TKenyon  
JMoore, 0-15 B18  
MSiemien, OGC  
MFranovich  
REmch, 0-10 D4  
JKudrick, 0-8 H7

DCrutchfield  
TQuay  
WHuffman  
WDean, EDO  
ACRS (11)  
BZalcman  
JLee, 0-10 D4  
JMonninger, 0-8 H7

DOCUMENT NAME: A: SRC TRM.FWN

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDST:DRPM	SC:PDST:DRPM		
NAME	TKenyon:sg	RArchitzel		
DATE	10/ /95	10/3/95		

11/2/95

Mr. Nicholas J. Liparulo  
Westinghouse Electric Corporation

Docket No. 52-003  
AP600

cc: Mr. B. A. McIntyre  
Advanced Plant Safety & Licensing  
Westinghouse Electric Corporation  
Energy Systems Business Unit  
P.O. Box 355  
Pittsburgh, PA 15230

Mr. Ronald Simard, Director  
Advanced Reactor Programs  
Nuclear Energy Institute  
1776 Eye Street, N.W.  
Suite 300  
Washington, DC 20006-3706

Mr. John C. Butler  
Advanced Plant Safety & Licensing  
Westinghouse Electric Corporation  
Energy Systems Business Unit  
Box 355  
Pittsburgh, PA 15230

STS, Inc.  
Attn: Lynn Connor  
Suite 610  
3 Metro Center  
Bethesda, MD 20814

Mr. M. D. Beaumont  
Nuclear and Advanced Technology Division  
Westinghouse Electric Corporation  
One Montrose Metro  
11921 Rockville Pike  
Suite 350  
Rockville, MD 20852

Mr. James E. Quinn, Projects Manager  
LMR and SBWR Programs  
GE Nuclear Energy  
175 Curtner Avenue, M/C 165  
San Jose, CA 95125

Mr. Sterling Franks  
U.S. Department of Energy  
NE-42  
Washington, DC 20585

Mr. John E. Leatherman, Manager  
SBWR Design Certification  
GE Nuclear Energy, M/C 781  
San Jose, CA 95125

Mr. S. M. Modro  
Nuclear Systems Analysis Technologies  
Lockheed Idaho Technologies Company  
Post Office Box 1625  
Idaho Falls, ID 83415

Barton Z. Cowan, Esq.  
Eckert Seamans Cherin & Mellott  
600 Grant Street 42nd Floor  
Pittsburgh, PA 15219

Mr. Frank A. Ross  
U.S. Department of Energy, NE-42  
Office of LWR Safety and Technology  
19901 Germantown Road  
Germantown, MD 20874

Mr. Ed Rodwell, Manager  
PWR Design Certification  
Electric Power Research Institute  
3412 Hillview Avenue  
Palo Alto, CA 94303

Mr. Charles Thompson, Nuclear Engineer  
AP600 Certification  
U.S. Department of Energy  
NE-451  
Washington, DC 20585