

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel 309-654-2244



LWP-95-096

November 2, 1995

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Reference: Quad Cities Nuclear Power Station
Docket Number 50-265, DPR-30, Unit 2

Enclosed is Licensee Event Report (LER) 95-006, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(iv). The licensee shall report any event or condition that resulted in manual or automatic actuation of any Engineered Safety Feature.

The report is also submitted in accordance with Title 10, Part 50.73 (a)(2)(ii). The licensee shall report any event or condition of the nuclear power plant, including its principal safety barriers, being seriously degraded, or that resulted in the nuclear plant being in a condition that was outside the design basis of the plant.

The following commitments are being made by this letter:

1. Raise the trip settings for the affected MCCs and evaluate maximum expected loading. Loading will be administratively controlled to prevent exceeding cable ampacities. Engineering is evaluating the need for modifications to replace the feed cables for overloaded MCCs with larger cables. If needed, modifications for Unit 1 will be performed during Q1R14 and Unit 2 during Q2R14. (NTS #2651809500601 Engineering for Unit 1), (NTS# 2651809500602 Engineering for Unit 2).
2. The level 2 investigation for PIFs 95-2534, 95-2545 and 95-2546 is being performed. Further corrective actions and root cause will be determined by the investigation and forwarded as a supplemental report. The level 2 investigation is expected to be complete by 11/17/95.

STMGR\09695.LWP

070007
9511080073 951102
PDR ADCK 05000265
S PDR

All nicom Company

LWP-95-096
11/02/95
page 2

If there are any questions or comments concerning this letter, please refer them to Nick Chrissotimos, Regulatory Assurance Administrator at 309-654-2241, ext. 3100.

Respectfully,

COMMONWEALTH EDISON

D. B. Cook for

L. W. Pearce
Station Manager

LWP/NC/plm

Enclosure

cc: J. Schrage
C. Miller
INPC Records Center
NRC Region III