



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

NORTHEAST NUCLEAR ENERGY COMPANY
THE CONNECTICUT LIGHT AND POWER COMPANY
THE WESTERN MASSACHUSETTS ELECTRIC COMPANY
DOCKET NO. 50-336
MILLSTONE NUCLEAR POWER STATION, UNIT NO. 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 190
License No. DPR-65

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Northeast Nuclear Energy Company, et al. (the licensee), dated August 31, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-65 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 190, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance, to be implemented within 60 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Phillip F. McKee, Director
Project Directorate I-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 2, 1995

ATTACHMENT TO LICENSE AMENDMENT NO. 190

FACILITY OPERATING LICENSE NO. DPR-65

DOCKET NO. 50-336

Replace the following page of the Appendix A, Technical Specifications, with the attached page. The revised page is identified by amendment number and contains vertical lines indicating the areas of change.

Remove

6-2

Insert

6-2

ADMINISTRATIVE CONTROLS

FACILITY STAFF (CONTINUED)

- d. An individual qualified in radiation protection procedures shall be on site when fuel is in the reactor. (Table 6.2-1)
- e. ALL CORE ALTERATIONS after the initial fuel loading shall be directly supervised by either a licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation.
- f. A site Fire Brigade of at least 5 members shall be maintained onsite at all times. (Table 6.2-1) The Fire Brigade shall not include 2 members of the minimum shift crew necessary for safe shutdown of the unit or any personnel required for other essential functions during a fire emergency.
- g. Administrative procedures shall be developed and implemented to limit the working hours of unit staff who perform safety-related functions. These procedures should follow the general guidance of the NRC Policy Statement on working hours (Generic Letter No. 82-12).

6.3 FACILITY STAFF QUALIFICATIONS

- 6.3.1 Each member of the facility staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions, except for:
- a. If the Operations Manager does not hold a senior reactor operator license for Millstone Unit No. 2, then the Operations Manager shall have held a senior reactor operator license at a Pressurized Water Reactor and an individual serving in the capacity of the Assistant Operations Manager shall hold a senior reactor operator license for Millstone Unit No. 2.
 - b. The Shift Technical Advisor (STA) who shall meet the requirements of Specification 6.3.1.b.1 or 6.3.1.b.2.
 - 1. Dual-role individual: Must hold a senior reactor operator's license at Millstone Unit No. 2, meet the STA training criteria of NUREG-0737, Item I.A.1.1, and meet one of the following educational alternatives:
 - a. Bachelor's degree in engineering from an accredited institution;
 - b. Professional Engineer's license obtained by the successful completion of the PE examination;