

Georgia Power Company  
40 Investment Center Parkway  
Post Office Box 1295  
Birmingham, Alabama 35201  
Telephone 205 877-7122



Georgia Power

*the southern electric system*

C. K. McCoy  
Vice President, Nuclear  
Vogtle Project

February 7, 1992

ELV-03408  
001117

Docket Nos. 50-424  
50-425


U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555

Gentlemen:

VOGTLE ELECTRIC GENERATING PLANT  
REQUEST TO REVISE TECHNICAL SPECIFICATIONS  
4.5.2.d AND 4.4.9.3.2 TO ALLOW REMOVAL  
OF RESIDUAL HEAT REMOVAL SYSTEM SUCTION VALVE AUTOCLOSURE INTERLOCK

By letter dated November 20, 1991, Georgia Power Company (GPC) requested an amendment to the Vogtle Electric Generating Plant (VEGP) Unit 1 and Unit 2 Technical Specifications which would allow the removal of the residual heat removal system (RHRS) suction isolation valve autoclosure interlock (ACI). In that amendment request, GPC committed to install an alarm which will actuate if any RHRS suction isolation valve is open and the pressure of the reactor coolant system (RCS) exceeds a setpoint which is greater than the open permissive setpoint but less than the RHRS design pressure minus the RHRS pump developed head pressure. During a subsequent telephone conversation with the NRC staff reviewer, GPC committed to develop an annunciator response procedure for the new alarm which, upon receipt of the alarm, would direct the operator to close the valve(s) or reduce RCS pressure to less than the alarm setpoint. This procedure will be ready for use at the time the PHRS is returned to service after implementation of the design change to remove the ACI and add the alarm.

Sincerely,

  
C. K. McCoy

CKM/NJS/gmb

xc: Georgia Power Company  
Mr. W. B. Shipman  
Mr. M. Sheibani  
NORMS

U. S. Nuclear Regulatory Commission  
Mr. S. D. Ebnetter, Regional Administrator  
Mr. D. S. Hood, Licensing Project Manager, NRR  
Mr. B. R. Bonser, Senior Resident Inspector, Vogtle

9202110311 920207  
PDR ADOCK 05000424  
P PDR

AD61 / 10