



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

February 3, 1992

Docket No. 50-293

Mr. Roy A. Anderson
Senior Vice President - Nuclear
Boston Edison Company
Pilgrim Nuclear Power Station
Rocky Hill Road
Plymouth, Massachusetts 02360

Dear Mr. Anderson:

SUBJECT: PUMP AND VALVE INSERVICE TESTING PROGRAM TECHNICAL
EVALUATION REPORT (TAC NO. M74785)

Enclosed is Revision 1 of the Technical Evaluation Report (TER) for Pilgrim Nuclear Power Station (PNPS) Inservice Test (IST) program and an updated Table 1 "Summary of Relief Requests" which should replace the table in the Safety Evaluation (SE) sent to you in a letter, dated April 22, 1991.

The changes in the TER are identified by bars in the right border of the affected TER pages. Following is a list of the significant changes.

1. The language in the original TER was changed in Section 2.2.1.2, 2.4.1.2, 3.1.2.1.2, 3.1.3.1.2, 3.3.2.1.2, 3.4.1.1.2, and Anomalies 1, 3, and 6. This change was made to eliminate a possible conflict with the plant Technical Specifications. The text now states that, "For the purpose of this report, refueling outage is the plant condition as defined in plant Technical Specifications. For inservice testing purposes, the interval associated with refueling outage testing may be up to 2 years."
2. Deleted Section 3.9 and revised Anomaly 16 relating to cold shutdown justification CS-03. The licensee would have extreme difficulty complying with the recommendations in the time allowed. The affected valves are addressed in the evaluation of relief request RV-27 (see Section 3.1.3 of the TER). Also, since relief is granted in Section 3.1.3 to comply with GL 89-04, Position 2, this cold shutdown justification is not needed and may be deleted.

9202120224 920203
PDR ADOCK 05000293
PDR

DF01
NRC FILE CENTER COPY

February 3, 1992

Mr. Roy A. Anderson

- 2 -

If you have questions regarding this TER, please call me on (301) 504-3041.

Original signed by

Ronald B. Eaton, Senior Project Manager
Project Directorate I-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION: Docket File 50-293, NRC&Local PDRs, PDI-3 Reading, SVarga, JCalvo, REaton, MRushbrook, TMendiola, WButler, OGC, ACRS(10), JLinville, RI, RLobel, JColaccino

CFC	:PDI-3/LA	:PDI-3/PM	: NRR:EMEB	:PDI-3/ADIR:	:
NAME	:MRushbrook	:REaton:mw	:ESullivan	:TMendiola	:
DATE	:02/3/92	:02/3/92	:02/3/92	:02/3/92	:
DOCUMENT:	IST.WP				

Mr. R. A. Anderson

Pilgrim Nuclear Power Station

cc:

Mr. William C. Rothert, Acting
Vice President of Operations
and Station
Pilgrim Nuclear Power Station
RFD #1 Rocky Hill Road
Plymouth, Massachusetts 02360

Mr. H. Vernon Oheim
Manager, Reg. Affairs Dept.
Pilgrim Nuclear Power Station
RFD #1 Rocky Hill Road
Plymouth, Massachusetts 02360

Resident Inspector
U. S. Nuclear Regulatory Commission
Pilgrim Nuclear Power Station
Post Office Box 867
Plymouth, Massachusetts 02360

Ms. Elaine D. Robinson
Nuclear Information Manager
Pilgrim Nuclear Power Station
RFD #1, Rocky Hill Road
Plymouth, Massachusetts 02360

Chairman, Board of Selectmen
11 Lincoln Street
Plymouth, Massachusetts 02360

Mr. Dale C. Jenkins, Jr.
Secretary of Public Safety
Executive Office of Public Safety
One Ashburton Place
Boston, Massachusetts 02108

Office of the Commissioner
Massachusetts Department of
Environmental Protection
One Winter Street
Boston, Massachusetts 02108

Mr. David Rodham, Director
Massachusetts Civil Defense Agency
400 Worcester Road
P.O. Box 1496
Framingham, Massachusetts 01701-0317
Attn: James Muckerheide

Office of the Attorney General
One Ashburton Place
20th Floor
Boston, Massachusetts 02108

Chairmen, Citizens
Urging Responsible Energy
P. O. Box 2621
Duxbury, Massachusetts 02331

Mr. Robert M. Hallisey, Director
Radiation Control Program
Massachusetts Department of
Public Health
305 South Street
Boston, Massachusetts 02130

Citizens at Risk
P. O. Box 3803
Plymouth, Massachusetts 02361

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

W. S. Stowe, Esquire
Boston Edison Company
800 Boylston St., 36th Floor
Boston, Massachusetts 02199

Mr. John Dietrich
Licensing Division Manager
Boston Edison Company
25 Braintree Hill Park
Braintree, Massachusetts 02184